

1 DRAFT 06/21/16

2 DEPARTMENT OF PUBLIC HEALTH AND ENVIRONMENT

3 Hazardous Materials and Waste Management Division

4 RADIATION CONTROL - LICENSES AND RADIATION SAFETY REQUIREMENTS FOR  
5 IRRADIATORS

6 6 CCR 1007-1 Part 19

7 [Editor's Notes follow the text of the rules at the end of this CCR Document.]

8

9 Adopted by the Board of Health on July 20, 2016.

10 PART 19: LICENSES AND RADIATION SAFETY REQUIREMENTS FOR IRRADIATORS

11 19.1 Purpose and Scope.

12 19.1.1 Authority.

13 Rules and regulations set forth herein are adopted pursuant to the provisions of sections 25-1-  
14 108, 25-1.5-101(1)(l), and 25-11-104, CRS.

15 19.1.2 Basis and Purpose.

16 A statement of basis and purpose accompanies this part and changes to this part. A copy may be  
17 obtained from the Department.

18 19.1.3 Scope.

19 Part 19 contains requirements for the issuance of a license authorizing the use of sealed sources  
20 containing radioactive materials in irradiators used to irradiate objects or materials using gamma  
21 radiation. Part 19 also contains radiation safety requirements for operating irradiators.

22 19.1.4 Applicability.

23 19.1.4.1 The regulations in this part apply to panoramic irradiators that have either dry or  
24 wet storage of the radioactive sealed sources and to underwater irradiators in  
25 which both the source and the product being irradiated are under water.  
26 Irradiators whose dose rates exceed 5 gray (500 rad) per hour at 1 meter from  
27 the radioactive sealed sources in air or in water, as applicable for the irradiator  
28 type, are covered by this part.

29 19.1.4.2 The regulations in this part do not apply to self-contained dry-source-storage  
30 irradiators (those in which both the source and the area subject to irradiation are  
31 contained within a device and are not accessible by personnel), medical  
32 radiology or teletherapy, radiography (the irradiation of materials for  
33 nondestructive testing purposes), gauging, or open-field (agricultural) irradiations.

34 19.1.4.3 The requirements of this part are in addition to the requirements of Parts 1, 3, 4,  
35 10, 12, 13, 17 and 4722.

36 19.1.4.4 Nothing in this part relieves the licensee from complying with other applicable  
37 Federal, State and local regulations governing the siting, zoning, land use, and  
38 building code requirements for industrial facilities.  
39

**Comment [jsj1]:**  
**EDITORIAL NOTE 1:** ALL COMMENTS (SUCH AS THIS ONE) SHOWN IN THE RIGHT SIDE MARGIN OF THIS DOCUMENT ARE FOR INFORMATION PURPOSES ONLY. THESE COMMENTS ARE NOT PART OF THE RULE AND WILL BE DELETED PRIOR TO FINAL SUBMISSION PRIOR TO THE COLORADO SECRETARY OF STATE.

**EDITORIAL NOTE 2:** THE ACRONYM "CRCPD" IN THE SIDE MARGIN NOTES REFERS TO THE CONFERENCE OF RADIATION CONTROL PROGRAM DIRECTORS (CRCPD), INC., WHICH DEVELOPS SUGGESTED STATE REGULATIONS FOR CONTROL OF RADIATION (KNOWN AS SSRCR'S). UNLESS OTHERWISE DETERMINED BY THE BOARD OF HEALTH, COLORADO'S RULES ARE TO BE CONSISTENT WITH THE U.S. NUCLEAR REGULATORY COMMISSION (NRC) REGULATIONS AND THE SSRCR REGULATIONS. HOWEVER, DUE TO DIFFERING LANGUAGE, IT MAY NOT ALWAYS BE POSSIBLE TO HAVE CONSISTENCY BETWEEN BOTH NRC RULES AND THE SSRCR'S. DIFFERENCES ARE IDENTIFIED WHEREVER POSSIBLE.

THE SSRCRS MAY BE FOUND ONLINE AT:  
<http://www.crcpd.org/ssrcrs/default.aspx>

THE PART 19 RULE IS BASED ON SSRCR PART "Q" DATED MAY 2005 EXCEPT WHERE NRC REGULATIONS HAVE BEEN UPDATED SINCE PART Q WAS LAST AMENDED. COMPATIBILITY WITH FEDERAL (NRC) REGULATIONS IS REQUIRED TO MAINTAIN AGREEMENT STATE STATUS. INFORMATION ON NRC COMPATIBILITY CATEGORIES MAY BE FOUND AT:

<https://scp.nrc.gov/procedures/sa200.pdf>

**EDITORIAL NOTE 3:** NRC RULE CHANGES ARE TRACKED THROUGH THE NRC REGULATORY ACTION TRACKING SYSTEM (RATS). INFORMATION ON THE NRC RATS MAY BE FOUND AT:  
[https://scp.nrc.gov/rss\\_regamendents.html](https://scp.nrc.gov/rss_regamendents.html)

**EDITORIAL NOTE 4:** THROUGHOUT THE RULE MULTIPLE PROVISIONS HAVE BEEN REALIGNED FOR FORMATTING PURPOSES.

**Comment [jsj2]:** This reflects the date of anticipated adoption by the Colorado Board of Health. The effective date is typically 60 days beyond this date.

**Comment [jsj3]:** Cross-reference to additional regulatory parts is added, consistent with 10 CFR Part 36.1(a).

References to Part 17 (transportation) and Part 22 (physical security) are added.

NRC RATS 2013-1  
NRC Compatibility = D

[ \* \* \* = Indicates omission of unaffected rules/sections]

\* \* \*

40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76

**SPECIFIC LICENSING REQUIREMENTS**

**19.3 Application for a ~~S~~pecific ~~L~~icense.**

19.3.1 A person shall file an application for a specific license authorizing the use of sealed sources in an irradiator pursuant to **Part 3, Section 3.8**.

**19.4 Specific ~~L~~icenses for ~~I~~rradiators.**

19.4.1 The Department will approve an application for a specific license for the use of licensed material in an irradiator if the applicant meets the requirements contained in this section.

**19.4.2** The applicant shall satisfy the general requirements specified in **Part 3, Sections 3.9, 3.9.1, 3.9.2, 3.9.4, and 3.14.1** of the regulations and the requirements contained in this part.

19.4.3 The applicant must describe the training provided to irradiator operators including:

- 19.4.3.1 Classroom training;
- 19.4.3.2 On-the-job or simulator training;
- 19.4.3.3 Safety reviews;
- 19.4.3.4 Means employed by the applicant to test each operator's understanding of the Department's regulations and licensing requirements and the irradiator operating and emergency procedures; and
- 19.4.3.5 Minimum training and experience of personnel who may provide training.

19.4.4 The application must include an outline of the written operating and emergency procedures listed in 19.19 that describes the radiation safety aspects of the procedures.

19.4.5 The application must describe the organizational structure for managing the irradiator, specifically the radiation safety responsibilities and authorities of the radiation safety officer and those management personnel who have important radiation safety responsibilities or authorities.

19.4.5.1 In particular, the application must specify who, within the management structure, has authority to stop unsafe operations.

19.4.5.2 The application must also describe the training and experience required for the position of radiation safety officer.

19.4.6 The application must include:

- 19.4.6.1 A description of the access control systems required by 19.8;
- 19.4.6.2 A description of the radiation monitors required by 19.11;
- 19.4.6.3 A description of the method of detecting leaking sources required by 19.22 including the sensitivity of the method; and
- 19.4.6.4 A diagram of the facility that shows the locations of all required interlocks and radiation monitors.

**Comment [jsj4]:** Cross-references are expanded for consistency with the expanded cross-references contained in 10 CFR 36.13(a) (to 30.33(a)(1-4) and 30.33(b) which were amended in 2011.

This provision is expanded for consistency with federal rules and differs from SSRCR Part Q. Part Q has not been updated since 2005 and is not current with all federal rules.

NRC RATS 2011-2  
NRC Compatibility (36.13(a)) = H&S

NRC Compatibility (30.33(a)(2), (3)) = H&S, while 30.33(a)(1), (a)(4), and (b) are compatibility "D" and are not required for compatibility.

77 19.4.7 If the applicant intends to perform leak testing of dry-source-storage sealed sources, the applicant  
78 shall establish procedures for leak testing and submit a description of these procedures to the  
79 Department. The description shall include the:

80 19.4.7.1 Instruments to be used;

81 19.4.7.2 Methods of performing the analysis; and

82 19.4.7.3 Pertinent experience of the individual who analyzes the samples.

83 19.4.8 If licensee personnel are to load or unload sources, the applicant shall describe the qualifications  
84 and training of the personnel and the procedures to be used. If the applicant intends to contract  
85 for source loading or unloading at its facility, the loading or unloading must be done by an  
86 organization specifically authorized by the ~~U.S. Nuclear Regulatory Commission~~NRC or an  
87 Agreement State to load or unload irradiator sources.

88 19.4.9 The applicant shall describe the inspection and maintenance checks, including the frequency of  
89 the checks required by 19.23.

90 **19.5 Start Commencement of Construction.**

91 19.5.1 ~~The applicant may not begin~~Commencement of construction of a new irradiator ~~may not occur~~  
92 prior to the submission to the Department of both the application for a license for the irradiator  
93 and the fee required by Part 12 of these regulations.

94 19.5.1.1 ~~As used in this section, the term "construction" includes the construction of any~~  
95 ~~portion of the permanent irradiator structure on the site but does not include: engineering~~  
96 ~~and design work, purchase of a site, site surveys or soil testing, site preparation, site~~  
97 ~~excavation, construction of warehouse or auxiliary structures, and other similar tasks.~~

98 19.5.1.21 Any activities undertaken prior to the issuance of a license are entirely at the risk  
99 of the applicant and have no bearing on the issuance of a license with respect to  
100 the requirements of the Act, and rules, regulations, and orders issued under the  
101 Act.

102 19.5.1.2 Commencement of construction as defined in Part 1 may include non-  
103 construction activities if the activity has a reasonable nexus to radiological  
104 safety.

105 **19.6 Applications for Exemptions.**

106 19.6.1 Any application for a license or for amendment of a license authorizing use of a teletherapy-type  
107 unit for irradiation of materials or objects may include proposed alternatives for the requirements  
108 of this part. The Department will approve the proposed alternatives if the applicant provides  
109 adequate rationale for the proposed alternatives and demonstrates that they are likely to provide  
110 an adequate level of safety for workers and the public.

111 **DESIGN AND PERFORMANCE REQUIREMENTS FOR IRRADIATORS**

112 **19.7 Requirements and Performance Criteria for Sealed Sources.**

113 Sealed sources shall:

114 19.7.1 Have a certificate of registration issued by the ~~U.S. Nuclear Regulatory Commission~~NRC or an  
115 Agreement State, or shall have been evaluated in accordance with 10 CFR 32.210 or the  
116 equivalent state regulation;

117 \* \* \*  
118

**Comment [jsj5]:** Section 19.5 is modified consistent with 10 CFR 36.15.  
  
Original subsection 19.5.1.1 is deleted and replaced by new provision 19.5.1.2  
  
Part 1 is currently being/has been amended to incorporate/expand the definitions for "construction" and "commencement of construction", consistent with the definitions in federal rule. These definitions were incorporated into an amendment to Part 1 (which became effective in February 2016) as these terms are used across multiple regulatory parts.  
  
This provision is expanded for consistency with federal rules and differs from SSRCR Part Q. Part Q has not been updated since 2005 and is not current with all federal rules or more recent rule changes.  
  
NRC RATS 2011-2  
NRC Compatibility (36.2\*)= D  
(\*definitions for "construction" and "commencement of construction").  
NRC Compatibility (36.15) = D

119 | **19.8 Access Control.**

120 | \* \* \*

121 | **19.9 Shielding.**

122 | 19.9.1 The radiation dose rate in areas that are normally occupied during operation of a panoramic  
123 | irradiator may not exceed 0.02 millisievert (2 millirem) per hour at any location 30 centimeters or  
124 | more from the wall of the room when the sources are exposed.

125 | 19.9.91.1 The dose rate must be averaged over an area not to exceed 100 square  
126 | centimeters having no linear dimension greater than 20 centimeters.

127 | 19.9.91.2 Areas where the radiation dose rate exceeds 0.02 millisievert (2 millirem) per  
128 | hour must be locked, roped off, or posted.

129 | 19.9.2 The radiation dose at 30 centimeters over the edge of the pool of a pool irradiator may not  
130 | exceed 0.02 millisievert (2 millirem) per hour when the sources are in the fully shielded position.

131 | 19.9.3 The radiation dose rate at 1 meter from the shield of a dry-source-storage panoramic irradiator  
132 | when the source is shielded may not exceed 0.02 millisievert (2 millirem) per hour and at 5  
133 | centimeters from the shield may not exceed 0.2 millisievert (20 millirem) per hour.

134 | **19.10 Fire Protection.**

135 | \* \* \*

136 | **19.11 Radiation Monitors.**

137 | \* \* \*

138 | **19.12 Control of Source Movement.**

139 | 19.12.1 The mechanism that moves the sources of a panoramic irradiator must require a key to actuate.

140 | 19.12.1.1 Actuation of the mechanism must cause an audible signal to indicate that the  
141 | sources are leaving the shielded position.

142 | 19.12.1.2 Only one key may be in used at any time, and only one operators or facility  
143 | management may possess it.

144 | 19.12.1.3 The key must be attached to a portable radiation survey meter by a chain or  
145 | cable.

146 | 19.12.1.4 The lock for source control must be designed so that the key may not be  
147 | removed if the sources are in an unshielded position.

148 | 19.12.1.5 The door to the radiation room must require the same key.

149 | 19.12.2 The console of a panoramic irradiator must have a source position indicator that indicates when  
150 | the sources are in the fully shielded position, when they are in transit, and when the sources are  
151 | exposed.

152 | 19.12.3 The control console of a panoramic irradiator must have a control that promptly returns the  
153 | sources to the shielded position.

154 | 19.12.4 Each control for a panoramic irradiator must be clearly marked as to its function.  
155 |  
156 |  
157 |

158 | **19.13 Irradiator Pools.**

**Comment [jsj6]:** Numbering for subsections 19.9.1.1 and 19.9.1.2 are corrected for consistency with standard rule numbering and are realigned for formatting purposes.

**Comment [jsj7]:** Minor wording changes are made consistent with 10 CFR 36.31(a) and SSR CR Part Q.  
NRC Compatibility = H&S

159 \* \* \*

160 19.14 Source Rrack Pprotection.

161 \* \* \*

162 19.15 Power Ffailures.

163 \* \* \*

164 19.16 Design Rrequirements.

165 \* \* \*

166 19.16.1.10 Seismic.

167 (1) For panoramic irradiators to be built in seismic areas, the licensee shall design  
168 the reinforced concrete radiation shields to retain their integrity in the event of an  
169 earthquake by designing to the seismic requirements of an appropriate source  
170 such as current national standards or local building codes.

171 19.16.1.11 Wiring.

172 (1) For panoramic irradiators, the licensee shall verify that electrical wiring and  
173 electrical equipment in the radiation room are selected to minimize failures due to  
174 prolonged exposure to radiation.

175 19.17 Construction Mmonitoring and Aacceptance Ttesting.

176 \* \* \*

177 OPERATION OF IRRADIATORS

178 19.18 Training.

179 19.18.1 Before an individual is permitted to operate an irradiator without a supervisor present, the  
180 individual must be instructed in:

181 19.18.1.1 The fundamentals of radiation protection applied to irradiators (including the  
182 differences between external radiation and radioactive contamination, units of  
183 radiation dose, Department dose limits, why large radiation doses must be  
184 avoided, how shielding and access controls prevent large doses, how an  
185 irradiator is designed to prevent contamination, the proper use of survey meters  
186 and personnel dosimeters, other radiation safety features of an irradiator, and the  
187 basic function of the irradiator);

188 19.18.1.2 The requirements of Parts 4, 10 and 19 that are relevant to the irradiator;

189 19.18.1.3 The operation of the irradiator;

190 19.18.1.4 Those operating and emergency procedures listed in 19.19 that the individual is  
191 responsible for performing; and

192 19.18.1.5 Case histories of accidents or problems involving irradiators.

193 19.18.2 Before an individual is permitted to operate an irradiator without a supervisor present, the  
194 individual shall pass a written test on the instruction received consisting primarily of questions  
195 based on the licensee's operating and emergency procedures that the individual is responsible  
196 for performing and other operations necessary to safely operate the irradiator without supervision.

197 19.18.3 Before an individual is permitted to operate an irradiator without a supervisor present, the  
198 individual must have received on-the-job training or simulator training in the use of the irradiator  
199 as described in the license application.

Comment [jsj8]: The draft rule presented during the stakeholder process and request for rulemaking before the board of health, originally proposed adding a reference to the American Concrete Institute (ACI) Standard 318-89m. Subsequent review by the Colorado Attorney General's Office indicated that such an added reference would likely require a specific date for the standard. However, discussions with both the NRC and the ACI have indicated that the standard referenced in current NRC (federal) rule has not been updated to reflect the most recent ACI standard date.  
  
Rather than incorporate the more recent standard before a federal rule change, the rule will defer to the original/current more general language of the Part 19 that is now in effect. In the future, should the federal rule be updated to reflect a more recent ACI standard, a rulemaking for Part 19 will be evaluated or initiated.  
  
The equivalent federal rule provision (10 CFR 36.39(j)) has a compatibility category of H&S and is not required for compatibility purposes.

200 19.18.3.1 The individual shall also demonstrate the ability to perform those portions of the  
201 | operating **and emergency** procedures that he or she is to perform.

**Comment [jsj9]:** The phrase "and emergency" is added, consistent with 10 CFR 36.51(c) and SSR CR Part Q. This wording was previously omitted from Part 19.

202 19.18.4 The licensee shall conduct safety reviews for irradiator operators at least annually.  
203 \* \* \*  
204

The requirement clarifies that the individual must demonstrate the capability to perform both operating and emergency procedures that they would be expected to perform. If not currently required, licensees using panoramic irradiators would be required to incorporate this requirement into the irradiator operator evaluation/demonstration process.

NRC Compatibility = H&S

205 **19.19 Operating and Eemergency Pprocedures.**

206 \* \* \*  
207

208 **19.20 Personnel Mmonitoring.**

209 19.20.1 Irradiator operators shall wear a personnel dosimeter that is processed and evaluated by an  
210 accredited National Voluntary Laboratory Accreditation Program (NVLAP) processor while  
211 operating a panoramic irradiator or while in the area around the pool of an underwater irradiator.

**Comment [jsj10]:** Minor grammar and language corrections are made to 19.20.1, consistent with 10 CFR 36.55 and SSR CR Part Q.21.

Section 19.20.1 is reformatted for alignment.

NRC Compatibility = H&S

212 19.20.1.1 The personnel dosimeter processor must be accredited for high-energy photons  
213 | in the normal and accident dose ranges (see **Part 4, Section 4.17.3**).

214 19.20.1.2 Each personnel dosimeter must be assigned to and worn by only one individual.

215 19.20.1.3 Film badges must be ~~replaced~~**processed** at least monthly and ~~each~~ other  
216 | personnel dosimeters ~~s~~ must be ~~replaced~~**processed** at least quarterly.

217 19.20.1.4 After replacement, each personnel dosimeter must be promptly processed.

218 19.20.2 Other individuals who enter the radiation room of a panoramic irradiator shall wear a dosimeter,  
219 | which may be a pocket dosimeter.

220 19.20.2.1 For groups of visitors, only two people who enter the radiation room are required  
221 | to wear dosimeters.

222 19.20.2.2 If pocket dosimeters are used to meet the requirements of this paragraph, a  
223 | check of their response to radiation must be done at least annually.

224 19.20.2.3 Acceptable dosimeters must read within ~~+ or -~~ **+20** percent of the true radiation  
225 | dose.

**Comment [jsj11]:**  
NOTE: The equivalent provision in 10 CFR 36.55(b) and SSR CR Part Q requires a 30 % tolerance. The 20% value is retained as it is more conservative.

[NOTE: Common industry practice and other regulatory requirements e.g., 10 CFR 34.47 (pertaining to industrial radiography) typically require a 20 % tolerance.]

NRC Compatibility = H&S

226 **19.21 Radiation Ssurveys.**

227 \* \* \*

228 19.21.5 Before releasing resins for unrestricted use, they must be monitored before release in an area  
229 | with a background level less than 0.5 microsievert (0.05 millirem) per hour.

230 19.21.5.1 The resins may be released only if the survey does not detect radiation levels  
231 | above background **radiation** levels.

**Comment [jsj12]:** In 19.21.5.1, "radiation" is added for clarity, consistent with 10 CFR 36.57(d) and SSR CR Part Q.

NRC Compatibility = H&S

232 19.21.5.2 The survey meter used must be capable of detecting radiation levels of 0.5  
233 | microsievert (0.05 millirem) per hour.

234 **19.22 Detection of LLeaking Ssources.**

235 19.22.1 Each dry-source-storage sealed source must be tested for leakage at intervals not to exceed 6  
236 | months using a leak test kit or method approved by the **U.S. Nuclear Regulatory**  
237 | **Commission****NRC** or an Agreement State.

- 238 19.22.1.1 In the absence of a certificate from a transferor that a test has been made within  
239 the 6 months before the transfer, the sealed source may not be used until tested.
- 240 19.22.1.2 The test must be capable of detecting the presence of 200 becquerel (0.005  
241 microcurie) of radioactive material and must be performed by a person approved  
242 by the ~~U.S. Nuclear Regulatory Commission~~**NRC** or an Agreement State to  
243 perform the test.
- 244 19.22.2 For pool irradiators, sources may not be put into the pool unless the licensee tests the sources for  
245 leaks or has a certificate from a transferor that a leak test has been done within the 6 months  
246 before the transfer.
- 247 19.22.2.1 Water from the pool must be checked for contamination each day the irradiator  
248 operates. This check may be done either by using a radiation monitor on a pool  
249 water circulating system or by analysis of a sample of pool water.
- 250 19.22.2.2 If a check for contamination is done by analysis of a sample of pool water, the  
251 results must be available within 24 hours.
- 252 19.22.2.3 If the licensee uses a radiation monitor on a pool water circulating system, the  
253 detection of above normal radiation levels must activate an alarm.
- 254 (1) The alarm set-point must be set as low as practical, but high enough to avoid  
255 false alarms.
- 256 (2) The licensee may reset the alarm set point to a higher level if necessary to  
257 operate the pool water purification system to clean up contamination in the pool if  
258 specifically provided for in written emergency procedures.
- 259 19.22.3 If a leaking source is detected, the licensee shall arrange to remove the leaking source from  
260 service and have it decontaminated, repaired, or disposed of by an ~~U.S. Nuclear Regulatory~~  
261 ~~Commission~~**NRC** or Agreement State licensee that is authorized to perform these functions.
- 262 19.22.3.1 The licensee shall promptly check its personnel, equipment, facilities, and  
263 irradiated product for radioactive contamination.
- 264 19.22.3.2 No product may be shipped until the product has been checked and found free of  
265 contamination.
- 266 19.22.3.3 If a product has been shipped that may have been inadvertently contaminated,  
267 the licensee shall arrange to locate and survey that product for contamination.
- 268 19.22.3.4 If any personnel are found to be contaminated, decontamination must be  
269 performed promptly.
- 270 19.22.3.5 If contaminated equipment, facilities, or products are found, the licensee shall  
271 arrange to have them decontaminated or disposed of by a ~~U.S. Nuclear~~  
272 ~~Regulatory Commission~~**NRC** or Agreement State licensee that is authorized to  
273 perform these functions.
- 274 19.22.3.6 If a pool is contaminated, the licensee shall arrange to clean the pool until the  
275 water contamination levels do not exceed the appropriate concentration in Part 4,  
276 Appendix 4B, Table 4B2, Column 2 (See **Part 4, Sections** 4.52 and 4.53 for  
277 notification and reporting requirements).
- 278 **19.23 Inspection and Maintenance.** \* \* \*
- 279
- 280 **19.24 Pool Water Purity.**

281 19.24.1 Pool water purification systems must be run sufficiently to maintain the conductivity of the pool  
282 water below 20 microsiemens per centimeter under normal circumstances.

283 19.24.1.1 If pool water conductivity rises above 20 microsiemens per centimeter, the  
284 licensee shall take prompt actions to lower the pool water conductivity and shall  
285 take corrective actions to prevent future recurrences.

286 19.24.2 The licensee shall measure the pool water conductivity frequently enough, but no less than  
287 weekly, to assure that the conductivity remains below 20 microsiemens per centimeter.  
288 Conductivity instruments must be calibrated at least annually.

### 289 19.25 Attendance During Operations.

290 19.25.1 Both an irradiator operator and at least one other individual, who is trained on how to respond  
291 and prepared to promptly render or summon assistance if the access control alarm sounds, shall  
292 be present onsite:

293 19.25.1.1 Whenever the irradiator is operated using an automatic product conveyor  
294 system; and

295 19.25.1.2 Whenever the product is moved into or out of the radiation room when the  
296 irradiator is operated in a batch mode.

297 19.25.2 At a panoramic irradiator at which static irradiations (no movement of the product) are occurring,  
298 an individual who has received the training required in 19.18.7 on how to respond to alarms must  
299 be onsite.

300 19.25.3 At an underwater irradiator, an irradiator operator must be present at the facility whenever the  
301 product is moved into or out of the pool.

302 19.25.3.1 An individual who moves the product into or out of the pool of an underwater  
303 irradiator need not be qualified as an irradiator operator; however, each such  
304 individual shall have received the training required in 19.18.6 and 19.18.7. Static  
305 irradiations may be performed without a person present at the facility.

Comment [jsj13]: Language relating to static irradiations is added consistent with 10 CFR 36.65(c) and SSRCR Part Q.26.c.

NRC Compatibility = H&S

### 306 19.26 Entering and Leaving the Irradiation Room.

307 \* \* \*

### 309 19.27 Irradiation of Explosive or Flammable Materials.

310 19.27.1 Irradiation of explosive material is prohibited unless the licensee has received prior written  
311 authorization from the Department.

312 19.27.1.1 Authorization will not be granted unless the licensee can demonstrate that  
313 detonation of the explosive would not rupture the sealed sources, injure  
314 personnel, damage safety systems, or cause radiation overexposures of  
315 personnel.

316 19.27.2 Irradiation of more than small quantities of flammable material (flash point below 140°C) is  
317 prohibited in panoramic irradiators unless the licensee has received prior written authorization  
318 from the Department.

Comment [jsj14]: Correction of temperature units, consistent with 10 CFR 36 and SSRCR Part Q.28.

319 19.27.2.1 Authorization will not be granted unless the licensee can demonstrate that a fire  
320 in the radiation room could be controlled without damage to the sealed sources  
321 or safety systems and without radiation overexposures of personnel.

## 322 RECORDS AND REPORTS



323 **19.28 Records and Retention Periods.**

324 19.28.1 The licensee shall maintain the following records at the irradiator for the periods specified:

325 19.28.1.1 A copy of the license, license conditions, documents incorporated into a license  
326 by reference, and amendments thereto until superseded by new documents or  
327 until the Department terminates the license for documents not superseded;

328 19.28.1.2 Records of each individual's training, tests, and safety reviews provided to meet  
329 the requirements of 19.18.1, 19.18.2, 19.18.3, 19.18.4, 19.18.6, and 19.18.7 until  
330 3 years after the individual terminates work;

331 19.28.1.3 Records of the annual evaluations of the safety performance of irradiator  
332 operators required by 19.18.5 for 3 years after the evaluation;

333 19.28.1.4 A copy of the current operating and emergency procedures required by 19.19  
334 until superseded or the Department terminates the license. Records of the  
335 radiation safety officer's review and approval of changes in procedures as  
336 required by 19.19.3.3 retained for 3 years from the date of the change;

337 19.28.1.5 Evaluations of personnel dosimeters (film badge, optically stimulated  
338 luminescence and thermoluminescence dosimeter) required by 19.20 in  
339 accordance with Part 4, Section 4.46 until the Department terminates the  
340 license;  
341 \* \* \*

342 19.28.1.13 Records related to decommissioning of the irradiator as required by Part 3,  
343 Section 3.16.6.85.

344 **19.29 Reports.**

345 19.29.1 In addition to the reporting requirements in other parts of the regulations, the licensee shall report  
346 the following events if not reported under other parts of Department regulations:

347 19.29.1.1 Source stuck in an unshielded position;

348 19.29.1.2 Any fire or explosion in a radiation room;

349 19.29.1.3 Damage to the source racks;

350 19.29.1.4 Failure of the cable or drive mechanism used to move the source racks;

351 19.29.1.5 Inoperability of the access control system;

352 19.29.1.6 Detection of radiation source by the product exit monitor;

353 19.29.1.7 Detection of radioactive contamination attributable to licensed radioactive  
354 material;

355 19.29.1.8 Structural damage to the pool liner or walls;

356 19.29.1.9 Abnormal water loss or leakage from the source storage pool; or

357 19.29.1.10 Pool water conductivity exceeding 100 microsiemen per centimeter.

358 19.29.2 The report must include a telephone report within 24 hours as described in Part 4, Section  
359 4.52.24.53.1.1, and a written report within 30 days as described in Part 4, Section 4.53.1.2.

**Comment [jsj15]:** Language modified consistent with 10 CFR 36.81(e) and SSRCR Part Q.

However, the original language in parenthesis and "in accordance with 4.46" which is not found in 10 CFR 36 (or SSRCR Part Q), is retained for clarity.

NRC Compatibility (36.81)= D

**Comment [jsj16]:** Cross-reference correction, consistent with 10 CFR 36.81.

NRC Compatibility = D

**Comment [jsj17]:** Clarifying language added, consistent with 10 CFR 36.83(a) and SSRCR Part Q.30.

NRC Compatibility = C

**Comment [jsj18]:** Cross reference is corrected for consistency with 36.83(b) and SSRCR Part Q.

NRC Compatibility = C

360

361 **EDITOR'S NOTES**

362 6 CCR 1007-1 has been divided into separate parts for ease of use. Versions prior to 04/01/2007 are  
363 located in the first section, 6 CCR 1007-1. Prior versions can be accessed from the All Versions list on the  
364 rule's current version page. To view versions effective on or after 04/01/2007, select the desired part of  
365 the rule, for example 6 CCR 1007-1 Part 01 or 6 CCR 1007-1 Part 10.

366 **History**

367