



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 17, 2016

Mr. Joseph W. Shea
Vice President, Nuclear Licensing
Tennessee Valley Authority
1101 Market Street, LP 3R-C
Chattanooga, TN 37402-2801

SUBJECT: SEQUOYAH NUCLEAR PLANT, UNITS 1 AND 2 – CORRECTION TO
LICENSE AMENDMENT TO REVISE TECHNICAL SPECIFICATION FOR
ESSENTIAL RAW COOLING WATER SYSTEM ALLOWED COMPLETION
TIME (CAC NOS. MF7450 AND MF7451)

Dear Mr. Shea:

On September 30, 2016, the U.S. Nuclear Regulatory Commission issued Amendment No. 336 to Renewed Facility Operating License (RFOL) No. DPR-77, and Amendment No 329 to RFOL No. DPR-79, for the Sequoyah Nuclear Plant, Units 1 and 2, respectively. The amendments consisted of changes to the RFOLs and Technical Specifications (TSs) in response to your application dated March 11, 2016, as supplemented by letters dated May 31, and July 22, 2016. These amendments revised the TSs for Essential Raw Cooling Water System Allowed Completion Time.


After issuance, it came to our attention that TS page number 3.7.8-2 for Unit 2, was incorrectly numbered. Please replace the incorrect page with the enclosed corrected page.

J. Shea

- 2 -

Thank you for bringing this matter to our attention. We regret any inconvenience this may have caused. If you have any questions, please call me at (301) 415-8480.

Sincerely,

A handwritten signature in black ink, appearing to read "Andrew Hon", with a long horizontal flourish extending to the right.

Andrew Hon, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

Enclosure:
Corrected TS Page for Unit 2

cc w/enclosures: Distribution via Listserv

ENCLOSURE

Corrected page 3.7.8-2

for Amendment No. 329 to DPR-79

<p>B. One ERCW System train inoperable for reasons other than Condition A.</p>	<p>B.1 -----NOTES----- 1. Enter applicable Conditions and Required Actions of LCO 3.8.1, "AC Sources - Operating," for emergency diesel generator made inoperable by ERCW System. 2. Enter applicable Conditions and Required Actions of LCO 3.4.6, "RCS Loops - MODE 4," for residual heat removal loops made inoperable by ERCW System. ----- Restore ERCW System train to OPERABLE status.</p>	<p>72 hours</p>
<p>C. Required Action and associated Completion Time of Condition A or B not met.</p>	<p>C.1 Be in MODE 3. <u>AND</u> C.2 Be in MODE 5.</p>	<p>6 hours 36 hours</p>

J. Shea

- 2 -

Thank you for bringing this matter to our attention. We regret any inconvenience this may have caused. If you have any questions, please call me at (301) 415-8480.

Sincerely,

/RA/

Andrew Hon, Project Manager
Plant Licensing Branch II-2
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-327 and 50-328

Enclosure:
Corrected TS Page for Unit 2

cc w/enclosures: Distribution via Listserv

DISTRIBUTION:

PUBLIC	LPL2-2 R/F	RidsACRS_MailCTR Resource
RidsNrrDssSbpb Resource	RidsNrrDorlLpl2-2 Resource	RidsNrrDssStsbResource
RidsNrrPMSequoyah Resource	RidsNrrLABClayton Resource	NHobbs, NRR
RidsRgn2MailCenter Resource	MHamm, NRR	JDion, NRR
LWheeler, NRR	RecordsAmend	

ADAMS Accession No.: ML16279A004

OFFICE	NRR/DORL/LPL2-2/PM	NRR/DORL/LPL2-2/LA	NRR/DORL/LPL2-2/BC	NRR/DORL/LPL2-2/PM
NAME	AHon	BClayton	JDion	AHon
DATE	10/7/2016	10/7/2016	10/17/2016	10/17/2016

OFFICIAL RECORD COPY