# Official Transcript of Proceedings NUCLEAR REGULATORY COMMISSION

Title: Advisory Committee on Reactor Safeguards

**ESBWR Subcommittee Meeting** 

Docket Number: (n/a)

Location: Rockville, Maryland

Date: Thursday, September 22, 2016

Work Order No.: NRC-2630 Pages 1-115

NEAL R. GROSS AND CO., INC.
Court Reporters and Transcribers
1323 Rhode Island Avenue, N.W.
Washington, D.C. 20005
(202) 234-4433

\_

DISCLAIMER

UNITED STATES NUCLEAR REGULATORY COMMISSION'S

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

The contents of this transcript of the proceeding of the United States Nuclear Regulatory Commission Advisory Committee on Reactor Safeguards, as reported herein, is a record of the discussions recorded at the meeting.

This transcript has not been reviewed, corrected, and edited, and it may contain inaccuracies.

**NEAL R. GROSS** 

COURT REPORTERS AND TRANSCRIBERS 1323 RHODE ISLAND AVE., N.W. WASHINGTON, D.C. 20005-3701

#### UNITED STATES OF AMERICA

## NUCLEAR REGULATORY COMMISSION

+ + + + +

## ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

(ACRS)

+ + + + +

2630 ESBWR SUBCOMMITTEE

+ + + + +

THURSDAY

SEPTEMBER 22, 2016

+ + + + +

ROCKVILLE, MARYLAND

+ + + + +

The Subcommittee met at the Nuclear Regulatory Commission, Two White Flint North, Room T2B1, 11545 Rockville Pike, at 1:00 p.m., Peter C. Riccardella, Chairman, presiding.

#### COMMITTEE MEMBERS:

RONALD G. BALLINGER, Chairman

CHARLES H. BROWN, JR., Member

JOSE A. MARCH-LEUBA, Member

DANA A. POWERS, Member

PETER C. RICCARDELLA, Member

JOHN W. STETKAR, Chairman

MATTHEW W. SUNSERI, Member

DESIGNATED FEDERAL OFFICIAL:

GIRIJA SHUKLA, NRR

ALSO PRESENT:

REGINA BORSH, Dominion

PATRICIA CAMPBELL, Dominion/GEH

MICHAEL DUDEK, NRR

ERICA GRAY, Sierra Club Virginia Chapter\*

JOE HEGNER, Dominion

THOMAS HICKS, Dominion/Excel Services Corp.

MICHAEL KEEGAN, Fermi 3 Proposal Intervenor\*

DOUGLAS KEMP, Dominion/Bechtel

JAMES SHEA, NRR

\* Present via telephone

## T-A-B-L-E O-F C-O-N-T-E-N-T-S

Page
Opening
Introductions
Presentation by Dominion Virginia Power on the
North Anna 3 combined license application
By Gina Borsh
Substantive Discussion
By Jim Shea40
Member Comments75
Public Comments7
Adjourn

# P-R-O-C-E-E-D-I-N-G-S

2	(1:00 p.m.)
3	CHAIRMAN RICCARDELLA: Good afternoon.
4	The meeting will now come to order. This is a
5	meeting of the Advisory Committee on Reactor
6	Safeguards ESBWR Subcommittee. I'm Pete
7	Riccardella, newly appointed Chairman of the
8	Subcommittee.
9	Subcommittee members in attendance are
10	Charles Brown, Jose March-Leuba, John Stetkar, Matt
11	Sunseri, Dana Powers, and Ron Ballinger.
12	MEMBER POWERS: The guy in the corner.
13	CHAIRMAN RICCARDELLA: Mr. Girija
14	Shukla of the ACRS staff is a Designated Federal
15	Official for this meeting. The meeting will be
16	open to public attendance.
17	This is an informational briefing by
18	the NRC staff and Dominion Virginia Power on the
19	North Anna 3 combined license application and the
20	staff's advanced safety evaluation report.
21	We've received no written comments or
22	requests at this time to make oral statements from
23	members of the public regarding today's meeting.
24	The Subcommittee will gather
25	information, analyze relevant issues and facts and

proposed positions 1 formulate and actions as 2 appropriate for deliberation by the full Committee. 3 for The rules the participation 4 today's meeting have been announced as part of the notice of the meeting previously published in the 5 Federal Register. A transcript of this meeting is 6 7 being kept and will be made available as stated in 8 the Federal Register notice. 9 Therefore, we request that participants 10 in the meeting use the microphones located 11 throughout the room when addressing the 12 Participants should first identify subcommittee. themselves and speak with sufficient clarity and 13 14 volume so that they may be readily heard. 15 A telephone bridge line has also been 16 established for this meeting. To preclude 17 interruption, the phone will be placed in a listen-18 presentations in mode during and Committee 19 discussions. 20 I ask everyone to please silence your 21 cell phones during the meeting, and we will now 22 proceed. Ι call upon NRR management to begin 23 please. 24 MR. SHEA: Good afternoon. This 25 I'm Jim Shea, the NRC's Division of New Reactor

Licensing and the Lead Project Manager for North Anna 3. And with me is Mike Dudek who is going to be, will be in the near future the acting branch chief for the branch.

So when we mention staff, we are it today, which I hope is good enough. I think we put together a pretty good summary of the review. And so our goal is basically to update the members and give them kind of a big overview of the review of including, you know, where Fermi and the ESBWR DCD fits in and how that in parallel was accomplished.

So we'll do that. We'll present that, and I just make a point that over the last probably 18 months since I've been involved and the Project Manager, the push has been the closure on the seismic reanalysis.

So it was approximately a year ago from now that we had a significant milestone. We're preparing for the first of two audits at GEH to review the seismic calculations and the seismic one structures and their evaluation.

And those were two significant items about just about a year ago, done on that. So that's been really the primary focus over the last year. And we'll see that during my presentation.

The other thing, I mean, we're speaking for the entire staff but we're, as the projects group, we're proposing what we believe would be the interest of the Committee when we go have our October 20th Subcommittee meeting. So we'll present that and we'll ask you for feedback so that bring the right information for we that subcommittee meeting.

I just want to say from the final thing from the project standpoint, and I know the staff isn't here because there's a lot of ongoing activities that they're involved in and so -- but I will just let you know maybe they'll read the transcript.

perspective from projects ΜV that between our staff and the diligent review of our staff along with Dominion's responses to information requests and along with the audit and several meetings over this last year, and again I'll give you more details on that, it was significantly hard effort that took a lot of time and effort from both sides and communication had, in order for us to be here where we are at the of the Phase 4 completion of the advanced final SER, it was a huge effort to get us there

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

over the last year.

So just want to give the staff kudos and recognize Dominions for their efforts and ensuring that they provided the information staff requested. And with that, I'll just turn it over to Girija to, you know, continue.

(Off mic comments.)

MR. SHUKLA: Yes, good afternoon. My name is Joe Hegner. I'm the licensing manager for the North Anna 3 project and have been the manager since its inception in 2001.

We are very pleased to be here today because to us it represents real progress. We had met with the Committee back in 2009 when we were the reference for ESBWR. Things evolved over time, and we find ourselves where we are today. But this, in our view, is a good thing.

Let me introduce the team that we brought today. We have Gina Borsh who is our licensing lead for Dominion and she'll be our primary spokesperson. But she is supported by the GEH and Bechtel teams who provide most of the subject matter experts in the areas we think you'll be interested in today.

We have Doug Kemp from Bechtel who will

assist us and Patricia Campbell who will provide 1 2 coordination for GΕ Hitachi. Also in 3 attendance is Tom Hicks from Excel Services. Не provides licensing support. He's Gina's right arm 4 and he'll be taking notes today to make sure that 5 we captured all the comments from the Subcommittee. 6 7 With that, I think you probably already 8 seen our presentation. We coordinated with the 9 Staff. We intend to just briefly talk about site, a few of the licensing milestones which we 10 11 have achieved, what we've done since 2013 when we 12 returned to the GEH ESBWR technology, I cover 13 departures and exemptions proposed topics for 14 October 20th meeting, entertain questions as best 15 and then have a few concluding remarks. 16 Mr. Chairman, that's what we have. 17 CHAIRMAN RICCARDELLA: Okay, thank you. 18 Please proceed. Or is it staff first? 19 MR. HEGNER: PARTICIPANT: You first. 20 21 MR. HEGNER: Okay. 22 MS. BORSH: Thank you for inviting us 23 to attend this meeting. We're hoping that the 24 information provided will help you in planning for

the October 20th meeting --

1	CHAIRMAN RICCARDELLA: Oh, yes. It's a
2	little thing that got it?
3	MS. BORSH: I'm Gina Borsh. All right,
4	so Joe covered the introduction. This first slide
5	that I'm going to talk about which is Slide 3 gives
6	you a sense of where the site is located in
7	Virginia. And as you can see the star, I can't use
8	the
9	Thank you. Okay, so this is the North
10	Anna Units 1 and 2 site. It would be the North
11	Anna 3 site. It is approximately 40 miles north
12	northwest of Richmond, about 20 or 22 miles west of
13	Fredericksburg and about 35 miles east of
14	Charlottesville.
15	MEMBER POWERS: Is it true it's above
16	ground, I mean elevated up in the air the way the -
17	_
18	MS. BORSH: No. No.
19	MEMBER POWERS: No?
20	MS. BORSH: No, no.
21	MEMBER POWERS: Okay.
22	MS. BORSH: That's just
23	MEMBER POWERS: That's a
24	misrepresentation?
25	MR. HEGNER: The southern border is

also a curious misrepresentation. But it does come 1 2 from Google. So it must be accurate. 3 PARTICIPANT: It must be true. Must be true. 4 MR. HEGNER: 5 MS. BORSH: Okay, this is a plan view of the site. And this is showing the North Anna 3 6 7 site. So over here is Units 1 and 2. This shows 8 you here's the reactor building, fuel building, the 9 turbine building, control building, 10 service complex is right here. 11 This is where the cooling towers are 12 located, and then over here is the switch yard. 13 But wait, there's more. How about this Slide 5, 14 this is a rendering that Bechtel prepared for us 15 showing you a view of what it will look like when 16 the plant is constructed. 17 Here is Units 1 and 2. Here are Units, 18 excuse me, are Units 1 and 2 over here. And this 19 is Unit 3. And over here are the cooling towers 20 for Unit 3 just to give you a sense. So this is 21 pretty much looking west. All right? 22 And then here is a view essentially 23 looking east. So you see Units 1 and 2 are here, 24 and here's Unit 3, the cooling towers. 25 So it looks like we MEMBER POWERS:

should start on the aging management programs now, 1 2 I mean, it's all here. right? 3 MS. BORSH: It's impressive, isn't it, 4 what people can put together. Yes, the wonders of 5 modern technology. So that's the location of the site and 6 7 plant layout. And then if you have 8 questions, further questions on that I will talk 9 about the milestones. 10 Joe said, we started in 11 working on our ESP application and we submitted it 12 in September of 2003. The NRC issued the EIS 13 December of 2006 and then we received the early 14 site permit from the NRC November of 2007. 15 And actually on the same day that the 16 ESP was issued, we submitted the R-COLA for the 17 ESBWR design and the NRC began their review. So we 18 went through the RAI review process, questions and 19 answers. 20 And then in, as some of you know, we 21 came before you in June, July, and August of 2009 22 and presented the R-COLA along with the NRC Staff. The full Committee met in October 2009 and then 23 24 issued the ACRS letter to the Commission in October

And then in February 2010, NRC issued the

2009.

supplemental EIS for the site. 1 2 I think most of you know that we made a 3 couple of technology changes. So we started out, as I said, as an ESBWR R-COLA, submitted it in 4 And in May of 2010, Dominion 5 November of 2007. management decided we were going to make a design 6 7 And so we revised the COLA to incorporate change. 8 the APWR technology. 9 MEMBER POWERS: Not a subtle change, 10 actually. 11 MS. BORSH: No, it was, there was a lot 12 content that stayed the same in the COLA, but It was a big technology change. So that, we 13 14 worked through that. 15 in April of 2013 Dominion And then 16 management determined that it would be best overall 17 for the company if we returned to the ESBWR 18 technology which we did. And so we had to revise 19 the COLA to reflect, to go back to the 20 technology. 21 And in order to do that, we followed 22 the following approach to make the COLA changes. 23 So basically what we said was we are going to be as

standard as possible following the design centered

working group approach that the NRC has endorsed.

24

And we used as much of the standard content from the Fermi COLA that we could, that would apply to us. And then for the site specific COLA content, we said okay, let's use as much of the previous ESBWR COLA content that we had for North Anna as possible in this reversion back to the ESBWR technology.

I think you all also recognize that we had to make substantial changes to the COLA in order to address the seismic ground motion response vector exceedances that were developed as a result of changes in industry guidance and NRC issued guidance. So we made those changes. There were other changes --

CHAIRMAN RICCARDELLA: Was that also as a result that the minerals, the mineral earthquake as well?

MS. BORSH: We made changes to address the mineral earthquake. The mineral earthquake by itself would not have required a change. It gets a little bit complicated, Dr. Riccardella. There is certain guidance out there that does say that when you're determining your spectrum and your sources you do need to take into account recent events, seismic events that have occurred in your area.

1	And so we did do that because we were
2	updating our sources to incorporate the new CEUS
3	SSE. If we had just had the earthquake or the
4	earthquake had just occurred and we didn't have
5	that CEUS SSE update, I don't know if we would have
6	had to incorporate the mineral earthquake.
7	MEMBER BROWN: Could you say that
8	again? I got lost in the transition. You didn't
9	have the CEUS in your original COLA.
10	MS. BORSH: That's right.
11	MEMBER BROWN: And then in the
12	intervening period we had the mineral springs
13	earthquake.
14	MS. BORSH: Yes.
15	MEMBER BROWN: But in the new COLA, you
16	have the CESU?
17	MS. BORSH: Yes.
18	MEMBER BROWN: Does the CESU bound the
19	mineral springs and did the design meet that? I
20	thought there was some parts of the design that
21	didn't meet the mineral springs seismic that bound
22	the conditions. I just, I'm not an expert on that,
23	it's just some stuff being talked about.
24	MS. BORSH: Right. So
25	CHAIRMAN RICCARDELLA: Just for the

1	record, it's CEUS, not CUES.
2	MEMBER BROWN: Okay, I got it
3	backwards. Sorry about that. I'm an electrical
4	guy, so you'll have to excuse me.
5	MS. BORSH: So it's Central Eastern
6	Unit
7	(Simultaneous speaking.)
8	MEMBER BROWN: I really know what that
9	is sort of.
10	MS. BORSH: All right, so
11	CHAIRMAN RICCARDELLA: Since you live
12	there.
13	MEMBER BROWN: Yes, I got hit by it.
14	My chimney shook and my house shook.
15	CHAIRMAN RICCARDELLA: I guess is the
16	CEUS spectra fully, does it fully bound the
17	mineral?
18	MS. BORSH: It doesn't exactly work
19	like that. And it would be best for our SMEs to
20	explain that to you. But what we did find, I can
21	tell you that what we did find was that when we
22	incorporated the mineral earthquake into our source
23	catalogue, looking at all the events that have
24	occurred, it had a minimal impact on the earthquake
25	response vector that were eventually developed.

1	Okay?
2	CHAIRMAN RICCARDELLA: Okay.
3	MEMBER POWERS: Just a point in the
4	probabilistic distribution of things, and it's not
5	a very big one. So that it's not what you would
6	call dominant at all unless there was something
7	found as a result of the earthquake that changed
8	its potential movement.
9	MS. BORSH: That's right. Doug, do you
10	want to add anything to that?
11	MR. KEMP: Doug Kemp here. Yes. I
12	think, Gina, you said it right. It had a very
13	insignificant effect. Once you consider the
14	history information, seismology and history of the
15	CEUS, it had insignificant effect.
16	MEMBER STETKAR: Charlotte and
17	Tennessee are still dominant, right?
18	MS. BORSH: Pardon me?
19	MEMBER STETKAR: The Charlotte
20	earthquakes and the eastern Tennessee earthquakes -
21	-
22	(Simultaneous speaking.)
23	MS. BORSH: Yes, that's right. And
24	you'll see that when we come back on October 20th.
25	We'll be showing you some figures that give you a

1	sense of the events that have occurred in the area.
2	MEMBER STETKAR: Thank you.
3	MS. BORSH: Does that answer your
4	question?
5	CHAIRMAN RICCARDELLA: Yes.
6	MS. BORSH: All right. So then this
7	last bullet is basically acknowledging that we did
8	receive NRC RAIs and we responded to those. And we
9	also did some, made some changes to the COLA in
10	order to address the open items that were
11	outstanding from the SER back in 2009.
12	I thought you might be interested in
13	giving you a sense of how far we're deviating from
14	the DCD. So basically, we are extremely consistent
15	in incorporating by reference the DCD unlike some
16	other technologies you may have seen.
17	But so I'll just go through these
18	departures and exemptions with you. The first
19	departure and exemption is about the seismic
20	response spectra exceeding the CSDRS.
21	And so that by far is the biggest
22	change we've made to the COLA, and you'll see that
23	when we come back on October 20th. I'm sure you'll
24	want to hear about that. It's a departure. It's
25	also an exemption because we had to change the

definition of the safe shutdown earthquake which is incorporated into the DCD Tier 1 content.

So that's why it's a departure and an exemption. And just to give you a sense of where we are, FERMI doesn't have this departure. This is site specific.

second departure is also an exemption, and this is very minor in the sense that it really is just a matter of figures. because of the site limitations that we have North Anna as far as space, we have to locate the circuit breaker and main generator the motor operated disconnects in an intermediate switch yard which is a little bit different from the DCD.

The DCD says we're going to have, that that equipment is in the Turbine Island Transformer Yard. So it's really just a matter of changing the figures, and those figures appear in the DCD Tier 2 content and Tier 1. So we need a departure and an exemption, and this is unique to North Anna also.

departure The third involves the switchyard. the '70s designed So in we and constructed the North Anna Units 1 and switchyard, and we used the Dominion standards that were, that we had at the time.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

subsequent to 1 Well, that, the NRC 2 issued some regulatory guidance about switchyard 3 it's protection. And, well, about lightening 4 protection. It covers both the standard design and 5 it also covers the switchyard. is one, the Reg Guide 6 And so there 7 refers to IEEE standards. And one of the standards 8 talks about surge protection. And we do not comply 9 completely with that IEEE standard for the surge 10 protection because it was basically non-existent at 11 the time. 12 However, what we do have for design in it meets the intent of 13 switchyard is 14 And so we're asking for it, or we've quidance. 15 2 reflected this departure to the Tier as а 16 information, and there's an explanation of that in 17 Part 7 of the COLA. 18 We're talking about MEMBER STETKAR: 19 electrical stuff here. Before you get to other 20 don't understand, things that I how are 21 addressing the open phase issue, because that's 22 after the DCD was accepted. MS. BORSH: 23 Yes, yes. 24 MEMBER STETKAR: So do vou 25 discussion of that in Chapter 8 of your --

MS. BORSH: Yes, we're following Fermi 1 2 for that. 3 MEMBER STETKAR: Okay, thank you. You're 4 MS. BORSH: welcome. Next 5 departure, this is the Fermi. We same as are 6 reconfiguring the design, reconfiguring the 7 Radwaste Building in order to allow us to have ten 8 years of storage for the Class B and C radwaste and 9 three months of storage for Class A. Right now the 10 DCD has six months. Yes, right. 11 And we're the same as Fermi here, 12 you've seen this already. The next departure 13 also an exemption, and this involves liquid waste 14 management systems. So the DCD right now says that we would discharge using the cooling tower 15 16 down line, but what we plan to do is construct a 17 radwaste defluent discharge piping line that will 18 handle the discharges from liquid waste management 19 system. 20 That's a figure also, or I'm sorry, 21 that's content also in the DCD Tier 1 information, 22 so it's a departure and it's an exemption. 23 And the then next departure and 24 exemption involves Reg Guide 1.221 which new 25 quidance, well fairly new guidance that the

issued about hurricanes and hurricane missiles.

And so the DCD was submitted before this Reg Guide was issued, and so it was not, I'm sorry, the DCD didn't address Reg Guide 1.221 requirements. And so we did. And what we found was that in certain instances, the velocities of certain missiles at North Anna is higher than the velocities that are in the DCD.

And so what we're going to have to do is, what we did was add additional requirements to meet the higher velocities that we're going to, that we could experience at North Anna. And that's a departure and an exemption also.

And then the last exemption I think you are familiar with. This is the exception that I think all of the Part 52 licensees are taking to the regulations in Part 70 and Part 74 for accountability of special nuclear material.

Right now the regulations give the Part 50 licensees exceptions to the requirements, but it doesn't specifically, the regulations don't specifically address the Part 52 licensees. And so this is the same as what Fermi did and what the other utilities I believe are doing also. Any questions about this? Okay.

1	So with that, these are some topics we
2	thought okay. Well
3	MR. HEGNER: That's not the yes.
4	MS. BORSH: Yes, this is a different
5	version than what I sent you but
6	MR. HEGNER: Close enough.
7	MS. BORSH: it's close enough.
8	Let's move on. Let's go through it. Okay.
9	(Off mic comments.)
10	MS. BORSH: I think so.
11	MEMBER BROWN: The difference is
12	(Simultaneous speaking.)
13	MEMBER MARCH-LEUBA: She has, for
14	example, Chapter 9 up there and we don't on our
15	hard copies.
16	MS. BORSH: Right.
17	PARTICIPANT: And the other change is
18	it says October 20th electronic copy.
19	MR. HEGNER: Oh yes, October 19th to
20	October that would be a hint, too.
21	MS. BORSH: Well, this is up to you
22	guys. All right, so let's go over this. So the
23	first row that we were talking about here is
24	hazardous chemicals.
25	And we did do a reanalysis of certain

1	hazardous chemicals for the site. And in
2	particular, we thought you might be interested in
3	the reanalysis we did for liquid hydrogen for
4	transport and storage. So that's one topic that
5	you might be interested in.
6	MEMBER STETKAR: Gina?
7	MS. BORSH: Yes, John?
8	MEMBER STETKAR: Let me ask you
9	something just sort of general because I might as
10	well ask you now. The North Anna has some revision
11	of a site safety analysis report, correct, that was
12	developed as part of the early site permit. Is
13	that correct?
14	MS. BORSH: An SSAR?
15	MEMBER STETKAR: SSAR.
16	MS. BORSH: Yes. And so what was your
17	question?
18	MEMBER STETKAR: Well, I hadn't got to
19	it yet.
20	MS. BORSH: Oh. We have
21	MEMBER STETKAR: How does your FSAR for
22	the I hate this because years ago I didn't speak
23	this way, but I'll start babbling. How does your
24	FSAR for the COLA relate to the SSAR for the ESP?
25	CHAIRMAN RICCARDELLA: Surprisingly, I

1	understood it.
2	MEMBER STETKAR: And you know it's time
3	to retire when you start speaking like that. And
4	understanding it, yes. I tried to annunciate
5	clearly so that our transcript has all of the
6	anyway, you get what I'm asking?
7	MS. BORSH: Yes.
8	MEMBER STETKAR: Because, so what's
9	your answer?
10	MS. BORSH: The answer is that we
11	followed Reg Guide 1.206 as far as incorporation.
12	Well, we followed 1.206 with the guidance about how
13	to write a COLA when you have a DCD and an ESP.
14	MEMBER STETKAR: Okay.
15	MS. BORSH: And in that section of
16	1.206 it says use the SSAR information and maybe
17	add something
18	MEMBER STETKAR: So that for example if
19	I'm interested in understanding some site specific
20	aspects of the meteorology, I might need to go look
21	at the SSAR rather than your FSAR, is that correct?
22	MS. BORSH: Not exactly. What happens
23	is that if that were to be the case, if we were
24	relying on the SSAR content, then what we do is we

incorporate the SSAR content by reference just like

1	we have been incorporating the DCD.
2	MEMBER STETKAR: Okay, by reference.
3	But I have the DCD. But what I'm hearing you say
4	is if I'm curious about some parameter, some
5	meteorological parameter, and I read the FSAR, you
6	may incorporate information from the SSAR by
7	reference.
8	MS. BORSH: Right.
9	MEMBER STETKAR: So I need that
10	document.
11	MS. BORSH: Yes.
12	MEMBER STETKAR: What's the most recent
13	revision of your SSAR, do you know?
14	MS. BORSH: Is it
15	MR. HEGNER: Rev 9 I think.
16	MS. BORSH: That's what I was going to
17	say.
18	MEMBER STETKAR: I think I have a
19	reference for that. I'm not sure I have the
20	document, but I can go find it. I just wanted to
21	make sure it wasn't, like, Rev 37.
22	MS. BORSH: No. And that document has
23	not been revised. It's static.
24	MEMBER STETKAR: Yes, I mean, it's like
25	a 2000

## (Simultaneous speaking.)

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MEMBER STETKAR: Yes, no, I've got an ML number for it. I just used the last one that I could find and I wasn't sure whether there was anything after that. So thank you.

BORSH: You're welcome. MS. So for Chapter 2, also think that you might we interested in some of the changes that we made. And these are the things where we thought okay, these are, we did some different revised analyses for these topics, and so that's why we thought you might be interested in them.

And so in Chapter 2 Section 2.4 we did some reanalysis for flooding and groundwater and accidental releases. And these were done to respond to some RAIs that we received from the staff. So you may be interested in seeing some of them.

The third row with Chapters 2, 3, 4, 9, 14, 19 all involve the seismic exceedances. All these chapters were affected in one way or another by the changes.

Chapters 3 and 19 on the next row, this is what I spoke about earlier, the Reg Guide 1.221 hurricane wind and missile analysis that we did, we

1	thought you might be interested in that. It's
2	different than what you saw at Fermi's ACRS
3	meetings and from what we had provided before.
4	MEMBER STETKAR: Since I'm a PRA guy
5	and Chapter 19 is PRA, would I form this be
6	accurate in inferring that the only changes to the
7	PRA might be in the external hazards
8	characterization, or have you made any other
9	changes to Chapter 19?
10	MS. BORSH: I think that was it. I
11	would have to look at them.
12	MEMBER STETKAR: That's fine, I can go
13	search it.
14	MS. BORSH: You want us to, I can ask
15	Patricia.
16	MEMBER STETKAR: It's fine, I can read.
17	MS. BORSH: Okay. Chapter 8, this is
18	the departure and exemption I told you about before
19	that both of them, one is the switchyard and
20	creating an intermediate switchyard for the site
21	because of its limited space, and then the other is
22	about having a departure from the Reg Guide on
23	surge protection.
24	Chapter 9, yes we made some site
25	

1	minimal. It was adding some information about
2	using the fiberglass reinforced piping that we're
3	going to be using for plant, PSWS and things like
4	that. Not too significant.
5	And then Chapter 11 is the departure
6	and exemption I told you about earlier which is
7	using the rad waste discharge piping rather than
8	the cooling tower blowdown line for the liquid
9	waste management system discharge piping.
10	MEMBER BROWN: So I'm sorry, John.
11	Were you going to
12	MEMBER STETKAR: No, go ahead.
13	MEMBER BROWN: Oh, I thought I heard
14	somebody else say something. Before you go on,
15	there's no Chapter 7 on there, that's INC. And
16	when we first approved the ESBR, ESBWR DCD in 2009,
17	or at least we reviewed it and then I guess we
18	wrote our letter. I forgotten the date you showed.
19	It's in
20	MS. BORSH: It's all right.
21	MEMBER BROWN: Is that October 9, 2009?
22	MS. BORSH: Yes.
23	MEMBER BROWN: There was considerable
24	angst in two major areas. One was the voting units
25	for the reactor trip and safeguards functions not

having watchdog timers that actually monitored those microprocessor based, software based voting units.

And there were changes made to institute if a voting unit in any division or channel however, I don't remember how you referred to them, locked up and couldn't monitor the vote, that the timer would, the hardware based timer, not software based supposedly, would then initiate a trip for that channel, a reactor trip or an alarm for a safequards unit because you don't want to obviously trip the safeguard systems on a failure like that.

And there were a bunch of promised DCD changes for that function to be included, and this was Rev 7 of the DCD I believe. The reason I'm hesitant right now, my laptop got scrubbed by NRC four years ago and I've lost, I got to go find the paper and I haven't been able to find it yet to recreate where those were supposed to be.

So it was supposed to be incorporated in the later revisions of Rev, after Rec 7 and since I can't find my information yet, I can't verify that. And it happened also with the Fermi one, so I've been taking it on face. But this time

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

I'm going to ask the question of how that got incorporated.

The second item was the way the networks communicated offsite. In other words, let me say it this way. Outside, no outside the plant.

So corporate or administrative areas, corporate workstations, et cetera, et cetera, they were initially based on software based firewalls and, you know, electrical, like you have in your computer today as opposed to data being transmitted to the administrative or outside the plant via hardware one way, data diodes without any ability to be monitored or controlled or monitored or changed via software externally or internally.

You manually had to qo something, you know, take it out, put something else in. Both of those were supposed to have been incorporated. Those are the two questions looking at trying to confirm that were still there now that we're up to, I think you all are doing Rev 10, at least based on the paperwork we've gotten so far.

And so those are the only two questions

I would like to try to make sure we have addressed.

This question is also for the staff obviously.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

1	MR. SHEA: Yes, we're up to Rev 10,
2	there's a supplement to that Rev 10.
3	MEMBER BROWN: Oh yes?
4	MR. SHEA: Yes, supplement one. So I
5	mean, and that was based on all the steam dryer
6	issues.
7	MEMBER BROWN: Yes, I saw that. But
8	that has nothing to do with this particular, the
9	INC part.
10	MR. SHEA: Right, right. There was an
11	INC from my understanding. INC, all those issues
12	were resolved long ago.
13	MEMBER BROWN: I'm not arguing about
14	that.
15	MR. SHEA: And we'll take that back and
16	we'll get you an answer.
17	MEMBER BROWN: I just want to make sure
18	they are not, I never saw the actual changes to the
19	original Rev 7 of the DCD. When we went through
20	this there were proposed changes to the DCD shown
21	to us and they were supposed to be incorporated. I
22	can't verify that right now. I admit, that
23	happened in 2009, so somebody's going to have to do
24	some digging.
25	MR. SHEA: We'll take that back and get

1	an answer for you ASAP.
2	MEMBER BROWN: There should be figures
3	that show the hardware based watchdog timer
4	approach for the building units and there should be
5	a picture showing hardware based data diodes for
6	all data going out of the plant networks into, you
7	know, like administrative functions, corporate,
8	whatever it is outside the plant. Okay?
9	MR. SHEA: Yes. Understand. We'll
10	take that back. Like I said, I think these were
11	all resolved in the DCD and
12	MEMBER BROWN: We were told they were
13	resolved.
14	MR. SHEA: we'll find it.
15	MEMBER BROWN: Okay. Thank you. Thank
16	you.
17	CHAIRMAN RICCARDELLA: So I understand
18	that your intent to have some technical details on
19	each of these topics at the October?
20	MS. BORSH: That was my intent. We had
21	a subsequent slide that didn't show up, but what we
22	were thinking was the reason that some of these
23	topics are on here is because there's a departure
24	and an exemption and it's different from Fermi.
25	So the last three for Chapters 8, 9,

and 11, I'm not sure they're significant enough. The only reason they're on here is because they're an exemption. But they're very straightforward changes. And so in the more recent revision that I submitted, and apparently it's gotten lost in the electrons, I would propose that we not even include those topics.

MR. SHEA: This is Jim Shea again from the staff. I would just add to what Gene has, and you'll see it in my presentation. But I kind of always thought of those three items as administrative exemptions. They're essentially changes to a figure in the DCD. And in the case of 8 and in the case of 9, that was the fiberglass piping.

MS. BORSH: Reinforced piping.

MR. SHEA: The staff did an extensive review on that. I mean, pages of review. And maybe because at the time that's not really a common material. But I think since then this really has become a common material even in the operating fleet where this is a common replacement for the current piping for service water, et cetera because of its corrosion abilities.

CHAIRMAN RICCARDELLA: Fiberglass or

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

HBP?

MR. SHEA: The fiberglass reinforced piping, yes. But we have an extensive review of that in our SER. And the other one, the rad waste discharge line, again another almost administrative change and an exemption I would call it because it's, and what's interesting about that one, and you'll see it in our SER, and we evaluate every one of these exemptions in our individual SER.

So you'll see a separate evaluation, separately for the exemption, and that's partly required by regulation. So we have a detailed evaluation of each one of these.

And in that particular case, the interesting fact is that the plant is planned to be a zero release liquid plant, and that is usually the case for BWRs because BWR's generally secondary side, steams a lot, and all the water, you end up making up water not discharging water in a BWR.

So with those, with that fact and what North Anna, and it's in our SCR what their goal was is to I think de-complicate the design of that discharge line and make it a simple discharge out to the discharge canal with a procedure that if you ever did release liquid, you would need Unit 1 or

Unit 2 operating for the dilution.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

And the point of the design if it's a stand-alone plant, the dilution is the cooling tower. That's where the credit for dilution of liquid release in the DCD. So this is just taking advantage of the fact that the site has two units and it can offer an alternate dilution.

Anyway, and I agree, and you'll see in my presentation I agree with Gina's assessment, that it's probably not a significant item to really review. And of course it's up to you but it's not significant. It's well written in our SER and also in the FSAR.

STETKAR: Ι think that, MEMBER personally, Ι you're saying. hear what And remember this is a subcommittee meeting so this isn't ACRS. ACRS has a responsibility to public to make sure that we, we have to reach our independent conclusion about assurance of safety.

And I hear what you're saying, that you think things are really easy. But our not having an opportunity to have a discussion about those things that are really easy and the presumption that we're going to agree with everything can be a

bit prejudicial.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

So I would say use caution in terms of saying well, we don't plan to discuss this stuff because I guarantee that members of the subcommittee are going to read everything. And although you might not have it on the agenda, you can get questions about anything. So just be aware of that.

MR. SHEA: Yes, Ι apologize if Ι misspoke but my point was that as far as perspective, what we're proposing, and you'll see in our presentation is that the lion share of the interest to the public as well as the Committee in our view is that the seismic analysis which really what the large technical issue was over the last two years.

But in fact, that's what we're looking for from this meeting is to get the feedback on what you want us to present. We would be happy to present that. But I just would point out that our SER that's been published now, I think all the SER's should have been published by today on the public website.

It's a simple review. And take a look at that and then let us know if you want to explore

1	that, for any of these items, explore further. And
2	that's what we hope to get back out of this
3	meeting.
4	CHAIRMAN RICCARDELLA: I would ask any
5	of my other colleagues of any thoughts on what
6	should or should not be presented at the October
7	meeting?
8	MEMBER POWERS: I would think that the
9	subcommittee would find it interesting to look at
LO	the evacuation time estimates. They don't have one
L1	for Unit 3, just the 1 and 2 evacuation time
L2	estimates. It's been relatively recent that you've
L3	done that.
L 4	MS. BORSH: The update?
L 5	MEMBER POWERS: Yes.
L 6	MS. BORSH: Yes.
L7	MEMBER POWERS: And it could be useful
L8	for them to get a feel for the site by seeing that
L 9	ETE. I mean, a fairly summary presentation I don't
20	think you need to go into chapter and verse on
21	methodology, but more focused on the results to get
22	a feel for what the site is like.
23	CHAIRMAN RICCARDELLA: Okay.
24	MEMBER POWERS: And the emergency
25	planning. I don't know, you probably don't have

1	one taking into account Unit 3. But with Units 1
2	and 2, I think it's good enough.
3	MR. HEGNER: It's a site.
4	MEMBER POWERS: Yes.
5	MEMBER SUNSERI: Yes, my input would be
6	I'm interested in the whole content, I mean all the
7	topics. If it's a real easy one, then it will be a
8	short discussion, theoretically. You know, but at
9	least it gives us a chance to ask a question should
10	we have one.
11	MS. BORSH: When you say may I ask a
12	question?
13	MEMBER SUNSERI: Yes.
14	MS. BORSH: When you say all of the
15	topics, are you saying all of these topics or all
16	of
17	MEMBER SUNSERI: Everything that you
18	have
19	MS. BORSH: Okay.
20	MEMBER SUNSERI: a deviation or I
21	forget what the
22	PARTICIPANT: Departure.
23	MEMBER SUNSERI: Departure on.
24	MS. BORSH: Okay. I wasn't sure if you
25	meant the whole COLA.

1	MEMBER SUNSERI: No, no. I'm sorry. I
2	was referring to the slide.
3	MEMBER POWERS: We want to go through
4	the whole thing.
5	MS. BORSH: Okay.
6	MEMBER POWERS: It was so much fun the
7	first time.
8	MS. BORSH: Okay, that's right. Thank
9	you for reminding me.
10	CHAIRMAN RICCARDELLA: Charlie, are you
11	specifically requesting that that item be covered,
12	or is that just something that you'll review on
13	your own in the DCD?
14	MEMBER BROWN: I'm just going to be
15	trying to find, no I'll try I want
16	CHAIRMAN RICCARDELLA: Charlie, turn
17	your
18	MEMBER BROWN: Oh, sorry about that.
19	CHAIRMAN RICCARDELLA: Thank you.
20	MEMBER BROWN: No, I want to have it
21	addressed in the subcommittee meeting by the staff.
22	Primarily the staff. I don't think Dominion could
23	be able to do that.
24	MS. BORSH: Yes, that was a DCD
25	CHAIRMAN RICCARDELLA: A DCD item, not

1	a COLA.
2	MEMBER BROWN: Yes, exactly. I just
3	want to make sure the DCD was updated as was
4	promised by the DCD sponsor after our final letter.
5	And where. Where in the DCD. That way you ought
6	to be able to see it in 7, 9 and 10. I may have
7	that page at home. I don't know.
8	MEMBER MARCH-LEUBA: And during the
9	Turkey Point review that we just did recently, we
10	had the issue with the low population density, the
11	500 people per square mile. You can now address
12	what the population density is for the plan.
13	CHAIRMAN RICCARDELLA: John?
14	MEMBER STETKAR: I tend to look at
15	everything.
16	CHAIRMAN RICCARDELLA: Okay.
17	MS. BORSH: Okay. So our conclusions
18	are that is that right, going to the next slide?
19	Okay. Just to remind you, we did follow the design
20	centered working group approach to creating the
21	COLA that you have before you. And as a result of
22	that, we've maximized standardization both with the
23	DCD and with Fermi 3.

site-specific

identified have been evaluated and resolved.

issues

The

24

25

were

The

that

42 seismic and structural analyses and the resulting design enhancements that we made demonstrate the capability of the structures, systems, components, and the North Anna site is adequate to support the construction and operation of Anna Unit 3 as an ESBWR. And that's all I have unless you have any other questions. CHAIRMAN RICCARDELLA: Thank you. Any other subcommittee members have questions? well we look forward to hearing more details these topics in October. MS. BORSH: Thank you. MR. SHEA: Oh is it there? Okav. All right, just move that over and just press the arrows right? There they are. Okay, big arrows.

All right, thank you. I want to thank

the Committee again for having us and have this public meeting. I think this was, originally, were just going to have an informal meeting with the Committee and then propose what we thought would be good for the subcommittee. But I think a much better way to present what this was staff has done over the last several years on the review of this North Anna 3.

> particularly, since I've And been

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

involved, like I said, the last 18 months, is the 1 2 seismic evaluation. So with that, we'll start with number 3 And what I did, really when I look at Gina's 4 -- and we did not do this together. I looked at 5 Gina's presentation, I think Tuesday. 6 And I had 7 already pretty much completed mine, and I looked at 8 them and I said, the good news here is we're all 9 pretty much on the same page. 10 And I think what's good, and I think 11 what helped the Committee on my presentation, is I 12 give a little more details, including dates, which is what the staff, you know, we look at the dates 13 14 of submittals and things like that. So I added 15 some of that detail. 16 But I won't go over, in lot а 17 detail, everything Gina already said. But I 18 highlight a couple things where she did not, 19 least initially. And also I'd like to just really 20 briefly talk about how Fermi and the DCD kind of 21 fit in. 22 Because if you look at this project, on 23 both Fermi and North Anna -- North Anna being the 24 original R-COLA, right? Up to Phase 2.

And essentially Fermi, incorporating by

reference in their SER -- if you look at the Fermi SER, I think we've provided, a lot of their content is IBR North Anna from Phase 2. And you'll see then the switch.

In the North Anna's case, if you're looking for this, really the most significant area where IBR occurred, or it shouldn't be IBR, but standard content from Fermi, was in Chapter, what we call Chapter 20. The Fukushima Chapter.

Which just as an aside, Fukushima Chapter, I kind of invented the Fukushima Chapter. When I was JLD before getting this job, and I was the liaison for NRO working with how to present the Fukushima evaluation in the COLs.

And this Chapter 20 was an invention so that really for the public's perspective, they could go to one single place of that huge event of interest and look. And essentially we sent out then, in that chapter, we show you in the FSAR where these things were evaluated specifically, so you don't have to go hunting for it if you're from the public. So we put it all in one place and evaluated it. So that's where you'll see where North Anna --

And there's other ways that they

incorporated Fermi information. 1 And we'll go 2 it in through that as we come across the 3 presentation. But big picture, that's kind of the overall view. 4 So this first slide, the only thing I 5 to highlight here was 6 really wanted the 7 information, expect with dates, that North 8 provided or Dominion provided. Is some of this 9 idea of how Dominion incorporated the Fermi 10 information. So on August 30th, somewhere down about 11 12 third of the way down through that slide, 2013, Dominion submitted its 13 30th, 14 reconciliation from Fermi R-COL. Which was 15 important for the staff to see, okay, these RAIs 16 that are still valid for North Anna, these are the 17 RAIs we incorporated from Fermi, the update 18 from Phase 2. And that was important so that we 19 could go forward with these RAIs. There's almost 900 RATS with 20 North 21 Just to give you some perspective. 22 So navigating all those RAI questions, 23 figuring out what applied, once they reverted back 24 to the ESBWR, was important.

And the other one I highlight here in

this same slide, which is also important, was this 1 2 January 23rd, 2015. Again, following the design-3 centered approach in the reverse, where became the reference COL, they incorporated much of 4 the finalized -- at that point, the Fermi SER was 5 finalized essentially. I mean it still had to go 6 7 through the licensing, et cetera. 8 But from that perspective, if you look 9 that, the incorporation into that particular at 10 revision, I think that was Revision 6 -- no. 11 it ended up in, later, in Revision 8 of the FSAR. 12 And in that revision, included all the 13 things like licensing conditions that previously in 14 Phase 2 looked different. In both applications. But after OGC, when it goes through the 15 16 licensing phase, OGC has their comments and 17 adjustments. So these license conditions all 18 looked a little different than you would see in a 19 Phase 2 SERs. 20 So all that was incorporated. Dominion 21 essentially incorporated the Dominion -the 22 Fermi license conditions. And it ended up reflected in that Rev. 8. 23 24 So as we proceeded with our review, we

essentially took those license conditions.

25

And

that's what is now reflected in the advanced final 1 2 SER. As you'll see in Phase 4. 3 Now of course, that could change. We're going to go through the licensing phase next 4 and some of those could be noodled again, 5 but 6 anyway. 7 So as part of that approach, you can 8 follow the breadcrumbs a little bit there on how 9 this, you know, it was a very complex issue of 10 first reverting back to the US-APWR 11 reverting back. 12 And it was a challenge, I think, both sides and for the staff to keep track of, 13 14 okay, what's valid? So that kind of fills in some 15 of those blanks there. And the only thing I just, I kind of 16 17 emphasis in my slide presentation is that Dominion 18 submitted a seismic closure plan. Like I said, the 19 focus of the last year and a half is really on the 20 seismic issue. There was other things, and we'll 21 talk about them, but this was the main focus. 22 seismic discussion started And that 23 over two years ago. The fall of 2014, correct? 24 And so there was meetings. 25 And a lot of this, because after the

and then after 1 Fukushima event the Mineral 2 earthquake event in August of 2011, of course the 3 staff had concerns about the seismic evaluation at There was several meetings to discuss 4 the time. how the path forward would go. 5 And so in that Seismic Closure Plan, 6 7 the staff came to agreement with, and Dominion, put 8 together a plan on how to close the issue. Which 9 incorporated all that, those events. The Fukushima 10 Learned and the seismic and the actual 11 Mineral earthquake in 2011. Both happening in 12 2011. So that's where that kind of comes in. 13 14 And that has been the crux in what we've been 15 working on over the last 18 months to come to 16 closure on this advance final SER Phase 4. 17 Any questions before I go to the next 18 It's kind of highlights. one? Okay, what's the 19 other one? It's easier to actually look up here. Oh, here is -- I put a few, just a few 20 21 highlights for the Fermi and ESBWR DCD review. 22 you can see in there that the Fermi application came a little later after North Anna in 2008. 23 So 24 they were the S-COL.

And in March 9th, 2011 the NRC actually

1	issued the ESBWR DCD FSER. But then there was some
2	issues. There was a couple issues.
3	I think the open phase was one of the
4	issues in the DCD, but that was addressed in the
5	DCD. So I believe that was one of the issues.
6	There was two issues. One was the
7	steam dryer. And there was this, I think it was
8	the open phase, but there was another issue that
9	was addressed in this Rev. 10. And Supplement 1
10	really includes the conclusion of the staff review
11	of the dryer issue.
12	So that's where we are is, oh, that's
13	the, right. It's Rev. 10 DCD. Supplement 1 is our
14	FSER. I know I'm having trouble reading my own
15	slide, but it was just pointed out I could just
16	look right in front. Look at that.
17	So that's where I got the Supplement 1.
18	The Supplement 1 is from FSAR.
19	MEMBER STETKAR: And you're right.
20	Rev. 10 of the DCD
21	MR. SHEA: Yes.
22	MEMBER STETKAR: addresses the open
23	phase stuff.
24	MR. SHEA: Right.
25	MEMBER STETKAR: ACRS hasn't seen a DCD
	1

1	in a long time.
2	MR. SHEA: Right. So that's why I
3	wanted to say, I think when you open
4	MEMBER STETKAR: You're right. I just
5	did a word search. It does.
6	MR. SHEA: Yes. Okay, so I had my
7	supplements backwards. It was the FSER Supplement
8	1 that addressed, that particularly addressed the
9	dryer issues. Rev. 10 addressed the open phase
10	issue. If that helps clarify that.
11	I actually, then I added just a couple,
12	a big picture staff FSER things for your, just for
13	your information, about the ESBWR rated for 4500
14	megawatt thermal so you get a feel for this plant.
15	But the one thing that always struck
16	me, of course, the Passive Containment Cooling
17	System. This plant is a passive plant, 72-hour
18	post-accident, no need for pumps.
19	MEMBER STETKAR: Coping time.
20	MR. SHEA: Coping time. And that's
21	addressed also as part of the Fukushima. So
22	another issue is that it's really past 72-hour
23	response on Fukushima is what they're addressing
24	when it comes to mitigating strategies.
25	And I also point out that in the staff

1	SER, Chapter 19, the staff did review the PRA in
2	that chapter, and it's pretty extensive. And of
3	course the applicant report is, core damage
4	frequency of $1.65 \times 10^{-8}$ . Which I believe is the
5	best core damage frequency, if you want to look in
6	terms of probability as far as
7	MEMBER POWERS: Of course that's a
8	totally meaningless core damage frequency.
9	MEMBER STETKAR: Yes. It's not the
10	best core damage frequency; it's the silliest core
11	damage frequency.
12	MEMBER POWERS: It's just a silly thing
13	to report.
14	MEMBER STETKAR: That's on record.
15	MR. SHEA: Right. Well, I mean it's a
16	number that's used in a PRA.
17	But what the staff did, if you look at
18	that, and that's why I wanted to point that out, is
19	what the staff has basically come to the conclusion
20	is, it's clear because of a few factors, because of
21	the passive nature of the PCCS system, and you've
22	got the ICS system and all these systems, add up to
23	a design. Of course that is reduction of risk in
24	comparison to current operating reactors.
25	So the point was

1	MEMBER POWERS: Is it really? If
2	earthquake dominates the risk, does it matter?
3	MEMBER STETKAR: And we won't know that
4	because North Anna doesn't have to quantify
5	earthquake risk until sometime after the COL is
6	issued and before fuel is loaded.
7	MEMBER POWERS: I think it's the great
8	leveler. It doesn't matter whether you put a Mark
9	I
10	MEMBER STETKAR: Right.
11	MEMBER POWERS: or an ESBWR on the
12	site. You're going to get dominated by your
13	seismic risk here.
14	MEMBER STETKAR: And we won't know what
15	that is.
16	MR. SHEA: Right.
17	MEMBER STETKAR: Until sometime before
18	they load fuel.
19	MR. SHEA: Yes. And I don't want to
20	belabor this point, but this is just
21	MEMBER POWERS: Do we know about fire?
22	MEMBER STETKAR: What?
23	MEMBER POWERS: How about fire?
24	MEMBER STETKAR: You don't to have to
25	finish the site-specific stuff until before they

I mean, you're not going to run a --1 load fuel. 2 MR. SHEA: But I think the answer -- to 3 address another question in that Chapter 9, and in fact in our SER for Chapter 19, we do discuss the 4 differences between the DCD PRA and the North Anna 5 specific PRA, and there are those differences. 6 7 And I believe it is dominated by things 8 such as external events rather than -- from my 9 recollection of going through that. But that's, 10 you know, so that's --11 MEMBER STETKAR: Just remember that I 12 don't believe, I'm skimming through it now, but I 13 suspect they have not done seismic 14 assessment. Ι they've suspect changed 15 seismic margin assessment to account for their 16 revised seismic hazard. That's not risk 17 assessment. It just looked at different deltas I 18 suspect. 19 mean Ι haven't read what thev've 20 done, but I can almost quarantee it's not a seismic 21 risk assessment. 22 I don't know. MR. SHEA: The DCD was not 23 MEMBER STETKAR: 24 seismic risk assessment. And unless they've done a 25 heck a lot of work in their PRA, and I'm sure they

haven't, they looked at a revised seismic margin 1 2 assessment looking at the revised hazard. 3 And that's not -- they will. They'll 4 perform a quantified seismic risk assessment before 5 they load fuel. But you're required by regulations, so they know they have that ahead of 6 7 And their estimated core damage frequency 8 might increase by a couple orders of magnitude. 9 MR. SHEA: Yes. Our SER does cover 10 some of those aspects, so I think you'll find some 11 of that information there. And in the FSAR. 12 All right, moving on. Okay, so here's 13 some, again, what was interesting about 14 parallel review, I call it, you know, you had the 15 ESBWR being reviewed at the same time as the Fermi 16 and same time as North Anna. By the time we got to 17 Phase 2, these were all being reviewed at the same 18 time. 19 And what you find is that a lot of the, 20 there was several RAIs that were sent to the actual 21 COLA applications that end up being deferred to the 22 So there was a lot of that going on during that timeframe. 23 24 And so you'll even see in our current 25 which are leftover from the Phase 2, SERs,

course, from the Phase 2 information that shows 1 2 that. And explains that. 3 mean, theoretically, I should have been able to weed all that out because it was 4 addressed in the DCD. But it was too hard at this 5 stage to try to take all that out. But you'll see 6 7 some of that in there where all these applications 8 were being reviewed, and you'll see where it was, 9 RAIs were redirected back into the DCD. On certain 10 aspects. 11 So you can see -- and then what I also 12 wanted do focus to next was to on the ACRS 13 interactions associated with the DCD, the Fermi and 14 now North Anna. All the details there. 15 Dominion had touched on it, but I have 16 a few more details associated with that. You can 17 see that, we mentioned already that there was June, 18 July, August ACRS subcommittee meetings presented 19 on each individual chapter. For the Phase 2 SERs. 20 And ultimately, we had the letter on 21 October 8th, where the ACRS Full Committee Meeting 22 Phase 2 was submitted. And on the next page I talk 23 about your conclusions there. 24 No significant issues. Of course, when 25 didn't have the Mineral that was sent, we

earthquake, and we didn't have Fukushima. So you can see -- so what we had been focusing on since 2011 has been really the seismic issue.

And I'll mention the way we close, the other thing I want to go over is the closed and the open items in Phase 2 SER. I gave some details there.

You can see the staff SER Phase 2. We actually had open items, confirmatory items. There was 71 open items from Phase 2, 40 confirmatory items. And now in Phase 4, there's 34 additional confirmatory items to review to show the latest update.

Mostly in the seismic area again, to reflect what the markups that were, you know, that are now in the FSAR. And we have that job ahead of us to confirm all that. And we're on our way to do that.

And the point is, like for example, the 71 open items that we had under -- for example, we had 19 chapters then; Chapter 20 didn't exist. So takeaway 19. Each chapter had DCD as an open item. So you could look at that as there's 52 actual open items from RAI. And these 40 items were already RAI responses with markups that just were

confirmatory.

In fact, what we have done recently in project staff is I assigned one of our project managers to basically look at each one of these.

Go back to the Phase 2; pull them all up; put them in a grid.

And I did that. And we then validated every single one of these open items and made sure they were in Rev. 8 of the FSAR. So that was a few months back.

But that's what we did to make sure we had closed all those items. I mean we could assume that because all the RAIs were closed. If you look at currently, there's not a single RAI that is open on the safety side of this review.

And so we went through 900 of these RAIs; made sure everything was closed, resolved; looked at all these open items; looked at all the confirmatory items. So as you can image, it was a pretty large effort on our side to make sure that all the i's and t's were crossed from the tech staff. And they were, fortunately.

And I just put up this one on the Fukushima. I mentioned before was, that this Chapter 20 was kind of a new invention. And Fermi

addressed RAIs that were part of the Fukushima SECY papers, and essentially Dominion took those RAIs and took it as standard content and put it in there FSAR, appropriate, and followed the as essentially verbatim. So you'll look in our Chapter 20, and you'll see it's standard content. The only subtle difference is that, and

The only subtle difference is that, and I mentioned it here, in case of North Anna, because following the Fukushima event, of course, all the new guidelines were created in the Central Eastern United States, et cetera. Dominion incorporated all that into their design for Chapter 3 and Chapter 2. And therefore there was no need to reevaluate the Seismic 2.1 for Fukushima, again.

So that's what Fermi actually did.

Because they weren't --

Yes. Fermi actually did reevaluate under the new central-eastern United States curve and had to show that they were bounded by the DCD. And that's how Fermi addressed in their Chapter 20. Whereas North Anna didn't have to do that step because they incorporated it, the new central-eastern United States curve. That followed.

So just so you're not confused about that. Only those recommendations were determined

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

to be necessary for North Anna. And again, Fermi only had that 2.1 recommendation also addressed. Everything else was determined because of this passive plant, none of the other recommendations were applicable.

Okay, so just to highlight the RAIs. A big effort on our part and project was just to make sure these things were all closed out, resolved and reviewed, so when we sent this to the public website they were finished. It looks like it's finished.

In fact, we're still finalizing that.

I think we've got a half a dozen/a dozen RAIs that
we're still tracking down.

What we're finding is there are a few of these RAIs that were leftover from the APWR. They're not applicable to North Anna, so it's just a matter of us going back and confirming what they are and then closing them out appropriately. So I think we're left with, I don't know, at the most a dozen of these that we're tracking down.

And I just want to point out that there were, this kind of surprised me, that since April 2013, when Dominion reverted back to the ESBWR, there's an additional 62 E-RAIs.

1	Now, that kind of E-RAIs, I didn't
2	have time to figure out all the RAIs that's
3	embedded in those E-RAIs, but for the most part,
4	all these, over the last, since then, most of the
5	have been single question RAIs. Because back in
6	the, prior to Phase 2, you'd get these multiple,
7	you'd get one E-RAI with 15 questions. So that's
8	kind of how that's done.
9	So if you look at the 62, I think even
10	Gina mentioned to me, when we were discussing this,
11	there was about a hundred actual questions since
12	this. And there's various reasons.
13	In fact, that's why I actually listed
14	them. These are all the ones that had been since
15	the conversion back with the ESBWR.
16	MEMBER STETKAR: And they're kind of
17	all over the map, aren't they?
18	MR. SHEA: They are. This kind of
19	surprised me. You know, there
20	MEMBER STETKAR: They're not all
21	seismic is why I was
22	MR. SHEA: Yes.
23	MEMBER STETKAR: They are kind of all
24	over.
25	MR. SHEA: But they aren't all seismic.

But I want to take a special note there. You see, 1 2 I've been on the project for 18 months, and you 3 notice how many RAIs went out under my watch? 4 And that was -- so we were more toward 5 the end, over the last 18 months, and we were really just closing the safety evaluations. 6 And 7 even though there was no really technical issues, 8 it still takes time to close these out. It's just 9 the nature of the beast. 10 We have to get through OGC and all of 11 our processes in order to close these. And it was 12 a big effort. Even though there really wasn't many 13 significant, in fact, the last four weren't very 14 significant RAIs. So if you go through this, you can see 15 16 there is a number of RAIs in rad waste area, And actually, if I have 17 Chapter 11 and 12. 18 quess where I spent most of my time, other than 19 seismic, it was with that section. Since I've been But that was early on. 20 involved in the project. 21 And I'm still confused why there was any additional 22 RAIs, to be honest. 23 And anyway, but --24 MEMBER STETKAR: That's not the kind of 25 thing you want to say in a public meeting with the

1 applicant here. Just saying. 2 (Laughter) 3 MR. SHEA: You're right, I'm sorry. But they're very important. Actually, I think what 4 part of it was, was you have new staff members who 5 take a different look and a different, you know, 6 7 and take a different view, and maybe we missed 8 something in Phase 2. So, you know. But anyway, a lot of them, obviously we 9 10 had some issues, and they were resolved, and we got 11 through those. But that's the other one you'll 12 see, other than seismic. And then there's some other ones. 13 14 other one that's just, just to point out for the 15 in Chapter 2, there was an issue committee was, 16 about the, because of the new design change there 17 was a reanalysis of the LIP event for the --18 MEMBER STETKAR: Hmm. 19 MR. SHEA: Only because of the physical 20 And so they reevaluated it. And that took 21 some time to resolve. And I think because it was 22 low on the radar. 23 But that was like the last Chapter 2 24 issue that was resolved was the reanalysis. And it 25 ended up with the --

MEMBER STETKAR: For the public record, 1 2 that's local intense precipitation. 3 MR. SHEA: Right. Local intense precipitation. 4 And the way that was eventually is the curbs in a couple of the seismic 5 structures, in the main structure, had a couple 6 7 curbs added to meet that new LIP evaluation. But other than that, and this other 8 9 control and habitability, there was 10 slight differences. Obviously Fermi. It's a site-11 specific evaluation based on the industrial area, 12 how the different tanks. I think you had a couple of tank sizes 13 14 that were different. Fermi had two tanks for 15 hydrogen, and North Anna has one. Reverse. 16 Yes, Dominion has tanks for two 17 hydrogen and Fermi has one large tank. So there's 18 some slight differences, some RAIs, and some issues 19 that were resolved following the 2013 submittal for 20 the ESBWR. 21 So anyway, I give those to you guys to 22 contemplate and ask us, and if you have questions about any of those, just Girija will let 23 24 me know. 25 All right, so this next slide, it just

points out the focus. And I'm sorry if I misspoke 1 2 about earlier what we think is really 3 significant issue, at least from a project side, is for the subcommittee. 4 And because the focus for us, 5 and for the staff really for the last 18 months or so, has 6 7 been it's similar to what on, and 8 mentioned the exemptions. The Tier 2 was 9 departures and the variances. 10 didn't talk about variances early 11 from the ESP. The variances from the ESP, I got a 12 list of those variances. And where that comes from is just the physical plant changing, and therefore 13 14 some of that, the original SSAR information didn't 15 quite fit into the new ESBWR footprint. 16 So you'll see a whole list of that. 17 They're not significant from a projects perspective 18 or from -- in fact I talked to the staff about 19 those and they said they're not a significant, 20 those variances aren't really significant. 21 And I think you brought up a question 22 earlier about this SSAR incorporated by reference. And you'll see in the, it's very clear in our SER, 23 how that was done. 24

And in fact, if you ask me, we usually

1	quote it we actually put it all in the SER, so
2	you don't really have to go anywhere. We address
3	it.
4	It's almost like a one-stop shop. You
5	don't have to go back to the SSAR to look at
6	things. Because pretty much the way the SER was
7	written included what the issue was; here's our
8	variation; and this is why it changed. Or if it's
9	incorporated, it describes what that was and where
10	it's from.
11	MEMBER STETKAR: So you've done a lot
12	of that?
13	MR. SHEA: Yes.
14	MEMBER STETKAR: Like what you're
15	saying is you've done a lot of that leg work, at
16	least from the staff side?
17	MR. SHEA: Yes.
18	MEMBER STETKAR: Okay.
19	MR. SHEA: From the staff side. That
20	was a big issue in Chapter 2. That was really.
21	So I know we talked this is actually
22	a table directly out of Part 7, to save you time
23	looking at that, instead of looking it up yourself.
24	But this just talks about these exemptions.
25	And I mentioned that on chapter that

that's a standard exemption number one. 1 They had 2 They went backwards, or they had a it different. 3 different order. They talked about it in different order. 4 I talk about it in this order. 5 I think 6 that was presented in Part 7. And this Chapter 1, 7 it's the typical exemption that all COLs are going 8 through. And then there's the other one. 9 Now 10 there's four other ones. Fermi did not have 11 other exemptions, other than this Number 1. So 12 where Dominion this is or the North Anna is And that's why I highlight it here. 13 different. 14 And we already talked about these 15 And the one I highlight is this, some degree. 16 course Number 3, which is the Tier 1 change, the 17 DCD, which changes the definition, essentially, of 18 the SSA from what the DCD was calling it. 19 So the other ones, like I said, 20 sure Dominion and the staff are more than happy to, 21 will have people to present these at the 22 subcommittee. That's what we'll plan to do since 23 you expressed interest in these. But they're 24 fairly straightforward in my thinking.

STETKAR:

**MEMBER** 

And we

25

have

also

1	Dominion's, whatever it is, the Departures,
2	Variances and Exemptions Report or whatever it is.
3	That's up to date, right? I think it's got a date
4	of June on it of this year.
5	MR. SHEA: Yes. I pulled this right
6	out of the Rev. 9. I failed to bring that. Rev. 9
7	of the FSAR was submitted in June of this year.
8	MEMBER STETKAR: But the, I happen to
9	be looking at that, it's the North Anna 3 COLA Part
10	7 Departures Report. That's Rev. 7. That's the
11	most current version of that document?
12	MS. BORSH: Yes.
13	MEMBER STETKAR: It is dated June of
14	this year, but
15	MS. BORSH: Yes.
16	MEMBER STETKAR: Okay.
17	MR. SHEA: And the way that works,
18	Gina, correct me if I'm wrong, if there was no
19	changes from the FSAR update, the rev didn't
20	change.
21	MS. BORSH: That's right. Even the
22	part is the same.
23	MR. SHEA: Right.
24	MEMBER STETKAR: It could be listed
25	anything as long as I have

1	MR. SHEA: Right.
2	MEMBER STETKAR: that this is the
3	latest and greatest.
4	MR. SHEA: Well that confused me. When
5	I first got this project I said, wait a minute,
6	Rev. 8 of the FSAR, but it's Rev. 6 of the, but
7	anyway. But that's why that is. It doesn't always
8	change on every revision.
9	Okay, so I actually squeezed in all
10	these departures also. Actually, when you look at
11	the SER, you would think there's a lot more
12	departures. But the reality is, you can see that
13	departure on Chapter 11.
14	I don't recommend reading Chapter 11
15	unless you are really tired at night and want to
16	get a good night's sleep. But you can see we
17	covered a lot in that chapter. It's a very long
18	chapter. And it talks about all these departures.
19	And that probably was part of the reasons why the
20	staff had additional RAIs, et cetera.
21	But Fermi also, I believe Fermi also
22	you're basically following the Fermi on that?
23	MS. BORSH: Yes.
24	MR. SHEA: Yes. Okay. And the same
25	thing, Chapter 12. There is that issue.

1	And 19A is the RTNSS. The effect of
2	the missile effect in RTNSS. Also, if you go to
3	Chapter 3, you'll see where they discuss the
4	missiles, and we discuss it there. And the bottom
5	line there is that the missiles are bounded by the
6	tornado, right? According to the FSAR.
7	So that the hurricane missiles really
8	are not a factor to that degree, expect maybe in
9	the RTNSS structures where
10	MS. BORSH: The velocities.
11	MR. SHEA: right. The velocities,
12	right.
13	So the RTNSS, that new reg guide
14	changed some of the velocities of the missiles.
15	MS. BORSH: That is correct.
16	MR. SHEA: But if you look at Chapter
17	3, it basically says that the missiles are bounded
18	by the tornado missile, which is the DCD tornado.
19	MEMBER STETKAR: Hmm. Well, we'll look
20	at it.
21	MR. SHEA: Okay, here's all that list
22	of variances. Again, it looks like, oh my gosh,
23	what's all that. But again, it was based on a fact
24	that the site physical plant changed from the time
25	of the ESP.

1	I think they actually moved, right?
2	From the ESP there was a where are you going to put
3	the plant originally, or where it was proposed, and
4	it moved? Was that the issue?
5	MR. HEGNER: Originally we were going
6	to put it closer
7	MEMBER STETKAR: You have to
8	MR. HEGNER: Yes.
9	MEMBER STETKAR: make sure you're
10	speaking in the microphone because that's the only
11	way
12	MR. HEGNER: Originally we were going
13	to put Unit 3 closer to Units 1 and 2, and then
14	overtime, we moved it farther away to be closer to
15	the cooling towers.
16	MR. SHEA: Okay. So that was the
17	reason why all these variances are there because it
18	ends up moving physically. So you got like ground
19	hydrology, and all these things slightly were
20	changed because of that move. So I just didn't
21	want this to confuse you.
22	But like I said, in Chapter 2, if you
23	want to pick out any one of these, just do a search
24	in Chapter 2, and it will be in there, and we would
25	have addressed it. The staff.

So that, actually that whole, all those actually complicated Chapter 2 a little bit. So that made Chapter 2 go a little longer than one would suspect from the Phase 2 SER.

Okay, I mentioned before the Seismic Closure Plan. Again, this has been our focus, really, from the staff's standpoint. And it has been a large effort.

I mentioned at the beginning that between Dominion staff and our staff, there was just, we had been meeting, and I'd put our meeting at 40 public meetings. Essentially we're meeting at least every other week on this.

Now, we did have, there was four major public meetings that we had face-to-face here at the Commission where major milestones occurred that were addressed, where they presented their results based on the seismic closure plan. Which provided a plan to give us all the FSAR markups, provide all the reanalysis. And it was done by date certain.

And there was some milestones there I mentioned. I think it's December 2015, RAI responses and COLA markups of the structural design. All these things were critical path, make or break, in order to keep the schedule that we're

currently on.

1

2

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

And between the staff and Dominion, we were able to meet all those goals. Meet the staff's issues, resolutions on all this.

And on top of that we did have, if you look at one of our audit plans, in fact, Audit Plan 2, you'll get a summary of all the issues the staff was resolving through this entire seismic closure plan. We ended up with 62.

were tracking it for а couple purposes. Just so we knew where we were as far as Had very open public information for the the RAIs. public to see what we were actually reviewing. just so that we could keep a track of all the issues that we are trying to resolve with the Applicant.

So you can see a very detailed list of all the issues and the sub-issues as part of those issues. There was a total of, what did I say, 60-some issues that had even sub-issues.

And every one of those, they were, it didn't look like we'd ever end to be honest. And the key to closing these issues was these face-to-face, onsite GEH audits where the staff spent, we spent a week, and we worked to resolve all these,

to review all the documents and raise additional issues.

We might have gone into Audit 1 with 30 issues; we came out of Audit 1 with 60 issues or something to that effect. Nothing significant, but just, hey, we want you to do additional analysis or benchmarking, or whatever the word is, on this particular aspect.

And so you can look at that. It's in our audit summary plans. It's pretty well detailed what went on there. And like I said, every meeting — we held public meetings every other week to go through that list. We took public comments as we went along.

And like I said, it was very open and transparent on how we did this. And you'll see that in the write-up for the FSER, or on our SER on Chapter 3. And it also references these major meetings.

And I just point out, the last major meeting we had, prior to the second audit, Dominion essentially presented their results of all the analysis. The talk about, what's the change to the structural design based on this new seismic analysis?

1	And if I could sum it up in a nutshell,
2	Dominion might be able to help me here, but
3	essentially the physical plant does not change
4	based on the seismic analysis.
5	There was some, in the case of the PCCS
6	structure, there was some increase bolt sizes to
7	accommodate the new demands. And in addition,
8	there was some rebar changes on some of the walls
9	in the reactor building. And the fuel pool had
LO	some structural changes.
L1	So when you boil all this down, there
L2	was really is that all the things that captured,
L3	Gina? There was like three
L 4	MS. BORSH: That's essentially it.
L5	MR. SHEA: Yes. There was three
L 6	issues. The big thing was that the physical plant
L7	did not change. It was not required. No
L8	additional thicknesses on the floors, the concrete
L 9	or the walls. Just additional strength and
20	reinforcement.
21	MS. BORSH: Yes. Jim, may I interrupt?
22	I just remembered, we should talk about the shear
23	keys for the Firewater Service Complex.
24	MR. SHEA: Okay.
25	MS. BORSH: So that is different.

1 MR. SHEA: Okay. Right, that was 2 other -- right. 3 MS. BORSH: Yes. 4 MR. SHEA: Yes. Okay. But that's it. 5 And you'll see that in FSAR Chapter 3. our There's, what else did I want to say on this. 6 7 could see that we are really running on a tight 8 schedule with this. 9 We had our March meeting, where they 10 gave us those final results. We had an audit two 11 weeks after that, the March, to review all those 12 design, detailed structural design calcs. And following the end of that audit, we 13 14 found no significant issues. In fact, all the 15 items of those action items were closed, expect for 16 couple, three, that maybe а two or 17 subsequently, with subsequent meetings, we were 18 able to close. And then the markups in the end of 19 The final markups that the staff used to Mav. finish their draft SER. 20 21 And of course then, when the final SER 22 came in, FSAR came in, on Rev. 9 in June, actually 23 seismic staff, you'll notice the we have 24 confirmatory items in Chapter 3 because actually

the seismic staff took the time to review all that

extensive changes in Chapter 3 and confirm that 1 2 everything has been incorporated. So that was a 3 huge job that's taken off, kind off my shoulders as far as confirmatory items for Phase 6. 4 Again, so that's why I -- I look at 5 that as the issue that I feel is the one that may 6 7 interest you the most. And so the subcommittee 8 meeting, we definitely will present, we'll have our 9 staff present aspects of their review, an overview. 10 But if there's anything in, as far as 11 that review goes, any specific things, we would 12 like the feedback as far as that, what you want to see as far as our presentation in the subcommittee 13 14 meeting. 15 With that, questions any on that? 16 Okay. 17 The last thing I just want to point out 18 is, I mentioned that the, essentially where we are. 19 This is the public information that we wrote, I 20 think it was the first week of September. We sent 21 application review letter. new Which 22 actually moved the date. I think it was two months 23 improved the date or three months that we 24 something. Three months.

Which,

okay, doesn't sound like much,

1	but I thought it was. Dominion was happy. I
2	thought it was a major effort on the staff's part
3	in order to do that, given the amount of
4	information that was reviewed and the amount of
5	information that the final FSAR Rev. 9 included on
6	the seismic aspect.
7	So going forward, we do have the so
8	the next step is of course the subcommittee meeting
9	that's to stay on track with our current schedule.
10	And we have the final, we have the full committee
11	meeting scheduled for November.
12	MR. SHUKLA: November?
13	MR. SHEA: With that, that's the end
14	of my presentation. Unless there's any questions?
15	MEMBER MARCH-LEUBA: No conclusions?
16	MR. SHEA: No. My conclusion is, oh,
17	here's my actual conclusion, which this is what I
18	feel will be the, at least the lion share of our
19	presentation coming up for the subcommittee
20	meeting, was this Departure 3.71. And it affects a
21	number of the chapters. And you see 2, 3, 4, 9 and
22	19.
23	And so that's what we feel would be the
24	big ticket items, as far as the subcommittee

meeting that we're going to address.

so we'll have the representative, essentially with Chapter 2, it's the seismology and the Mineral earthquake. And we can talk about that, and we'll have our guys in there to discuss the aspects of that. And the rest of it is actually the response.

Now, Chapter 4 also talks about a, there was a -- the fuel became an issue kind of late, based on the fact that it exceeded the DCD as far as the number, but did not exceed the actual fuel design. But it did exceed what the DCD had as far as seismic response to the fuel.

And so we're going to present that information there. And then other topics, as requested.

And I already heard, if I heard it right, we want to go through all these exemptions, at least in a cursory fashion, and discuss those. So we'll have the proper staff to do that.

MEMBER STETKAR: Yes, I would certainly have people available in case. It's a subcommittee meeting; we have one shot at this. And you don't necessarily want to run the risk of somebody asking a question that you say, well, we'll have to follow-up in a full committee meeting. Because we

1	don't have all that much time in the full committee						
2	meetings, as you're well aware.						
3	MR. SHEA: Yes, makes sense. Any other						
4	questions, comments?						
5	MR. SHUKLA: Do you want to talk about						
6	Chapter 7?						
7	MEMBER BROWN: Yes, only Chapter 7.						
8	MR. SHEA: Oh.						
9	MEMBER BROWN: Don't forget that one.						
10	MR. SHEA: Yes, Chapter 7.						
11	MEMBER BROWN: It's in the transcript.						
12	You can find the two areas of specific.						
13	MR. SHEA: Yes, I actually wrote them						
14	down.						
15	MEMBER BROWN: Oh, you did?						
16	MR. SHEA: Yes.						
17	MEMBER BROWN: Okay.						
18	MR. SHEA: Chapter 7 and all the						
19	exemptions.						
20	MEMBER BROWN: And population.						
21	MR. SHEA: And population. Okay. And						
22	I'll take back to the staff with those topics.						
23	MEMBER BROWN: Oh, estimated time of						
24	escape. And evacuation.						
25	MEMBER MARCH-LEUBA: Evacuation and						

1	escape.					
2	MEMBER BROWN: I couldn't remember the					
3	other word.					
4	MEMBER MARCH-LEUBA: Escape.					
5	MEMBER BROWN: Escape from the site;					
6	evacuate the site. It's all kind of the same					
7	thing.					
8	MEMBER POWERS: I'm going to have to					
9	take to beating you, Charlie.					
10	MEMBER BROWN: Pardon?					
11	MEMBER POWERS: I'm going to have to					
12	take up beating you.					
13	MEMBER BROWN: And you're good at it.					
14	MR. SHEA: All right, so if there's any					
15	additional details on any of these topics, Girija					
16	will let me know.					
17	MR. SHUKLA: Yes.					
18	CHAIRMAN RICCARDELLA: Okay, thank you.					
19	MR. SHUKLA: Any from the other					
20	members?					
21	CHAIRMAN RICCARDELLA: Any other					
22	comments from other members around the room?					
23	Questions?					
24	MEMBER BROWN: Is the bridge line on?					
25	CHAIRMAN RICCARDELLA: Yes. There's no					

members of the public in the room, since there's 1 2 nobody else in the room, but if we could turn the 3 bridge line on. MS. GRAY: Hello, can you hear me? 4 CHAIRMAN RICCARDELLA: Yes. 5 Yes, hi. This is Erica Gray 6 MS. GRAY: 7 calling from Richmond, Virginia. And I'm also with 8 the Sierra Club, Virginia Chapter. And just wanted 9 to let you that, yes, I have been listening in. 10 And I have been participating in the meetings when 11 they do have them. 12 I do have a question though. I heard that obviously they moved the location of where the 13 14 planned reactor will be, so I guess in some sense, that's a good thing because Reactor 1 and 2 sits on 15 16 top of an ancient fault. So I'm not sure how far 17 Reactor 3 would be from this ancient fault. 18 you guys know? 19 CHAIRMAN RICCARDELLA: Thank vou 20 Our staff will address that, if the question. 21 you'd like to --22 MEMBER STETKAR: We'll take note 23 that and make sure that we address it in 24 subcommittee meeting. But we typically don't 25 answer questions from the public in kind of in real

1	time.
2	MS. GRAY: Well that's fine. I
3	definitely just want you all to
4	MEMBER STETKAR: Yes.
5	MS. GRAY: I mean, because North
6	Anna has a history. And obviously prior to it
7	becoming the NRC, the Atomic Agency in Vepco were
8	fine for misrepresenting that there was a fault
9	they built Unit 1 and 2 on. And that fault line
10	runs directly under 1 and 2.
11	This project is a real risk. And so
12	participating in these meetings, I like how the
13	presenter made it sound like they've done so much
14	work, which I guess they have. But sitting in
15	these meetings, I can tell you, from a public's
16	perspective, that there is more work they really
17	should do. Thank you.
18	CHAIRMAN RICCARDELLA: Okay, thank you.
19	Is there anybody
20	MR. KEEGAN: Hello?
21	CHAIRMAN RICCARDELLA: Yes, hello.
22	MR. KEEGAN: Hello, Michael Keegan in
23	Michigan. I'm an interviewer on the Fermi 3
24	proposal.
25	I'm not seeing the documents being

filed in the record. And to my understanding, 1 2 there still seismic issues unresolved there? 3 is the -- is the central-And what eastern U.S. data been now encompassed and rolled 4 into the Fermi 3? 5 I don't have a good status on that and 6 7 there's missing records in the docket. So if you 8 could help get that corrected I would much 9 appreciate it. 10 CHAIRMAN RICCARDELLA: 11 MR. KEEGAN: Ι am tracking these 12 closely. Going back on the Fermi, the cost to do the proper foundation on the Fermi 3, the cost of 13 14 concrete would be exorbitant. Twice the cost of 15 all the rest of the concrete. So the seismic qualification is a big 16 17 deal. It is a budget buster. And I want to know 18 that they have met qualifications. 19 I am hearing advisory members talking 20 about a couple orders of magnitude regarding how 21 with the seismic issues. deal So 22 important. Just want you to know the public is 23 following very closely. 24 CHAIRMAN RICCARDELLA: Okav, thank you. 25 Is there anybody else out there that would like to

	84
1	make a comment? Hearing none, we will close the
2	bridge line and I guess adjourn the meeting if
3	there's no other comments.
4	(Whereupon, the above-entitled matter
5	went off the record at 2:43 p.m.)
6	
7	
8	
9	
10	
11	
12	
13	
14	
15	
16	



### North Anna Unit 3 COLA

## Planning Meeting with ACRS ESBWR Subcommittee

September 22, 2016



### Introduction

- North Anna Unit 3 (NA3) site
- NA3 licensing milestones
- COLA changes since 2013
- Departures and Exemptions
- Potential topics for October 20 Meeting
- Conclusions




### **North Anna Site Location**





### **NA3 Plan View**





## North Anna Site with Unit 3





## **NA3 Power Station**





### **NA3 Milestones**

	D
$oldsymbol{\square}$	

ESP Application submitted
 September 2003

EIS issued
 December 2006

ESP issued
 November 2007

### COLA (as ESBWR R-COLA)

COLA submitted
 November 2007

ACRS Subcommittee meetings
 June, July, August 2009

ACRS Full Committee meeting
 October 2009

ACRS LetterOctober 2009

Supplemental EIS issued
 February 2010

### Technology Changes

Changed to APWR technology
 May 2010

Reverted to ESBWR technology
 April 2013



### Approach to Post-2013 COLA Changes

- Standard COLA content generally followed R-COLA (Fermi 3) content
- Site-specific COLA content relied on information from previously reviewed ESBWR COLA as much as possible
- Substantial COLA revision was required to address changes to seismic ground motion response spectra
- Other changes were in response to NRC RAIs and SER open items



### **NA3 Departures and Exemptions**

Category	Topic	Same as Fermi 3?
Departure and Exemption	Seismic response spectra exceed CSDRS at certain frequencies/SSE Definition	No
Departure and Exemption	Relocate MG circuit breaker & motor-operated disconnects from Turbine Island/Transformer Yard to Intermediate Switchyard	No
Departure	Switchyard lightning protection design uses some Dominion rather than IEEE standards	No
Departure	Reconfigure Radwaste Bldg for 3 months of Class A & 10 years of Class B & C storage	Yes
Departure and Exemption	LWMS discharges only use radwaste effluent discharge piping, not CT blowdown line	No
Departure and Exemption	RG 1.221 results in higher velocities for certain hurricane wind-generated missiles	No
Exemption	Exception to certain regulations for SNM	Yes



### **Potential Topics for October 19 Meeting**

FSAR Chapter(s)	Topic
2, 6	Site-specific issues associated with hazardous chemicals
2	Site-specific issues associated with flooding, groundwater, accidental releases
2, 3, 4, 9, 14, 19	Changes associated with new seismic ground motion response spectra and revised structure foundation design
3 and 19	RG 1.221 hurricane wind and missiles
8	Site-specific switchyard and offsite power
9	Site-specific water system changes
11	Changes to radwaste discharge piping



### **Conclusions**

- Dominion implemented the design-centered review approach to maximize standardization
- Site-specific issues that were identified have been evaluated and resolved
- Seismic and structural analyses and resulting design enhancements demonstrate capability of structures, systems, and components
- North Anna site is adequate to support the construction and operation of NA3





James Shea PM (DNRL / NRO)

### **North Anna 3 Application Summary**

- ❖ September 25, 2003, North Anna ESP submittal.
- ❖ November 26, 2007 North Anna 3 ESBWR R-COL Application.
- ❖ June 28, 2010, Dominion revised its application to the US-APWR.
- ❖ April 25, 2013, Dominion reverted back to the ESBWR.
- ❖ August 30,2013, Submitted RAI S-COL RAI reconciliation from FERMI R-COL after May, 2010, through May 31, 2013.
- ❖ June 24, 2014, Dominion revised application that incorporated by reference the ESBWR DCD, Revision 10.
- ❖ January 23, 2015, Dominion followed the design center approach and reviewed the recent Detroit Edison Company Fermi 3 COL application updates.
- ❖ October 22, 2014, Dominion Submitted its Seismic Closure Plan.
- June 22, 2016, Dominion Submitted Revision 9 FSAR incorporating the staff reviewed FSAR markups from RAI responses.



# North Anna 3 ESBWR COL Staff Review ESBWR DCD / FERMI Staff Review Summary

- ❖ August 24, 2005 GEH submitted the ESBWR DCD.
- ❖ September 18, 2008 FERMI 3 S-COL Application.
- ❖ March 9, 2011 NRC staff issued the ESBWR DCD FSER.
- ❖ February 12, 2014 ESBWR DCD FSER NUREG-1966 Supplement 1.
- ❖ August 16, 2014 ESBWR DCD Final rule was issued.
- ❖ May 1, 2015 FERMI Combined License Issued.
- ❖ FSER Chapter 1 The ESBWR is rated up to 4500 MWt. Estimated gross electrical power output of 1594 MWe and net 1535 MWe.
- ❖ FSER Chapter 1 The Passive Containment Cooling System (PCCS) maintains containment pressure limits for DBAs.
- ❖ FSER Chapter 19 The applicant reported a CDF of 1.65×10-8/yr for internal events initiated during power operation.
- ❖ FSER Chapter 19 ESBWR design reflects a reduction in risk compared to the design of currently operating BWRs.

# North Anna 3 ESBWR COL Staff Review ESBWR DCD / FERMI ACRS Review Summary

- ❖ April 10-11, 2014, the ACRS, reviewed the supplemental Final Safety Evaluation Report (FSER) NUREG-1966 Supplement 1.
- ❖ September 4, 2014, ACRS Full Committee meeting FERMI.
- ❖ September 22, 2014, ACRS Letter regarding FERMI 3.
- ❖ November 14, 2014, Staff response to ACRS three generic issues related to seismic re-evaluations, mitigating strategies, and spent fuel pool instrumentation.

# North Anna 3 ESBWR COL Staff Review North Anna 3 ACRS Review Summary

- ❖ June 18, 2009: ACRS subcommittee meeting presented SER/OI chapters 1, 4, 6, 7, 8,15,18,19.
- ❖ July 21, 2009: ACRS subcommittee meeting presented SER/OI chapters 5, 9, 10, 11, & 12.
- July 22, 2009: ACRS subcommittee meeting presented SER/OI chapters 13, & 16.
- ❖ August 21, 2009: ACRS subcommittee meeting presented the remaining SER/OI chapters 2, 3, & 14.
- October 8, 2009: ACRS full committee meeting Phase 2 SER/OI
- 1) SER Section 2.3 (MET), 2.4 (Hydro) & 2.5 Geology, Seismology & Geotech Eng
- 2) SER Section 3.9.6 (IST), Section 3.11 (EQ),
- 3) SER Section 9.2.1 (SW), 9.2.3 Makeup & 10.4.5 Circ Water
- 4) SER Section 14.3 ITAAC



### **North Anna 3 ACRS Review Summary**

- ❖ October 23, 2009, ACRS Letter to EDO Phase 2 SER (ML092890370)
- 1. We have not identified any significant issues at this time regarding the North Anna COL application. The staff should proceed with the development of the final SER after resolving all open items.
- 2. The completion of the ESBWR Design Certification SER with no open items is a major activity that remains to be resolved for the North Anna COL.
- 3. We will review the resolution of North Anna COL open items when the final North Anna SER is issued by the staff.



# North Anna 3 ESBWR COL Staff Review North Anna 3 Post Phase 2 Review Summary

- ❖ <u>Staff SER Phase 2 Open Items -</u> closed by incorporation of approved RAI response In the North Anna 3 FSAR Revision 8, June 2014. (71 Items)
- Staff SER Phase 2 Confirmatory Items- Incorporated in Revision 6 FSAR July 2013 (40 Items)
- ❖ <u>Staff SER Phase 4 Confirmatory Items</u> Staff confirmation in progress in Revision 9 FSAR June 2016 (34 Items) –Phase 6 FSER.
- ★ Tier 1 [Fukushima] recommendations SECY-11-0137, as modified in SECY-12-0025 applicable to North Anna 3 COL review SER Chapter 20:
  - 1. Recommendation 4.2: Equipment covered under 10 CFR 50.54(hh)(2)
  - 2. Recommendation 7.1: Spent fuel pool instrumentation
  - 3. Recommendation 9.3: Emergency preparedness regulatory actions
- North Anna 3 Standard Content with FERMI response to these recommendations.
- ❖ The applicant evaluated the seismic and flood hazards using current guidance and methodologies, therefore Recommendation 2.1 not addressed in SER Chapter 20.

- ❖ All Safety RAIs are Resolved/Unresolved closed Over 900 Total RAIs.
- ❖ 62 E-RAIs submitted since April 2013.

1	RAI 8616	01 - Introduction and Interfaces	Closed	Shea, James	6/15/2016
2	RAI 8459	02.05.04 - Stability of Subsurface Materials and Foundations	Closed	Shea, James	2/12/2016
3	RAI 8417	01.05 - Other Regulatory Considerations	Closed	Shea, James	1/7/2016
4	RAI 8074	01.05 - Other Regulatory Considerations	Closed	Shea, James	9/20/2015
5	RAI 7853	08.02 - Offsite Power System	Closed	Buckberg, Perry	5/23/2015
6	RAI 7820	02.05.02 - Vibratory Ground Motion	Closed	Weisman, Robert	7/7/2015
7	RAI 7810	03.07.02 - Seismic System Analysis	Closed	Buckberg, Perry	3/26/2015
8	RAI 7774	02.04.13 - Accidental Releases of Radioactive Liquid Effluents in Ground and Surface Waters	Closed	Buckberg, Perry	1/14/2015
9	RAI 7772	02.04.13 - Accidental Releases of Radioactive Liquid Effluents in Ground and Surface Waters	Closed	Buckberg, Perry	1/11/2015
10	RAI 7745	06.04 - Control Room Habitability System	Closed	Buckberg, Perry	1/8/2015
11	RAI 7710	02.04.12 - Groundwater	Closed	Buckberg, Perry	12/21/2014
12	RAI 7708	02.04.02 - Floods	Closed	Patel, Chandu	1/10/2015
13	RAI 7704	12.02 - Radiation Sources	Closed	Buckberg, Perry	12/14/2014
14	RAI 7703	12.02 - Radiation Sources	Closed	Buckberg, Perry	12/14/2014
15	RAI 7701	11.04 - Solid Waste Management System	Closed	Patel, Chandu	11/14/2014
16	RAI 7697	11.02 - Liquid Waste Management System	Closed	Buckberg, Perry	12/14/2014
17	RAI 7696	01 - Introduction and Interfaces	Closed	Buckberg, Perry	11/28/2014
18	RAI 7693	11.04 - Solid Waste Management System	Closed	Williams, Stephen	12/21/2014
19	RAI 7692	11.02 - Liquid Waste Management System	Closed	Weisman, Robert	10/22/2014
20	RAI 7691	11.02 - Liquid Waste Management System	Closed	Weisman, Robert	10/22/2014

21	RAI 7690	11.02 - Liquid Waste Management System	Closed	Williams, Stephen	5/3/2015
22	RAI 7689	11.02 - Liquid Waste Management System	Closed	Buckberg, Perry	12/14/2014
23	RAI 7683	13.04 - Operational Programs	Closed	Patel, Chandu	11/14/2014
24	RAI 7682	12.03-12.04 - Radiation Protection Design Features	Closed	Patel, Chandu	11/7/2014
25	RAI 7681	14.02 - Initial Plant Test Program - Design Certification and New License Applicants	Closed	Patel, Chandu	11/14/2014
26	RAI 7680	12.03-12.04 - Radiation Protection Design Features	Closed	Patel, Chandu	11/14/2014
27	RAI 7679	12.03-12.04 - Radiation Protection Design Features	Closed	Patel, Chandu	11/14/2014
28	RAI 7677	12.03-12.04 - Radiation Protection Design Features	Closed	Patel, Chandu	11/14/2014
29	RAI 7676	12.02 - Radiation Sources	Closed	Patel, Chandu	11/14/2014
30	RAI 7670	09.02.04 - Potable and Sanitary Water Systems	Closed	Buckberg, Perry	12/14/2014
31	RAI 7660	02.03.05 - Long-Term Atmospheric Dispersion Estimates for Routine Releases	Closed	Patel, Chandu	10/8/2014
32	RAI 7654	03.07.04 - Seismic Instrumentation	Closed	Patel, Chandu	11/13/2014
33	RAI 7646	02.04 - Hydrology	Closed	Klos, John	8/28/2014
34	RAI 7642	02.05.01 - Basic Geologic and Seismic Information	Closed	Patel, Chandu	8/31/2014
35	RAI 7580	04.02 - Fuel System Design	Closed	Patel, Chandu	8/23/2014
36	RAI 7559	06.04 - Control Room Habitability System	Closed	Chien, Nan	7/20/2014
37	RAI 7557	12.02 - Radiation Sources	Closed	Patel, Chandu	8/31/2014
38	RAI 7556	12.02 - Radiation Sources	Closed	Patel, Chandu	8/31/2014
39	RAI 7552	03.09.02 - Dynamic Testing and Analysis of Systems Structures and Components	Closed	Patel, Chandu	7/24/2014
40	RAI 7547	19.02 - Review of Risk Information Used to Support Permanent Plant-Specific Changes to the Licensing Basis: General Guidance	Closed	Patel, Chandu	7/24/2014

41	RAI 7546	02.02.03 - Evaluation of Potential Accidents	Closed	Patel, Chandu	8/17/2014
42	RAI 7545	02.02.03 - Evaluation of Potential Accidents	Closed	Klos, John	6/27/2014
43	RAI 7538	03.08.05 - Foundations	Closed	Patel, Chandu	7/4/2014
44	RAI 7537	03.08.04 - Other Seismic Category I Structures	Closed	Patel, Chandu	7/4/2014
45	RAI 7536	03.07.02 - Seismic System Analysis	Closed	Patel, Chandu	7/4/2014
46	RAI 7535	03.07.03 - Seismic Subsystem Analysis	Closed	Patel, Chandu	7/4/2014
47	RAI 7533	03.05.01.04 - Missiles Generated by Tornadoes and Extreme Winds	Closed	Patel, Chandu	7/18/2014
48	RAI 7520	03.07.01 - Seismic Design Parameters	Closed	Patel, Chandu	7/4/2014
49	RAI 7483	13.03 - Emergency Planning	Closed	Patel, Chandu	6/4/2014
50	RAI 7481	09.02.01 - Station Service Water System	Closed	Patel, Chandu	5/29/2014
51	RAI 7477	02.05.01 - Basic Geologic and Seismic Information	Closed	Patel, Chandu	5/14/2014
52	RAI 7476	13.06.01 - Physical Security - Combined License	Closed	Patel, Chandu	6/6/2014
53	RAI 7474	03.07.04 - Seismic Instrumentation	Closed	Patel, Chandu	5/1/2014
54	RAI 7473	02.05.02 - Vibratory Ground Motion	Closed	Patel, Chandu	5/1/2014
55	RAI 7472	02.05.02 - Vibratory Ground Motion	Closed	Patel, Chandu	5/1/2014
56	RAI 7471	03.05.01.04 - Missiles Generated by Tornadoes and Extreme Winds	Closed	Patel, Chandu	5/2/2014
57	RAI 7468	02.05.05 - Stability of Slopes	Closed	Patel, Chandu	5/1/2014
58	RAI 7414	03.12 - ASME Code Class 1, 2, and 3 Piping Systems and Piping Components and TheirAssociated Supports	Closed	Patel, Chandu	3/12/2014
		• •		,	
59	RAI 7411	13.06.01 - Physical Security - Combined License	Closed	Caldwell, Robert	3/1/2014
60	RAI 7309	13.06.01 - Physical Security - Combined License	Closed	Klos, John	6/1/2014
61	RAI 7286	19 - Probabilistic Risk Assessment and Severe Accident Evaluation	Closed	Patel, Chandu	12/7/2013
62	RAI 7278	03.09.06 - Functional Design Qualification and Inservice Testing Programs for Pumps, Valves, and Dynamic Restraints	Closed	Weisman, Robert	10/24/2013

### **North Anna 3 Post Phase 2 Review Summary**

Staff Review <u>Focus</u> included the North Anna 3 Site Characteristics as described in FSAR Chapter 2, Chapter 3 and Part 7 of the COL application including:

- Exemptions
- ESBWR Tier 2 Departures
- Variances from the ESP

COL Part 7 Exemption	Description	Regulation	Location of Evaluation in FSER
1	Special nuclear material control and accounting (MC&A) program description	10 CFR 70.22(b), 70.32(c), 74.31, 74.41, 74.51	Chapter 1 Section 1.5.5
2	An exemption is requested for certain information depicted on DCD, Tier 1, Figure 2.13.1-1, <i>Electric Power Distribution System Functional Arrangement</i> , Sheet 1.	As permitted by 10 CFR 52.7 and Section VIII.A.4 of the Design Certification Rule,	Chapter 8 Section 8.1.4
3	The exemption involves a new definition in Tier 1 and a change to DCD Tier 1, Table 5.1-1, Footnote (4) to define the Unit 3 SSE for purposes of performing the verification, through inspections, tests, and analyses, that applicable acceptance criteria specified in DCD Tier 1 ITAAC are met for the seismic design, analyses, and qualification of structures, systems, and components.	10 CFR §§50.12, 52.7, and 52.63(b)(1).	Chapter 3 Section 3.7.4
4	"The LWMS either returns processed water to the condensate system or discharges to the environment via the circulating water system." This description is changed to: "The LWMS either returns processed water to the condensate system or discharges to the environment using the liquid radwaste effluent discharge pipeline."	10 CFR §§ 50.12, 52.7, and 52.63(b)(1).	Chapter 11 Section 11.2.4
5	This exemption modifies Footnote 7 to DCD Tier I Table 5.1-1 to specify that the Unit 3 site-specific missile velocities derived in accordance with RG 1.221 are used in the design of structures housing RTNSS equipment when the site-specific missiles are more severe than the missiles specified in the DCD.	10 CFR §§ 50.12, 52.7, and 52.63(b)(1).	Chapter 19 Appendix 19A

DCD Departure Number	Location of Evaluation in NA3 COL	Staff Evaluation FSER Section	Description and Acceptability
NAPS DEP 3.7-1	FSAR Sections 1.3, 2.0, 3.7, 3.8, 4.2, 19.2, and Appendices 3A, 3C, and 19A.		Ground Response Spectra for Seismic Structural Loads and Floor Response Spectra
NAPS DEP 8.1-1	FSAR Section Figure 8.1-1, Sheet 1,and Section 8.2.1.2.1,		Figure 8.1-1, Sheet 1, Electrical Power Distribution System
NAPS DEP 8.1-2:	FSAR Section 8.1.5.2.4 and Table 8.1-1R.		On-site Power System SRP Criteria Applicability Matrix
NAPS DEP 11.4-1	FSAR Sections 1.2.2.10.2, 1.2.2.16.9, 11.4, 11.4.1, 11.4.2.2.1, 11.4.2.3.1, 12.2 and 12.3; FSAR Tables 1.9-11R, 9A.5- 5R, 11.4-1R, 11.4-2R, 12.2-22R, and 12.3-8R; and FSAR Figures 1.2-21R, 1.2-22R, 1.2-23R, 1.2- 24R, 1.2-25R, 9A.2- 20R, 9A.2-21R, 9A.2- 22R, 9A.2-23R, 9A.2-24R, 11.4-1R, 11.4-2R, 12.3- 19R, 12.3-20R, 12.3- 39R, 12.3-40R, 12.3-41R, 12.3-42R, 12.3-61R, 12.3-62R, 12.3-63R, and 12.3-64R.		Long-term, Temporary Storage of Class B and C Low-Level Radioactive Waste
NAPS DEP 12.3-1	FSAR Section 11.2.3.2		Liquid Radwaste Effluent Discharge Piping Flow Path
NAPS DEP 19A-1	FSAR Section 2.0 Table 2.2-201,and Appendix 19A.		Design of Structures Housing RTNSS Equipment for Hurricane Wind Generated Missiles

#### **COL Variances from the ESP**

- NAPS ESP VAR 2.0-1 Long-Term Dispersion Estimates ( $\chi/Q$  and D/Q)
- NAPS ESP VAR 2.0-2 Hydraulic Conductivity
- NAPS ESP VAR 2.0-3 Hydraulic Gradient
- NAPS ESP VAR 2.0-4 Vibratory Ground Motion
- NAPS ESP VAR 2.0-5 Distribution Coefficients (Kd)
- NAPS ESP VAR 2.0-6 DBA Source Term Parameters and Doses
- NAPS ESP VAR 2.0-7 Coordinates and Abandoned Mat Foundations
- NAPS ESP VAR 2.3-1 Tornado Site Characteristics
- NAPS ESP VAR 2.4-1 Void Ratio, Porosity, and Seepage Velocity
- NAPS ESP VAR 2.4-2 NAPS Water Supply Well Information
- NAPS ESP VAR 2.4-3 Well Reference Point Elevation
- NAPS ESP VAR 2.4.4 Lake Level Increase
- NAPS ESP VAR 2.4-5 Lake Anna PMF Level Increase
- NAPS ESP VAR 2.5-1 Stability of Slopes
- NAPS ESP VAR 2.5-2 [Deleted]
- NAPS ESP VAR 12.2-1 Gaseous Pathway Doses
- NAPS ESP VAR 12.2-2 [Deleted]
- NAPS ESP VAR 12.2-3 Annual Liquid Effluent Releases
- NAPS ESP VAR 12.2-4 Existing Units' Doses
- NAPS ESP VAR 12.2-5 Annual Gaseous Effluent Releases

#### North Anna 3 Seismic Closure Plan SCP

- October 22, 2014, Dominion Submitted its Seismic Closure Plan.
- ❖ September 28-October 2, 2015 Staff seismic demand analyses audit.
- ❖ December 2015: RAI responses and COLA markups structural design
- March 21-25, 2016 Staff site-specific design analyses of category I seismic structures audit.
- Staff maintained an action list of 61 items that tracked staff issues related to the review of FSAR Chapter 3 Section 3.7 and 3.8.
- Final FSAR Markups submitted end of May 2016
- Approximately 40 Public Meetings / Phone Meetings Held
- Staff Completed AFSER Chapter 3 on September 9, 20016 to complete North Anna 3 COL AFSE Phase 4.

#### **North Anna Combined License Application Review Milestones**

#### **Safety Review:**

Task Description	Completion Date
Phase 1 - Preliminary Safety Evaluation Report (PSER) and Requests for Additional Information	Completed August 2008
Phase 2 - SER with Open Items (OIs)	Completed July 2009
Phase 3 - Advisory Committee on Reactor Safeguards (ACRS) Review of SER with Ols	Completed November 2009
Phase 4 - Advanced SER with no OIs	August 2016
Phase 5 – ACRS Review of Advanced SER with no Ols	November 2016
Phase 6 – Final SER	January 2017

#### **Environmental Review**:

Task Description	Completion Date
Draft Supplemental Environmental Impact Statement	August 2008
Final Supplemental Environmental Impact Statement	February 2010

## North Anna 3 ESBWR COL Staff Review ACRS October 20 Meeting Topics

- ✓ **Departures 3.7-1 from the reference ESBWR DCD** Staff plans to present the staff review of the North Anna 3 site specific seismic design, analyses, and qualification of structures, systems, and components to the ACRS Subcommittee on October 20, 2016.
- ✓ Departures 3.7-1 FSER Chapters 2, 3, 4, 9, & 19
- ✓ Other Topics as Requested from the ACRS