

---

---

**RESPONSE TO REQUEST FOR ADDITIONAL INFORMATION**

---

---

10/15/2016

**SAFETY SYSTEM DIGITAL PLATFORM  
- MELTAC (MITSUBISHI ELECTRIC TOTAL ADVANCED CONTROLLER) -  
TOPICAL REPORT**

**Mitsubishi Electric Corporation**

**TAC NO.:** MF4228  
**RAI NO.:** #1  
**DATE OF RAI ISSUE:** 6/29/2016

---

**QUESTION NO.:** 1 for JEXU-1041-1023, "Summary of MELTAC Platform Equipment Qualification," Rev.2

Results of the testing is identified only as "acceptance criteria was met," or "test results will be added to this section upon test completion." The results should identify any failures occurring during the test as well as the changes and/or modifications that were made to the modules or the testing to complete the test satisfactorily.

---

**ANSWER:**

The explanation of the test results, including any failures has been added to Sections 5.2.1, 5.2.2, 5.2.3, and 5.2.4 of "Summary of MELTAC Platform Equipment Qualification" (JEXU-1041-1023), Rev.3.

[

]

Section 5.0 of "Summary of MELTAC Platform V&V" Rev.3 (JEXU-1041-1026) has been revised and Appendix C has been added with consideration to the same point of view as "Summary of MELTAC Platform Equipment Qualification" (JEXU-1041-1023), Rev.3 to summarize V&V results including findings and corrective actions.

[

]

[

]



**Impact on Technical Report**

“Summary of MELTAC Platform Equipment Qualification” (JEXU-1041-1023) and  
“Summary of MELTAC Platform V&V” (JEXU-1041-1026) have been revised.