

TVA

WALL THICKNESS
PROFILE SHEET

REPORT NO:


R-P0101

PROJECT: W3N
UNIT: 2

WELD NO: RCS-1-6
SYSTEM: RCS

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°	
1	N/A	N/A	N/A	N/A	
2	N/A	N/A	N/A	N/A	
3	*	2.59	2.62	2.70	2.59
4	*	2.46	2.60	2.65	2.41
5	*	2.42	2.45	2.41	2.43



CROWN HEIGHT: Flush DIAMETER: 6.0
CROWN WIDTH: 2.4 - 2.5 WELD LENGTH: 50.0

Branch Connection

Main Run Pipe

similar profiles at 0°/180°

similar profiles at 90°/270°

* Thickness measurements on main run pipe only.

EXAMINER: Jose Alejandro Pulido
LEVEL: II
DATE: 12-08-08

REVIEWED BY: [Signature]
LEVEL: III DATE: 30/8/2009

ANII: [Signature]
DATE: 2/4/09
PAGE 5 OF 6

TVA

Office of Nuclear Power

PROJECT: WBN

SYSTEM: RCS

REPORT NO.:


UNIT: 2

WELD NO: RCS-1-6

R-P001

Branch Connection

Main Run Pipe



BY: Jose Alejandro Jim Cepeda LEVEL: II DATE: 12-08-08 PAGE 6 OF 6