

TVA

WALL THICKNESS  
PROFILE SHEET

REPORT NO:


R-P0105

PROJECT: WBN  
UNIT: 2

WELD NO: RCS-2-6  
SYSTEM: RCS

Record Thickness Measurements As Indicated, Including Weld Width, Edge-To-Edge At 0°

Position	0°	90°	180°	270°	
1	N/A	N/A	N/A	N/A	
2	N/A	N/A	N/A	N/A	
3	*	2.44	2.44	2.46	2.46
4	*	2.46	2.47	2.45	2.45
5	*	2.48	2.46	2.44	2.47



CROWN HEIGHT: Flush DIAMETER: 6.0  
CROWN WIDTH: 2.4 - 2.5 WELD LENGTH: 50.0

Branch Connection

Main Run Pipe

similar profiles at 0°/180°

similar profiles at 90°/270°

\* Thickness measurements on main run pipe only.

EXAMINER: Jose Alejandro Jimenez  
LEVEL: II  
DATE: 12-09-08

REVIEWED BY: [Signature]  
LEVEL: III DATE: 12/22/08

ANN: [Signature]  
DATE: 2/4/09  
PAGE 5 OF 6

TVA

Office of Nuclear Power

PROJECT: WBN

SYSTEM: RCS

REPORT NO.:


UNIT: 2

WELD NO: RCS-2-6

R-P0105

Branch Connection

Main Run Pipe



BY: Jose Alejandro Quijano LEVEL: II DATE: 12-09-08 PAGE 6 OF 6