TVA		WALL TH	ICKNESS		REPORT NO:
IVA		PROFILE		•	R-P0767
PROJECT:			WELD NO: RHR		
	180° 270° 51.14 1.14 21.10 1.03 1.51 1.56 N/A N/A	1 E side	Weld Centerli	2.5"	* Weld Edge
CROWN HEIGHT:	Flush 1.1		DIAMETER:	10'' 33.75	
Valve		- F	20w		Elbow
900		E			
180°		£			
270°		E E			
EXAMINER: KEIK LEVEL: II DATE: 7-30		REVIEWED BY:	DATE: 8-11-00	DATE:	9/31/09 of 6

PROJECT: WBN SYSTEM: RHR **REPORT NO.: TVA** R-P0767 2 Office of Nuclear Power WELD NO: <u>RHRF-D031-14</u> **UNIT:** 1 FLOW EL 35° ID £ 45°450 Phased array angles used 25.70°, Phased array RL angles used 40°-70°

LEVEL: DATE: 7-3 PAGE 6 OF

## Watts Bar Unit 2

	TVA Procedure N-GP-31 Attachments 3 & 4	Measured Calculated Fields Fields
	Worksheet Version 1.0 dated 07/01/09	
WELD NUMBER	RHRF-D031-14	-
Item 1	Required examination Volume in sq. in. (width x height)	1.6 0.45 0.72 sq. in.
Item 2	Number of scan directions	4 directions
Item 3	Total Scan <b>volume</b> in sq. in.	2.88 sq. in.
Item 4	Total <b>length</b> of weld	33.75 inches
Item 5	Total required <b>exam volume</b> in cubic inches	97.2 cu. in.
Item 6	Exam volume acheived (sq. in.) in direction 1 X length of weld achieved	0.72 33.75 24.3 cu. ln.
Item 7	Exam volume acheived (sq. in.) in direction 2 X length of weld achieved	0.72 33.75 24.3 cu. ln.
Item 8	Exam volume acheived (sq. in.) in direction 3 X length of weld achieved	0.72 33.75 24.3 cu. ln.
Item 9	Exam volume acheived (sq. in.) in direction 4 X length of weld achieved	0.42 33.75 14.175 cu. In.
Item 10	Determined the <b>acheived exam volume</b> add 6, 7, 8 & 9	87.075 cu. ln.
Item 11	Exam <b>volume percentage</b> item 10/item 5 x 100	89.58
	Limitation due to Valve configuration	Initials  JPN
	INFORMATION ONLY	<b>Date</b> 08/06/2009