

R-P1770



IHI Southwest Technologies Examination Summary Record

Utility: TVA		Site: Watts Bar Nuclear Plant Unit 2 PSI		Outage:		Summary Sheet No. 002000	
System: Reactor Pressure Vessel			Line Subassembly: Outlet Nozzle to Shell @ 338-degree			Identification: N-18	
NDE Method	Proc/Rev/Chg/ICN	NDE Examination	Calibration Sheet No's.	Exam Sheet No.	NRI	Other	Remarks
AUT	ISwT-PDI-AUT5/1/0/1	Probe 1	1100097	78	X	-	
AUT	ISwT-PDI-AUT5/1/0/1	Probe 2	1100098	78	X	-	
AUT	ISwT-PDI-AUT5/1/0/1	Probe 3	1100099	78	X	-	
AUT	ISwT-PDI-AUT5/1/0/1	Probe 4	1100100	78	X	-	
AUT	ISwT-PDI-AUT4/3/0/0	Probe 1	1100001-A	79 - 84	X	-	

Examination Summary:

This weld was examined from the inside surface using AIRIS-21 and Dynaray examination equipment. No recordable indications were detected during this examination. Examination Angles for each probe used with procedure ISwT-PDI-AUT 5 include: PA60°-80°L, PA40°-50°S, PA30°-60°L, & PA0°L. Examination Angles for probe used with procedure ISwT-PDI-AUT-4 include: PA5°- 40°L, PA35°-45S. Exam #78 was divided into sections A - D (sections C & D were additional exams using specific probes for improved examination coverage). The examination was limited due to the proximity of the nozzle integral extension. The examination coverage was 84%.

This weld was examined from the nozzle inside surface using ANT & T-III examination equipment. AB 12-15-11

Prepared By: Steven J. Todd			
Signature: <i>Steven J. Todd</i>	Date: <i>9/2/2011</i>		
Reviewed By: <i>[Signature]</i>		Reviewed By: <i>Daniel R Williams</i>	
Signature: <i>[Signature]</i>	Date: <i>10/26/11</i>	Signature: <i>[Signature]</i>	Date: <i>12/12/11</i>
Tennessee Valley Authority		ANII	