

Central File

50-269
270
287

DUKE POWER COMPANY USNRC REGION II
POWER BUILDING ATLANTA, GEORGIA

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

80 JAN 28 AIO: 25

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

January 24, 1980

TELEPHONE: AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Re: RII:JPO
50-269
50-270
50-287
IE Bulletin 79-17

Dear Sir:

This visual examination of inaccessible portion of Oconee Unit 1 have been completed in accordance with the schedule supplied in my letter of November 28, 1979. No indication of leakage through cracks in stagnant borated water systems piping was observed.

Very truly yours,

William O. Parker, Jr.
William O. Parker, Jr.

KRW:scs



8002120 038

8058
ORIGINAL COPY *for*