

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9406280313 DOC. DATE: 94/06/21 NOTARIZED: NO DOCKET #
 FACIL: 50-269 Oconee Nuclear Station, Unit 1, Duke Power Co. 05000269
 50-270 Oconee Nuclear Station, Unit 2, Duke Power Co. 05000270
 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co. 05000287

AUTH. NAME AUTHOR AFFILIATION
 HAMPTON, J.W. Duke Power Co.
 RECIP. NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Requests that NRC close out second 10-yr ISI interval Relief Requests 88-07, 88-08, 88-09 & 89-01 based on listed info.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3
 TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PD2-3 LA		1	0		PD2-3 PD		1	1
	WIENS, L		2	2					
INTERNAL:	ACRS		6	6		AEOD/DSP/ROAB		1	1
	NRR/DE/EMEB		1	1		NRR/EMCB		1	1
	NUDOCS-ABSTRACT		1	1		OC/LEDCE		1	1
	OGC/HDS2		1	0		<u>REG FILE</u> 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	EG&G BROWN, B		1	1		EG&G RANSOME, C		1	1
	NRC PDR		1	1		NSIC		1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 22 ENCL ~~10~~ 0

MAY

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

090
Duke Power Company
Oconee Nuclear Site
P.O. Box 1439
Seneca, SC 29679

J. W. HAMPTON
Vice President
(803)885-3499 Office
(803)885-3564 Fax



DUKE POWER

June 21, 1994

U.S. Nuclear Regulatory Commission
Attention Document Control Desk
Washington, DC 20555

Subject: Duke Power Company
Oconee Nuclear Station
Docket Nos. 50-269, -287 ^{1/270}
Second Ten Year Inservice Inspection Interval
Request for Relief Nos. 88-07, 88-08, 88-09, 89-01
Supplementary Information

Duke Power Company submitted the subject Relief from Code Requests in the period of August 1988 to February 1989. Duke Power requests that the Nuclear Regulatory Commission close out these Relief Requests based on the following information:

Relief Request 88-07, submitted to the NRC on August 23, 1988, stated as a part of the alternate examinations that a hydrostatic test would be performed on the welds for valve 3AS-39 during the ten year inservice inspection hydrostatic test. Relief Request 89-09, submitted to the NRC on December 5, 1989, requests relief identical to that which is stated in Relief Request 88-07. The NRC promulgated an SER dated October 29, 1990 granting relief for Relief Request 89-09.

Relief Request 88-08, submitted to the NRC on August 24, 1988, stipulated as a part of the alternate examinations that a hydrostatic test would be performed on the welds for 3FDW-232 and 3FDW-233 during the ten year inservice inspection hydrostatic test. The welds on these two valves were hydrostatically tested in February 1994.


Relief Request 88-09, submitted to the NRC on December 9, 1988, asked to allow NDE and a VT-2 examination in lieu of a hydrostatic test of the welds used to replace 1SE-89. These welds were a part of the 10 year inservice inspection hydrostatic test boundary performed in April 1991.

Relief Request 89-01, submitted to the NRC on January 24, 1989, stipulated as a part of the alternate examinations, that the inlet welds for 1MS-83 and 85 would be hydrostatically tested during the 10 year inservice inspection hydrostatic test. The welds for these two valves were hydrostatically tested in June 1994.

270
9406280313 940621
PDR ADDCK 05000269
Q PDR

If there are any questions or further information is needed you may contact D. A. Nix at (803) 885-3634.

Very truly yours,

A handwritten signature in cursive script, appearing to read "J. W. Hampton". The signature is written in dark ink and is positioned to the left of the typed name.

J. W. Hampton
Site Vice President

U. S. Nuclear Regulatory Commission
Page 3

xc :

Mr. L. A. Wiens
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, DC 20555

Mr. S. D. Ebnetter
Regional Administrator, Region II
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon
Senior NRC Resident Inspector
Oconee Nuclear Station

Mr. Virgil R. Autry
Bureau of Radiological Health
SC Dept. of Health & Environmental Control
2600 Bull St.
Columbia, SC 29201