

Central File

DUKE POWER COMPANY
ATLANTA
POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

79 JUL 17 A 8:15
July 13, 1979

WILLIAM O. PARKER, JR.
VICE PRESIDENT
STEAM PRODUCTION

TELEPHONE: AREA 704
373-4083

Mr. James P. O'Reilly, Director
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

RE: RII:JPO
50-269
50-270
50-287

Dear Mr. O'Reilly:

With regard to your letter dated May 22, 1979 concerning IE Bulletin 79-11, the following is Duke Power Company's response for Oconee Nuclear Station. Westinghouse type DB-75 breakers are installed in the Keowee Hydro Station, which supplies emergency electric power to Oconee. The actions required by items 2, 3, and 4 will be taken and a report will be provided on or before August 15, 1979.

Very truly yours,

William O. Parker, Jr.
William O. Parker, Jr.
By [Signature]

RLG:scs

602
CLP

7908070805 OFFICIAL COPY