



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

October 26, 2016

Mr. Loren D. Sharp
Senior Director Humboldt Bay Nuclear
Humboldt Bay Power Plant
1000 King Salmon Avenue
Eureka, CA 95503

SUBJECT: HUMBOLDT BAY POWER PLANT UNIT 3 – MARSSIM RECLASSIFICATION
OF INTAKE STRUCTURE

Dear Mr. Sharp:

In your letter dated September 28, 2016, you informed us of your intent to revise the MARSSIM classification of the intake structure from Class 1 to Class 3. Your reclassification was based on characterization surveys performed after the Humboldt Bay Power Plant Historical Site Assessment was developed. The letter further indicated that PG&E performed these surveys on the area of the intake structure where the most potential for contamination exists (i.e., the Unit 1 intake chambers with proximity to spill area) as the configuration of the intake structure was such that the entire structure was a confined space and could not be safely accessed.

We have reviewed your proposed reclassification and have no objections. We would like to note that this does not constitute approval of the survey unit for license termination. To support such a review in the future, the Final Status Survey Report should clearly describe the extent of and results of surveys performed, the as-left configuration of the structure after any demolition occurs, the reasoning for your survey approach, and a justification for the non-accessibility of the structure. In addition, since a portion of the structure is proposed to remain, the accessibility of the remaining structure should be assessed after any demolition to determine whether the same safety concerns exist at that point or not. If not, it may be prudent to survey additional accessible areas at that time.

Sincerely,

/RA/

John B. Hickman, Project Manager
Reactor Decommissioning Branch
Division of Decommissioning, Uranium Recovery
and Waste Programs
Office of Nuclear Material Safety and Safeguards

Docket No. 50-133

cc: Humboldt Bay Service List

October 26, 2016

Mr. Loren D. Sharp
Senior Director Humboldt Bay Nuclear
Humboldt Bay Power Plant
1000 King Salmon Avenue
Eureka, CA 95503

SUBJECT: HUMBOLDT BAY POWER PLANT UNIT 3 – MARSSIM RECLASSIFICATION
OF INTAKE STRUCTURE

Dear Mr. Sharp:

In your letter dated September 28, 2016, you informed us of your intent to revise the MARSSIM classification of the intake structure from Class 1 to Class 3. Your reclassification was based on characterization surveys performed after the Humboldt Bay Power Plant Historical Site Assessment was developed. The letter further indicated that PG&E performed these surveys on the area of the intake structure where the most potential for contamination exists (i.e., the Unit 1 intake chambers with proximity to spill area) as the configuration of the intake structure was such that the entire structure was a confined space and could not be safely accessed.

We have reviewed your proposed reclassification and have no objections. We would like to note that this does not constitute approval of the survey unit for license termination. To support such a review in the future, the Final Status Survey Report should clearly describe the extent of and results of surveys performed, the as-left configuration of the structure after any demolition occurs, the reasoning for your survey approach, and a justification for the non-accessibility of the structure. In addition, since a portion of the structure is proposed to remain, the accessibility of the remaining structure should be assessed after any demolition to determine whether the same safety concerns exist at that point or not. If not, it may be prudent to survey additional accessible areas at that time.

Sincerely,

/RA/

John B. Hickman, Project Manager
Reactor Decommissioning Branch
Division of Decommissioning, Uranium Recovery
and Waste Programs
Office of Nuclear Material Safety and Safeguards

Docket No. 50-133

cc: Humboldt Bay Service List

DISTRIBUTION: DCD r/f

OGC ACRS/ACNW

RKeller, RIV

ML16299A387

OFFICE	DUWP:PM	DUWP:LA	DUWP:HP	DUWP:BC	DUWP:PM
NAME	JHickman	CHolston	JClements	BWatson	JHickman
DATE	10 / 25 /2016	10 / 26 /2016	10 / 26 /2016	10 /26/2016	10 /26/2016

OFFICIAL RECORD COPY

Humboldt Bay Power Plant, Unit 3 Service List

cc:

Mr. Edward D. Halpin
Senior Vice President and
Chief Nuclear Officer
Pacific Gas and Electric Company
P.O. Box 56
Mail Code 104/6
Avila Beach, CA 93424

Loren Sharp
Director and Plant Manager
Humboldt Bay Nuclear
Pacific Gas & Electric Company
1000 King Salmon Avenue
Eureka, CA 95503

Jennifer K. Post
Law Department
Pacific Gas and Electric Company
77 Beale Street, B30A
San Francisco, CA

Hossein Hamzehee
Regulatory Services Manager
Diablo Canyon and Humboldt Bay Power
Plant
Pacific Gas and Electric Company
P.O. Box 56
Avila Beach, CA 93424

Chairman, Humboldt County Board
of Supervisors
County Courthouse
825 Fifth Street
Eureka, CA 95501

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 400
Arlington, TX 76011-8064

California Public Utilities Commission
505 Van Ness, Room 4102
San Francisco, CA 94102

Redwood Alliance
P.O. Box 293
Arcata, CA 95521
Dr. Rich Ferguson, Energy Chair
Sierra Club California
1100 11th Street, Suite 311
Sacramento, CA 94814

Mr. Gonzalo Perez, Radiation Program
Director
Radiologic Health Branch
Dept. of Health Services, MS-7610
P.O. Box 997414
Sacramento, CA 95899-7414

Stephen Hsu, M.S., Senior Health Physicist
Radiological Assessment Unit
Radioactive Material Licensing Section
Radiologic Health Branch
Dept. of Health Services, MS-7610
P.O. Box 997414
Sacramento, CA 95899-7414

Commissioner
California Energy Commission
1516 Ninth Street
Sacramento, CA 95814

Deputy Attorney General
Office of the Attorney General for the
State of California
600 W. Broadway, Suite 1800
San Diego, CA 92101