

# ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9210060049      DOC. DATE: 92/09/22      NOTARIZED: NO

DOCKET #

FACIL: 50-287 Oconee Nuclear Station, Unit 3, Duke Power Co.

05000287

AUTH. NAME                      AUTHOR AFFILIATION

HAMPTON, J.W.                  Duke Power Co.

RECIP. NAME                    RECIPIENT AFFILIATION

Document Control Branch (Document Control Desk)

SUBJECT: Forwards Request for Relief 92-13 covering stress weld on LPIS low pressure portion. Relief required due to impracticality of meeting ASME Code requirements re required weld area coverage for periodic inservice surface exam.

DISTRIBUTION CODE: A047D    COPIES RECEIVED: LTR 1 ENCL 1 SIZE: S  
 TITLE: OR Submittal: Inservice Inspection/Testing/Relief from ASME Code

NOTES:

	RECIPIENT		COPIES		RECIPIENT		COPIES	
INTERNAL:	ID CODE/NAME	L	T	E	N	ID CODE/NAME	L	T
	PD2-3 LA	1		0		PD2-3 PD	1	1
	WIENS, L	2		2				
	ACRS	6		6		NRR/DET/ECMB 9H	1	1
	NRR/DET/EMEB 7E	1		1		NUDOCS-ABSTRACT	1	1
	OC/LFMB	1		0		OGC/HDS2	1	0
	<u>REG FILE</u> 01	1		1		RES MILLMAN, G	1	1
	RES/DSIR/EIB	1		1				
	EG&G BROWN, B	1		1		EG&G RANSOME, C	1	1
	NRC PDR	1		1		NSIC	1	1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK.  
 ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION  
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR    22    ENCL    19

R  
I  
D  
S  
/  
A  
D  
D  
S  
/  
A  
D  
S

*MA 8-21*

Duke Power Company  
Oconee Nuclear Station  
P.O. Box 1439  
Seneca, S.C. 29679

(803) 882-5363



DUKE POWER

September 22, 1992

U.S. Nuclear Regulatory Commission  
Attention Document Control Desk  
Washington, DC 20555


Subject: Duke Power Company  
Oconee Nuclear Station  
Docket No. 50-287  
Request for Relief No. 92-13

Pursuant to 10CFR50, 50.55a, please find the subject Request for Relief from ASME Section XI, 1980 Edition through the Winter 1980 Addenda. This relief is needed due to the impracticality of meeting the code requirements concerning required weld area coverage for the periodic Inservice Surface Examination on Unit 3 weld 3-53B-33-28 in the Low Pressure Injection System piping.

Code Case N-460 states, in part, " When the entire examination volume or area cannot be examined due to interference by another component or part geometry a reduction in examination coverage on any Class 1 or 2 weld may be accepted provided the reduction in coverage for that weld is less than 10%". We have reviewed this Code Case and find it's applicability to Oconee to be acceptable. This code Case has been referenced in the Oconee Inservice Inspection Plan. The attached request identifies a weld examined during the Unit 3 EOC 13 refueling outage, because of interference by another component, did not meet the less than 10% criteria given in Code Case N-460.

Please review and approve this request prior to the completion of Oconee's Second Ten-Year Inservice Inspection Interval, ending on February 28, 1994.

Very truly yours,

  
J. W. Hampton  
Attachment

020026

4210060049 920922  
PDR ADCCK 05000287  
P PDR

A047  
11

U. S. Nuclear Regulatory Commission  
Page 2

xc: Mr. L. A. Wiens  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555

Mr. S. D. Ebnetter  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission

Mr. P. E. Harmon  
Senior NRC Resident Inspector  
Oconee Nuclear Station

Mr. Heyward G. Shealy  
Bureau of Radiological Health  
SC Dept. of Health & Environmental Control  
2600 Bull St.  
Columbia, SC 29201

DUKE POWER COMPANY

Request for Relief From  
Inservice Inspection Requirement

Station: Oconee

Unit: 3

Requesting Department: Nuclear Generation Department

Reference Code: ASME Boiler and Pressure Vessel Code, Section XI 1980  
Edition through Winter 1980 Addenda

I. Component for which exemption is requested:

a. Name and Identification Number:

Weld 3-53B-33-28, (Stress weld on the Low Pressure Injection System,  
low pressure portion)

b. Function:

Provides an emergency injection function in case of a LOCA

c. ASME Section XI Code Class:

2

d. Construction Code and Class (If Applicable):

ANSI B31.7 Class 2

e. Valve Category (If Applicable):

NA

II. Reference Code Requirement that has been determined to be impractical:  
IWC-2500-7, Examination Category C-F (surface examination), Item Number  
C05.011.009

III. Basis for Requesting Relief:

The Construction Permit for Oconee was issued on November 6, 1967. 10  
CFR 50.55a(g) allows for plants whose Construction Permit was issued  
prior to January 1, 1971 to meet the requirements of ASME Section XI to the

extent practical within the limitations of design, geometry and materials of construction of the components.

Weld 3-53B-33-28 is on a 14 inch, schedule 10 stainless steel pipe. The design parameters for this pipe are, pressure 388 psig and temperature 300 degrees F. This section of pipe is not used except when the reactor is shutdown. This line is one of two lines the LPI pumps can use to take a suction on the emergency sump during an extended emergency situation.

Due to physical obstructions (pipe saddle) obtaining coverage on at least 90% of the weld volume as required by ASME Section XI, 1980 Edition as modified by Code Case N-460 is not possible. A total of 80% of the weld was examined by the liquid penetrant method and was found to be acceptable. The 20% of the weld that is inaccessible is on the bottom side of the pipe. The section was visually inspected and no indications of a leak were observed. In addition, this line is scheduled to receive a VT-2 functional test at normal operating condition this outage.

Based on the results of the liquid penetrant and visual examination that was performed and the functional test, which verified there were no leaks at normal operating conditions, there is no danger to the health and safety of the general public.

IV. Alternate Examination:

No alternate examination is planned for this weld due to the inaccessibility of the lower portion of the weld. A hydrostatic test was performed on this line on September 7, 1989 and was found to be satisfactory. Additionally, this line will receive a VT-2 functional test at normal operating conditions

V. Implementation Schedule:

Refueling Outage 13 (current outage August, 1992).

Evaluated By:

R/S Rouse

Date:

9/15/92

Engineering  
Review By:

Jed K. Royal

Date:

9/21/92

Reviewed By:

N. G. Goodman

Date:

9/15/92

INFORMATION ONLY

DUKE POWER COMPANY


PROJECT OCONEE

MAGNETIC PARTICLE/LIQUID PENETRANT EXAMINATION REPORT

Weld No. 3-538-33-28 Unit No. 3 Date 08/27/92  
 Diameter 14.00 Schedule/Thickness 00.250 Type Material  SS  CS  
 Work Order No. N/A QA Condition 1

Procedure NDE-35 AF / Rev 13  
 NDE-98 Approved N/A  
 Radiation Level N/A

Inspector	Level
<i>EBC</i>	<i>II</i>



Indication Number	Indication Dimensions Length/Width/Dia., etc.	Acceptable	Reportable	Reference Documents
		* see		
		remarks		

**MT DATA**  
 MT Method Used  
 Fluorescent  Nonfluorescent  Wet  Dry  
 MT Unit Serial No. \_\_\_\_\_  
 Particle Batch No. \_\_\_\_\_  
 MT Technique Used: \_\_\_\_\_  
 Circular  
 Direct Contact Amp \_\_\_\_\_  
 Central Conductor Amp \_\_\_\_\_  
 MT Field Indicator Used  Yes /  No  
 Yoke  AC  DC  Prod  
 Longitudinal No. Turns in Coil \_\_\_\_\_ Amps

**PT DATA**  
 PT Batch Number  
 Cleaner 92001  
 Penetrant 87K043  
 Developer 91C17P  
 Remover  
 Fluorescent  Nonfluorescent  
 Black Light Intensity Verified  
 Time \_\_\_\_\_ Date \_\_\_\_\_  
 Ser.No. Lt. Meter \_\_\_\_\_  
 Ser. No. Blk Light \_\_\_\_\_  
 Remarks:  
 LIMITED AREA IS 20% OF EXAM SURFACE OR APP. 4.4" EACH SIDE OF BOTTOM C/L  
 NO VISUAL EVIDENCE OF LEAKAGE IN LIMITED AREA.  
 NO RECORDABLE INDICATIONS FOUND

ANI Review <i>YMB Chapman</i>	Date <u>8-28-92</u>	Final QA Review <i>T. J. Coleman</i>	Date <u>8-28-92</u>	Item No. C05.011.009
----------------------------------	------------------------	---	------------------------	-------------------------