Charles R. Pierce Regulatory Affairs Director Southern Nuclear Operating Company, Inc. 40 Inverness Center Parkway Post Office Box 1295 Birmingham, AL 35242

**Southern Nuclear** 

Tel 205.992.7872 Fax 205.992.7601

## OCT 2 6 2016

Docket Nos.: 50-321 50-366 NL-16-2013

U. S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D. C. 20555-0001

#### Edwin I. Hatch Nuclear Plant – Units 1 & 2 <u>Transmittal of Revised Technical Specification Pages</u>

Ladies and Gentlemen:

By letter dated March 14, 2016, and as supplemented by letter dated May 17, 2016, Southern Nuclear Operating Company (SNC) submitted a license amendment request (LAR) to adopt TSTF-65-A, Rev. 1. SNC would like to amend this request to include three administrative corrections to the Edwin I. Hatch Nuclear Plant (HNP) Technical Specifications (TSs).

- 1. Include a missing "(Continued)" at the bottom of Unit 1 page 3.4-20 to signify that the Surveillance Requirements for TS 3.4.9 continue onto the following page.
- Add the term STAGGERED TEST BASIS back to the Unit 2 Definitions. This term was added to page 1.1-5 of the definitions section in Unit 2 Amendment No.
  220. Due to an unrelated change to this same page, this term was inadvertently deleted with the issuance of Amendment 221.
- 3. Update Unit 1 and Unit 2 Surveillance Requirement (SR) 3.6.4.1.3 to incorporate approved changes in Unit 1 Amendments 280 and 279 and in Unit 2 Amendments 224 and 223. By letter dated September 29, 2016, the Nuclear Regulatory Commission (NRC) issued HNP Amendments 279 (Unit 1) and 223 (Unit 2). By letter dated September 30, 2016, the NRC issued HNP Amendments 280 (Unit 1) and 224 (Unit 2). These Unit 1 and Unit 2 Amendments both made unrelated changes to SR 3.6.4.1.3. The changes approved in Amendments 279 (Unit 1) and 223 (Unit 2), however, were not incorporated in the TS pages issued in Amendments 280 (Unit 1) and 224 (Unit 2).

All of these administrative corrections simply incorporate changes to the TS that the NRC has previously approved. There is no proposed expansion of scope from what was previously approved by the NRC. As such, the conclusion of the No Significant Hazards Consideration (NSHC) provided in the March 14, 2016 LAR stating that a finding of "no significant hazards consideration" is justified remains unchanged.

This letter contains no NRC commitments. If you have any questions, please contact Ken McElroy at 205.992.7369.

**U.S. Nuclear Regulatory Commission** NL-16-2013 Page 2

Mr. C. R. Pierce states he is Regulatory Affairs Director of Southern Nuclear Operating Company, is authorized to execute this oath on behalf of Southern Nuclear Operating Company and, to the best of his knowledge and belief, the facts set forth in this letter are true.

Respectfully subprited,

C. R. Pierce **Regulatory Affairs Director** 

CRP/RMJ

Sworn to and subscribed before me this <u>26</u> day of <u>October</u> 2016. Notary Public

My commission expires: 10-8-2011

1. Marked-up Technical Specification Pages Enclosures:

2. Clean Typed Technical Specification Pages

CC: Southern Nuclear Operating Company

Mr. S. E. Kuczynski, Chairman, President & CEO Mr. D. G. Bost, Executive Vice President & Chief Nuclear Officer Mr. D. R. Vinevard, Vice President - Hatch Mr. M. D. Meier, Vice President - Regulatory Affairs Mr. D. R. Madison, Vice President - Fleet Operations Mr. B. J. Adams, Vice President - Engineering Mr. G. L. Johnson, Regulatory Affairs Manager – Hatch RType: CHA02.004

U. S. Nuclear Regulatory Commission Ms. C. Haney, Regional Administrator

Mr. M. D. Orenak, NRR Project Manager - Hatch

Mr. D. H. Hardage, Senior Resident Inspector - Hatch

State of Georgia Mr. J. H. Turner, Director - Environmental Protection Division

#### Edwin I. Hatch Nuclear Plant – Units 1 & 2 Transmittal of Revised Technical Specification Pages

Enclosure 1

Marked-up Technical Specification Pages

#### SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.4.9.4	NOTE Only required to be met in MODES 1, 2, 3, and 4 during startup of a recirculation pump.	
	Verify the difference between the reactor coolant temperature in the recirculation loop to be started and the RPV coolant temperature is $\leq$ 50°F.	Once within 15 minutes prior to starting an idle recirculation pump
SR 3.4.9.5	NOTE Only required to be met when tensioning/ detensioning the reactor vessel head bolting studs. 	Once within 30 minutes prior to tensioning/ detensioning the reactor vessel head bolting studs and in accordance with the Surveillance Frequency Control Program

(continued)

HATCH UNIT 1

### 1.1 Definitions (continued)

	PHYSICS TESTS	PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation. These tests are:		
		a.	Described in Chapter 14, Initial Tests and Operation, of	the FSAR;
		b.	Authorized under the provisions of 10 CFR 50.59; or	
		С.	Otherwise approved by the Nuclear Regulatory Commis	sion.
	PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)	The P pressu the cu tempe accord	TLR is the unit specific document that provides the reactor are and temperature limits, including heatup and cooldown rrent reactor vessel fluence period. These pressure and rature limits shall be determined for each fluence period in lance with Specification 5.6.7.	r vessel 1 rates, for n
	RATED THERMAL POWER (RTP)	RTP s coolar	hall be a total reactor core heat transfer rate to the reacto t of 2804 MWt.	r
	REACTOR PROTECTION SYSTEM (RPS) RESPONSE TIME	The R monito senso respor overla	PS RESPONSE TIME shall be that time interval from when ored parameter exceeds its RPS trip setpoint at the chann r until de-energization of the scram pilot valve solenoids. hase time may be measured by means of any series of seq pping, or total steps so that the entire response time is me	en the lel The luential, easured.
	SHUTDOWN MARGIN (SDM)	SDM s or wou	shall be the amount of reactivity by which the reactor is su IId be subcritical assuming that:	bcritical
		а.	The reactor is xenon free;	
		b.	The moderator temperature is 68°F; and	
		C.	All control rods are fully inserted except for the single co of highest reactivity worth, which is assumed to be fully With control rods not capable of being fully inserted, the worth of these control rods must be accounted for in the determination of SDM.	ntrol rod withdrawn. reactivity
$\rightarrow$				
	THERMAL POWER	THER reacto	MAL POWER shall be the total reactor core heat transfer r coolant.	rate to the
STAGGER	ED A STAGGERE	ED TES	T BASIS shall consist of the testing of one of the chappels, or other designated components during	
	the interval sp	ecified I	by the Surveillance Frequency, so that all systems,	
	subsystems, c n Surveillance	hannels Freque	s, or other designated components are tested during ency intervals, where <i>n</i> is the total number of	X
	systems, subs	ystems	, channels, or other designated components in the	ontinued)
	associated ful	ouori.		

ACT	IONS			
CONDITION		F	REQUIRED ACTION	COMPLETION TIME
C.	(continued)	C.2	Suspend CORE ALTERATIONS.	Immediately
		<u>AND</u>		
		C.3	Initiate action to suspend OPDRVs.	Immediately

## SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY		
SR 3.6.4.1.1	In accordance with the Surveillance Frequency Control Program			
SR 3.6.4.1.2	3.6.4.1.2 Verify one secondary containment access door in each access opening is closed.			
SR 3.6.4.1.3	The number of standby gas treatment (SGT) subsystem(s) required for this Surveillance is dependent on the secondary containment configuration, and shall be one less than the number required to meet LCO 3.6.4.3, "Standby Gas Treatment (SGT) System," for the given configuration.			
	treatment (SGT) subsystem(s).	(continued)		

Amendment No. 280

I

AC	TIONS
AC	CINO

CONDITION		R	EQUIRED ACTION	COMPLETION TIME
C.	(continued)	C.2	Suspend CORE ALTERATIONS.	Immediately
		AND		
		C.3	Initiate action to suspend OPDRVs.	Immediately

## SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.6.4.1.1	Verify all secondary containment equipment hatches are closed and sealed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.2	Verify one secondary containment access door in each access opening is closed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.3	The number of standby gas treatment (SGT) subsystem(s) required for this Surveillance is dependent on the secondary containment configuration, and shall be one less than the number required to meet LCO 3.6.4.3, "Standby Gas Treatment (SGT) System," for the given configuration. Can be drawn down Verify required SGT subsystem(s) will draw Bown the secondary containment to ≥ 0.20 inch of vacuum water gauge in ≤ 10 minutes using required standby gas	In accordance with the Surveillance Frequency Control Program
	treatment (SGT) subsystem(s).	(continued)

## Edwin I. Hatch Nuclear Plant – Units 1 & 2 Transmittal of Revised Technical Specification Pages

Enclosure 2

Clean Typed Technical Specification Pages

### SURVEILLANCE REQUIREMENTS (continued)

	SURVEILLANCE	FREQUENCY
SR 3.4.9.4	NOTENOTE Only required to be met in MODES 1, 2, 3, and 4 during startup of a recirculation pump.	
	Verify the difference between the reactor coolant temperature in the recirculation loop to be started and the RPV coolant temperature is $\leq$ 50°F.	Once within 15 minutes prior to starting an idle recirculation pump
SR 3.4.9.5	Only required to be met when tensioning/ detensioning the reactor vessel head bolting studs. Verify reactor vessel flange and head flange temperatures are within the limits specified in the PTLR.	Once within 30 minutes prior to tensioning/ detensioning the reactor vessel head bolting studs and in accordance with the Surveillance Frequency Control Program
		(continued)

PHYSICS TESTS	PHYSICS TESTS shall be those tests performed to measure the fundamental nuclear characteristics of the reactor core and related instrumentation. These tests are:					
	a.	Described in Chapter 14, Initial Tests and Operation, of the FSAR;				
	b.	Authorized under the provisions of 10 CFR 50.59; or				
	с.	Otherwise approved by the Nuclear Regulatory Commission.				
PRESSURE AND TEMPERATURE LIMITS REPORT (PTLR)	The P pressu the cu tempe accord	PTLR is the unit specific document that provides the reactor vessel ssure and temperature limits, including heatup and cooldown rates, for current reactor vessel fluence period. These pressure and perature limits shall be determined for each fluence period in ordance with Specification 5.6.7.				
RATED THERMAL POWER (RTP)	RTP s coolar	hall be a total reactor core heat transfer rate to the reactor It of 2804 MWt.				
REACTOR PROTECTION SYSTEM (RPS) RESPONSE TIME	The R monito senso respor overla	The RPS RESPONSE TIME shall be that time interval from when the monitored parameter exceeds its RPS trip setpoint at the channel sensor until de-energization of the scram pilot valve solenoids. The response time may be measured by means of any series of sequential, overlapping, or total steps so that the entire response time is measured.				
SHUTDOWN MARGIN (SDM)	SDM s	shall be the amount of reactivity by which the reactor is subcritical and be subcritical assuming that:				
	a.	The reactor is xenon free;				
	b.	The moderator temperature is 68°F; and				
	C.	All control rods are fully inserted except for the single control rod of highest reactivity worth, which is assumed to be fully withdrawn. With control rods not capable of being fully inserted, the reactivity worth of these control rods must be accounted for in the determination of SDM.				
STAGGERED TEST BASIS	A STA system the int subsys <i>n</i> Surv system assoc	STAGGERED TEST BASIS shall consist of the testing of one of the ystems, subsystems, channels, or other designated components during the interval specified by the Surveillance Frequency, so that all systems, ubsystems, channels, or other designated components are tested during Surveillance Frequency intervals, where <i>n</i> is the total number of ystems, subsystems, channels, or other designated components in the ssociated function.				
THERMAL POWER	THER	MAL POWER shall be the total reactor core heat transfer rate to the r coolant.				
	(continued)					

ACTIONS

CONDITION		F	EQUIRED ACTION	COMPLETION TIME	
C.	(continued)	C.2	Suspend CORE ALTERATIONS.	Immediately	
		AND			
		C.3	Initiate action to suspend OPDRVs.	Immediately	

# SURVEILLANCE REQUIREMENTS

SURVEILLANCE		FREQUENCY
SR 3.6.4.1.1 Verify all secondary contai hatches are closed and se	nment equipment aled.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.2 Verify one secondary conta each access opening is clo	ainment access door in osed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.3 The number of standby ga subsystem(s) required for dependent on the seconda configuration, and shall be number required to meet L Gas Treatment (SGT) Sys configuration. Verify secondary containm down to ≥ 0.20 inch of vac ≤ 10 minutes using require	E s treatment (SGT) this Surveillance is one less than the CO 3.6.4.3, "Standby tem," for the given ent can be drawn uum water gauge in d standby gas	In accordance with the Surveillance Frequency Control
configuration. 	ent can be drawn uum water gauge in d standby gas n(s).	In acco the Su Freque Progra

(continued)

ACTIONS

CONDITION		F	EQUIRED ACTION	COMPLETION TIME	
C.	(continued)	C.2	Suspend CORE ALTERATIONS.	Immediately	
		AND			
		C.3	Initiate action to suspend OPDRVs.	Immediately	

### SURVEILLANCE REQUIREMENTS

	SURVEILLANCE	FREQUENCY
SR 3.6.4.1.1	Verify all secondary containment equipment hatches are closed and sealed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.2	Verify one secondary containment access door in each access opening is closed.	In accordance with the Surveillance Frequency Control Program
SR 3.6.4.1.3	NOTE The number of standby gas treatment (SGT) subsystem(s) required for this Surveillance is dependent on the secondary containment configuration, and shall be one less than the number required to meet LCO 3.6.4.3, "Standby Gas Treatment (SGT) System," for the given configuration. 	In accordance with the Surveillance Frequency Control Program

(continued)