

CHAPTER 4.0
RADIATION SAFETY

4.1 ALARA (AS LOW AS IS REASONABLY ACHIEVABLE) POLICY

GNF-A’s standard of care for occupationally exposed individuals is to maintain exposures below the limits established by the U.S. Nuclear Regulatory Commission. Beyond the standard of care, GNF-A’s radiation protection staff has a commitment to establish, maintain, and implement an effective radiation protection program. This includes program commitment to maintain employee exposures As Low As Reasonably Achievable (ALARA) which is delineated by documented radiation protection program practices and procedures. Area Managers maintain worker exposures ALARA by proper use of procedures, equipment, and process design.

The radiation safety function ensures that occupational radiation exposures are maintained ALARA via timely exposure monitoring and interaction via Radiation Safety Committee participation with manufacturing personnel, and annual ALARA program assessments with senior management.

The Wilmington Safety Review Committee (Chapter 2) also plays a role in the overall ALARA program at GNF-A.

4.2 RADIATION SAFETY PROCEDURES AND RADIATION WORK PERMITS (RWPS)

Routine work performed in radiation controlled areas is administered by the use of standard practices and procedures described in Chapter 11.0. Non-routine activities, particularly those performed by non-GNF-A employees, which generally are not covered by documented procedures, are administered by the Radiation Work Permit (RWP) system. The RWP system is described in documented plant practices and procedures.

RWPs are issued by a radiation safety technician or supervisor for non-routine operations not addressed by an operating procedure when special radiation control requirements are necessary. The RWP specifies the necessary radiation safety controls, as appropriate, including personnel monitoring devices, protective clothing, respiratory protective equipment, special air sampling, and additional precautionary measures to be taken. RWPs are reviewed and approved by radiation safety supervision prior to issuance.

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.1

The RWP requirements are reviewed by each affected individual and a copy is made available to the radiation safety function throughout the duration of the activity. Work is monitored by the radiation safety function as required. RWPs have expiration dates and the status of issued RWPs is reviewed on a weekly basis by a radiation safety technician or supervisor.

4.3 VENTILATION REQUIREMENTS

4.3.1 INTER-AREA AIR FLOW DESIGN

Ventilation equipment is designed to provide air flow from areas of lesser potential contamination to areas of higher potential contamination. Direction of air flow between areas is checked monthly or after significant changes to the ventilation system. If insufficient air flow results in airborne concentrations greater than 10 DAC, then the affected processes are shut down. Specific facilities and capabilities of ventilation systems are detailed in Table 4.1.

4.3.2 ENCLOSURES AND LOCALIZED VENTILATION

Hoods and other localized ventilation designs are utilized to minimize personnel exposure to airborne uranium. Activities and process equipment that generate airborne uranium are designed with filtered enclosures, hoods, dust capturing exhaust ports and other devices which maintain air concentrations of radioactivity in work areas such that personnel exposures are below 10 CFR 20 limits under normal operating conditions.

Air flows through hood openings and localized vents are maintained in accordance with Table 4.1. Additionally, differential pressure indicators are installed across exhaust system filters to monitor system performance. The flows and differential pressures are checked monthly or after significant changes to the ventilation system. If insufficient air flow results in airborne concentrations greater than 10 DAC, then the affected processes are shut down in accordance with plant procedures.

4.3.3 EXHAUST SYSTEM

Potentially contaminated air from fuel manufacturing processes is exhausted as appropriate through high efficiency filter media which are at least 99.97% efficient

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.2

for removal of 0.3 micron particles. HEPA filters in the exhaust system are equipped with a device for measuring differential pressure. Differential pressures greater than four inches of water are investigated. In no case will filters be operated at a differential pressure which exceeds the manufacturer's ratings for the filter.

Water scrubbers or other appropriate devices are provided where necessary to treat effluents before stack discharge.

4.3.4 AIR RECIRCULATION

Room air may be recirculated within the uranium processing areas after being filtered. Room air recirculated within areas where airborne concentrations are likely to exceed 0.1 DAC is filtered by HEPA filters and/or water scrubbers.

4.4 AIR SAMPLING PROGRAM

Air samples are continuously taken from each main process area where airborne concentrations are likely to exceed 0.1 DAC when averaged over 40 hours to assess the concentrations of uranium in air. The air samples are collected in such a way that the concentrations of uranium measured are representative of the air which workers breathe. Air sampling results and individual personnel exposure assignments are monitored by the radiation safety function to evaluate the effectiveness of personnel exposure controls.

Evaluations of air sampling representativeness are performed in accordance with the methods and acceptance criteria in Table 2 of Regulatory Guide 8.25, "Air Sampling in the Workplace".

Filters from air samplers are changed each shift during normal operating periods or at more frequent intervals following the detection of an event that may have released airborne uranium, based upon knowledge of the particular circumstances. Filters are not changed as frequently during periods when no work is in progress. The filters are processed to determine the uranium concentration in air for each area.

Each air sampler is equipped with a rotameter to indicate flow rate of air sampled. These rotameters are calibrated or replaced at least every 18 months.

Air sampling results in excess of 2.5 DAC (8 hr. sample) and not resulting from a specific known cause are investigated to determine the probable cause. Operations or equipment will be shut down, and immediate corrective action will be taken, at

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.3

locations where an air sample exceeds 10 DAC without a specific known cause. Corrective actions are implemented and documented based on the frequency and magnitude of events causing releases of airborne uranium.

Routine air sampling is supplemented by portable air sample surveys as required to evaluate non-routine activities or breaches in containment. Based on these surveys, additional radiation protection requirements for the particular operation may be established.

4.5 CONTAMINATION CONTROL

4.5.1 SURVEYS

Routine contamination survey monitoring is performed for uranium process and manufacturing areas including non-controlled areas such as hallways and lunch rooms immediately adjacent to controlled areas. Removable contamination measurements are made based on the potential for contamination in these areas and operational experience. Survey frequencies are determined by the radiation safety function. Survey results are compared to action guide values as specified in plant procedures and appropriate responses are taken.

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.4

The minimum survey frequencies and maximum removable contamination action levels are as follows:

<u>Area</u>	<u>Frequency</u>	<u>Action Limit (dpm α/100 cm²)</u>
Controlled Areas (Floors & Other Readily Accessible Surfaces)	Weekly	$\geq 5,000$
Eating Areas used primarily by Controlled Area Personnel	Weekly	≥ 220
Non-controlled Areas	Monthly	≥ 220

When contamination levels in excess of action limits are found, mitigating actions are taken within 24 hours.

Personnel contamination surveys for external contamination on clothing and the body are required by personnel when exiting the change rooms. If contamination is found in excess of background levels, the individual attempts self-decontamination at the facilities provided in the change rooms. If decontamination attempts are not successful, decontamination assistance will be provided by the radiation safety function. If skin or personal clothing is still found contaminated above background levels, the individual may not leave the area without prior approval of the radiation protection function.

4.5.2 ACCESS CONTROL

Routine access points to controlled areas are established through change rooms. Each change room includes a step-off area provided between the contamination controlled and non-controlled areas. Instructions controlling entry and exit from controlled area are posted at the entry points. Personnel survey instrumentation is provided in the step-off area of each change room for use by personnel leaving the controlled areas. Posted instructions address the use of the instrumentation and appropriate decontamination methods.

Alternate access points to controlled areas are established for specific activities that are not accommodated by the change rooms. Such access is governed by approved procedures, or Radiation Work Permits, which establish controls to prevent the spread of contamination to non-controlled areas.

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.5

4.5.3 PROTECTIVE CLOTHING

Protective clothing is provided to persons who are required to enter the controlled areas where personnel contamination potential exists as determined by the radiation safety function. The amount and type of protective clothing required for a specific area or operation is determined by operational experience and the contamination potential. Available clothing includes caps, hoods, laboratory coats, coveralls, safety glasses, boots overshoes, shoe covers, rubber and cloth gloves and safety shoes.

The minimum clothing requirement for airborne controlled area entry is as follows:

Area Workers	Inspectors and Visitors Only Observing Operations
Shoe covers or work area shoes	Shoe covers
Coveralls	Laboratory coats
Rubber gloves	Rubber gloves (as needed)
Safety glasses	Safety glasses

The protective clothing is removed upon exit in the controlled area change rooms.

In laboratory areas where uranium is handled the minimum protective clothing requirement for entry is a laboratory coat and safety glasses.

4.5.4 LEAK TESTING OF PLUTONIUM ALPHA SOURCES

The sources when not in use shall be stored in a closed container adequately designed and constructed to contain plutonium which might otherwise be released during storage.

The sources shall be tested for loss of plutonium at intervals not to exceed 110 days, using radiation detection instrumentation capable of detecting 0.005 μCi of alpha contamination.

If any survey or measurement performed as required by the preceding paragraph discloses the loss of more than 0.005 μCi of plutonium from the source, or if a source has been damaged or broken, the source shall be deemed to be losing

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.6

plutonium. The licensee shall immediately withdraw it from use, and cause the source to be decontaminated and repaired, or disposed of in accordance with the Commission regulations.

Records of test results shall be kept in units of microcuries and maintained for inspection by the Commission.

Notwithstanding the periodic test required above, any plutonium alpha source containing not more than 0.1 μCi of plutonium is exempted from the above requirements.

4.6 **EXTERNAL EXPOSURE**

Deep-dose equivalent and shallow-dose equivalent from external sources of radiation are determined by individually assigned dosimeters. The radiation safety function makes a determination to issue personnel dosimetry to individuals based on work area surveys, occupancy time, or other exposure information such as area monitor results. Personnel dosimeters are processed by a National Voluntary Laboratory Accreditation Program (NVLAP) accredited vendor. The capability exists to process dosimeters expeditiously if there is an indication of an exposure in excess of established action guides. Action guides for external exposures are established in plant procedures. Maximum radiation exposure action levels are specified in Section 4.9.

External exposures may be calculated by the radiation safety function on the basis of data obtained by investigation when the results of individual monitoring are unavailable or are invalidated by unusual exposure conditions.

4.7 **INTERNAL EXPOSURE**

Intakes are assigned to individuals based upon one or more types of measurements as follows: air sampling (described in Section 4.4), urinalysis and in vivo lung counting. Intakes are converted to committed dose equivalent (CDE) and committed effective dose equivalent (CEDE) for the purposes of limiting and recording occupational doses. Action levels are established in plant procedures to prevent an individual from exceeding the occupational exposure limits specified in 10 CFR 20. Maximum radiation exposure action levels are specified in Section 4.9. Control actions include temporarily restricting the individual from working in an area containing airborne radioactivity, and actions are taken as necessary to assure against recurrence.

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.7

4.7.1 URINALYSIS PROGRAM

The urinalysis program is conducted primarily to evaluate the intake of soluble uranium to assure that the 10 CFR 20 intake limit of 10 mg is not exceeded. Individuals assigned to work in areas where soluble airborne uranium compounds are present in concentrations that are likely to result in intakes in excess of 10 percent of the applicable limits in 10 CFR 20 are monitored by urinalysis. The minimum sampling frequency for these individuals is biweekly. Urinalysis may also be used to monitor individuals involved in non-routine operations, perturbations or incidents.

Urine sampling frequencies and action levels are established in plant procedures based on the appropriate biokinetic models for the uranium compounds present. Results above the applicable action level are investigated. Urinalysis action levels are based on maximum radiation exposure action levels specified in Section 4.9. Results that exceed action levels result in a temporary work restriction for the individual to prevent additional exposure and allow a more accurate assessment of the intake.

4.7.2 IN VIVO LUNG COUNTING

Routine in vivo lung counting frequencies are established for individuals who normally work in areas where non-transportable uranium compounds are processed. Baseline and termination counts are performed when feasible. Lung counting frequencies are based upon individual airborne exposure assignments and previous counting results. The minimum count frequency is annual for individuals with an assigned intake greater than 10 percent of the Annual Limit on Intake (ALI).

Appropriate actions are taken based upon in vivo lung counting results to ensure the ALI will not be exceeded. If an individual's lung burden indicates an intake greater than the applicable action level, the individual is temporarily restricted from working in areas containing airborne uranium. In vivo lung counting action levels are based on the maximum radiation exposure action levels specified in Section 4.9.

4.8 SUMMING INTERNAL AND EXTERNAL EXPOSURE

Internal and external exposures determined as described in the preceding sections of this application are summed in accordance with the requirements of 10 CFR 20 for

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.8

the purposes of limiting occupational doses and recording individual monitoring results.

4.9 ACTION LEVELS FOR RADIATION EXPOSURES

Work activity restrictions will be imposed when an individual's exposure exceeds 80% of the applicable 10 CFR 20 limit.

4.10 RESPIRATORY PROTECTION PROGRAM

The respiratory protection program shall be conducted in accordance with the applicable portions of 10 CFR 20, including written procedures for air sampling sufficient to identify the potential hazard, proper equipment selection, maintenance and testing, dose estimation; and surveys or bioassays, as necessary, to evaluate actual intakes. Respiratory protection equipment specifically approved by the National Institute for Occupational Safety and Health (NIOSH) is utilized.

4.10.1 QUALIFICATIONS OF RESPIRATOR USERS

Individuals designated to use respiratory protection equipment are evaluated by the medical function and periodically thereafter at a frequency specified by the medical function to determine if the individual is medically fit to use respiratory protection devices. If there are no medical restrictions precluding respirator use, the individual is provided respiratory training and fitting by a qualified instructor. Additional training on the use and limitations of self-contained breathing devices is provided to designated individuals.

An adequate fit is determined for all face-sealing respirators using either a quantitative fit test method or a qualitative method. Qualitative fit testing is acceptable if (1) it is capable of verifying a fit factor of 10 times the assigned protection factor (APF) for facepieces operated in a negative pressure mode or (2) it is capable of verifying a fit factor of ≥ 100 for facepieces operated in a positive pressure mode. Mask fits are re-evaluated annually.

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.9

4.10.2 RESPIRATORY PROTECTION EQUIPMENT

Only NIOSH approved respiratory protection equipment is utilized. Protection factors specified in 10 CFR 20 Appendix A are used for selecting the proper equipment and estimating personnel exposures.

4.10.3 EQUIPMENT MAINTENANCE

Respiratory protection equipment is cleaned, serviced, tested and inspected in accordance with the instructions specified by the manufacturer per the NIOSH certification and 10 CFR 20 for each respiratory protection device. Equipment maintenance is always conducted in accordance with the applicable portions of 10 CFR 20 and as documented in written procedures.

4.11 INSTRUMENTATION

Appropriate radiation detection instruments are available in sufficient number to ensure adequate radiation surveillance can be accomplished. Selection criteria of portable and laboratory counting equipment is based on the types of radiation detected, maintenance requirements, ruggedness, interchangeability and upper and lower limits of detection capabilities. The radiation safety function annually reviews the appropriateness of the types of instruments being used for each monitoring function. Table 4.2 lists examples of the types and uses of available instrumentation.

4.11.1 CALIBRATION

Portable instrumentation is calibrated before initial use, after major maintenance, and on a routine basis at least annually following the last calibration. Calibration consists of a performance check on each range scale of the instrument with a radioactive source of known activity traceable to a recognized standard such as the National Institute of Standards and Technology (NIST).

Prior to each use, operability checks are performed on monitoring and laboratory counting instruments. The background and efficiency of laboratory counting instruments are determined on a daily basis when in use.

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.10

TABLE 4.1
SPECIFIC FACILITIES & CAPABILITIES OF VENTILATION SYSTEMS

<u>Facility</u>	<u>Alarms, Interlocks & Safety Features</u>	<u>Purpose</u>
Hoods	Air flow during operation \geq 80 linear feet per minute	Prevents spread of radioactive materials
	Effluent air filtered with HEPA filters	Prevents release of radioactive materials to environs
High Velocity Local Ventilation	Air flow designated to maintain an average of 200 linear feet per minute	Prevents spread of radioactive materials from work area to immediate room area
Recirculating Air Systems & Exhaust Air Systems	Air filtered in potentially contaminated zones with HEPA filters or water scrubbers	Removes essentially all contaminants from room and exhaust to environs
	Pressure drop indicator set to alarm at $\geq 4''$ H ₂ O Δ P across final filter	Maintains adequate circulation for removal of dust and contaminants from the room air
	Effluent air filtered with HEPA filters	Prevents release of radioactive materials in environs

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.11

TABLE 4.2
TYPES & USES OF AVAILABLE INSTRUMENTATION (TYPICAL)

<u>Type</u>	<u>Typical Range</u>	<u>Routine Use</u>
<u>DOSE RATE METERS</u>		
GM Low Range	0.01 mR/hr - 2000 mR/hr	Area Dose Rate Survey, Shipment Survey
GM High Range	0.1 mR/hr - 1000 R/hr	Emergency Monitoring
Ion Chamber - Low Range	0.1 mR.hr - 10 R/hr	Area Dose Rate Survey, Shipment Survey
Ion Chamber - High Range	1 mR/hr - 1000 R/hr	Emergency Monitoring
<u>ALPHA SURVEY METERS</u>		
	50 cpm - 2 x 10 ⁶ cpm	Direct Area Equipment Surveys
<u>NEUTRON METERS</u>		
	0.5 mR/hr - 5 R/hr	Special Dose Rate Surveys
<u>PERSONAL CONTAMINATION MONITORS</u>		
	N/A	Personal Surveys
<u>LABORATORY INSTRUMENTATION</u>		
Automatic air sample counter	N/A	Lab Analysis
Fixed geometry Geiger-Mueller counter	N/A	Lab Analysis
Scintillation Counter	N/A	Lab Analysis
In Vivo Lung Counter	N/A	Lung Deposition Measurements

LICENSE	SNM-1097	DATE	10/27/16	Page
DOCKET	70-1113	REVISION	5	4.12