

Co9/09/78

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)  
DISTRIBUTION FOR INCOMING MATERIAL

50-269

REC: DENTON H R  
NRC

ORG: PARKER W O  
DUKE PWR

DOCDATE: 09/26/78  
DATE RCVD: 09/29/78

DOCTYPE: LETTER NOTARIZED: NO  
SUBJECT:

COPIES RECEIVED  
LTR 1 ENCL 0

FURNISHING RESPONSE TO NRC'S QUESTION 4 AS CONTAINED IN LTR DTD 08/21/78,  
CONCERNING SUM OF THE WORTH GROUPS 5, 6, & 7.

PLANT NAME: OCONEE -- UNIT 1

REVIEWER INITIAL: XJM  
DISTRIBUTOR INITIAL: Jjm

\*\*\*\*\* DISTRIBUTION OF THIS MATERIAL IS AS FOLLOWS \*\*\*\*\*

NOTES:

1. M. CUNNINGHAM -- ALL AMENDMENTS TO FSAR AND CHANGES TO TECH SPECS

GENERAL DISTRIBUTION FOR AFTER ISSUANCE OF OPERATING LICENSE.  
(DISTRIBUTION CODE A001)

FOR ACTION: BR CHIEF ORB#4 BC\*\*LTR ONLY(7)

INTERNAL:

REG FILE\*\*LTR ONLY(1)

I & E\*\*LTR ONLY(2)

HANAUER\*\*LTR ONLY(1)

AD FOR SYS & PROJ\*\*LTR ONLY(1)

REACTOR SAFETY BR\*\*LTR ONLY(1)

EEB\*\*LTR ONLY(1)

J MCGOUGH\*\*LTR ONLY(1)

NRC PDR\*\*LTR ONLY(1)

OELD\*\*LTR ONLY(1)

CORE PERFORMANCE BR\*\*LTR ONLY(1)

ENGINEERING BR\*\*LTR ONLY(1)

PLANT SYSTEMS BR\*\*LTR ONLY(1)

EFFLUENT TREAT SYS\*\*LTR ONLY(1)

EXTERNAL:

LPDR'S

WALHALLA, SC\*\*LTR ONLY(1)

TERA\*\*LTR ONLY(1)

NSIC\*\*LTR ONLY(1)

ACRS CAT B\*\*LTR ONLY(16)

DISTRIBUTION: LTR 40 ENCL 0  
SIZE: 1P

CONTROL NBR: 781430118

\*\*\*\*\* THE END \*\*\*\*\*

may

R

REGULATORY DOCKET FILE COPY

DUKE POWER COMPANY

POWER BUILDING

422 SOUTH CHURCH STREET, CHARLOTTE, N. C. 28242

WILLIAM O. PARKER, JR.  
VICE PRESIDENT  
STEAM PRODUCTION

September 26, 1978

REGULATORY DOCKET  
BRANCH

1978 SEP 29

TELEPHONE: AREA 704  
373-4083

REGULATORY DOCKET  
BRANCH

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attention: Mr. R. W. Reid, Chief  
Operating Reactors Branch #4

Re: Oconee Nuclear Station, Unit 1  
Docket No. 50-269

Dear Sir:

As discussed during a telephone conversation with members of your staff on September 25, 1978, the following response to Question 4 of your letter of August 21, 1978 is provided:

If the sum of the worth of groups 5, 6, and 7 differs from the predicted by more than  $\pm 10\%$ , group 4 will be measured by dilution. If the sum of the worths of groups 4, 5, 6, and 7 differs from the predicted by more than  $\pm 10\%$ , additional measurements, as well as evaluation of the discrepancy will be made, as necessary.

Very truly yours,

*William O. Parker Jr.*  
William O. Parker, Jr. *by WAH*

RLG:scs

781430118

*1001  
1/0*