



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 2, 2016

Mr. Bryan C. Hanson
President and Chief Nuclear Officer
Exelon Generation Company, LLC
4300 Winfield Road
Warrenville, IL 60555

SUBJECT: CALVERT CLIFFS NUCLEAR POWER PLANT, UNIT NOS. 1 AND 2 -
ACCEPTANCE REVIEW OF REQUESTED LICENSING ACTION RE:
CONTROL ROOM EMERGENCY VENTILATION SYSTEM
(CAC NOS. MF8406 AND MF8407)

Dear Mr. Hanson:

By letter dated September 22, 2016, Exelon Generation Company, LLC (Exelon) submitted a license amendment request (LAR) for Calvert Cliffs Nuclear Power Plant, Units 1 and 2 (CCNPP 1 and 2). The proposed amendment would revise the CCNPP 1 and 2 Technical Specification (TS) Section 3.8.3, "Control Room Recirculation Signal (CRRS)," and TS 3.7.8, "Control Room Emergency Ventilation System (CREV)," to eliminate certain CREV system components that no longer serve the purpose of establishing and isolating the control room boundary. The purpose of this letter is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of this LAR. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations* (10 CFR), an amendment to the license (including the TSs) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications. Section 10 CFR 50.34 addresses the content of technical information required. This section stipulates that the submittal address the design and operating characteristics, unusual or novel design features, and principal safety considerations.

The NRC staff has reviewed your application and concluded that the information delineated in the enclosure to this letter is necessary to enable the staff to make an independent assessment regarding the acceptability of the proposed amendment request in terms of regulatory requirements and the protection of public health and safety and the environment.

In order to make the application complete, the NRC staff requests that Exelon supplement the application to address the information requested in the enclosure by November 18, 2016. This will enable the NRC staff to begin its detailed technical review. If the information responsive to the NRC staff's request is not received by the above date, the application will not be accepted for review pursuant to 10 CFR 2.101, and the NRC will cease its review activities associated with the application. If the application is subsequently accepted for review, you will be advised of any further information needed to support the staff's detailed technical review by separate correspondence.

B. Hanson

- 2 -

The information requested and associated time frame in this letter were discussed with Mr. Enrique Villar of your staff on November 1, 2016.

If you have any questions, please contact me at (301) 415-1030.

Sincerely,

A handwritten signature in black ink, appearing to read "R. Guzman", with a long horizontal line extending to the right.

Richard V. Guzman, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosures:
As stated

cc w/encl: Distribution via Listserv

NRC STAFF ACCEPTANCE REVIEW COMMENTS

REQUESTED LICENSING ACTION RE:

CONTROL ROOM EMERGENCY VENTILATION SYSTEM

RENEWED FACILITY OPERATING LICENSE NOS. DPR-53 AND DPR-69

EXELON NUCLEAR GENERATION, LLC

CALVERT CLIFFS NUCLEAR POWER PLANT, UNITS 1 AND 2

DOCKET NOS. 50-317 AND 50-318

By letter dated September 22, 2016 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16266A086), Exelon Nuclear Generation, LLC (Exelon) submitted a license amendment request (LAR) for Calvert Cliffs Nuclear Power Plant, Units 1 and 2. The Nuclear Regulatory Commission (NRC) staff has reviewed Exelon's application and concluded that the information delineated below is necessary to enable the staff to make an independent assessment regarding the acceptability of the proposed amendment request in terms of regulatory requirements and the protection of public health and safety and the environment.

Title 10 of the *Code of Federal Regulations* (10 CFR) Section 50.36(b) states in part that..."The technical specifications will be derived from the analyses and evaluation included in the safety analysis report, and amendments thereto, submitted pursuant to § 50.34." The NRC staff has determined the application lacks depth of technical information in the discussion regarding the modification of the Control Room Emergency Ventilation System (CREV) including the design change control process used, analyses, evaluations and criteria used to assess acceptability of the modification.

The licensee is requested to supplement their application by providing a detailed explanation of the design change which should include the process used to control the design change, the evaluation criteria used to assess the acceptability of the design change as well as any analyses and evaluations used to justify the design change. The staff notes that the modification discussed in the LAR was performed in 1999; the licensee is requested to provide a detailed explanation of its rationale for leaving the technical specifications unaltered and the reasons for the subsequent determination years later to submit a license amendment request proposing the TS changes.

B. Hanson

- 2 -

The information requested and associated time frame in this letter were discussed with Mr. Enrique Villar of your staff on November 1, 2016.

If you have any questions, please contact me at (301) 415-1030.

Sincerely,

/RA/

Richard V. Guzman, Senior Project Manager
Plant Licensing Branch I-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket Nos. 50-317 and 50-318

Enclosures:
As stated

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC LPL1-1 R/F	RidsNrrDorIDpr Resource	RidsNrrDssStsb Resource
RidsNrrDorlLpl1-1 Resource	RidsOGCMailCenter Resource	RidsNrrDraArcb Resource
RidsRgn1MailCenter Resource	RidsNrrPMCalvertCliffs Resource	MHamm, NRR
RidsAcrsAcnw_MailCenter Resource	RidsOgcRp Resource	EDickens, NRR
RidsNrrKGoldstein Resource	RidsNrrDssSbpb Resource	NKaripineni, NRR

ADAMS Accession No. ML16306A471

*Concurrence and Input provided by e-mail. No substantial changes made.

OFFICE	DORL/LPL1-1/PM	DORL/LPL1-1/LA	DSS/STSB/BC
NAME	RGuzman	KGoldstein	Klein*
DATE	11/01/16	11/02/16	11/02/16
OFFICE	DSS/SBPB/BC	DORL/LPL1-1/BC(A)	
NAME	GCasto*	BMozafari	
DATE	11/02/16	11/02/16	

OFFICIAL RECORD COPY