### Job Performance Measure

### **Determine Venting Time for Reactor Vessel Void**

JPM Number: S-108

Revision Number: 151

Date: 03 / 21 / 2016

Developed By: <u>Eric Steinberg</u> <u>03/21/2016</u>

Instructor Date

Validated By: <u>Dan Burton</u> <u>4/22/2016</u>

SME or Instructor Date

Reviewed By: Kevin Lueshen 04/22/2016

Operations Representative Date

Approved By: <u>Eric Steinberg</u> <u>04/26/2016</u>

Training Department Date


### Braidwood S-108 rev 151

JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE:	•	of this checklist should be performed upon in PM usage, revalidate JPM using steps 9 and		
	1.	Task description and number, JPM descrip	tion and number are identified.	
	2.	Knowledge and Abilities (K/A) references a	re included.	
	3.	Performance location specified. (in-plant, c	ontrol room, simulator, or other)	
	4.	Initial setup conditions are identified.		
	5.	Initiating cue (and terminating cue if require	ed) are properly identified.	
	6.	Task standards identified and verified by S	ME review.	
	7.	Critical steps meet the criteria for critical statement (*).	eps and are identified with an	
	8.	If an alternate path is used, the task standa completion.	ard contains criteria for successfu	اړ
	9.	Verify the procedure(s) referenced by this Procedure 1BwFR-I.3 Rev: 201 Procedure Rev: Rev: Rev: Rev:	JPM reflects the current revision:	
	10.	Verify cues both verbal and visual are free	of conflict.	
	11.	Verify performance time is accurate		
	12.	If the JPM cannot be performed as written revise the JPM.	with proper responses, then	
	13.	When JPM is initially validated, sign and davalidations, sign and date below:	ate JPM cover page. Subsequer	ıt
		SME / Instructor	Date	
		SME / Instructor	Date	
		SME / Instructor	Date	

## **Revision Record (Summary)**

**Revision 151,** updated to current JPM template and most recent procedure revision.



iii

# Braidwood SIMULATOR SETUP INSTRUCTIONS

1. NONE



## Braidwood INITIAL CONDITIONS

Unit 1 is recovering from an event that caused a suspected hydrogen bubble to accumulate in the reactor vessel head. The crew is currently performing 1BwFR-I.3, RESPONSE TO VOIDS IN REACTOR VESSEL. The TSC has directed the crew to perform a direct vessel vent. Current plant conditions are:

Containment temperature (dry bulb) = 160°F

Containment pressure = 3.5 psig

Containment hydrogen concentration = 1%

RCS pressure = 1900 psig

#### **INITIATING CUE**

The Shift Manager has directed you to calculate the vessel vent time per 1BwFR-I.3, Attachment B. Inform the Shift Manager when you have completed the calculation.

Provide examinee with a copy of 1BwFR-I.3.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment
*1	Calculate containment temperature in Rankine.	Perform Attachment B, step 1:  o Enter 160 in °F blank.  • Add 460 to 160 and enter 620 in °R blank.			
*2	Calculate containment air volume based on current temperature and pressure.	<ul> <li>Perform Attachment B, step 2:</li> <li>Enter 620 in °R blank.</li> <li>Enter 3.5 in CNMT press blank.</li> <li>Perform calculation and enter 2,750,968 (or approx. 2.75E6) in ft³ blank.</li> </ul>			
*3	Calculate maximum hydrogen volume that can be vented keeping cnmt concentration below 3%.	Perform Attachment B, step 3: <ul> <li>Enter 1 in cnmt hydrogen conc. blank.</li> <li>Enter 2,750,968 (or approx. 2.75E6) in ft³ blank</li> </ul> <li>Perform calculation and enter 55,019 (or approx. 5.5E4) in ft³ blank.</li>			
*4	Determine hydrogen flow rate from RCS vent.	Perform Attachment B, step 4:  • Plot RCS pressure on Figure 1BwFR I.3-4 and determine flow rate will be 5850 scfm (range of 5800 to 5900)  • Enter flow rate in step 4 SCFM blank.			
*5	Calculate maximum venting time.	Perform Attachment B, step 5:  • Enter 55,019 (or approx. 5.5E4) in ft³ blank.  • Enter 5850 (5800 – 5900) in SCFM blank.  • Calculate minutes and enter 9.4 (range of 9.3 to 9.5) in minutes blank.			
6	Report to SM results of venting calculation.	Notify SM that RCS venting can be performed for approx. 9.4 minutes.			
CUE	This completes this JPM.				

JPM Stop Time:			

### JPM SUMMARY

Operator's Name	e: E	mp. ID#:	_
Job Title: 🗆 E	O □ RO ⊠SRO □ FS □ STA/IA	☐ SRO Cert	
JPM Title: Determ	nine Venting Time for Reactor Vessel	Void	
JPM Number: S-1	108 Revision No	umber: <u>151</u>	
Task Number and	d Title: <u>S-FR-017 Determine venting ti</u>	me for Reactor Vessel \	√oid_
K/A Number and	Importance: <u>0020002.1.25 SRO 4.2</u>		
Suggested Testin	ng Environment: Simulator or Classro	<u>om</u>	
Alternate Path:	∃Yes ⊠No SRO Only: ⊠Yes [	☐No Time Critical: [	∐Yes ⊠No
Reference(s): 1E	BwFR-I.3, rev 201, RESPONSE TO V	OIDS IN REACTOR VE	SSEL
<b>Actual Testing E</b>	Environment: Simulator Co	ntrol Room   In-Plan	nt ⊠ Other
<b>Testing Method:</b>	: ☐ Simulate ☒ Perform		
Estimated Time to	o Complete: 10 minutes Ac	tual Time Used:	minutes
<b>EVALUATION SI</b> Were all the Critic	UMMARY: cal Elements performed satisfactorily?	? □Yes	No
	erformance was evaluated against sta this JPM and has been determined to		☐Unsatisfactory
Comments:			
			_
			_
		_	_
Evaluator's Nam	<b>ne</b> (Print):		
Evaluator's Sign	nature:	Date:	

## Braidwood INITIAL CONDITIONS

Unit 1 is recovering from an event that caused a suspected hydrogen bubble to accumulate in the reactor vessel head. The crew is currently performing 1BwFR-I.3, RESPONSE TO VOIDS IN REACTOR VESSEL. The TSC has directed the crew to perform a direct vessel vent. Current plant conditions are:

Containment temperature (dry bulb) = 160°F

Containment pressure = 3.5 psig

Containment hydrogen concentration = 1%

RCS pressure = 1900 psig

#### **INITIATING CUE**

The Shift Manager has directed you to calculate the vessel vent time per 1BwFR-I.3, Attachment B. Inform the Shift Manager when you have completed the calculation.

SRRS: 3D.100; There are no retention requirements for this section

### Job Performance Measure

### **Determine if Reactor Start-up should continue.**

JPM Number: S-114

Revision Number: 151

Date: 03 / 30 / 2016

Developed By: <u>Eric Steinberg</u> <u>3/30/2016</u>

Instructor Date

Validated By: <u>Dan Burton</u> <u>04/22/2016</u>

SME or Instructor Date

Reviewed By: Kevin Lueshen 04/22/2016

Operations Representative Date

Approved By: <u>Eric Steinberg</u> <u>04/26/2016</u>

Training Department Date

## JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE:		of this checklist should be performed upon i PM usage, revalidate JPM using steps 9 an		
	1. 2. 3. 4. 5. 6. 7.	Task description and number, JPM description and number, JPM description and number, JPM descriptions and Abilities (K/A) references a Performance location specified. (in-plant, of Initial setup conditions are identified.  Initiating cue (and terminating cue if require Task standards identified and verified by Standards steps meet the criteria for critical standards.	etion and number are iden are included. control room, simulator, or ed) are properly identified ME review.	other)
	8.	asterisk (*).  If an alternate path is used, the task standa completion.		
	<u> </u>	Verify the procedure(s) referenced by this Procedure 1BwGP-100-2 Rev: 40 Procedure 1BwGP-100-7T2 Rev: 17 Procedure BwCB-1 Fig 2A Rev: 25 Procedure BwCB-1 Fig 9 Rev: 24 Procedure 1BwGP-100-2A1 Rev: 5	JPM reflects the current re	evision:
	10.	Verify cues both verbal and visual are free	of conflict.	
	11.	Verify performance time is accurate		
	12.	If the JPM cannot be performed as written revise the JPM.	with proper responses, th	en
	13.	When JPM is initially validated, sign and davalidations, sign and date below:	ate JPM cover page. Sub	sequent
		SME / Instructor	Date	
		SME / Instructor	Date	
		SME / Instructor	Date	

## **Revision Record (Summary)**

Revision 151, New JPM for ILT 15-1 NRC exam.



iii

## Braidwood simulator setup instructions

- 1. None, perform in classroom.
- 2. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 3. This completes the setup for this JPM.



## Braidwood INITIAL CONDITIONS

- 1. Unit 1 is being started up from a 5 day long forced outage for turbine repairs.
- 2. The reactor core burnup is 1681.3 EFPH.
- 3. 1BwGP 100-2, PLANT STARTUP, is in progress at step F.23.I.
- 4. Control Bank C is at 90 steps.
- 5. Counts are stable at 8-fold count rate.
- 6. There is no ITR for this startup.

#### **INITIATING CUE**

- 1. You are the Unit 1 Reactivity Manager.
- 2. The RO has predicted criticality at control bank D at 65 steps based on 8-fold rod position.
- 3. The Shift Manager has directed you to determine if the reactor start-up should continue.

Provide the examinee a place kept copy of 1BwGP100-2, and a filled out copy of 1BwGP 100-7T2, estimated critical conditions table.

BwCB curve books should also be available for reference.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

#### **Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

Dialuwood	
JPM Start Time:	

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
NOTE:	The correct critical rod height (CB C at 120 is the same he	nt from the 8 fold graph is Control Eeight).	Bank D	) at 5 s	teps
*1	Verify estimated critical rod height.	<ul> <li>Refer to BwCB-1 Figure 9.</li> <li>Determine page 2 of 5 is the correct graph for the current core burn up.</li> <li>Determine correct estimated critical rod height is CB C 120 steps +/- 5 steps.</li> <li>Inform the Shift Manager the RO's estimated critical rod height is incorrect.</li> </ul>			
CUE	If told as the Shift Manager that the report.	ne estimated critical position is wro	ng, ac	knowle	edge
*2	Determine startup should be stopped.	<ul> <li>Refers to note before step F.23.I.</li> <li>The estimated critical rod height is below the 750 pcm limit and no ITR exists.</li> <li>Checks if ICRR estimate outside +/- 750 pcm limit. (yes)</li> <li>Determines 1BwGP 100-2 Attachment A needs to be performed.</li> <li>Directs the RO to stop the startup.</li> </ul>			
CUE	If asked as the Nuclear Engineer criticality at CB C at 120 steps or If asked for an ITR, "There is no I	•	RR pr	edicts	

Braidwood S-114 rev 151

	T	<u></u>				
3	Inform the Shift Manager.	<ul> <li>Calls Shift Manager to inform him that you are suspending the reactor startup.</li> <li>Direct that an IR be written.</li> </ul>				
CUE	As the Shift Manager acknowledge the report of suspending the startup and need to write an IR.					
	Inform the Examinee, "The unit supervisor will oversee the remaining actions."					
	That completes this JPM.					

JPM Stop Time: _			

Braidwood S-114 rev 151

#### JPM SUMMARY

Operator's Name:	Emp. ID#:				
Job Title: ☐ EO ☐ RO ☐ SRO ☐ FS ☐ STA/I	A ☐ SRO Cert				
JPM Title: Determine if Reactor Start-up should conting					
	Number: <u>151</u>				
Task Number and Title: S-AM-151, PERFORM prope	r reactivity management on unit startup				
and during normal plant operations.					
K/A Number and Importance: 001G2.1.37, 4.6					
Suggested Testing Environment: <u>Classroom</u>					
Alternate Path:   Yes  No SRO Only:  Yes  No Time Critical:  Yes  No					
Reference(s): 1BwGP 100-2, rev 40, PLANT STARTUP, 1BwGP 100-2A1, rev 5, Attachment A contingency for suspended reactor startup, 1BwGP 100-7T2, rev 17,					
	ion based on known boron concentration,				
	nit 1 cycle 19 HZP differential and integral				
rod worth vs RCCA steps withdrawn, BwCB-1 Fig. 9, rev 24, Braidwood unit 1					
cycle 19 ECC bank position VS 8-Fold	d increase bank position.				
Actual Testing Environment: ☐ Simulator ☐ C	ontrol Room ☐ In-Plant ☒ Other				
<b>Testing Method:</b> □ Simulate ⊠ Perform					
Estimated Time to Complete: 10 minutes	ctual Time Used: minutes				
EVALUATION SUMMARY: Were all the Critical Elements performed satisfactorily	y? □Yes □No				
The operator's performance was evaluated against so contained within this JPM and has been determined to					
Comments:					
Comments.					
	_				
Evaluator's Name (Print):					
Evaluator's Signature:	Date:				

## Braidwood S-114 rev 151

#### **INITIAL CONDITIONS**

- 1. Unit 1 is being started up from a 5 day long forced outage for turbine repairs.
- 2. The reactor core burnup is 1681.3 EFPH.
- 3. 1BwGP 100-2, PLANT STARTUP, is in progress at step F.23.I.
- 4. Control Bank C is at 90 steps.
- 5. Counts are stable at 8-fold count rate.
- 6. There is no ITR for this startup.

#### **INITIATING CUE**

- 1. You are the Unit 1 Reactivity Manager.
- 2. The RO has predicted criticality at control bank D at 65 steps based on 8-fold rod position.

The Shift Manager has directed you to determine if the reactor start-up should continue.

### Job Performance Measure

### **Review Surveillance and Determine Battery operability Requirements**

JPM Number: S-204

Revision Number: 151

Date: 03 / 22 / 2016

Developed By: <u>Eric Steinberg</u> <u>03/22/2016</u>

Instructor Date

Validated By: <u>Dan Burton</u> <u>04/22/2016</u>

SME or Instructor Date

Reviewed By: Kevin Lueshen 04/22/2016

Operations Representative Date

Approved By: <u>Eric Steinberg</u> <u>04/26/2016</u>

Training Department Date

### JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

	ि of this checklist should be performed upon i JPM usage, revalidate JPM using steps 9 an		
 _ 1.	Task description and number, JPM descript	ion and number are	identified.
 _ 2.	Knowledge and Abilities (K/A) references as	re included.	
 _ 3.	Performance location specified. (in-plant, co	ontrol room, simulato	r, or other)
 _ 4.	Initial setup conditions are identified.		
 _ 5.	Initiating cue (and terminating cue if require	d) are properly ident	ified.
 _ 6.	Task standards identified and verified by SM	ME review.	
 _ 7.	Critical steps meet the criteria for critical steasterisk (*).	eps and are identified	l with an
_ 8.	Verify the procedure(s) referenced by this J Procedure 1BwOSR 3.8.6.5-2 Rev: 13 Procedure 1BwOL 3.8.4 Rev: 7 Procedure 1BwOL 3.8.6 Rev: 3 Procedure 1BwOL TRM 3.8.c Rev: 4	PM reflects the curre	ent revision:
 _ 9.	Verify cues both verbal and visual are free of	of conflict.	
 _ 10.	Verify performance time is accurate		
 _ 11.	If the JPM cannot be performed as written wrevise the JPM.	vith proper response	s, then
12.	When JPM is initially validated, sign and da validations, sign and date below:	te JPM cover page.	Subsequent
	SME / Instructor	Date	
	SME / Instructor	Date	
	SME / Instructor	Date	

## **Revision Record (Summary)**

**Revision 151,** updated to current revision of the JPM template and procedures.



# Braidwood JPM SETUP INSTRUCTIONS

- 1) Fill out the data sheet D-2 as follows:
  - a) F.1: Mode 1, make up numbers for serial numbers for all 4 instruments.
  - b) F.6: 130V
  - c) F.7: Check no corrosion present.
  - d) F.8: record 4.0 for amps and 0.4 mvdc for shunt voltage.
  - e) F.9: record 130V
  - f) F.12 record 1.225
  - g) F.13 record 0.032
  - h) F.14 record 80
  - F.15 record 81
  - i) F.16 record 2.24
  - k) F.17 record 0.18
- 2) Fill out data sheet D-3 and D-4 as follows:
  - a) N/A all temp correct factors
  - b) Y for all cell levels
  - c) For cell 18 enter: 80°, 1.193, 2.06V, 1.193
  - d) For the remaining cell temperatures enter the following (randomly): 79° in 9 cells, 81° in 9 cells, and 80° in the remaining cells.
  - e) For the remaining cell ICVs enter the following randomly: 2.24 in 36 cells, 2.25 in 9 cells, 2.26 in 7 cells, and 2.23 in 5 cells.
  - f) For the remaining cell SGs (corrected and uncorrected) enter the following randomly: 1.226 in 33 cells, 1.227 in 1 cell, 1.224 in 1 cell, 1.223 in 1 cell, and 1.225 in 21 cells.
- 3) Place keep the main body and fill in the following (connected cells =58):
  - a) F.12: sum = 71.05, average = 1.225
  - b) F.13 1.225 1.193 = 0.032
  - c) F.14 sum = 4640, average = 80
  - d)  $F.15.81^{\circ} 80^{\circ} = 1^{\circ}$
  - e) F.16 sum =129.92, average = 2.24
  - f) F.17 2.24 2.06 = 0.18

## Braidwood Initial conditions

- 1. You are the Unit 1 Unit Supervisor.
- 2. Both units are at full power.

#### **INITIATING CUE**

- 1. An EO has informed you that 1BwOSR 3.8.6.5-2, Unit One 125V DC Battery 112 Operability Surveillance, is complete and ready for review.
- 2. Cell #47 is the pilot cell for battery 112.
- 3. Review the surveillance and inform the Shift Manager when the surveillance is complete.

Hand student completed copy of 1BwOSR 3.8.6.5-2.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*1	Review Data Sheet D-2.	Review Data Sheet D-2:			
		Determine battery parameters unsat. (Regulatory Compliance)			
		o Present Mode: 1			
		<ul> <li>Instrument data</li> </ul>			
		o Battery terminal voltage SAT			
		<ul> <li>No visible corrosion on cells</li> </ul>			
		<ul> <li>Battery float current UNSAT</li> </ul>			
		Battery Shunt Volt UNSAT			
		<ul> <li>Battery charger float voltage</li> </ul>			
		<ul> <li>Average corrected cell specific gravity SAT</li> </ul>			
		Maximum corrected specific gravity deviation below average corrected specific gravity UNSAT			
		<ul> <li>Average cell electrolyte temperature SAT</li> </ul>			
		<ul> <li>Maximum individual cell temperature deviation SAT</li> </ul>			
		<ul> <li>Average individual cell voltage SAT</li> </ul>			
		<ul> <li>Maximum ICV deviation below average ICV UNSAT</li> </ul>			
NOTE	If examinee notifies SM of UNSA	T parameters, acknowledge report			

	2.6				
STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*2	Review Data Sheets D-3, D-4, and D-5.	Review Data Sheets D-3, D-4, and D-5.			
		Determine Cell #18 parameters unsat. (Regulatory Compliance)			
		• Cell #18 ICV <2.07.			
		Cell #18 corrected specific gravity <1.195.			
		<ul> <li>All other cell parameters SAT.</li> </ul>			
		<ul> <li>Cell #47 is pilot cell (from comments sheet D-5 and cue sheet).</li> </ul>			

		T			
STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*3	Refer to Tech Specs/Bases	Refer to Tech Specs/Bases: (Regulatory Compliance)			
		Determine that TRM: 3.8.c, Condition A is applicable for Cell #18.			
		<ul> <li>Cell #18 does not meet category B limits for float voltage and specific gravity.</li> </ul>			
		Verify cell parameters     within category C limits     within 24 hours.			
		<ul> <li>Category A limits do not apply to cell #18 (not a pilot cell)</li> </ul>			
		Determine that Tech Spec 3.8.6 Conditions A, B, and F are applicable for Battery 112			
		<ul> <li>Cell #18 float voltage</li> <li>&lt;2.07V and battery</li> <li>current &gt;3A.</li> <li>Immediately declare</li> <li>battery 112 inoperable.</li> </ul>			
		Determine that Tech Spec 3.8.4 Condition D is applicable for Division 12 DC electrical power subsystem.			
		<ul> <li>From T.S. 3.8.4 Bases, one source (Battery 112) inoperable. Restore battery 112 within 2 hours.</li> </ul>			
NOTE	Provide copies of LCOAR paperv	work and Tech Specs when reques	ted by	exam	inee.

JPM Stop Time:

### JPM SUMMARY

Operator's Nan	ne:	Emp. ID#	·	_
Job Title: 🔲 i	EO □RO □SRO □	FS □ STA/IA □ SR	O Cert	
JPM Title: Revie	w Surveillance and D	etermine Battery Oper	rability Require	<u>ments</u>
JPM Number: <b>S</b>	-204	Revision Number:	<u>151</u>	
Task Number a		view Surveillances to		ance with Tech
		n-Tech Spec requirem	<u>ients.</u>	
	d Importance: <u>063000G</u>			
-	ing Environment: Simu			
	<del></del>	Only: ⊠Yes □No		<del></del>
` '	1BwOSR 3.8.6.5-2, Re <sup>,</sup> Surveillance	v 13, Unit One 125V DC	ESF Battery 11	2 Operability
	1BwOL 3.8.4, Rev 7, L0 1BwOL 3.8.6, Rev 3, L0 1BwOL TRM 3.8.c, Rev	COAR DC Sources – Op COAR Battery Paramete 4, Technical Requirem Maintenance Tech Spe	ers Tech Spec Lo ents Manual (TF	CO 3.8.6
<b>Actual Testing</b>	Environment: ⊠ Sim	ulator   Control Ro	om 🗌 In-Plar	nt ⊠ Other
Testing Method	d: ☐ Simulate ☒	Perform		
Estimated Time	to Complete: 16 minut	es Actual Tin	ne Used:	minutes
<b>EVALUATION S</b> Were all the Crit	SUMMARY: tical Elements performe	ed satisfactorily?	□Yes	□No
	performance was evalu this JPM and has bee	ated against standards n determined to be:	☐ Satisfactory	☐ Unsatisfactory
Comments:				_
		· ·		
_				
Evaluator's Na	me:		_ (Print)	
Evaluator's Sig	ınature <sup>.</sup>		Date <sup>.</sup>	

#### **INITIAL CONDITIONS**

- 1. You are the Unit 1 Unit Supervisor.
- 2. Both units are at full power.

#### **INITIATING CUE**

- 1. An EO has informed you that 1BwOSR 3.8.6.5-2, Unit One 125V DC Battery 112 Operability Surveillance is complete and ready for review.
- 2. Cell #47 is the pilot cell for battery 112.
- 3. Review the surveillance and inform the Shift Manager when the surveillance is complete.

### Job Performance Measure

### **Review Waste Gas Decay Tank Release**

JPM Number: S-301

Revision Number: 151

Date: 03 / 23 / 2016

Developed By: <u>Eric Steinberg</u> <u>03/23/2016</u>

Instructor Date

Validated By: <u>Dan Burton</u> <u>04/22/2016</u>

SME or Instructor Date

Reviewed By: Kevin Lueshen 04/22/2016

Operations Representative Date

Approved By: <u>Eric Steinberg</u> <u>04/26/2016</u>

Training Department Date

## Braidwood

S-301 rev 151 JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE:		All steps of this checklist should be performed upon initial validation. Prior to JPM usage, revalidate JPM using steps 9 and 13 below.				
	1. 2. 3. 4. 5. 6. 7.	Task description and number, JPM description and number, JPM description and Abilities (K/A) references a Performance location specified. (in-plant, continuous linitial setup conditions are identified. Initiating cue (and terminating cue if require Task standards identified and verified by SI Critical steps meet the criteria for critical steps asterisk (*).	ion and number are identified re included. ontrol room, simulator, or othed) are properly identified. ME review.			
	8.					
	9.	9. Verify the procedure(s) referenced by this JPM reflects the current revision: Procedure BwOP GW-500T1 Rev: 43 Procedure 0BwOS RETS 2.2.B-1 Rev: 02 Procedure Rev:				
	10.	Verify cues both verbal and visual are free	of conflict.			
	11.	Verify performance time is accurate				
	12.	If the JPM cannot be performed as written versities the JPM.	vith proper responses, then			
	13.	When JPM is initially validated, sign and davalidations, sign and date below:	te JPM cover page. Subsequ	ent		
		SME / Instructor	Date			
		SME / Instructor	Date			
		SME / Instructor	Date			

## **Revision Record (Summary)**

**Revision 151,** updated to new template and current revision of the procedures.



## Braidwood simulator setup instructions

#### 1. NONE

NOTE:

It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

- 2. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 3. This completes the setup for this JPM.



## Braidwood INITIAL CONDITIONS

- 1. You are the Unit 1 Unit Supervisor.
- 2. BOTH Units are at 100% power.
- 3. The Unit 1 Assist NSO has just completed a release package for the 0F Gas decay tank up to step D.21.

#### **INITIATING CUE**

- 1. The Shift Manager directs you to complete the review and approval of the gas decay tank release package.
- 2. Inform the Shift Manager when you have approved the release package for release.

Hand examinee marked up BwOP GW-500T1.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time: \_\_\_\_\_

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
	GW-500T1 Part D contains TWO performed (step D.2) AND 0PB1	g the student review BwOP GW- errors. 0BwOS RETS 2.2.B-1 ha 02 high alarm is set too high (ste ors PRIOR TO approving the rele	as NO ep D.2	Γ beer	1
1	Review partially completed Part D of BwOP GW-500T1.	Review partially completed Part D of BwOP GW-500T1  Read step D.22 and determines SRO review of Part D of BwOP GW-500T1 required.  Review Part D of BwOP GW-500T1			
*2	Determine 0BwOS RETS 2.2.B-1 has NOT been performed. (step D.2).	<ul> <li>Determine 0BwOS RETS 2.2.B-1 has NOT been performed.</li> <li>Determine step D.2 is not initialed or signed as completed.</li> <li>Determine 0BwOS RETS 2.2.B-1 is required to be performed.</li> <li>Determine 0BwOS RETS 2.2-1a is NOT in effect (Step A.3)</li> <li>Notify SM 0BwOS RETS 2.2.B-1 has NOT been performed.</li> </ul>			
CUE					
3	Review 0BwOS RETS 2.2.B-1.	<ul> <li>Review 0BwOS RETS 2.2.B-1.</li> <li>Determine acceptance criteria met.</li> <li>Complete BwOP GW-500T1, step D.2.</li> </ul>			

Braidwood S-301 rev 151

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*4	Continue review of Part D of BwOP GW-500T1.	Determine 0PB102 high alarm incorrectly set.  Notify SM 0PB102 high alarm incorrectly set.  Inform NSO to adjust 0PB102 high alarm to correct setpoint.  Sign and date Part D review (step D.22).			
CUE	That completes this JPM.				

JPM Stop Time:		

Braidwood S-301 rev 151

#### JPM SUMMARY

Operator's Name:	_	Emp. ID#	<b>#</b> :	_
Job Title: □ EO □ R	O ⊠SRO □ FS □	STA/IA □ SR	O Cert	
JPM Title:Review Waste	Gas Decay Release			
JPM Number: <u>S-301</u>	Rev	ision Number:	<u>151</u>	
Task Number and Title: S	S-HP-002, Authorize Ga	as Decay tank	Rad Waste Rel	<u>ease</u>
K/A Number and Importa	nce: <u>0730002.3.6 3.8</u>			
Suggested Testing Environment	onment: <u>Simulator or C</u>	lassroom		
Alternate Path: ☐ Yes	oxtimesNo SRO Only: $oxtimes$	Yes □No	Time Critical:	□Yes ⊠No
Reference(s): BwOP GF	<sup>2</sup> -500T1, rev 43, Gas [	ecay Tank rel	ease form	
	RETS 2.2.B-1, UNIT CO			
	L CHECK FOR GAS D	ECAY TANK	EFFLUENT MO	NITOR 0PR02J
rev 02				
Actual Testing Environ	ment: ⊠ Simulator	☐ Control Ro	oom 🗌 In-Pla	ınt ☐ Other
<b>Testing Method:</b> □ S	Simulate 🖂 Perform			
Estimated Time to Comp	lete: 15 minutes	Actual Tir	me Used:	_ minutes
<b>EVALUATION SUMMAR</b> Were all the Critical Elem		ectorily?	□Yes	□No
The operator's performar contained within this JPM				☐ Unsatisfactory
Comments				
Comments:				
Evaluator's Name (Print	:):		_	
Evaluator's Signature:			Date:	

## Braidwood S-301 rev 151

#### **INITIAL CONDITIONS**

- 1. You are the Unit 1 Unit Supervisor.
- 2. BOTH Units are at 100% power.
- 3. The Unit 1 Assist NSO has just completed a release package for the 0F Gas decay tank up to step D.21.

#### **INITIATING CUE**

- 1. The Shift Manager directs you to complete the review and approval of the gas decay tank release package.
- 2. Inform the Shift Manager when you have approved the release package for release.

### Job Performance Measure

### **Classify Event, Cold Matrix**

JPM Number: S-413

Revision Number: 151

Date: 03 / 25 / 2016

Developed By: <u>Eric Steinberg</u> <u>03/25/2016</u>

Instructor Date

Validated By: <u>Dan Burton</u> <u>04/22/2016</u>

SME or Instructor Date

Reviewed By: Kevin Lueshen 04/22/2016

Operations Representative Date

Approved By: <u>Eric Steinberg</u> <u>04/26/2016</u>

Training Department Date

## Braidwood

S-413 rev 151 JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

NOTE:	•	of this checklist should be performed upon i PM usage, revalidate JPM using steps 9 an	
-	1.	Task description and number, JPM descrip	tion and number are identified.
	2.	Knowledge and Abilities (K/A) references a	are included.
	3.	Performance location specified. (in-plant, o	control room, simulator, or other)
	4.	Initial setup conditions are identified.	
	5.	Initiating cue (and terminating cue if require	ed) are properly identified.
	6.	Task standards identified and verified by S	ME review.
	7.	Critical steps meet the criteria for critical st asterisk (*).	eps and are identified with an
	8.	If an alternate path is used, the task stands completion.	ard contains criteria for successful
	9.	Verify the procedure(s) referenced by this Procedure <u>EP-AA-1001 AD 3</u> Rev: <u>1</u> Procedure <u>EP-MW-114-100</u> Rev: <u>16</u> Procedure Rev:	JPM reflects the current revision:
	10.	Verify cues both verbal and visual are free	of conflict.
	11.	Verify performance time is accurate	
	12.	If the JPM cannot be performed as written revise the JPM.	with proper responses, then
	13.	When JPM is initially validated, sign and divalidations, sign and date below:	ate JPM cover page. Subsequent
		SME / Instructor	Date
		SME / Instructor	Date
	<u> </u>	SME / Instructor	Date

## **Revision Record (Summary)**

**Revision 151,** modified from JPM S-408. Revised to new TQ-AA-150-J020 template and new revision of procedures verified.



# Braidwood simulator setup instructions

1. None, this is a desk top admin JPM.

NOTE:

It is okay to use a similar IC to the IC listed above, provided the IC actually used is verified to be compatible with this and other JPMs that are scheduled to be run concurrently.

- 2. When the above steps are completed for this and other JPMs to be run concurrently then validate, if not previously validated, the concurrently run JPMs using the JPM Validation Checklist.
- 3. This completes the setup for this JPM.



## Braidwood INITIAL CONDITIONS

- 1. Unit 1 is defueled.
- 2. Bus 142 is OOS for the next 24 hours for a scheduled maintenance window.
- 3. Unit 1 SATs just de-energized due to a switchyard fault on unit 1.
- 4. The SAT fault will take 2 hours to emergency clear.
- 5. 1A DG seized on startup.
- 6. Bus 141 was successfully cross tied to bus 241 in less than 10 minutes.
- 7. There are no Rad monitors alarming as a result of this event.
- 8. 34' Wind speed is 4.5 mph.
- 9. 34' Wind direction is from 270°.

#### **INITIATING CUE**

- 1. You are the Shift Emergency Director (SED).
- 2. Classify the event and fill out the NARS form for unit 1.
- 3. This is a **TIME CRITICAL JPM**. The time critical portion of this JPM begins once you have read and understand these conditions and the initiating cue.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

JPM Start Time:

STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number	
NOTE:	If the examinee does not go	to the cold table the wrong EAL w	rill be fo	ound.		
1	Determine the correct EAL Matrix.	<ul> <li>Refer to Braidwood Annex.</li> <li>Determine Cold Matrix is applicable.</li> </ul>				
NOTE:	EAL MA-1 would be applica	ble if the Hot Matrix is mistakenly u	used.			
*2	Determine EAL.	<ul> <li>Review classification against initial conditions given.</li> <li>Determines that EAL CU-1 loss of all but one AC source to emergency busses for 15 minutes or longer is applicable.</li> <li>Updates the team on current EAL.</li> </ul>				
NOTE:	NOTE: Once the examinee determines the EAL, the timing for the time critical portion ends. (expected completion time 5-7 minutes) Record the time the EAL was determined:					
*3	Critical time met.	Critical time met.				
, ,		Time EAL Determined - Start Time ≤ 15minutes				
		<u>&lt;</u> 15minutes				

		T			
STEP	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*4	Fill out the NARS Form.	Fill in the NARS form EP-MW- 114-100-F01:  Utility Message No: 1  State Message No: N/A  Status – [B] Drill/Exercise  Station – [A] Braidwood  Consite Condition – [A] Unusual Event  Accident Classified:  Time: Time recorded in note before JPM step 3.  Date: Todays date.  EAL #: CU1  Accident Terminated Date and Time: N/A  Release Status: [A] None  Type of Release: [A] Not Applicable  Wind Dir: 270  Wind Speed:  [A] is N/A  [B] 4.5 Miles/Hr  Recommended Actions: Utility Recommendation: None  Verified With: N/A  Approved By: Examinee  Signature			
CUE	The Shift Manager will verify the that completes this JPM.	form and complete the rest of the S	SED ac	ctions.	

JPM Stop Time:		
	<del></del>	 

### JPM SUMMARY

Operator's Name:		_ Emp. ID#:	
Job Title: ☐ EO	□RO □SRO □FS □ST	A/IA ☐ SRO Cert	
K/A Number and Im Suggested Testing Alternate Path: \( \subseteq \) Reference(s): EP-	3 Revision  Title: S-ZP-008 Classify/Reclass  Apportance: 2.4.38 4.0  Environment: Simulator or Cla  Yes ⊠No SRO Only: ⊠Ye		
<b>Actual Testing En</b>	vironment: ⊠ Simulator □	Control Room ☐ In-Plant ☐	Other
Testing Method:	☐ Simulate ☐ Perform		
Estimated Time to	Complete: 10 minutes	Actual Time Used: minute:	s
<b>EVALUATION SUN</b> Were all the Critica	MMARY: I Elements performed satisfacto	orily? □ Yes □ No	
	ormance was evaluated agains s JPM and has been determine		tisfactory
Comments:			
		,	
Evaluator's Name (Print):			
Evaluator's Signa	ture:	Date:	

# Braidwood INITIAL CONDITIONS

- 1. Unit 1 is defueled.
- 2. Bus 142 is OOS for the next 24 hours for a scheduled maintenance window.
- 3. Unit 1 SATs just de-energized due to a switchyard fault on unit 1.
- 4. The SAT fault will take 2 hours to emergency clear.
- 5. 1A DG seized on startup.
- 6. Bus 141 was successfully cross tied to bus 241 in less than 10 minutes.
- 7. There are no Rad monitors alarming as a result of this event.
- 8. 34' Wind speed is 4.5 mph.
- 9. 34' Wind direction is from 270°.

#### **INITIATING CUE**

- 1. You are the Shift Emergency Director (SED).
- 2. Classify the event and fill out the NARS form for unit 1.
- 3. This is a **TIME CRITICAL JPM**. The time critical portion of this JPM begins once you have read and understand these conditions and the initiating cue.

SRRS: 3D.100; There are no retention requirements for this section