



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 3, 2016

Mr. Charles R. Pierce
Regulatory Affairs Director
Southern Nuclear Operating Company, Inc.
P.O. Box 1295, Bin 038
Birmingham, AL 35201-1295

SUBJECT: VOGTLE ELECTRIC GENERATING PLANT, UNIT 2 – CORRECTION TO
TECHNICAL SPECIFICATION PAGE FOR AMENDMENT NO. 164
RE: ISSUANCE OF AMENDMENT FOR 2B NUCLEAR SERVICE COOLING
WATER TRANSFER PUMP (CAC NO. MF8274)

Dear Mr. Pierce:

By letter dated October 31, 2016 (Agencywide Documents Access and Management System Accession No. ML16265A162), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 164 to Renewed Facility Operating License No. NPF-81 for the Vogtle Electric Generating Plant, Unit 2. Revised Technical Specification (TS) page 3.7.9-2 contained a typographical error. Specifically, the error consisted of the omission of "Amendment No. 179 (Unit 1)" at the bottom right of the page. Also, a change bar should have appeared after "Amendment No. 164 (Unit 2)" at the bottom right of the page.

This was an administrative error on the part of the NRC. The correction does not change any of the NRC staff's conclusions in the safety evaluation associated with the license amendment or the no significant hazards consideration determination as published in the *Federal Register*.

A corrected TS page 3.7.9-2 is enclosed. We apologize if this error has caused any inconvenience.

Sincerely,


Bob Martin, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-425

Enclosure:
Corrected TS page 3.7.9-2

cc w/enclosure: Distribution via Listserv

ENCLOSURE

**Corrected TS page 3.7.9-2 for Vogtle Electric Generating Plant, Unit 2
for Amendment No. 164 dated October 31, 2016**

ACTIONS (continued)

CONDITION	REQUIRED ACTION	COMPLETION TIME
<p>D. One NSCW basin transfer pump inoperable.</p>	<p>D.1 Restore the transfer pump to OPERABLE status.</p> <p><u>OR</u></p> <p>D.2.1 Implement an alternate method of basin transfer.</p> <p><u>AND</u></p> <p>D.2.2 Restore the transfer pump to OPERABLE status.</p>	<p>8 days</p> <p>8 days</p> <p>-----NOTE----- A one-time only change of the Completion Time to 46 days is permitted for the 2B NSCW transfer pump refurbishment during Vogtle Unit 2, Cycle 19. The increased Completion Time is applicable only to the 2B NSCW transfer pump. -----</p> <p>31 days</p>
<p>E. Required Action and associated Completion Time not met.</p> <p><u>OR</u></p> <p>UHS inoperable for reasons other than Conditions A, B, C, or D.</p>	<p>E.1 Be in MODE 3.</p> <p><u>AND</u></p> <p>E.2 -----NOTE----- LCO 3.0.4.a is not applicable when entering MODE 4. -----</p> <p>Be in MODE 4.</p>	<p>6 hours</p> <p>12 hours</p>

November 3, 2016

Mr. Charles R. Pierce
Regulatory Affairs Director
Southern Nuclear Operating Company, Inc.
P.O. Box 1295, Bin 038
Birmingham, AL 35201-1295

SUBJECT: VOGTLE ELECTRIC GENERATING PLANT, UNIT 2 – CORRECTION TO
TECHNICAL SPECIFICATION PAGE FOR AMENDMENT NO. 164
RE: ISSUANCE OF AMENDMENT FOR 2B NUCLEAR SERVICE COOLING
WATER TRANSFER PUMP (CAC NO. MF8274)

Dear Mr. Pierce:

By letter dated October 31, 2016 (Agencywide Documents Access and Management System Accession No. ML16265A162), the U.S. Nuclear Regulatory Commission (NRC) issued Amendment No. 164 to Renewed Facility Operating License No. NPF-81 for the Vogtle Electric Generating Plant, Unit 2. Revised Technical Specification (TS) page 3.7.9-2 contained a typographical error. Specifically, the error consisted of the omission of “Amendment No. 179 (Unit 1)” at the bottom right of the page. Also, a change bar should have appeared after “Amendment No. 164 (Unit 2)” at the bottom right of the page.

This was an administrative error on the part of the NRC. The correction does not change any of the NRC staff’s conclusions in the safety evaluation associated with the license amendment or the no significant hazards consideration determination as published in the *Federal Register*.

A corrected TS page 3.7.9-2 is enclosed. We apologize if this error has caused any inconvenience.

Sincerely,
/RA/
Bob Martin, Senior Project Manager
Plant Licensing Branch II-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-425

Enclosure:
Corrected TS page 3.7.9-2

cc w/enclosure: Distribution via Listserv

DISTRIBUTION:

PUBLIC	LPL2-1 R/F
RidsACRS_MailCTR Resource	RidsNrrPMVogtle Resource
RidsNrrDorLpl2-1 Resource	RecordsAmend Resource
RidsNrrDssStsb Resource	RidsNrrLALRonewicz Resource
RidsRgn2MailCenter Resource	

ADAMS Accession No.: ML16308A225

OFFICE	DORL/LPL2-1/PM	DORL/LPL2-1/LA	DORL/LPL2-1/BC	DORL/LPL2-1/PM
NAME	BMartin	LRonewicz	MMarkley	BMartin
DATE	11/03/16	11/03/16	11/03/16	11/03/16

OFFICIAL RECORD COPY