

1717 Wakonade Drive
Welch, MN 55089

800.895.4999
xcelenergy.com



NOV 04 2016

L-PI-16-089
10 CFR 21.21(a)(2)

ATTN: Document Control Desk
U.S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Prairie Island Nuclear Generating Plant, Unit 1
Docket No. 50-282
Renewed Facility Operating License No. DPR-42

Interim Report of a Deviation or Failure to Comply

Pursuant to 10 CFR 21.21(a)(2), Northern States Power Company, a Minnesota Corporation, (NSPM), doing business as Xcel Energy, hereby submits this interim report.

The deviation to be evaluated is the failed bench test of a Clark Relay Model 4U3-130. The relay has been sent to the vendor for evaluation.

If there is any question or if additional information is needed, please contact Frank Sienczak, at 651-267-1740.

Summary of Commitments

This letter makes no new commitments and no revisions to existing commitments.

A handwritten signature in black ink, appearing to read 'Scott Northard', written in a cursive style.

Scott Northard
Site Vice President, Prairie Island Nuclear Generating Plant
Northern States Power Company – Minnesota

cc: Administrator, Region III, USNRC
Project Manager, Prairie Island, USNRC
Resident Inspector, Prairie Island, USNRC