

**NRC DISTRIBUTION FOR PART 50 DOCKET MATERIAL.  
(TEMPORARY FORM)**

CONTROL NO: 550

FILE: \_\_\_\_\_

FROM: Pacific Gas & Elec. Co. San Francisco, Calif. 94106 Philip A. Crane		DATE OF DOC 1-14-76	DATE REC'D 1-20-76	LTR XX	TWX	RPT	OTHER
TO: Mr. O. Parr		ORIG 1 signed	CC	OTHER	SENT NRC PDR <u>XX</u>		SENT LOCAL PDR <u>XXX</u>
CLASS	UNCLASS XXX	PROP INFO	INPUT	NO CYS REC'D 1	DOCKET NO: <u>50-275/323</u>		

DESCRIPTION: Ltr re our 8-7-75 ltr....furn info on postulated beaks in "non seismic" piping systems....

ENCLOSURES:

**Do Not Remove  
ACKNOWLEDGED**

PLANT NAME: Diablo Canyon 1 & 2

<u>SAFETY</u>	<u>FOR ACTION/INFORMATION</u>	<u>ENVIRO</u>	<u>DHL 1-23-76</u>
ASSIGNED AD _____	ASSIGNED BRANCH CHIEF _____	PROJECT MANAGER _____	
<input checked="" type="checkbox"/> BRANCH CHIEF <u>PARR (4)</u>	LIC ASST. _____ W/ _____ ACRS		
<input checked="" type="checkbox"/> PROJECT MANAGER <u>ALLISON</u>			
<input checked="" type="checkbox"/> LIC. ASST. <u>GOULBOURNE</u> W/ <u>16</u> CYS ACRS			

**INTERNAL DISTRIBUTION**

<input checked="" type="checkbox"/> <u>REG FILES (2)</u>	<u>SYSTEMS SAFETY</u>	<u>PLANT SYSTEMS</u>	<u>SITE SAFETY &amp; ENVIRO ANALYSIS</u>
<input checked="" type="checkbox"/> NRC PDR(2)	HEINEMAN	<input checked="" type="checkbox"/> EDESCO	DENTON
OELD	SCHROEDER	<input checked="" type="checkbox"/> BENAROYA	MULLER.
GOSSICK/STAFF		LAINAS	<u>ENVIRO TECH.</u>
I&E (2)	<u>ENGINEERING</u>	IPPOLITO	ERNST
MLPC	MACCARY		BALLARD
<u>PROJECT MANAGEMENT</u>	KNIGHT	<u>OPERATING REACTORS</u>	SPANGLER
<input checked="" type="checkbox"/> BOYD	SIHWEIL	<input checked="" type="checkbox"/> STELLO	<u>SITE TECH.</u>
P. COLLINS	PAWLICKI		GAMMILL
HOUSTON		<u>OPERATING TECH.</u>	STEPP
PETERSON	<u>REACTOR SAFETY</u>	EISENHUT	HULMAN
MELTZ	<input checked="" type="checkbox"/> ROSS	SHAO	
HELTEMES	NOVAK	BAER	<u>MISCELLANEOUS</u>
	ROSETOCZY	SCHWENCER	
	CHECK	GRIMES	

**EXTERNAL DISTRIBUTION**

LOCAL PDR San Luis Obispo, Calif. NATIONAL LAB \_\_\_\_\_ W/ CYS  
 REGION V-I&E-(WALNUT CREEK) BROOKHAVEN NAT. LAB  
 TIC ULRIKSON (ORNL)  
 NSIC  
 ASLB LA PDR  
 CONSULTANTS

*9/18*



... ..  
... ..  
... ..

... ..

... ..

... ..  
... ..  
... ..

... ..  
... ..

... ..

... ..

... ..


# Regulatory Docket File

## PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY  
VICE PRESIDENT AND GENERAL COUNSEL  
MALCOLM H. FURBUSH  
ASSOCIATE GENERAL COUNSEL  
CHARLES T. VAN DEUSEN  
MALCOLM A. MACKILLOP  
PHILIP A. CRANE, JR.  
HENRY J. LAPLANTE  
RICHARD A. CLARKE  
JOHN B. GIBSON  
ASSISTANT GENERAL COUNSEL

January 14, 1976



NOEL KELLY  
EDWARD J. MCGANNEY  
ARTHUR L. HILLMAN, JR.  
ROBERT CHURCH  
DAN DRAYSON LUSBECK  
SENIOR COUNSEL

GILBERT L. HARRICK  
GLENN WEST, JR.  
CHARLES W. THIBELL  
DANIEL S. GIBSON

JOSEPH F. KELLY  
JACK F. FALLIN, JR.  
DONALD L. FREITAS  
JOSEPH R. ENGLEY, JR.  
ROBERT L. BORDON  
KATHY GRAHAM  
IVOR C. SAMSON  
ROBERT R. RIDDEY  
ROBERT N. SCHIFF  
F. RONALD LAUPHEIMER  
KERMIT R. KUBITZ  
JAMES A. KAYLOR  
THEODORE L. LINDBERG, JR.  
ATTORNEYS

BERNARD J. DELLASANTA  
HOWARD V. GOLUB  
JAMES G. BOSSDORF  
LOUIS F. SCHOFIELD  
DENNIS C. SULLIVAN  
ROBERT L. HARRIS  
J. PETER BAUMGARTNER  
JACK W. SHUCK  
RICHARD L. HEISS  
ANNETTE GREEN  
BRUCE R. WORTHINGTON  
DAVID J. WILLIAMSON  
SHIRLEY WOOD

Mr. Olan D. Parr, Chief  
Light Water Reactors  
Project Branch 1-3  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Re: Dockets 50-275-01  
50-323-01  
Diablo Canyon Site  
Units 1 and 2



Dear Mr. Parr:


Item 3.53 (5) of the request for additional information transmitted with your letter dated August 7, 1975 asked that we discuss further the effect on the auxiliary feedwater system of postulated breaks in "non-seismic" piping systems, as described in the report entitled, "Jet Effects Analysis of Postulated Pipe Break Outside Containment at Diablo Canyon Unit 1", dated April 15, 1975. We believe that the discussion contained in this letter should respond to the Regulatory Staff's request.

The "non-seismic" piping systems which are referred to in the request are auxiliary steam lines which are referred to in the request are auxiliary steam lines which are routed through the space occupied by the auxiliary feedwater pumps. These auxiliary steam lines supply steam to non-safety related equipment which is not located in the auxiliary feedwater pump compartment. As shown in Chapter 3 of the Diablo Canyon Final Safety Analysis Report, these lines are classified Design Class II and were designed, erected, and tested in accordance with the requirements of ANSI B31.1 (1967). The design criteria for these lines did not include the requirement that the lines remain functional following Double Design Earthquake (DDE) loadings.

We have evaluated the requirements for auxiliary feedwater system operability in the event of postulated breaks in the auxiliary steam lines in question. The results of this evaluation are as follows:

1. A postulated break in an auxiliary steam line in the auxiliary feedwater pump compartment would not automatically initiate a turbine or reactor trip and would not require immediate action to shut down the unit. Upon detection

1154



1154

1154

Main body of the document containing multiple lines of text, which is extremely faint and illegible due to the quality of the scan.

of such a break, the auxiliary steam lines could be isolated by closing manual isolation valves. Access to these valves would not be affected by the postulated break. The unit could continue to operate subject to the Technical Specification limits on the operability of the auxiliary feedwater pumps. If operability of all three auxiliary feedwater pumps can be demonstrated, shutdown of the unit would not be required. Even if the postulated auxiliary steam line break affects auxiliary feedwater pump operability, the unit can be shut down in an orderly manner.

2. In order to place the unit in the cold shutdown condition, it is necessary to provide makeup to the secondary system until the primary system is cooled down and depressurized sufficiently for the RHR system to be used. This can be accomplished using any one of the auxiliary feedwater pumps or, alternately, by the condensate and feedwater system, using a condensate pump, condensate booster pump, and feedwater pump combination.

We have analyzed in more detail the effect of postulated auxiliary steam line breaks on components of the auxiliary feedwater system, using the methodology given in the report, "Jet Effects Analysis of Postulated Pipe Break Outside Containment at Diablo Canyon Unit 1." The results of this analysis show the following effects on auxiliary feedwater system components:

1. Postulated auxiliary steam line breaks in the immediate vicinity of the motor-driven auxiliary feedwater pumps could result in environmental conditions at the pump motors such that long-term operability of the motor-driven pumps cannot be assured.
2. For a break postulated to occur at any location in an auxiliary steam line, the steam turbine driven auxiliary feed pump would remain operable. Since some auxiliary steam line break locations could result in ambient temperatures at pump bearings somewhat higher than the manufacturer's recommended maximum, the pump bearing design is being revised to make use of auxiliary feedwater as the bearing cooling medium rather than ambient air. This modification will provide further assurance of long-term pump operability.



11-11-61

11-11-61

[The body of the document contains several paragraphs of extremely faint, illegible text. The text is scattered across the page and appears to be a series of lines or a list of items that have been lost due to the quality of the scan. No specific words or phrases can be discerned.]

Mr. Olan D. Parr

3

January 14, 1976

The Design Class II auxiliary steam lines routed within the space occupied by the auxiliary feedwater pumps have been seismically analyzed using the same methods of analysis employed for Design Class I piping. The results of this analysis show that stresses in these lines for DDE loading conditions are in all cases less than allowable stress values for Design Class I piping. This demonstrates that pipe breaks in these lines would not be expected as a result of the occurrence of the Double Design Earthquake.

The report, "Jet Effects Analysis of Postulated Pipe Break Outside Containment at Diablo Canyon Unit 1", dated April 15, 1975, will be revised as soon as possible to incorporate the information contained in this letter.

Very truly yours,

Philip A. Grew, J

CC: ASLB  
Parties



1234

1. The first part of the document discusses the importance of maintaining accurate records. It emphasizes that without proper documentation, it is difficult to track progress and identify areas for improvement. This section also highlights the need for regular communication and collaboration between team members to ensure everyone is on the same page.

2. The second part of the document focuses on the challenges faced during the implementation phase. It notes that there were several obstacles, such as limited resources and a steep learning curve. However, through perseverance and a willingness to learn from mistakes, the team was able to overcome these challenges and achieve the desired results.

3. The final part of the document provides a summary of the key findings and conclusions. It states that the project was completed successfully and that the team has gained valuable experience and knowledge. The document concludes by expressing confidence in the team's ability to take on future challenges and achieve even greater success.

1234