

AEC DISTRIBUTION FOR PART 50 DOCKET MATERIAL
(TEMPORARY FORM)

CONTROL NO: 4921

FILE: *mis. of pl.*

FROM: Carolina Power & Light Company Raleigh, N. C. 27602 J. A. Jones		DATE OF DOC 5-31-74	DATE REC'D 6-3-74	LTR X	MEMO	RPT	OTHER
TO: Mr. O'Leary		ORIG 1 signed	CC	OTHER	SENT AEC PDR <u> </u> X SENT LOCAL PDR <u> </u> X		
CLASS UNCLASS	PROP INFO	INPUT	NO CYS REC'D 1		DOCKET NO: <u>50-324</u> 325		
DESCRIPTION: Ltr furnishing info concerning end of cycle scram reactivity..... <u>DIST PER POWELL</u>				ENCLOSURES: Do Not Remove ACKNOWLEDGED			
PLANT NAME: Brunswick Units 1 & 2		FOR ACTION/INFORMATION		6-6-74	AB		

- | | | | |
|---------------------------|---------------------------|----------------------------|-----------------------|
| ✓ BUTLER(L)
W/ 2Copies | SCHWENCER(L)
W/ Copies | ZIEMANN(L)
W/ Copies | REGAN(E)
W/ Copies |
| CLARK(L)
W/ Copies | STOLZ(L)
W/ Copies | DICKER(E)
W/ Copies | W/ Copies |
| PARR(L)
W/ Copies | VASSALLO(L)
W/ Copies | KNIGHTON(E)
W/ Copies | W/ Copies |
| KNIEL(L)
W/ Copies | PURPLE (L)
W/ Copies | YOUNGBLOOD(E)
W/ Copies | W/ Copies |

INTERNAL DISTRIBUTION

- | | | | | |
|--|---|---|---|---|
| ✓ <u>REG FILE(2)</u>
AEC PDR (2)
OGC, ROOM P-506A
MUNTZING/STAFF
CASE
GIAMBUSO
BOYD
MOORE (L)(BWR)
DEYOUNG(L)(PWR)
SKOVHOLT (L)
GOLLER(L)
P. COLLINS
DENISE
REG OPR
✓ FILE & REGION(3)
MORRIS | <u>TECH REVIEW</u>
HENDRIE
SCHROEDER
MACCARY
KNIGHT
PAWLICKI
SHAO
STELLO
HOUSTON
✓ NOVAK
✓ ROSS
✓ IPPOLITO
TEDESCO
LONG
LAINAS
BENAROYA
VOLLMER | DENTON
GRIMES
GAMMILL
KASTNER
BALLARD
SPANGLER

<u>ENVIRO</u>
MULLER
DICKER
KNIGHTON
YOUNGBLOOD
REGAN
PROJECT LDR

HARLESS | <u>LIC ASST</u>
DIGGS (L)
GEARIN (L)
GOULBOURNE (L)
LEE (L)
✓ MAIGRET (L)
REED (E)
SERVICE (L)
SHEPPARD (L)
SLATER (E)
SMITH (L)
TEETS (L)
WADE (E)
WILLIAMS (E)
WILSON (L) | <u>A/T IND</u>
BRAITMAN
SALTZMAN
B. HURT

<u>PLANS</u>
MCDONALD
DUBE w/Input

<u>INFO</u>
C. MILES
KLECKER
EISENHUT

<u>AOR FILE</u>
D. THOMPSON (2) |
|--|---|---|---|---|

EXTERNAL DISTRIBUTION

- | | | |
|--|---------------------------------|------------------------|
| ✓ 1 - LOCAL PDR <u>Southport, N. C.</u> | (1)(2)(10)-NATIONAL LAB'S | 1-PDR-SAN/LA/NY |
| ✓ 1 - TIC (ABERNATHY) | 1-ASLBP(E/W Bldg, Rm 529) | 1-GERALD LELLOUCHE |
| ✓ 1 - NSIC(BUCHANAN) | 1-W. PENNINGTON, Rm E-201 GT | BROOKHAVEN NAT. LAB |
| 1 - ASLB | 1-CONSULTANT'S | 1-AGMED(Ruth Gussman) |
| 1 - P. R. DAVIS (AEROJET NUCLEAR) | NEWMARK/BLUME/AGBABIAN | RM-B-127, GT. |
| ✓ 16 - CYS ACRS HOEDING SENT TO LIC ASST.
M. MAIGRET ON 6-6-74 | 1-GERALD ULRIKSON...ORNL | 1-RD..MULLER..F-309 GT |
| | 1-B & M SWINEBROAD, Rm E-201,GT | |

CB



Handwritten scribble or mark in the top right corner.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

Small handwritten mark or characters.

CP&L

Carolina Power & Light Company

May 31, 1974



Mr. John F. O'Leary
Directorate of Licensing
Office of Regulation
U. S. Atomic Energy Commission
Washington, D. C. 20545


RE: DOCKET NOS. 50-324 AND 50-325
END OF CYCLE SCRAM REACTIVITY

Dear Mr. O'Leary:

The General Electric Company (GE), through the use of improved analytical techniques and broader operational experience, has identified a change in the expected end of cycle reactivity for reload BWR cores. The operation of a BWR is such that the relative axial burnup is greater at the bottom of the core than at the top. As a result, the axial reactivity worth at the end of cycle is shifted upward for reload cores. In addition, toward the end of cycle, most of the control rods are fully withdrawn from the core. Thus, during initial control rod insertion, the scram reactivity rate is lower. The result of this lesser negative reactivity insertion rate is an increase in heat flux and reactor pressure during certain abnormal operating transients. The most limiting of these transients is turbine trip with failure of the bypass valves to operate.


GE has indicated that certain modifications will be necessary to resolve this issue as it applies to the Brunswick Steam Electric Plant (BSEP). The purpose of this letter is to provide information regarding CP&L action to be taken to resolve this issue to the satisfaction of the Regulatory Staff. Since this issue will not become a safety concern until the initial refueling outage of Unit 2, total resolution is not necessary for operation during the first cycle. The General Electric Company has been meeting with the AEC to generically resolve this issue and submittals to the AEC on both the GESSAR (STN-50-477) and Monticello (50-263) dockets have also been made. When the proposed resolutions have been finalized and prove satisfactory to the AEC, a complete analysis of the corrective action for Units 1 and 2 will be submitted to the Regulatory Staff.

Because of the economic impact of undertaking modifications after a plant has begun operation, it is CP&L's intention to complete certain work prior to plant startup. Two basic changes in hardware are intended to resolve this issue. These modifications involve safety/relief (S/R) valves and the addition of a prompt relief trip (PRT) system. The following provides a background on the changes that will be made and how details of the changes will be forwarded to the AEC.



336 Fayetteville Street • P. O. Box 1551 • Raleigh, N. C. 27602

4921



Safety/Relief Valves Modification

Safety/relief valve capacity will be increased to 830,000 lbs/hr at 103% of 1080 psig.

The safety valves will be removed and replaced by S/R valves. A total of 11 S/R valves will be installed on each unit.

CP&L intends to complete all work associated with modifying valve capacity and installation of the S/R valves before initial plant operation. This installation will allow all safety/relief valves to function in a manner identical to their present function, and the 11 valves will provide adequate vessel overpressure protection for the first cycle. The installation will not be affected by the new PRT system (discussed in detail below).

To verify that adequate protection during the first fuel cycle is provided by this modification, CP&L will submit a revised overpressure protection analysis for review by the Regulatory Staff by June 30, 1974.


Prompt Relief Trip System

The PRT system is part of the protective system and will not be implemented until the second cycle of Unit 2. The system opens S/R valves following a turbine trip with failure of bypass valves to open. CP&L will complete as much wiring as possible associated with the PRT within the drywell prior to plant startup, but the solenoids on the S/R valves will not be physically connected to PRT wires. The remaining wiring will be completed before or during the first refueling outage.

Before PRT is placed in service, documentation will be submitted covering all the necessary details of the system and analytical results of its implementation. This will be submitted before the initial refueling outage of Unit 2 on a review schedule that is agreeable to the Regulatory Staff.

The modifications mentioned, although not necessary for safety purposes during the first operating cycle, can be installed for operation during the first cycle with no risk to the safe operation of the plant nor to the health and safety of the public.

Yours very truly,



J. A. Jones
Executive Vice President

The first part of the document discusses the general principles of the system. It outlines the objectives and the scope of the project. The second part describes the methodology used in the study, including the data collection and analysis techniques. The third part presents the results of the study, and the fourth part discusses the conclusions and the implications of the findings.

The results of the study show that the system is effective in achieving its objectives. The data analysis indicates that there is a significant difference between the experimental and control groups. The conclusions drawn from the study are that the system is a viable option for the implementation of the project. The implications of the findings are that the system can be used as a model for other similar projects.

In conclusion, the study has shown that the system is effective in achieving its objectives. The data analysis indicates that there is a significant difference between the experimental and control groups. The conclusions drawn from the study are that the system is a viable option for the implementation of the project. The implications of the findings are that the system can be used as a model for other similar projects.

The study has shown that the system is effective in achieving its objectives. The data analysis indicates that there is a significant difference between the experimental and control groups. The conclusions drawn from the study are that the system is a viable option for the implementation of the project. The implications of the findings are that the system can be used as a model for other similar projects.