

Docket Nos. 50-275 ←
and 50-323

JAN 31 1974

APPLICANT: PACIFIC GAS AND ELECTRIC COMPANY (PG&E)

FACILITY: DIABLO CANYON UNITS 1 AND 2

SUMMARY OF MEETING HELD TO DISCUSS THE SAFETY CONCERNS OF THE STAFF RELATED TO THE DESIGN OF ELECTRICAL AND INSTRUMENTATION SYSTEMS PRESENTED IN THE DIABLO CANYON FSAR

A meeting between representatives of PG&E, Westinghouse, and the AEC was held in Bethesda on December 11, 1973. The purpose of the meeting was to discuss in detail certain sections of the FSAR related to Instrumentation & Controls and Electric Power. A list of attendees is given in Enclosure No. 1.

Before proceeding with the electrical discussions, PG&E and Westinghouse responded to questions regarding the submittal of revised FSAR chapters describing the new 17 x 17 fuel design to be utilized in the Diablo Canyon Units. Representatives of the Reactor Systems and Core Performance Branches indicated that Chapters 4 and 15 of the FSAR have been submitted for a 15 x 15 fuel design, and are not in the standard format. In addition, these chapters are not complete. PG&E, with the concurrence of Westinghouse, stated that revised Chapters 4 and 15 for the 17 x 17 fuel design would be submitted to the staff by March 1, 1974. This submittal will be in the standard format, Revision 1, and will contain essentially the same material as the latest revision of WCAP-8185, "Reference Core Report - 17 x 17". PG&E implied that some modifications of the information in the topical report may be made as required by differences in the Diablo Canyon design from the reference four loop plant. PG&E agreed that the review would be expedited if the staff concentrated their efforts on review of WCAP-8185, rather than on the current material in Chapters 4 and 15 of the Diablo Canyon FSAR.

The staff asked PG&E about the percentage of electrical completion on Unit 1 in regard to a future site visit. PG&E indicated that electrical work on Unit 1 was approximately 70-80% complete. The staff replied that, on this basis, a late-February or early-March site visit would probably be appropriate.

lg

OFFICE ▶						
SURNAME ▶						
DATE ▶						

Top section of the document, containing two circular marks and faint, illegible text.

Second section of the document, containing faint, illegible text.

Third section of the document, containing faint, illegible text.

Fourth section of the document, containing faint, illegible text.

Fifth section of the document, containing faint, illegible text.

Sixth section of the document, containing faint, illegible text.

Seventh section of the document, containing faint, illegible text.

Eighth section of the document, containing faint, illegible text.

Ninth section of the document, containing faint, illegible text.

Tenth section of the document, containing faint, illegible text.

Small handwritten mark or signature at the bottom left corner.

Several areas of the FSAR related to the design of Instrumentation and Control and Electric Power Systems were then covered in detail by the staff. On some items, the staff indicated that a formal question would be asked during the first round requests for additional information. In other areas, PG&E agreed to make voluntary changes in the FSAR.

The following is a tabulation of the voluntary changes agreed to by the applicant:

1. Section 3.1: In addition to indicating conformance with AEC General Design Criteria, PG&E will also provide documentation describing how the recommendations presented in the Regulatory Guides are included in the design.
2. Criterion 24, page 3.1-24: The wording in the second paragraph will be changed to indicate that the four diesels can supply the power required to bring the second unit to shutdown while the other unit is in an accident condition.
3. Chapter 6: PG&E will provide a complete description of the auxiliary feedwater control system since auxiliary feedwater has been identified as an Engineered Safety Feature.
4. Page 7.1-11: Item b. will be clarified to indicate that the initial discharge point for the safety injection pumps is the cold leg.
5. Page 7.1-15: The Section on separation criteria for circuits entering containment will be expanded to provide more information on the penetrations, e.g., layout, circuit identification, effects of single events.
6. Pages 7.2-8 through 7.2-10: References are made to two Westinghouse topical reports (WCAP-7671 and WCAP-7669); these reports are general descriptions of instrumentation systems and do not provide detailed functional descriptions. PG&E and Westinghouse will provide more detail in this area.
7. Page 7.2-15: The reference to Figure 7.2-1 in the third paragraph should be Sheet 16, not Sheet 7.
8. Page 7.2-24: The last paragraph refers to a Westinghouse topical report, WCAP-7486. This report discusses equipment which is not included in the Diablo Canyon design. This reference will be changed to reflect an analysis which is pertinent to the solid state (rather than the relay) logic system.

OFFICE ▶					
SURNAME ▶					
DATE ▶					

Faint, illegible text at the top of the page, possibly a header or introductory paragraph.

Second block of faint, illegible text, appearing as a separate paragraph.

Third block of faint, illegible text, continuing the document's content.

Fourth block of faint, illegible text, showing further detail or a list.

Fifth block of faint, illegible text, possibly a sub-section or a specific note.

Sixth block of faint, illegible text, continuing the main body of the document.

Seventh block of faint, illegible text, appearing as a distinct section.

Eighth block of faint, illegible text, possibly a concluding paragraph or a signature area.

Ninth block of faint, illegible text, located near the bottom of the page.

Tenth block of faint, illegible text at the very bottom of the page, possibly a footer or a reference.

- 9. Pages 7.2-36, 37: The discussion under Paragraph 6.2.2 of IEEE-336 will be modified to include a description of the design and factory testing which is the basis for reducing noise effects.
- 10. Page 8.1-3: IEEE-323 (1971) will be added to the list of Codes and Standards which were implemented.
- 11. Page 8.2-4: PG&E will provide a description of the 230 and 500 kV switchyard control systems and the power sources for these controls.
- 12. Page 8.3-17: PG&E will change the diesel engine low lube oil pressure shutdown function from an unconditional shutdown function to one which will provide an alarm to the operator if low oil pressure develops after an automatic start, and shutdown of the unit if low oil pressure develops after a manual start.
- 13. Page 8.3-26: A description will be provided of the caustic sprays which were used in the environmental qualification testing of equipment required to operate during a LOCA.
- 14. Page 8.3-26: Under the Section "Fill of Raceways", the wording will be changed to indicate that maximum fills for trays and conduits are 32 and 42%, respectively.
- 15. Page 8.3-28: The current design of the cable tray fire stops will be presented.
- 16. Page 8.4-1: Item 5 under d-c power systems design features will be reworded to indicate that the batteries and circuit breakers are also designed to Class IE requirements.

Other significant items discussed include the following:

- 1. Sizing of Transformers: PG&E agreed to check the sizing of the startup/standby transformers to define the limiting conditions of operation when one of the transformers is out of service. These limits will be defined in the Technical Specifications.
- 2. Transfer of Power Busses: The staff expressed concern about the delay in the transfer of the power busses, e.g., 2-3 seconds. PG&E stated that the actual transfer occurs at 25% of normal bus voltage. This item will be studied further during the drawing review.

3. CR

OFFICE ▶						
SURNAME ▶						
DATE ▶						

1. The first section of the document discusses the importance of maintaining accurate records of all transactions and activities. It emphasizes the need for transparency and accountability in all financial dealings.

2. The second section outlines the specific procedures for recording and reporting financial data. It details the required formats, frequencies, and review processes for all reports.

3. The third section addresses the responsibilities of the various departments and individuals involved in the financial reporting process. It clarifies the roles and expectations for each party.

4. The fourth section discusses the consequences of non-compliance with the reporting requirements. It outlines the disciplinary actions and legal implications for failure to adhere to the established procedures.

5. The fifth section provides a summary of the key points and reiterates the commitment to high standards of financial reporting and integrity.

6. The sixth section contains the concluding remarks and a statement of approval from the relevant authority.

7. The seventh section includes the date and signature of the official responsible for the document.

8. The eighth section provides additional information and contact details for further inquiries or assistance.

9. The ninth section contains the distribution list and the number of copies of the document.

10. The tenth section includes the names and titles of the individuals who reviewed and approved the document.

11. The eleventh section provides the final version of the document and its effective date.

JAN 31 1974

- 3. CO₂ Fire Protection System: PG&E agreed to provide more data on the design of the CO₂ fire protection system, and to investigate the potential effects of CO₂ flooding on electrical equipment.
- 4. Electrical Separation Criteria: PG&E provided additional description of their separation criteria. All safety wiring, where there is more than one train in an area, is run in separate conduits with a minimum separation of one inch. The separation of this wiring in equipment racks is at least five inches. Where conduit is run through potential missile areas, the minimum separation between conduits is two feet.
- 5. Protection System Drawings: The staff requested that all Westinghouse solid state protection system drawings be submitted on the Diablo Canyon docket. Westinghouse said they will comply with this request.

In summary, all areas of concern to the staff were covered in the meeting. No serious problems were noted in the electrical chapters, although the area of seismic testing and qualification of equipment (to be covered with a formal question) may present some difficulties for PG&E regarding conformance with IEEE 344-1971.

Thomas J. Hiron
 Light Water Reactors Group 1-3
 Directorate of Licensing

Enclosure:
 Attendance List

DISTRIBUTION:
 Docket (2)
 RP Reading
 LWR 1-3 Reading

cc w/encl:
 AEC PDR
 Local PDR
 RP Assistant Directors
 RP Branch Chiefs
 S. Varga
 R. W. Klecker
 J. M. Hendrie
 TR Assistant Directors
 TR Branch Chiefs
 R. Cushman
 L. Chandler, OGC
 RO (3)
 V. H. Wilson
 Meeting Attendees from REG

R. Fraley, AGRS (16)					
OFFICE ▶	L: LWR 1-3	TR: I&CS			
SURNAME ▶	x7415 TJH TJHiron:esp	D. McDonald			
DATE ▶	1/31/74	1/31/74			

1950

...

...

...

...

...

...

ENCLOSURE NO. 1

ATTENDANCE LIST

PACIFIC GAS AND ELECTRIC COMPANY

J. B. Hoch
D. Nielsen
R. A. Young
L. Wilson

WESTINGHOUSE

A. J. Abels
J. W. Dorrycott
J. C. Mesmeringer

AEC - LICENSING

Projects

T. J. Hiron

Electrical Instrumentation & Control Systems Branch

D. R. Lasher*
D. McDonald
C. F. Miller
R. Scholl
L. Weintraub*

Core Performance Branch

G. E. Bailey*
P. M. Wood*

Reactor Systems Branch

G. Sullivan*

Operational Safety Branch

J. R. Sears*

* Denotes part-time attendance

OFFICE ▶						
SURNAME ▶						
DATE ▶						



1
 2
 3
 4
 5
 6
 7
 8
 9
 10
 11
 12
 13
 14
 15
 16
 17
 18
 19
 20
 21
 22
 23
 24
 25
 26
 27
 28
 29
 30
 31
 32
 33
 34
 35
 36
 37
 38
 39
 40
 41
 42
 43
 44
 45
 46
 47
 48
 49
 50
 51
 52
 53
 54
 55
 56
 57
 58
 59
 60
 61
 62
 63
 64
 65
 66
 67
 68
 69
 70
 71
 72
 73
 74
 75
 76
 77
 78
 79
 80
 81
 82
 83
 84
 85
 86
 87
 88
 89
 90
 91
 92
 93
 94
 95
 96
 97
 98
 99
 100

101
 102
 103
 104
 105
 106
 107
 108
 109
 110
 111
 112
 113
 114
 115
 116
 117
 118
 119
 120
 121
 122
 123
 124
 125
 126
 127
 128
 129
 130
 131
 132
 133
 134
 135
 136
 137
 138
 139
 140
 141
 142
 143
 144
 145
 146
 147
 148
 149
 150
 151
 152
 153
 154
 155
 156
 157
 158
 159
 160
 161
 162
 163
 164
 165
 166
 167
 168
 169
 170
 171
 172
 173
 174
 175
 176
 177
 178
 179
 180
 181
 182
 183
 184
 185
 186
 187
 188
 189
 190
 191
 192
 193
 194
 195
 196
 197
 198
 199
 200

201
 202
 203
 204
 205
 206
 207
 208
 209
 210
 211
 212
 213
 214
 215
 216
 217
 218
 219
 220
 221
 222
 223
 224
 225
 226
 227
 228
 229
 230
 231
 232
 233
 234
 235
 236
 237
 238
 239
 240
 241
 242
 243
 244
 245
 246
 247
 248
 249
 250

251
 252
 253
 254
 255
 256
 257
 258
 259
 260
 261
 262
 263
 264
 265
 266
 267
 268
 269
 270
 271
 272
 273
 274
 275
 276
 277
 278
 279
 280
 281
 282
 283
 284
 285
 286
 287
 288
 289
 290
 291
 292
 293
 294
 295
 296
 297
 298
 299
 300