



Entergy Nuclear Operations, Inc.
Palisades Nuclear Plant
27780 Blue Star Memorial Highway
Covert, MI 49043
Tel 269 764 2000

Jeffery A. Hardy
Regulatory Assurance Manager

PNP 2016-062

10 CFR 72.212(b)(2)

November 14, 2016

Document Control Desk
Director, Division of Spent Fuel Management
Office of Nuclear Material Safety and Safeguards
U. S. Nuclear Regulatory Commission
Washington, DC 20555-0001

Subject: Registration of Holtec HI-STORM FW System Casks


Palisades Nuclear Plant
Dockets 50-255 and 72-7
License No. DPR-20

Dear Sir or Madam:

In accordance with the requirements of 10 CFR 72.212(b)(2), Entergy Nuclear Operations, Inc. is providing the attached information to register the use of approved spent fuel storage casks at the Palisades Nuclear Plant Independent Spent Fuel Storage Installation (ISFSI).

This letter contains no new commitments and no revisions to existing commitments.

Sincerely,


Terry Davis

JAH/bed

Attachment: Cask Registration Information

CC Administrator, Region III, USNRC
Project Manager, Palisades, USNRC
Resident Inspector, Palisades, USNRC

**ATTACHMENT
CASK REGISTRATION INFORMATION**

Licensee's Name: Entergy Nuclear Operations, Inc.

Licensee's Address: 27780 Blue Star Memorial Highway
Covert, MI 49043

Reactor License Number: DPR-20

Reactor Docket No.: 50-255

ISFSI Docket No.: 72-7

Cask Certificate No.: 1032, Amendment 1, Rev 1

Cask Model No.: HI-STORM FW MPC Storage System

Contact: Tim Crocker
Sr. Project Manager
(269) 764-2856

MPC Serial Number	MPC Unit ID Number	HI-STORM Serial Number	HI-STORM Unit ID Number	MPC Aggregate Heat Load	Placed in Service
MPC-37-023	MPC-37-01	HISTORM-037	HISTORM-01	23.68 kW	10/25/2016
MPC-37-024	MPC-37-02	HISTORM-036	HISTORM-02	26.38 kW	10/29/2016
MPC-37-025	MPC-37-03	HISTORM-035	HISTORM-03	27.57 kW	11/04/2016
MPC-37-026	MPC-37-04	HISTORM-038	HISTORM-04	28.61 kW	11/11/2016