



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

November 21, 2016

LICENSEE: FirstEnergy Nuclear Operating Company

FACILITY: Perry Nuclear Power Plant, Unit 1

SUBJECT: SUMMARY OF NOVEMBER 9, 2016, PUBLIC TELECONFERENCE CALL WITH FIRSTENERGY NUCLEAR OPERATING COMPANY REGARDING UPCOMING PERRY NUCLEAR POWER PLANT, UNIT 1 LICENSE AMENDMENT REQUEST TO REVISE TECHNICAL SPECIFICATIONS TO SUPPORT IMPLEMENTATION OF ALTERNATE SOURCE TERM AMENDMENT (CAC NO. MF8502)

The U.S. Nuclear Regulatory Commission (NRC) conducted a Category 1 public teleconference call with representatives of FirstEnergy Nuclear Operating Company (FENOC, the licensee) on November 9, 2016. The purpose of the call was to discuss Perry Nuclear Power Plant, Unit 1's upcoming license amendment request (LAR) to revise certain technical specifications (TSs) in support of implementation of the alternate source term (AST) amendment that was issued in March 2015 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML15075A139). A list of attendees is enclosed.

The meeting notice can be found in ADAMS under Accession No. ML16302A035. The meeting notice is also posted on the NRC public website.

Summary of Teleconference Call:

On November 9, 2016, staff from the NRC conducted a public teleconference call with representatives from FENOC to discuss an upcoming LAR to revise certain TSs to support implementation of the AST amendment.

During the teleconference call, FENOC described the changes it plans to request for certain TSs and the basis for the changes. Below is a list the proposed changes as discussed during the call.

- References to "movement of recently irradiated fuel assemblies" will be deleted from the following TSs:
 - TS 3.3.6.1, "Primary Containment and Drywell Isolation Instrumentation"
 - TS 3.3.7.1, "CRER System Instrumentation"
 - TS 3.6.1.2, "Primary Containment Air Locks"
 - TS 3.6.1.3, "Primary Containment Isolation Valves (PCIVs)"
 - TS 3.6.1.10, "Primary Containment-Shutdown"
 - TS 3.6.1.11, "Containment Vacuum Breakers"
 - TS 3.6.1.12, "Containment Humidity Control"
 - TS 3.6.4.1, "Secondary Containment"
 - TS 3.6.4.2, "Secondary Containment Isolation Valves (SCIVs)"
 - TS 3.6.4.3, "Annulus Exhaust Gas Treatment (AEGT) System"

- TS 3.7.3, "Control Room Emergency Recirculation (CRER) System"
 - TS 3.7.4, "Control Room Heating, Ventilating and Air Conditioning (HVAC) System"
 - TS 3.8.2, "AC Sources-Shutdown"
 - TS 3.8.5, "DC Sources-Shutdown"
 - TS 3.8.8, "Distribution Systems-Shutdown"
- The following TS will be revised to increase the allowable secondary containment bypass leakage rate:
 - TS 3.6.1.3, "Primary Containment Isolation Valves (PCIVs)"
 - The following TSs will be revised to change the runtime requirements:
 - TS 3.6.4.3, "Annulus Exhaust Gas Treatment (AEGT) System"
 - TS 3.7.3, "Control Room Emergency Recirculation (CRER) System"
 - The following TSs will be deleted because they are no longer necessary:
 - TS 3.7.8, "Fuel Handling Building"
 - TS 3.7.9, "Fuel Handling Building Ventilation Exhaust System"
 - The following TS will be added (new):
 - TS 3.9.10, "Decay Time"
 - The following TS will be revised to remove references to the fuel handling building as well as to increase the relative humidity value for the charcoal adsorber:
 - TS 5.5.7, "Ventilation Filter Testing Program"

The NRC staff asked clarifying questions about the proposed LAR regarding whether any additional changes are being made to AST methodology, if the environmental qualification of any electrical equipment is affected, and the safety qualification and future testing of the fuel handling building ventilation exhaust system. FENOC answered the staff's questions during the teleconference call.

No regulatory decisions or commitments were made during the meeting. The public was invited to participate in the call and was given an opportunity to communicate with the NRC before the call ended. The NRC staff received no public comments and no meeting feedback forms were received.

- 3 -

Please direct any inquiries to me at 301-415-1627, or Kimberly.Green@nrc.gov.

A handwritten signature in black ink that reads "Kimberly Green". The signature is written in a cursive style with a large, stylized initial 'K'.

Kimberly Green, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

LIST OF ATTENDEES

NOVEMBER 9, 2016, PUBLIC TELECONFERENCE CALL WITH

FIRSTENERGY NUCLEAR OPERATING COMPANY

REGARDING PERRY NUCLEAR POWER PLANT, UNIT 1 LICENSE AMENDMENT REQUEST

TO REVISE TECHNICAL SPECIFICATIONS TO IMPLEMENT THE ALTERNATE SOURCE

TERM

<u>Name</u>	<u>Affiliation</u>
Kimberly Green	U.S Nuclear Regulatory Commission (NRC)
Ravi Grover	NRC
Alex Chereskin	NRC
Larry Wheeler	NRC
Shavon Edmonds	NRC
Jerry Bettle	NRC
Diana Woodyatt	NRC
Scott Krepel	NRC
John Parillo	NRC
Cal Heintz	FirstEnergy Nuclear Operating Company (FENOC)
Stanley Gorski	FENOC
David Mackovjak	FENOC
David Olderman	FENOC
Matthew Engle	FENOC
Walter Hilbish	FENOC
Tom Lentz	FENOC
Phil Lashley	FENOC

Enclosure

Please direct any inquiries to me at 301-415-1627, or Kimberly.Green@nrc.gov.

/RA/

Kimberly Green, Senior Project Manager
Plant Licensing Branch III-1
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Docket No. 50-440

Enclosure:
List of Attendees

cc w/encl: Distribution via Listserv

DISTRIBUTION:

PUBLIC	RidsNrrDssSbpb Resource	ACHereskin, NRR
Branch Reading	RidsNrrDssStsb Resource	LWheeler, NRR
RidsAcrs_MailCTR Resource	RidsNrrDssSrxb Resource	SEdmonds, NRR
RidsNrrDorLpl3-1 Resource	RidsNrrDssSnpb Resource	JBettle, NRR
RidsNrrPMPerry Resource	RidsNrrDeEsgb Resource	DWoodyatt, NRR
RidsNrrLASRohrer Resource	RidsNrrDeEeeb Resource	SKrepel, NRR
RidsOgcRp Resource	RidsNrrDraArcb Resource	JParillo, NRR
RidsRgn3MailCenter Resource	RGrover, NRR	

ADAMS Accession No. ML16321A005

OFFICE	DORL/LPL3-1/PM	DORL/LPL3-2/LA	DORL/LPL3-1/BC	DORL/LPL3-1/PM
NAME	KGreen	SRohrer	DWrona	KGreen
DATE	11/18/16	11/16/16	11/21/16	11/21/16

OFFICIAL RECORD COPY