

NRR-PMDAPem Resource

From: Klos, John
Sent: Wednesday, November 16, 2016 2:40 PM
To: Garcia, Richard M.
Cc: Klos, John
Subject: FW: EICB RAIs for Columbia MUR (CAC No. MF8060)

Dear Mr. Garcia,

By letter dated June 28, 2016, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16183A365), as supplemented by letter dated August 18, 2016 (ADAMS Accession No. ML16231A511), Energy Northwest submitted a license amendment for Columbia Generating Station (CGS). The proposed amendment would revise the operating license and technical specifications to implement an increase in rated thermal power from the current licenses thermal power of 3486 megawatts thermal (MWt) to a measurement uncertainty recapture thermal power of 3544 MWt.

The U.S. Nuclear Regulatory Commission (NRC) staff, specifically the Instrumentation and Controls Branch (EICB) in the Office of Nuclear Reactor Regulation, has reviewed the submittal and determined that the attached request for additional information (RAIs) are needed to complete its technical review and make a regulatory finding regarding this license amendment request.

Please see the formal RAIs below. A clarification call was held on November 16, 2016 to ensure your staff understood the RAIs. In the clarification call, Energy Northwest agreed to submit the response to the RAIs by Thursday Jan 5, 2017.

REQUEST FOR ADDITIONAL INFORMATION
MEASUREMENT UNCERTAINTY RECAPTURE POWER UPRATE
LICENSE AMENDMENT REQUEST
COLUMBIA GENERATING STATION
DOCKET NO. 50-397
CAC NO. MF8060

By letter dated June 28, 2016, (Agencywide Documents Access and Management System (ADAMS) Accession No. ML16183A365), as supplemented by letter dated August 18, 2016 (ADAMS Accession No. ML16231A511), Energy Northwest submitted a license amendment for Columbia Generating Station (CGS). The proposed amendment would revise the operating license and technical specifications (TS) to implement an increase in rated thermal power from the current licenses thermal power of 3486 megawatts thermal (MWt) to a measurement uncertainty recapture (MUR) thermal power of 3544 MWt.

The U.S. Nuclear Regulatory Commission (NRC) staff, specifically the Instrumentation and Controls Branch (EICB) in the Office of Nuclear Reactor Regulation, has reviewed the submittal and determined that the following request for additional information (RAIs) are needed to complete its technical review and make a regulatory finding regarding this license amendment request.

EICB-RAI 1

In TS 3.3.6.1, "Primary Containment Isolation Instrumentation," Table 3.3.6.1-1, "Primary Containment Isolation Instrumentation Function," Function 1.c "Main Steam Line Flow – High" is being revised from an

Allowable Value of ≤ 124.4 pounds per square inch – differential (psid) to ≤ 137.9 psid. This change is being made due to the increased steam flow at the MUR power level.

In Section 5.3.5, "Main Steam Line High Flow Isolation," of Enclosure 7 to the application, General Electric-Hitachi (GEH) Report NEDC-33853P, "Safety Analysis Report for Columbia Generating Station Thermal Power Optimization," Revision 0 (proprietary), the licensee states that the Analytical Limit of 140% was not changed but the Allowable Value (AV) for this function was recalculated using the GEH methodology and a TS AV change is required to change the differential pressure at the allowable steam flow.

In Section 2.5 of the application, the licensee proposes to revise the AV for Main Steam Line Flow-High from a current value of ≤ 124.4 psid to ≤ 137.9 psid.

In order to meet the requirements of Title 10 of the *Code of Federal Regulations* 50.36, "Technical specifications," and Regulatory Guide 1.105, "Setpoints for Safety-related Instrumentation," Revision 3, dated December 1999, please provide a summary of the calculation used to calculate the revised AV on the docket.

Thank you,

John Klos

DORL Callaway, Columbia Project Manager

U.S. NRC, Office of Nuclear Reactor Regulation,

Division of Operating Reactor Licensing, O8E7

NRC/NRR/DORL/LPL4-1, MS O8H4A

Washington, DC 20555-0001

301.415.5136, 301.415.2102 (fax)

John.Klos@NRC.gov

Hearing Identifier: NRR_PMDA
Email Number: 3164

Mail Envelope Properties (161fcad861cd4d73b22b3ce42c9e2ff1)

Subject: FW: EICB RAIs for Columbia MUR (CAC No. MF8060)
Sent Date: 11/16/2016 2:40:25 PM
Received Date: 11/16/2016 2:40:26 PM
From: Klos, John

Created By: John.Klos@nrc.gov

Recipients:
"Klos, John" <John.Klos@nrc.gov>
Tracking Status: None
"Garcia, Richard M." <rmgarcia@energy-northwest.com>
Tracking Status: None

Post Office: HQPWMSMRS05.nrc.gov

Files	Size	Date & Time
MESSAGE	4050	11/16/2016 2:40:26 PM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: