



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**

REGION III
2443 WARRENVILLE RD. SUITE 210
LISLE, IL 60532-4352

November 18, 2016

Mr. Keith J. Polson
Site Vice President
DTE Electric Company
6400 North Dixie Highway
Newport, MI 48166

SUBJECT: NRC INSPECTION REPORT 05000016/2016008(DNMS) - ENRICO
FERMI ATOMIC POWER PLANT, UNIT 1

Dear Mr. Polson:

On November 3, 2016, the U.S. Nuclear Regulatory Commission (NRC) completed an inspection at the Enrico Fermi Atomic Power Plant, Unit 1 (Fermi 1). The purpose of the inspection was to determine whether decommissioning activities were conducted safely and in accordance with NRC requirements. At the conclusion of the inspection on November 3, the NRC inspector discussed the inspection results with members of your staff.

The inspection consisted of an examination of activities at the facility as they relate to safety and compliance with the Commission's rules and regulations. Areas examined during the inspection included facility management and control and radiological safety. Within these areas, the inspection consisted of a selective examination of procedures and representative records, field observations of activities in progress, and interviews with personnel.

Based on the results of this inspection, the NRC did not identify any violations.

In accordance with Title 10 of the *Code of Federal Regulations* (CFR) 2.390, "Public Inspections, Exemptions, Requests for Withholding," of the NRC's "Rules of Practice," a copy of this letter and its enclosure will be available electronically for public inspection in the NRC's Public Document Room or from the Publicly Available Records System (PARS) component of NRC's Agencywide Documents Access and Management System (ADAMS). ADAMS is accessible from the NRC's web site at <http://www.nrc.gov/reading-rm/adams.html> (the Public Electronic Reading Room).

K. Polson

-2-

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

/RA/

Michael Kunowski, Chief
Materials Control, ISFSI, and
Decommissioning Branch
Division of Nuclear Materials Safety

Docket No. 05000016
License No. DPR-9

Enclosure:
IR 05000016/2016008(DNMS)

cc: Dan Breiding, Fermi 1 Custodian
Lynne Goodman
Jon Christinidis
Stanley Stasek
Paul Fessler
Radiological Protection Section,
Michigan Department of
Environmental Quality

cc: Distribution via LISTSERV®

K. Polson

-2-

We will gladly discuss any questions you have concerning this inspection.

Sincerely,

/RA/

Michael Kunowski, Chief
Materials Control, ISFSI, and
Decommissioning Branch
Division of Nuclear Materials Safety

Docket No. 05000016
License No. DPR-9

Enclosure:
IR 05000016/2016008(DNMS)

cc: Dan Breiding, Fermi 1 Custodian
Lynne Goodman
Jon Christinidis
Stanley Stasek
Paul Fessler
Radiological Protection Section,
Michigan Department of
Environmental Quality

cc: Distribution via LISTSERV®

DISTRIBUTION:

Darrell Roberts
John Giessner
Christine Lipa
Richard Skokowski
Carole Ariano
Paul Pelke
MCID Inspectors

ADAMS Accession Number: ML16323A235

Publicly Available Non-Publicly Available Sensitive Non-Sensitive

To receive a copy of this document, indicate in the concurrence box "C" = Copy without attach/encl "E" = Copy with attach/encl "N" = No copy

OFFICE	RIII-DNMS		RIII-DNMS		RIII		RIII	
NAME	PLee:ps REwards for		MKunowski REwards for					
DATE	11/18/2016		11/18/2016					

OFFICIAL RECORD COPY

U.S. NUCLEAR REGULATORY COMMISSION

REGION III

Docket No.: 05000016

License No.: DPR-9

Report No.: 05000016/2016008(DNMS)

Licensee: DTE Electric Company

Facility: Enrico Fermi Atomic Power Plant, Unit 1

Location: 6400 North Dixie Highway
Newport, MI 48166

Inspection Dates: November 3, 2016

Inspector: Peter J. Lee, Ph.D., CHP

Approved by: Michael Kunowski, Chief
Materials Control, ISFSI, and
Decommissioning Branch
Division of Nuclear Materials Safety

Enclosure

EXECUTIVE SUMMARY

Enrico Fermi Atomic Power Plant, Unit 1 NRC Inspection Report 05000016/2016008(DNMS)

This routine decommissioning inspection included reviews of facility management and control, and radiological safety.

Facility Management and Control

- The inspector concluded that the licensee conducted the quarterly surveillances in accordance with the requirement of the Technical Specification. (Section 1.1)
- The inspector determined that the licensee adequately implemented the audits of technical specification monitoring surveillances in accordance with its Quality Assurance Program.

Radiological Safety

- The inspector verified that no detectable licensed material had been released to the Environment through the discharges from the active sumps. (Section 2.1)

Report Details

Summary of Plant Activities

During the inspection period, the licensee has returned to a passive monitoring Safe Storage (SAFSTOR) status from the active final decontamination phase of SAFSTOR.

1.0 Facility Management and Control

1.1 Decommissioning Performance and Status Review at Permanently Shut Down Reactors (Inspection Procedure (IP) 71801)

a. Inspection Scope

The inspector reviewed the quarterly radiation surveillance results of 2016. The inspector also toured the plant to observe the condition of the plant.

b. Observations and Findings

The postings and boundaries for the contamination control were well maintained. Final status survey areas were adequately isolated and posted. There were no unexpected radiation readings detected. The radiation readings were consistent with the measurements taken during preparing to return to passive monitoring SAFSTOR.

c. Conclusions

The inspector concluded that the licensee conducted the quarterly surveillances in accordance with the requirement of the Technical Specification.

1.2 Self-Assessment, Auditing, and Corrective Action (IP 40801)

a. Inspection Scope

The inspector reviewed the licensee's audit of its technical specification monitoring surveillances (Audit 16-0107) conducted from June 20-21, 2016. Selected corrective action work orders associated with identified deficiencies were also reviewed.

b. Observations and Findings

The audit of technical specification monitoring surveillances (Audit 16-0107) was appropriately focused in both scope and level of detail, and the licensee initiated appropriate corrective actions to resolve the audit findings. No significant problems were identified.

c. Conclusions

The inspector determined that the licensee adequately implemented the audits of technical specification monitoring surveillances in accordance with its Quality Assurance Program.

2.0 Radiological Safety

2.1 Effluent and Environmental Monitoring (IP 84750)

a. Inspection Scope

The inspector reviewed the analytical sampling data of ground water from Fermi 1 active sumps to evaluate the potential release of radioactive material to the environment.

b. Observations and Findings

According to Surveillance Performance Form, Event FI 97, Fermi 1 sumps are sampled semi-annually. Based on the review of the analytical sampling data from the sumps, the inspector determined that only natural occurring radioactive materials were identified.

c. Conclusion

The inspector verified that no detectable licensed material had been released to the environment through the discharges from the active sumps.

3.0 Exit Meeting

The inspector presented the inspection results to members of the licensee's staff at the conclusion of the inspection on November 3, 2016. The licensee did not identify any of the documents or processes reviewed by the inspector as proprietary.

ATTACHMENT: SUPPLEMENTAL INFORMATION

SUPPLEMENTAL INFORMATION

PARTIAL LIST OF PERSONS CONTACTED

L. Goodman, Manager Licensing, MEP and Fermi 1 Custodial Delegate
* D. Breiding, Fermi 1 Custodian
B. Rumans, Radiation Protection Supervisor

* Present at the November 3, 2016, exit meeting.

LIST OF PROCEDURES USED

Inspection Procedure 71801: Decommissioning Performance and Status Review at Permanently Shut Down Reactors
Inspection Procedure 84750: Effluent and Environmental Monitoring
Inspection Procedure 40801: Self-Assessment, Auditing, and Corrective Action

LIST OF ACRONYMS USED

ADAMS	Agencywide Documents Access and Management System
CFR	Code of Federal Regulations
IP	Inspection Procedure
SAFSTOR	Safe Storage
DNMS	Division of Nuclear Materials Safety
NRC	Nuclear Regulatory Commission

LICENSEE DOCUMENTS REVIEWED

Licensee documents reviewed and utilized during the course of this inspection are specifically identified in the "Report Details" above.

ITEMS OPENED, CLOSED, AND DISCUSSED

None