



← CALCULATED  
 ← MEASURED  
 ← DIFFERENCE

PEAKING FACTORS  
 $\bar{F}_z = 1.5$   
 $F_{\Delta H} = 1.357$   
 $F_{\rho} = 2.07$  LOCATED AT  
 14-8 SOUTH

**UNIT 2**

16.4	REVISED PER 99-UFSAR-1242
REV. NO.	DESCRIPTION
REVISIONS	
AMERICAN ELECTRIC POWER COOK NUCLEAR PLANT NUCLEAR GENERATION GROUP BRIDGMAN, MICHIGAN	TITLE ILLUSTRATION OF A COMPARISON BETWEEN CALCULATED AND MEASURED RELATIVE FUEL ASSEMBLY POWER DISTRIBUTION
	DWG. NO. FSAR FIG. 3.3-23
	SH 1 of 1