

	<p align="center"> <b>INDIANA AND MICHIGAN POWER</b>  <b>D. C. COOK NUCLEAR PLANT</b>  <b>UPDATED FINAL SAFETY ANALYSIS REPORT</b> </p>	<p>Revised: 27.0</p> <p>Table: 4.1-9</p> <p>Page: 1 of 1</p>
---	---	--

## Reactor Coolant System Design Pressure Drop<sup>(1)</sup>

	Pressure Drop, psi (estimated)	
	Unit 1	Unit 2
Across Pump Discharge Leg	1.5	1.5
Across Reactor Vessel, Including Nozzles	51.0	51.0
Across Hot Leg	1.9	1.9
Across Steam Generator, Including Nozzles	31.4	26.1
Across Pump Suction Leg	1.8	1.8
Total Pressure Drop	87.6	82.3

---

<sup>(1)</sup> Data represents historical data.