

Records Facilities Branch
016 Phil

(3)

CF

NUCLEAR REGULATORY COMMISSION

IN THE MATTER OF:

PACIFIC GAS & ELECTRIC COMPANY

(Diablo Canyon Units 1 and 2)

Docket Nos. 50-275
50-323

Place - Avila Beach, California

Date - 6 January 1979

Pages 7603-7697

Telephone:
(202) 347-3700

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capitol Street
Washington, D.C. 20001

NATIONWIDE COVERAGE - DAILY

7901170027

cap

T

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PREMIUM
CR1933

WRBloom/wb

Madelon

WELandon

UNITED STATES OF AMERICA

NUCLEAR REGULATORY COMMISSION

In the matter of:

PACIFIC GAS & ELECTRIC COMPANY

Docket Nos. 50-275
50-323

(Diablo Canyon Units 1 and 2)

Cavalier Room,
San Luis Rey Inn,
Avila Beach, California.

Saturday, January 6, 1979.

The hearing in the above-entitled matter was
reconvened, pursuant to adjournment, at 8:30 a.m.

BEFORE:

ELIZABETH BOWERS, Esq., Chairman,
Atomic Safety and Licensing Board.

DR. WILLIAM E. MARTIN, Member.

GLENN O. BRIGHT, Member.

APPEARANCES:

On behalf of Applicant, Pacific Gas & Electric Company:

BRUCE NORTON, Esq., 3216 No. Third Street,
Phoenix, Arizona 85012.

MALCOLM H. FURBUSH, Esq. and PHILIP CRANE, Esq.,
Legal Department, Pacific Gas and Electric Company,
77 Beale Street, San Francisco, California 94106.

wb

On behalf of the Joint Intervenors:

DAVID S. FLEISCHAKER, Esq., Suite 602,
1025 15th Street N.W., Washington, D.C.

STEPHEN KRISTOVICH, Esq., Center for Law in
the Public Interest, 10203 Santa Monica Boulevard,
Los Angeles, California 90067.

On behalf of the Regulatory Staff:

JAMES R. TOURTELLOTT, Esq., MARC STAENBERG, Esq.
and EDWARD KETCHEN, Esq., Office of Executive
Legal Director, U. S. Nuclear Regulatory
Commission, Washington, D.C. 20555.

wel 1

C O N T E N T S

EXAM CK

BY ON VOIR

WITNESS: DIRECT CROSS REDIRECT RECROSS BD. BD. DIRE

H. James Gormly)

Thomas C. Esselman)

7508

7553

7552

Wilmer C. Gangloff)

Panos G. Antiochos)

(resumed)

H. James Gormly)

Thomas C. Esselman) 7558

Wilmer C. Gangloff)

Richard E. Bacher)

H. James Gormly)

Thomas C. Esselman) 7583 7587

Wilmer C. Gangloff)

Robert A. Young)



1

2



3

4



1A 1

wrb/agbl 2

P R O C E E D I N G S

MRS. BOWERS: Mr. Kristovich, are you ready to
continue?

MR. KRISTOVICH: Yes.

Whereupon,

H. JAMES GORMLY,

THOMAS C. ESSELMAN,

WILMER C. GANGLOFF,

and

PANOS G. ANTIOCHOS

resumed the stand as witnesses on behalf of the Applicant,
and, having been previously duly sworn, were examined and
testified further as follows;

CROSS-EXAMINATION (Continued)

BY MR. KRISTOVICH:

Q Mr. Antiochos, I'd like to direct your attention
to Table 7-7A of the Hosgri Report.

For the equipment listed in that table, was an
OBE analysis required?

A (Witness Antiochos) I would ask Dr. Esselman
to respond to this question.

A (Witness Esselman) Yes, sir. That was the table
that we had discussed last night before we recessed.

Q Table 7-7A? I believe last night when we ended,
we were discussing Table 7-7.

WRB/agb2

1 A That's correct. I'm sorry.

2 Q Mr. Esselman, maybe we should start with Table 7-7
3 then.

4 A I believe we adequately covered that last night.

5 Q But I'm confused now what we were covering last
6 night.

7 MR. NORTON: Well the transcript says you covered
8 7-7, the questions and answers were asked. He thought it was
9 7-7A, and it wasn't, it was 7-7. So I don't understand why
10 you don't proceed. Why go back to 7-7 if it has been
11 covered?

12 MR. KRISTOVICH: I thought he just said that last
13 night we had covered 7-7A. So perhaps he was looking at
14 that. If that's not the case, he can tell me that right
15 now.

16 BY MR. KRISTOVICH:

17 Q Mr. Esselman, which table were you discussing when
18 we ended the proceedings yesterday?

19 A (Witness Esselman) Last night when we ended
20 we were discussing Table 7-7.

21 Q Thank you.

22 I'd now like to direct your attention to Table 7-7A.

23 For the equipment listed in that table, was an
24 OSE analysis required?

25 A The requirement at the time was for a design

AB/agb3

1 earthquake analysis.

2 Q How is a design earthquake analysis different
3 from an OBE analysis?

4 A It was primarily in terminology at the time.

5 Q And at this time how is it different?

6 A The FSAR still only refers to a design earthquake
7 analysis. The OBE is terminology that has come into use
8 since then and has been commonly transposed.

9 Q So the analysis is the same and the terminology
10 is the only thing that's different?

11 A Yes, sir.

12 Q Well, was an OBE analysis performed for the equip-
13 ment listed in Table 7-7A?

14 MR. NORTON: Object, asked and answered. Twice.

15 MR. KRISTOVICH: May I respond?

16 MRS. BOWERS: Respond to the objection.

17 MR. KRISTOVICH: My previous question was whether
18 an OBE analysis was required, not whether it was performed.

19 MR. NORTON: I think the first question of the
20 morning was whether it was performed in 7-7A and he said
21 yes. I'll withdraw the objection. Let him answer it again.

22 MRS. BOWERS: Go ahead.

23 BY MR. KRISTOVICH:

24 Q Mr. Esselman?

25 A (Witness Esselman) Will you repeat the question

WRB/agh4

again?

Q Was an OBE analysis performed for the equipment listed in Table 7-7A?

A The qualifications that were performed for the valves in 7-7A did cover the OBE or the design earthquake case.

Q How?

A The original specifications for the valves in this table required seismic qualification. The manner in which the specifications addressed that was by specifying a single seismic acceleration with stress limits set according to the specifications.

In terms of the OBE requirements, the stress limits that were set in the specification were essentially identical to the OBE stress limits that are in use today. A single seismic criteria -- a single seismic acceleration was set with stress limits that are essentially the same as OBE requirements today. The double design earthquake and the design earthquake were both adequately considered simultaneously in the original specifications.

Q For any of the items, was the OBE limiting?

A The evaluations, as I stated, were performed essentially at the same time. Which is limiting is not possible to say, because the evaluations were performed simultaneously.

WRB/agb5

Q I'd like to direct your attention to Table 7-8 of the Hosgri Report.

Was an OBE analysis required for the equipment in that table?

A The valves in this table are similar to the valves in Table 7-7A, and the answers I made for the valves in Table 7-7A would also apply here.

Q So an OBE analysis was required for the equipment in Table 7-8?

A Yes, sir.

Q And an OBE analysis was performed?

A Yes, sir.

Q And for any of the items, was the OBE limiting?

A For the same --

MR. NORTON: Excuse me, Mrs. Bowers.

He just said the answers to the questions for Table 7-8 are the same as they were for 7-7A and Mr. Kristovich is proceeding to ask each and every question again.

MRS. BOWERS: It is repetitiva.

MR. KRISTOVICH: Mrs. Bowers, I'm not sure if he remembers each and every question that was asked on the previous table.

MRS. BOWERS: He has the transcript, and you just covered it this morning. He attempted to give a rapid answer for 7-8 by saying his answers would be identical to the

WRB/agb6

1 answers he just gave for 7-7A, so why repeat the question?

2 MR. KRISTOVICH: I just want to make sure.

3 MRS. BOWERS: Well the objection is sustained.

4 BY MR. KRISTOVICH:

5 Q I'd like to turn your attention now to Table 7-5.

6 For the items listed in that table, if the OBE
7 were increased to 0.25g, would the OBE be limiting?

8 A (Witness Esselman) I have no way of being able
9 to tell that now without going back and making a detailed
10 review of the analyses and the margins and such things as
11 that.

12 Q Have you ever done any study on what would be
13 the consequence of increasing the OBE to 0.25 for those items?

14 A (Witness Antiochos) I have looked at at least
15 three items.

16 Q Which three items?

17 A Okay, I'll tell you: the diesel generators, the
18 diesel generator fuel oil filter--Items Number 3, 5, 6, 7, 8
19 and 19.

20 Q Could you explain how you looked at these
21 items?

22 A Yes. Either the items themselves or components of the
23 items were in the rigid region of the spectrum. Which means
24 that the accelerations applied for the analysis were those
25 that are not affected by any amplification, and the Hogri



WRB/agb

1 is the limiting condition of analysis in this particular
2 case because the accelerations are approximately 2.5 times
3 higher than the OBE values.

4 (Pause.)

5 MR. KRISTOVICH: Perhaps this discussion by the
6 witnesses should be on the record if they each have different
7 things to say.

8 MR. NORTON: If counsel would ask a question, we'd
9 be glad to put the answers on the record.

10 MR. KRISTOVICH: I asked a question. The witnesses
11 are conferring.

12 MR. NORTON: No, the witness answered the question.
13 I think the record will reflect that. There is no question
14 pending. The witnesses can talk to each other if they want
15 to.

16 BY MR. KRISTOVICH:

17 Q Mr. Esselman, do you have anything to add to
18 Mr. Antiochos' answer?

19 A (Witness Esselman) No, sir.

20 Q Do you have anything further to add, Mr. Antiochos?

21 A (Witness Antiochos) No, sir.

22 Q Was a study made of any of the other items listed
23 in Table 7-5 of what would be the consequences of raising
24 the OBE to 0.25g?

25 A I don't know of any more items.

WRB/agb8

1 Q Mr. Esselman?

2 A (Witness Esselman) No, I know of none.

3 Q I'd like to direct your attention now to Table

4 7-6.

5 And Mr. Antiochos, what would be the consequence
6 of raising the OBE to 0.25g for the items listed in that
7 table?

8 MR. NORTON: Excuse me, Mrs. Bowers.

9 I don't understand the relevancy of these
10 questions. The OBE that was done was at 0.2g. Obviously,
11 if you change values of different analysis, you're going to
12 get different numbers. And to ask somebody what those numbers
13 would be when it's an analysis and they obviously can't
14 give a number, there's no way, and obviously the numbers
15 would change. What's the relevancy of all this? Where are
16 we going?

17 MR. KRISTOVICH: Mrs. Bowers, I'll withdraw the
18 question and rephrase it and narrow the question. The
19 question was overly broad.

20 MRS. BOWERS: Well, will you be able to establish
21 the relevancy?

22 MR. KRISTOVICH: I believe so.

23 BY MR. KRISTOVICH:

24 Q Mr. Antiochos, for the items listed in Table 7-6,
25 would an OBE of 0.25 be limiting?

WRB/agb⁹

MR. NORTON: Same objection, same reason.

We can put in any numbers we want. We can make an OBE of, instead of 0.2, 1.5 or any numbers anybody wants to pick. There's no relevancy and no basis and no foundation for 0.25.

MRS. BOWERS: Mr. Kristovich, could you tell us why it's relevant?

MR. KRISTOVICH: Yes.

10 CFR Part 100 Appendix A, Section 5, Subpart A --

MRS. BOWERS: Wait a minute.

(Pause.)

All right. Part 100, Appendix A, and then what else did you say?

MR. KRISTOVICH: Part 5, Subpart A, Subpart 2, entitled "Determination of Operating Basis Earthquake."

The last sentence in the first paragraph of Subpart 2 states:

"The maximum vibratory ground acceleration of the operating basis earthquake shall be at least one-half the maximum vibratory ground acceleration of the safe shutdown earthquake."

MR. NORTON: And would Mr. Kristovich relate that number of 0.25, and tell me how 0.25 is relevant to his interpretation of that statute -- Excuse me, that regulation?

WRB/agbl

1 MR. KRISTOVICH: Well Mrs. Bowers, if we assume --
2 what I've done -- 0.25 is very conservative. If we start
3 out with peak instrumental acceleration of 1.15 and then go
4 down to effective acceleration of 0.75, one-half of 0.75 is
5 0.375. I could ask the same questions for 0.375. I was taking
6 a more conservative approach and asking 0.25.

7 MR. NORTON: Well, Mrs. Bowers, the statute
8 also says -- excuse me, the regulation:

9 "If an Applicant believes that the
10 particular seismology and geology of a site
11 indicate that some of these criteria or portions
12 thereof need not be satisfied, the specific
13 sections of these criteria should be identi-
14 fied in the license application and supporting
15 data to justify clearly such departures should
16 be presented."

17 And that's exactly what's been done in this case.
18 Now if they want to argue that it should be something else,
19 fine. But to go through this silly exercise of saying if you
20 change the numbers in the formula are the answers going to be
21 different is -- that's a given, of course they are.

22 MRS. BOWERS: Does the Staff have a position on this?

23 MR. TOURTELLOTT: We think the line of questioning
24 is not relevant in that an adequate basis has not been
25 established because what they're talking about hypothetically

RB/agb11

1 is a situation which we know does not exist. Namely, they
2 are talking hypothetically about adherence on a design basis,
3 adherence to that particular last sentence of Subparagraph 2
4 when in fact we proceeded under another paragraph which says
5 roughly what Mr. Norton was talking about.

6 MR. KRISTOVICH: What is that --

7 MRS. BOWERS: Mr. Kristovich?

8 MR. KRISTOVICH: Well I would like a citation to
9 the paragraph Mr. Tourtellotte just referred to, and I would
10 also like to refer to Appendix A of 10 CFR Part 100, Subpart 1
11 -- Subpart 2, excuse me, the second paragraph, the second
12 sentence states:

13 "Additional investigations and/or
14 more conservative determinations than those
15 included in these criteria may be required
16 for sites located in areas having complex
17 geology or in areas of high seismicity."

18 MR. NORTON: And I would like to know where in
19 the record this is an area of high seismicity? In fact,
20 the evidence in the record is totally to the contrary. The
21 testimony has established it's an area of low seismicity.
22 Those were the exact words of the seismologists who testified.

23 MRS. BOWERS: Well the Board has determined
24 that the objection would be sustained, that this line of
25 questioning is not relevant. It seems to us an exercise in

RB/agbl2

futility. You could assign a series of numbers to each item
and we'd be here for all of 1979.

endIA

BY MR. KRISTOICH:

Q Mr. Antiochos, directing your attention to page 1 of the written testimony, lines 24 and 25, does the ASME code for valves address the structural integrity of valves under earthquake loading?

A (Witness Antiochos) The earthquake loading is taken into account in the equations that determine the allowable stresses.

Q Is that a yes answer, then?

A Yes, sir.

Q Thank you.

Does the ASME code for valves address the functional operability of valves during and following earthquake loads?

A No, sir.

A (Witness Gormly) I might add one thing.

I believe we indicated here that the applicable regulation is 50.55A; and I think we said we evaluate our plant in accordance with that regulation.

Q Mr. Antiochos, what additional analysis or testing have you done for functional operability of valves?

A (Witness Antiochos) We have done two types of tests besides the analysis, of course. The first one is testing of valves in place as they are installed on the piping systems with conditions that simulate the actual

WRB/wb2

1 conditions of the valves on that particular system; which
2 means it is pressurized, it is stroked -- opened and closed --
3 and at the same time we impose on the valve loads, forces
4 which correspond to the forces equivalent to those that would
5 be exerted on the valves when the earthquake happens.

6 The second method of qualifying the valves is
7 in the laboratory, testing them on the shaker table with
8 simulation, again, of conditions of performance, that is,
9 pressurizing the valves, stroking them, opening and closing
10 all the time, and subjecting them to vibration in single
11 frequency, multi-frequency and biaxial random motion.

12 Q Okay, Mr. Antiochos.

13 In your revised analysis of the component cooling
14 water heat exchanger were the supports overstressed?

15 A Are you referring to before or after the analysis?

16 Q You can answer before the analysis first.

17 A If we modified something, that is indicative that
18 it was overstressed. And as it was modified, or actually is
19 being modified, the stresses are within allowables.

20 Q Is it currently being modified?

21 A Yes, sir.

22 Q And can you describe that modification?

23 A In how much detail would you like to have it?

24 Q Well can you just describe the modification,
25 please?

WRB/wb3

1 A Basically the modification consists of reinforcing
2 the two supports of the heat exchanger by adding braces in
3 both horizontal directions, which are going to relieve the
4 stresses on the pipes that previously were overstressed.

5 Q Mr. Antiochos, is the structural integrity and
6 operability of safety valves required during and following
7 a Hosgri earthquake?

8 MR. NORTON: Excuse me, Mrs. Bowers. May I ask
9 what the term "safety valves" means in this question?

10 MRS. BOWERS: Could you identify, Mr. Kristovich?

11 MR. KRISTOVICH: Category 1.

12 WITNESS ANTIOCHOS: Mr. Kristovich, could you
13 please repeat the question so I understand it thoroughly?

14 MR. KRISTOVICH: Yes.

15 BY MR. KRISTOVICH:

16 Q For the valves in Table 7-5 through 7-8 of the
17 Hosgri Report-- Those are the valves I'm referring to.

18 A (Witness Antiochos) There are no valves in 7-5.

19 Q Okay. Well, then, 7-6.

20 A There are no valves in 7-6 either.

21 Q There are no valves in Table 7-5?

22 A No, sir.

23 Q 7-6?

24 A No, sir.

25 Q 7-7?

1 A Yes.

2 Q 7-7A?

3 A Yes, sir.

4 Q 7-8?

5 A Yes, sir.

6 Q Okay. For the valves in those last three
7 tables is structural integrity and operability required
8 during and following the Hosgri earthquake?

9 MR. NORTON: Excuse me, Mrs. Bowers.

10 The problem I have with that question is, when
11 he says "required during the Hosgri earthquake," required
12 for safe shutdown? required for hot shutdown? required for
13 cold shutdown? required for operability? required by regula-
14 tions? required by what? required for what?

15 MRS. BOWERS: Mr. Kristovich, could you be more
16 specific?

17 MR. KRISTOVICH: Yes.

18 MRS. BOWERS: And when you say "during the
19 earthquake," aren't you talking about seconds?

20 MR. KRISTOVICH: Yes. Some of these valves have
21 to operate during an earthquake.

22 MR. NORTON: Is that testimony, Mr. Kristovich?

23 MR. KRISTOVICH: I think that statement is similar
24 to statements you've made, whether you're statements were
25 testimony or not.

WRB/wb5

1 (Laughter)

2 Haven't you wound down yet?

3 (Laughter)

4 MRS. BOWERS: Can you break out the question?

5 MR. KRISTOVICH: I'll try to.

6 BY MR. KRISTOVICH:

7 Q Perhaps, Mr. Antiochos, it would be easier to
8 direct your attention to page 3-33 of SER-8. And I can just
9 read the relevant section to you.

10 MRS. BOWERS: Where are you, Mr. Kristovich?

11 MR. KRISTOVICH: Supplement 8, 3-33.

12 MR. NORTON: What paragraph?

13 MR. KRISTOVICH: 6 and 7.

14 MR. NORTON: Thank you.

15 BY MR. KRISTOVICH:

16 Q The first line of 6 and 7 states "Submittal
17 of information concerning qualification documents for remain-
18 ing valves demonstrating functional operability and updating
19 Table 7-5 through 7-8 of Amendment 50."

20 A (Witness Gormly) What is the question,
21 mr. Kristovich?

22 Q I haven't asked the question yet.

23 Have you provided the documentation for
24 Valve 9351A as described in the second paragraph of Section.
25 6 and 7?

WRB/wb6

1 A (Witness Esselman) It is not clear to me at
2 this time that that documentation has been provided. I do
3 know for a fact that those analyses have been completed.

4 Q And is that for each and every one of those
5 valves listed in that paragraph?

6 A That's correct.

7 Q So you don't know, then, whether the NRC review
8 of these items has been completed?

9 A No, sir, I don't.

10 Q Directing your attention to page 2 of the written
11 testimony, lines 25 and 26, does all the auxiliary mechanical
12 equipment that is addressed in your testimony satisfy the
13 design requirements of the ASME code?

14 MR. NORTON: Excuse me, Mr. Kristovich. In terms
15 of that question are you asking if that statement is true,
16 because I wasn't sure by the words you used in your question--
17 This is a longer question than the question and I wasn't able
18 to pick up whether you were just rephrasing that or asking
19 something different; I'm sorry.

20 May I have the question repeated or read back.
21 I was trying to read this at the same time the question was
22 being asked.

23 MRS. BOWERS: Can you repeat the question or
24 do you want the reporter to read it?

25 MR. KRISTOVICH: I can repeat it.

1 BY MR. KRISTOVICH:

WRB/wb7

2 Q Does all the auxiliary mechanical equipment that
3 is addressed in your testimony satisfy the design requirements
4 of the ASME code?

5 A (Witness Esselman) The current requirements of
6 the ASME code were used with regard to the stress limits of
7 the auxiliary components for structural integrity. As was
8 mentioned previously, the ASME code does not specify require-
9 ments for functional operability assurance of an active
10 valve or pump. For those cases we have exceeded the ASME
11 code requirements by making the requirements more restrictive.

12 MR. NORTON: Excuse me, Mrs. Bowers. May I ask
13 if the answer to the question is Yes?

14 MRS. BOWERS: Can the witness respond to that?

15 MR. KRISTOVICH: Has he become a hostile witness?

16 (Laughter)

17 MR. NORTON: I'm not sure I understood the question
18 or the answer. That's what I'm trying to find out.

19 WITNESS ESSELMAN: The question, if I recall
20 correctly, was whether we met all of the requirements of the
21 ASME code for....

22 BY MR. KRISTOVICH:

23 Qauxiliary mechanical equipment that is listed
24 in this written testimony.

25 A Was that an accurate restatement of the question?

WRB/agbl

lwsWRB/wb7

Q Yes. Not only those listed but that is addressed in this testimony.

A The design codes that were used for the valves and pumps were not the current edition of the ASME code. The codes that were used to design the equipment were the codes that were available at the time of the procurement.

In direct answer to your question then, the answer would be no. My statement that I've made in the first response to your question was that we did take those portions of the code that applied to stress limits for assurance of the capability of the valve to retain its pressure boundary integrity. In those cases where we had a valve which was required to operate, we were more restrictive in our choice of criteria.

endlB

weLandonflws



1 Q Directing your attention to page 3 of the
2 testimony, at line 17, Mr. Antiochos, could you describe
3 the on-site testing?

4 A (Witness Antiochos) Yes, sir.

5 Basically, it consists of forced vibration of
6 certain equipment with various means. The most common is
7 the application of excitation by the eccentric mass vibrator
8 and determination of the natural frequencies of vibration,
9 the mode shapes of response, and determination of damping
10 values for those modes.

11 Q And how is this accomplished?

12 A Which part of it?

13 Q Finding the damping value in the modes.

14 A That could be a lengthy discussion, but I will
15 very briefly tell you how.

16 The first thing that is done is to excite with
17 a proper means the equipment, and by strategically locating
18 accelerometers on certain points of the structure you can,
19 in varying the frequency of the excitation, you can detect
20 those points that have resonance.

21 Of course, we do not go to infinity, but we just
22 search the region of the spectrum that we are -- that is
23 significant for the analysis, usually between 2 and 33 or 35
24 hertz, sometimes a little bit higher.

25 The mode shape determination, when you reach

C-6

wel 2

1 resonance the structure shows some kind of significant
2 displacement at certain points in stagnant or steel points,
3 or in other areas, and by moving the accelerometers and
4 recording the response you can determine the way the shape
5 of the structure deforms for that particular frequency.

6 Now, the third part, the critical damping, is
7 determined by methods that are described in engineering
8 manuals or in codes like perhaps the IEEE-344, and the
9 discussion of that is rather cumbersome at this level, unless
10 you want me to refer to formulas and methods of determining
11 the damping.

12 Q What is the level of excitation that's used?

13 A Usually it is low, and the reason is that, first
14 of all it depends on the item you are going to test. If you
15 have a 200,000 pound heat exchanger you apply different
16 excitation. If you have a 300 pound small vessel, tank, or
17 valve, the excitation is small.

18 Q How small?

19 A Usually it might be of the order of between, say,
20 .01 g up to .3 g, even more. We have cases we have recorded
21 up to .5 g, but for very heavy items.

22 Q .5 or .05?

23 A 5.

24 Q .5?

25 A .5, half a g.

Q

wel 3

1 Q Thank you. How is the low excitation sufficient
2 to determine damping?

3 A Perhaps going through all this enlightenment
4 by your counsel you have found out that damping is a
5 function of the excitation. It is not a clear-cut case.
6 However, the experimental data indicate that when you have
7 low excitation usually you measure lower damping. And there
8 are mathematical ways to extrapolate and get from that small
9 excitation, and the damping you obtain for that excitation
10 what is the reasonable value of critical damping for
11 excitation which is much higher than the one you apply on
12 the item, that you are going to expect in the case of a
13 strong earthquake.

14 Q Can you give an example of about how you go
15 from correlating low damping to high damping, the extrapola-
16 tion? What I'm asking is to describe the procedures.

17 A One easy way is to excite the same item with
18 different values. For example, with .1 g, .2 g, .3 g,
19 something like that, and you create a series of damping
20 values versus excitation. And you plug these values on two
21 axes, which is damping versus excitation, and with mathemat-
22 ical means you can extrapolate the curve.

23 Q Is this a lineal relationship?

24 A As far as I can tell, no, it is not.

25 Q Moving to page 3 of the written testimony, at

wel 4

1 lines 21 to 23 you state:

2 "In a few cases, mathematical models were
3 refined with information based on the
4 experimental data."

5 Could you list each and every case where you
6 refined the mathematical models?

7 A Really that is not easy right now, because I
8 don't have all the documents with me. But I can look very
9 briefly and I'll give you one or two examples of how I did
10 it.

11 Is that going to be enough?

12 (Pause.)

13 If you look on Table 7-5 --

14 Q Just a second, please.

15 Okay.

16 A Table 7-5, which is the summary of seismic
17 qualification of Class-1 equipment required for following
18 Hosgri event, one item that the model of which was refined
19 based on the information obtained from the test is item
20 number 4, the diesel generators.

21 Q Can you describe how the model was refined?

22 A Yes. On that particular item, the assumption
23 was that the hold-down bolts were providing practically
24 infinitely rigid attachment to the concrete floor. Actually,
25 it's a floor with an inch of plate, steel plate. And it

wel 5

1 seems that this assumption was not 100 percent accurate,
2 that the hold-down bolts really do not provide -- on that
3 particular item -- very infinitely rigid connection.

4 We tested that item, and the mathematical model
5 we run this assumption was giving more rigid behavior.
6 However, the test proved that due to this kind of assumption
7 that it was not correct, and the test data we obtained
8 enabled us to refine the model by introducing some kind of
9 flexibility there, where previously it was assumed
10 infinitely rigid. And it came to perfect agreement with
11 the test results.

12 May I proceed now to the next item?

13 Q Yes.

14 A Okay. Another item is number 10, again the same
15 reason there was this kind of slight discrepancy. It was
16 assumed that the tank, which is supported through a skirt
17 and flange with 36 bolts, it was really infinitely rigid,
18 which is another case. And we refined the model in such a
19 way that it agrees with the test. And then we analyzed it
20 with this refined mathematical model, and we obtained
21 stresses that were below allowables.

22 In both of these cases, the margin of safety
23 was so big that we didn't have any trouble. The assumption
24 of rigidity being made here, although it didn't prove
25 accurate, didn't affect it. I mean we stayed below allowables

wel 6

1 even after we introduced the real constant inflexibility at
2 the base of the tank.

3 I probably have one or two more, but unless you
4 want me to look at my papers I probably will not be able to
5 give you exact descriptions of the reasons why they did not
6 match.

7 But I recall those two.

8 Q Which two are those?

9 A Excuse me?

10 Q Which two are those?

11 A Which two are you referring to?

12 Q I thought you said there were one or two others
13 you could recall.

14 A I might have, but I am not -- even if I mentioned
15 the items it might not be -- I would have to stretch my
16 memory to think what was the reason for not agreeing.

17 Q Okay. Well, you don't have to give us the
18 reason, but just refer us to those.

19 A All right. I'll give those.

20 (Pause.)

21 The next item probably is number 18, the component
22 coolant heat exchanger, which was one of the items that we
23 modified. I don't remember anything else right here.

24 Q Okay. When you state in line 21 of page 3, "in
25 a few cases," approximately how many cases are you referring

wel 7

1 to?

2 A I would say three or four. I mentioned already
3 three.

4 Q Mr. Antiochos, does this statement on lines 21
5 to 23 only apply to the items in Table 7-5?

6 A There probably are one or two items in 7-6, but
7 I can't recall right now, because there are almost 40 of
8 them there, and it might be hard to give you an answer to
9 that.

10 Q Were there items in the other tables in the
11 Hosgri Report that you referred to earlier this morning?

12 A There might be, but I don't remember. There are
13 so many items, really, it's very hard to identify them.

14 Q I'd like to direct your attention to page 6 of
15 the written testimony, where you have listed the items
16 tested on laboratory shaker table.

17 Could you describe this procedure?

18 MR. NORTON: Excuse me, Mrs. Powers. I didn't
19 object to the last line, but this information is all
20 contained in the Hosgri Report that was submitted to
21 intervenors a long time ago.

22 A description of the procedure is there.

23 Are we playing a game where we're supposed to
24 check his memory against the procedures listed in the Hosgri
25 Report, or what's the purpose of this line of questioning?

wel 8

1 The information is there in the Hosgri Report,
2 obviously in far more detail than someone can sit there and
3 remember off the top of their head.

4 I just don't understand what we're doing.

5 MRS. BOWERS: Mr. Kristovich?

6 MR. KRISTOVICH: Is that an objection to my
7 question to describe the shaker table procedure?

8 MR. NORTON: Yes, it is.

9 MRS. BOWERS: Does the Staff have --

10 MR. KRISTOVICH: I have a position.

11 MR. TOURTELLOTTE: I assume the basis of the
12 objection is that this line of questioning is cumulative and
13 repetitive and, therefore, should not be allowed to
14 continue.

15 My understanding is that a question has been
16 asked for an explanation to show that it isn't cumulative
17 and repetitive, and I would tend to agree with that and
18 would be interested in an explanation, if there is one,
19 and if there isn't, then I think we should move on to
20 something else.

21 MRS. BOWERS: Mr. Norton, you have submitted --
22 your witnesses have submitted direct testimony. Now, are
23 you taking the position that whatever is in the Hosgri
24 Report need not be explained, or --

25 MR. NORTON: No. No, not at all. If there needs

1 to be an explanation, fine. But in the Hosgri Report, at
2 7.6.2, it's got laboratory testing, and it starts explaining
3 in detail all the tests.

4 The testimony just says that there were items
5 tested on a laboratory shaker table, and the description of
6 all that is right here.

7 I mean, I don't understand why they want a
8 description of the testing. Now, if they want to read the
9 description, and there's something in there that bothers
10 them, or something that doesn't make sense to them, or
11 something they don't understand -- whatever -- then
12 questions about that would seem proper.

13 But to ask the witness to say off the top of
14 his head what the testing was, when it's all set forth in
15 great detail in the record already, it seems cumulative.
16 I mean it's in the record, it's in evidence.

17 MRS. BOWERS: Well, in other matters, when
18 questions have come up there have been specific references
19 to the Hosgri Report or the FSAR. The witnesses have not --
20 of course they haven't had an opportunity in this particular
21 situation to give a reference to the Hosgri report. You
22 have.

23 MR. NORTON: Yes. You know, if the question were
24 asked, "Is that procedure described in the Hosgri Report?"
25 "Yes, it is," and so on, that's all right.. But to have

1 him do it again, when it's all written out here in great
2 detail, just doesn't seem to accomplish any purpose.

3 MRS. BOWERS: Well, you made a point yesterday that
4 someone reviewing the record might not get into the Hosgri
5 Report or the FSAR. So we think the witness can briefly
6 describe what the Shaker table is, so it will be a part of
7 the transcript.

8 MR. KRISTOVICH: Thank you.

9 BY MR. KRISTOVICH:

10 Q Mr. Antiochos, could you describe the Shaker table
11 test?

12 A (Witness Antiochos) I could read it if you could
13 understand my accent.

14 (Laughter.)

15 Q We're merely interested in a brief explanation for
16 the record. You can just hit the high points.

17 A Okay. Are you referring to the Shaker table
18 testing?

19 Q Correct.

20 A Okay. I have witnessed this, and really can tell
21 you perhaps much more than time allows here.

22 I will tell you this:

23 Basically it consists of the following: The item
24 that is going to be tested is mounted on the shaker table.
25 The shaker table is really a steel table which could move in

1 two directions, one horizontal and one vertical.

2 The way that it moves on these directions is
3 controlled by electronic equipment which simulate the
4 movement that creates, with proper controls, the response
5 that resembles very closely to the floor response spectrum
6 where the item is located.

7 The item is mounted as realistically as possible
8 on the table, and it is instrumented with accelerometers
9 in special locations that, either by experience or by
10 intuition, you feel this is a weak point or the point it is
11 going to respond most.

12 In addition to that, you can put strain gauges
13 or other equipment, if you wish, to measure stresses. And
14 there is some kind of preliminary surge of the natural
15 frequencies of the item in one axis at a time. The
16 frequency of excitation starts from, say, 2 hertz and goes
17 up to 35, very slowly, in a way prescribed in the code, and
18 by observation of the responses from the accelerometers you
19 can tell if you have reached a resonance somewhere in
20 between, and you record it.

21 Then you will take the item, or if the table is
22 capable to have the other axis activated, you repeat that
23 on each particular axis, major axis, of the equipment, and
24 you record the natural frequencies.

25 The second step after that is to subject the item

wel 12

1 in specific frequencies of vibration. We are still in the
2 one-axis domain. And you vibrate the table -- I forgot to
3 tell you something basic, that the resonance surge is done
4 with very low excitation, but after that you apply excitations
5 on particular frequencies of interest with an input that is
6 going to create on the table conditions simulating the
7 conditions that it is expected to encounter on the plant.

8 After you have done the single-frequency test per.
9 axis, the third step is to subject the item in bi-axial
10 excitation, which means one vertical and one horizontal, in
11 such a way -- full blast now. The code allows, before you
12 do that, to subject it to five OBE's before you apply the
13 full excitation level.

14 Then you will take the equipment in the other
15 major axis and you repeat the bi-axial random test.

16 That is very briefly the way they test it.

17 And at the same time -- excuse me, I forgot to
18 tell you this -- the item, if it is supposed to act, for
19 example a valve, to open or close, during this kind of test
20 it is always opened and closed. The valve actuator, for
21 example, opens and closes the valve as if the valve was
22 called upon to function during shaking conditions.

23 Q What code were you referring to when you mentioned
24 five OBE's?

25 A Excuse me. It's IEEE 344-1975 standard.

wel 13

1 Q Did you qualify the equipment, then, to an IEEE
2 standard? Mechanical equipment?

3 A We just tested the items according to that.

4 Q Did you use actual plant equipment for these shaker
5 table tests?

6 A Yes. In some cases we had extra components that
7 we tested that are not in the plant, but they are identical
8 items.

9 Q But the other items you re-installed in the plant?

10 A Excuse me?

11 Q Were some of the items you tested reinstalled in
12 the plant?

13 A Yes.

14 Q Which items?

15 A The items listed under B-1 in the table.

16 Q Did you verify before re-installing these items
17 that the shaker table test did not provide excess aging to
18 the equipment?

19 A Yes, sir.

20 Q And how did you do that?

21 A The NRC Staff requested that we evaluate the aging
22 of the item, and the effect of the vibratory motion on the
23 two main steam safety valves. There is a procedure within the
24 ASME code which according to the stress levels you have reached
25 during the test and the duration of the test, actually the --

1 the actual number of cycles the items are subject to. There
2 is a procedure that tells you if you have exceeded any limits
3 that could impair the integrity of the item.

4 We did that on the request of the Staff, and we
5 have submitted information, and as far as I know, it is
6 accepted.

7 Q How was aging specifically accounted for in the
8 Hosgri reanalysis for the auxiliary mechanical equipment?

9 A I don't think that applies to the mechanical
10 equipment.

MB fls

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

MADELON
c5 mpbl
flws
WELL

1 Q I thought you just said you provided information
2 to the NRC on aging.

3 A We went an extra mile. That's all. They asked,
4 and we supplied the information.

5 Q Well, Mr. Antiochos, correct me if I'm wrong:

6 Did you not, then, account for aging in the
7 Hosgri analysis of the auxiliary mechanical equipment?

8 A That is not a requirement.

9 Q Well, that's not an answer to the question I
10 asked.

11 MR. NORTON: Excuse me, Mrs. Bowers.

12 Based on the answer to the question that was
13 asked, the question is irrelevant if it's not a requirement.
14 If there's no requirement under the regulations, Reg Guides,
15 Standard Review Plans or anything else, then it's not rele-
16 vant.

17 MRS. BOWERS: Well, I think I asked a question
18 yesterday about what equipment was there a requirement for
19 aging. And it may have been a panel prior to this panel, but
20 consisting of some of the same members. And it was explained
21 that it was required only for the IEEE.

22 But there was some testimony about giving informa-
23 tion to NRC on aging, as I recall.

24 WITNESS ANTIOCHOS: Yes, Mrs. Bowers.

25 MRS. BOWERS: And I think that's what Mr.

mpb2

1 Kristovich is trying to find out about.

2 MR. NORTON: No, I'm afraid that wasn't his
3 question at all, Mrs. Bowers.

4 MR. KRISTOVICH: I was asking an additional ques-
5 tion.

6 MRS. BOWERS: Your question was is it required?

7 MR. KRISTOVICH: No.

8 The question was: How was aging accounted for
9 in the Hosgri reanalysis of the auxiliary mechanical equip-
10 ment.

11 MR. NORTON: The objection was it's not relevant
12 because it's not required, as stated by the witness. The
13 question is not relevant. There is no requirement at all.

14 MR. KRISTOVICH: Where does it say in the regula-
15 tions it's not required?

16 MR. NORTON: Well, I think one does not do every-
17 thing in the world that the regulations say is not -- that
18 the regulations are quiet about. I think that one does what
19 the regulations require to be done.

20 MRS. BOWERS: Does the Staff have a position on
21 this?

22 MR. TOURTELLOTTE: I guess I'd like to know where
23 in the regulations it is required. If there is a basis for
24 it, then I think Mr. Kristovich can state his question in
25 terms of a specified regulation.

mpb3

1 MRS. BOWERS: Could you identify, Mr. Kristovich,
2 the requirement in the regulations?

3 MR. KRISTOVICH: One moment, please.

4 (Pause.)

5 MR. NORTON: Mrs. Bowers, to proceed along, I
6 think the witnesses can probably answer the question. It's
7 not required; there's no place in the regulations that it is.

8 I think the witnesses can answer the question
9 anyway. So I think to speed things up, I think we should
10 allow -- I think it's Mr. Gormly who's got the microphone in
11 his hands, or Mr. Esselman, I can't tell which -- to proceed
12 to answer the question so we can speed things along, because
13 they're reading the regulations. I'm afraid they're going to
14 read a long time before they find anything.

15 (Laughter.)

16 MRS. BOWERS: You're withdrawing your objection?

17 MR. NORTON: Yes.

18 WITNESS GORMLY: I'd be always happy to pass the
19 mike to Dr. Esselman.

20 I might add, just maybe because Mrs. Bowers has
21 asked this question, that we're having a little problem as
22 mechanical engineers with some people using a term "aging"
23 which is coming out of an IEEE or an electrical code. It is
24 bothering me a little because the implication is that the
25 effect of life or duty cycles on our equipment has not been

mpb4

1 considered, and that is not the case. And each of our
2 witnesses who have discussed qualifying things to the code --
3 the consideration of service life is considered in the
4 design of mechanical equipment. But the term "aging" is
5 inappropriate and we don't understand it as it applies to
6 mechanical equipment. That's basically the problem.

7 MRS. BOWERS: Well, but the specific question is
8 is there a requirement in the regulations.

9 WITNESS GORMLY: To my knowledge there is no
10 requirement in the regulation to evaluate mechanical equip-
11 ment for aging.

12 BY MR. KRISTOVICH:

13 Q Does mechanical equipment age?

14 A (Witness Gormly) I think I said yesterday it
15 ages like I do, yes. But in the term you're using it -- we
16 don't understand the term.

17 Do you understand, Mr. Kristovich, we design our
18 equipment for service life, for the life of the plant. We
19 take into consideration service life, and our codes require
20 it.

21 And I think Dr. Esselman and Mr. Antiochos can
22 enlarge on how the codes do indeed take into effect such
23 things as repetitive cycles and the rest of it that we expect
24 during the life of the plant.

25 A (Witness Antiochos) Mrs. Bowers, may I add

mpb5

1 something on this, just because we promise too many things
2 that we don't deliver.

3 (Laughter.)

4 The mechanical equipment, one of the major
5 problems usually is the corrosion, and the ASME code takes
6 into account the fact that things corrode, for example. When
7 you design a tank and it is new you have extra thickness of
8 walls to take into account this kind of degradation of the
9 material.

10 So in a direct way I think the aging is taken
11 care of. And, of course, if the material is more exotic,
12 if it is stainless steel or an alloy steel or something that
13 doesn't corrode, we have one more reason not to worry about
14 it. But for those cases that there is something, that
15 something can degrade, by that time we take care of it.

16 In the meantime, of course, the engineers
17 will age more than the degradation of the equipment.

18 (Laughter.)

19 Q Well, Mr. Antiochos, could you amplify a little
20 more on how you take into consideration service life of the
21 equipment?

22 A Dr. Esselman would like to respond to that.

23 A (Witness Esselman) The additional evaluation
24 which was performed for the Staff on this item that was tested
25 was the fatigue analysis that calculated the damage or usage

mpb6

1 factor that was induced in the component because of the
2 additional testing that was done on it.

3 The codes as they were developed take into
4 account the service life of the component. The ASME boiler
5 and pressure vessel code does this and it does it differently
6 for different classes of components.

7 For instance, class 1 components in the primary
8 system, specific fatigue analyses are performed for the cycles
9 that would occur, both seismic and operating type transients
10 that would occur over the life of the plant.

11 For this type of auxiliary mechanical equipment
12 the stress limits in the code are set at a point such that
13 fatigue is not required to be considered or evaluated
14 specifically or explicitly, but it is inherently included
15 in the way the code sets up the stress allowables and the
16 way you combine stresses and the way you limit the stresses
17 in the component.

18 A (Witness Gormly) I think the summary, Mr.
19 Kristovich, is the way we understand aging, aging was consider-
20 ed.

21 (Pause.)

22 MRS. BOWERS: Mr. Kristovich, do you have con-
23 siderable more examination?

24 We're thinking in terms of the mid-morning break.

25 MR. KRISTOVICH: Right.

mpb7 1

Actually this would be a good time for a break.

2

MRS. BOWERS: I never heard anyone say it would be a bad time for a break.

3

4

(Laughter.)

5

MRS. BOWERS: Ten minutes, then.

6

(Recess.)

7

MRS. BOWERS: Are you ready to continue, Mr.

8

Kristovich?

9

MR. KRISTOVICH: Yes.

10

BY MR. KRISTOVICH:

11

Q Mr. Gormly, I would just like a little clarification.

12

13

How is aging for electrical equipment different from service life for mechanical equipment?

14

15

A (Witness Gormly) Mr. Kristovich, I'm really not an expert on codes which are not applicable to this plant. And I believe that the word "aging" is some new version of some code which is not a requirement on this plant.

16

17

There is going to be a later panel of people that may be a little more familiar with that code.

18

19

But I believe you're talking about the word "aging" as it somehow or other appears in some new code, some '74 or '75 version of IEEE 323.

20

21

22

IEEE 323 1971 is the code or the standard that we are required to meet.

23

24

25

mpb8 1

MR. KRISTOVICH: No further questions.

2

MRS. BOWERS: Mr. Tourtellotte?

3

BY MR. TOURTELLOTTE:

4

Q Dr. Esselman, earlier Mr. Kristovich was asking you questions about certain tests, specifically with reference to the SER, to a paragraph in the SER. He asked about whether or not PG&E had met all ASME Code requirements for auxiliary mechanical equipment. And I'm trying to give you an idea of the way I understood what happened because it was not clear to me.

11

It seems like you first answered him that you met the code in every respect or did something better. Then the second time around on what I thought was the same question, you answered that no code existed with reference to certain items at the beginning when the plant was designed, and therefore the answer to his question would be no, that you didn't meet all of the requirements.

18

And then you also said that in some cases you met it, and in some cases you did more than was required. So I guess I'm a little confused about what all that exchange was, and I thought maybe we could give a better elaboration or understanding about exactly what are we talking about when we say "meet all the requirements of the ASME code". Is that really necessary to ensure the plant's safety, or are there certain parts of the code which are really more safety related

25

mpb9 1 than others?

2 A (Witness Esselman) The ASME code is used several
3 times in the process of designing and qualifying a compo-
4 nent. In designing a component the ASME has -- the ASME code
5 has rules for, for instance, the shape of the component or
6 the wall thickness of the component.

7 The current requirements in the ASME code, that
8 would be the 1978 version of the ASME Boiler Pressure Vessel
9 Code, was not available when we performed those functions on
10 the component, when we did the original design on the compo-
11 nent.

12 My previous answer was that the 1978 version of
13 the code, since it was not in existence in 1968 or 1970, was
14 not used. However, we did use the applicable codes that were
15 available at the time. In some cases this was the ASME code,
16 in others it was the Pump and Valve Code, et cetera.

17 The second way in which you would use the ASME
18 Boiler and Pressure Vessel Code in the sequence of events
19 that occurs on a component is in qualifying that component
20 for offnormal events, such as the seismic conditions that
21 we're discussing here.

22 In the evaluation of the Hosgri earthquake, which
23 was done in the 1978 time period, we used the code requirements
24 from the most currently available code in that evaluation.
25 My answer was no, we did not meet all the requirements of the

mpb10¹ current code, as when some of the steps were taken the current
2 code was not available.

3 However, in performing the Hosgri evaluation we
4 did meet all of the current requirements of the code for the
5 evaluation. In particular, that was the stress limits.

6 Q There's a statement in the SER, Supplement number
7 73-65, Paragraph 3.9.3.7 --

8 MRS. BOWERS: Would you run through that again?

9 BY MR. TOURTELLOTTE:

10 Q And that's the fourth paragraph --

11 MRS. BOWERS: Well, but what page?

12 MR. TOURTELLOTTE: Supplement 73-65 is the page.

13 MRS. BOWERS: Okay.

14 BY MR. TOURTELLOTTE:

15 Q The fourth paragraph says "For analytical
16 procedures"--

17 A (Witness Anticchos) Excuse me, could you wait a
18 minute?

19 (Pause.)

20 MR. NORTON: Excuse me.

21 It's also quoted in the testimony, at the bottom
22 of page 2 of Mr. Anticchos' testimony, for quick reference.

23 BY MR. TOURTELLOTTE:

24 Q Do you agree with that paragraph?

25 A (Witness Esselman) Yes, sir.

mpb11 1

MR. TOURTELLOTTE: No other questions.

2

EXAMINATION BY THE BOARD

3

BY MRS. BOWERS:

4

Q I have a question that goes to what was really a series of questions and answers between Mr. Kristovich and the panel. And it may well be that there was an explanation.

7

But the questions I'm concerned about to make sure that the record is explicit, the panel was asked a number of times if the ODE was limiting for certain items. And now, could you respond to exactly what is meant by the term "limiting"?

12

A (Witness Gormly) Mrs. Bowers, I really think that was Mr. Kristovich's word. It wasn't ours.

14

Q Well, but you answered.

15

A We attempted to answer the question by saying that to our knowledge the DE stresses were not controlling, were not controlling this.

18

The stress levels that we were getting in the DE analysis in general to the best of our knowledge, the panel's knowledge -- we keep seeing that the Hosgri stresses are controlling our design. I think we're answering the question in that context.

23

We keep looking at things and saying No, the most critical stresses we're seeing are the result of Hosgri type inputs we're getting, not the old DE stresses that we saw.

25

mpb12 1

A (Witness Gangloff) I think there are probably two ways to consider the word "limiting", at least in the context of limiting a design.

One way to look at it would be is the configuration of the item determined by the calculation in question? In other words, does the OBE or some other condition determine the size, shape, strength, whatever, of the item. And I think our answer was no; in all these cases, no, that wasn't the thing that determined what size it was.

The other way is is it a limit on the design? And the answer to that, of course, is yes. We have to meet that limit and many other limits. We have several conditions for which we have to show satisfactory results, and the OBE is a limit in that sense. It has to be satisfied.

But it didn't govern the configuration, in other words. Now that's another way of saying 'which event brought you closest to your limit', and I guess that's what Mr. Gormly was talking about. The Hosgri, in all the cases that we've looked at here, brings you the closest to your limits.

MRS. BOWERS: The Board has no further questions.

MR. NORTON: I have just a few.

REDIRECT EXAMINATION

BY MR. NORTON:

Q You were asked questions about the testimony on page 1, line 22, where it says:

mpb13 1

2 criteria were selected to meet or exceed
3 1978 requirements."

4 You were asked a few questions about that.

5 Let me ask you this, either Mr. Antiochos or
6 Dr. Esselman or both:

7 Were the stress limits and other associated
8 criteria selected to meet or exceed all applicable require-
9 ments, whether they be 1978 or 1971 or 1974, in other words,
10 whatever was applicable at the time?

11 As the Board is well aware, there was a great
12 deal of discussion about what was applicable for this plant;
13 and what I'm really asking is:

14 This sentence doesn't meet that you didn't meet
15 other applicable requirements, is that correct?

16 A (Witness Esselman) That's correct.

17 Q All right.

18 Now, Mr. Antiochos, there were two pieces of
19 equipment you identified in the tables, Table 5 and 5A, that
20 an OBE analysis was not done per se, Item number 6 in Table
21 7.5, which was the diesel generators fuel oil priming tank.

22 Can you tell the Board which event controls in
23 that situation?

24 A (Witness Antiochos) Before I answer the question,
25 I should point out that this item was introduced to our



mpbl4 1 systems after the word "Hosgri" was introduced to our vocab-
2 ulary.

3 Q In other words, the fuel oil priming tank didn't
4 exist at the time of the DE analysis, is that correct?

5 A Correct.

6 Q All right.

7 And it was introduced after the Hosgri analysis
8 was started, is that correct?

9 A Correct, for reasons independant of the seismic
10 qualification. It doesn't have anything to do with Hosgri.
11 It was not introduced because of Hosgri.

12 Q It was introduced for other reasons?

13 A For other reasons.

14 Q All right.

15 And a Hosgri analysis was done on it?

16 A Yes, sir.

17 Q All right.

18 Now, would a DE or an OBE analysis be a limiting
19 condition vis-a-vis the Hosgri analysis?

20 A No, sir, the Hosgri is the limiting.

21 Q All right.

22 And what do you base that opinion on?

23 A The reason is that this item, since we are in the
24 post-Hosgri, we designed everything in such a way that it
25 meets the Hosgri criteria, first.



mpb15 1

2 Secondly is that the item, per se, as it is design-
3 ed and installed, is a rigid item, which means that there is
4 no effect on the analysis by where the item is -- by the
5 rigidity of the item, which is very high. Which means, again,
6 that the 7.5 -- the .75g earthquake is by far higher than the
7 .2g originally stipulated.

8 Q All right.

9 Now the next item was from Table 75A, item 2, which
10 is the auxiliary feedwater pump motor.

11 The same series of questions, of course, for that
12 item, which event controls and why?

13 A Again, in this case the Hosgri event controls
14 because the item, as you can see from the table, is a rigid
15 item, from the frequencies. And the stress levels of the
16 motor bearing -- that is the most stressed part -- is much
17 lower in the case of the OBE.

18 Q All right.

19 Dr. Esselman, I believe yesterday that you testi-
20 fied something about the 33 hertz, which is what is listed
21 for the diesel generator fuel oil priming tank, and the 37
22 hertz, which is auxiliary feedwater, as to why the Hosgri
23 would control vis-a-vis the OBE.

24 Could you amplify on that again today in relation-
25 ship to these two items we just talked about?

A (Witness Esselman) Yes, sir.



mpbl6 1

2 For a piece of equipment which has a frequency
3 which is greater than 33 hertz, the component is considered
4 rigid, there is no amplification within the component, and
5 therefore damping does not have an effect. In a flexible
6 component the damping differences between CRE and the Hosgri
7 earthquake in some cases would make the relative accelerations
8 smaller.

9 For a rigid component this is not as significant
10 because the damping does not have any effect.

11 Q Then would you agree with Mr. Antiochos that these
12 two items, that the Hosgri event would be controlling?

13 A Yes, sir, I would agree with that.

14 Q All right.

15 MR. NORTON: That's all I have, Mrs. Bowers.

16 MRS. BOWERS: Mr. Kristovich?

17 MR. KRISTOVICH: No further questions.

18 MRS. BOWERS: Mr. Tourtellotte?

19 MR. TOURTELLOTTE: One moment.

20 (PAUSE.)

21 MR. TOURTELLOTTE: No questions.

22 MRS. BOWERS: The Board has no further questions.

23 MR. NORTON: We would ask that Mr. Antiochos be
24 excused.

25 And we would like to call Mr. Bachar, who was
sworn -- was it the day before yesterday when we swore all



mpb17 1 those witnesses? It was either the day before yesterday --
2 yesterday morning, okay.

3 (The panel excused.)

4 Whereupon,

5 H. JAMES GORMLY,

6 THOMAS C. ESSELMAN,

7 WILMER C. GANGLOFF,

8 and

9 RICHARD E. BACHER

10 resumed the stand as witnesses on behalf of the Applicant, and
11 having been previously duly sworn, were examined and testified
12 further as follows:

13 DIRECT EXAMINATION

14 BY MR. NORTON:

15 Q Mr. Bacher, you reviewed your professional
16 qualifications and they are true and correct copies that
17 have been placed in evidence, is that correct?

18 A (Witness Bacher) Yes, they are.

19 Q All right.

20 Dr. Esselman, would you now summarize the written
21 testimony on Class 1 Piping systems -- or Other Class 1
22 Piping Systems, I should say.

23 A (Witness Esselman) This testimony prepared by
24 Mr. Bacher and myself describes the analysis of piping other
25 than the reactor coolant system, which we covered in earlier



mpb18 1 testimony.

2 The testimony describes the piping that is included
3 ed and describes the codes and analyses that were performed
4 to evaluate that piping. The testimony describes the response
5 spectra that were used in the evaluation of the piping, and it
6 concluded that as a result of the analyses performed that the
7 other piping, that is piping other than the reactor cooling
8 loop, is adequate for the Hosgri event and will retain its
9 structural integrity.

10 MR. NORTON: Mrs. Bowers, at this time we'd ask
11 that the prepared testimony of Dr. Esselman and Mr. Bacher
12 be placed in the record as though read.

13 WITNESS ESSELMAN: We have two corrections.

14 MR. NORTON: Oh, excuse me. I forgot to ask for
15 the corrections.

16 MRS. BOWERS: Right.

17 WITNESS ESSELMAN: On page 2, line 24, there is
18 a comma after the word "fuel" which should be deleted. It
19 should read "the spent fuel pool cooling systems".

20 And on page 7, line 2, the word "approximately"
21 should be replaced with "at least". That will read:

22 "At least 900 or 5000 piping supports have
23 been or are being modified."

24 MR. NORTON: Mrs. Bowers, we would now ask that
25 this testimony be placed in the record as though read.



mpbi9 1

2 MRS. BOWERS: Mr. Norton, if you don't ask it,
Mr. Kristovich will:

3 Does the entire panel adopt this testimony?

4 MR. NORTON: Mrs. Bowers has already asked it.
5 And I think the witnesses are assenting.

6 WITNESS GORMLY: Yes.

7 WITNESS GANGLOFF: Yes.

8 MRS. BOWERS: Any objection to the testimony being
9 inserted?

10 MR. KRISTOVICH: No objection.

11 MRS. BOWERS: Mr. Tourtellotte?

12 MR. TOURTELLOTTE: No.

13 MRS. BOWERS: Well, the testimony will be physically
14 inserted in the transcript as if read.

15 (The testimony on Other Piping Systems
16 follows:)

17

18

19

20

21

22

23

24

25



1 TESTIMONY OF
2 RICHARD E. BACHER
3 AND
4 THOMAS C. ESSELMAN
5 ON BEHALF OF
6 PACIFIC GAS AND ELECTRIC COMPANY
7 DECEMBER 4, 1978
8 DOCKET NOS. 50-275, 50-323

9 OTHER PIPING SYSTEMS

10 The purpose of this testimony is to briefly sum-
11 marize the content and extent of the work performed by
12 Pacific Gas and Electric Company and Westinghouse Corporation
13 to qualify the piping systems in the Diablo Canyon plant.
14 This testimony will cover all necessary piping except for
15 the reactor coolant loop piping which was the subject of
16 previous testimony presented by Dr. Esselman.

17 These piping systems in the Diablo Canyon plant
18 are designed to meet all the appropriate requirements of 10
19 C.F.R. Part 50, 10 C.F.R. Part 100, and the applicable
20 related codes and standards.

21 The piping systems at Diablo Canyon that were
22 evaluated and qualified for the Hosgri event can be classified
23 into four categories:

24 Steam Cycle - Those piping systems that deliver
25 water to the steam generators and then carry the steam to
26 the turbine. It is that piping necessary to operate the
turbine (Condensate, Feedwater, Main Steam, Reheat Steam,
Extraction Steam, Heater Drains, Make-up and Clean-up, Salt
Water for cooling, Auxiliary Steam--all of which are part of

1 the traditional steam cycle). They are mostly Design Class II
2 and are common to any power plant.

3 Reactor Operation - Those piping systems that are
4 used to control the operation of the reactor during normal
5 operation (Pressure Relief Piping, Residual Heat Removal,
6 Chemical Volume and Control, Charging, Resistance Temperature
7 Detectors). These are integrated with the various emergency
8 systems used to shut down the reactor (Safety Injection,
9 Boron Injection, Accumulators, Relief Valve Piping).

10 Reactor Auxiliaries - The secondary, or auxiliary
11 piping systems, that provide heat sinks to the reactor
12 systems (Component Cooling Water, Containment Spray, Make-up
13 Water, Auxiliary Feedwater, Auxiliary Steam).

14 The Reactor Operation and Reactor Auxiliaries
15 systems are Design Class I Systems with the exception of
16 portions of the make-up water system. These were originally
17 classified as Design Class II, but its design and analysis
18 has been upgraded to Design Class I. Thus, a much larger
19 source of water in a seismically qualified piping system is
20 provided to assure long-term cooldown capabilities for the
21 reactor.

22 Other Piping Systems - The other piping systems
23 that were included in the qualification evaluation are Spent
24 Fuel, Pool Cooling Systems piping, fire system piping,
25 Containment Hydrogen Purge piping and the Radwaste piping.
26

1 The design class and code class delineation of the
2 specific pieces of equipment and its associated piping is
3 shown in the equipment tabulations in the FSAR, Chapter 3.2.

4 The seismic analysis for the Reactor Coolant
5 System Branch Piping was performed by Westinghouse from data
6 supplied by PGandE. The remaining analyses were done by
7 PGandE.

8 The evaluation of the piping is performed per the
9 requirements of the ANSI B31.1 code entitled, "Power Piping".
10 The piping system must meet the Equation 11 of B31.1, i.e.,
11 that sustained load bending stress plus longitudinal pressure
12 stress shall be less than or equal to the code allowable
13 stresses at maximum operating temperature. Generally, the
14 dead load bending stresses are kept below 1500 psi per the
15 recommendation of B31.1. Thus, excessive sag between the
16 supports is prevented and a considerable margin remains to
17 allow for other loading conditions. Furthermore, all piping
18 subjected to thermal expansion and/or differential anchor
19 movements will meet the requirements of Equation 13 of B31.1
20 which establishes that the expansion of the piping caused by
21 temperature changes plus any differential terminal point
22 movements (such as connections to equipment or buildings) be
23 less than or equal to the allowable stress range, S_A . S_A is
24 defined in Equation 1 of B31.1.

25 The allowable piping stresses for seismic design
26 are shown in equation form in Chapter 8 of the Hosgri Report.

1 An allowable is established for each earthquake intensity
2 such that the sum of the primary stresses (dead load, pressure
3 and seismic) are less than or equal to a factor, k , times
4 S_h , the allowable stress at maximum temperature per B31.1,
5 Appendix A, for the material involved. The value of S_h is
6 the lesser of 25% of the ultimate strength, or 67% of the
7 yield strength. The k factor is 2.4 for the Hosgri event.

8 The Hosgri evaluation required reanalysis with a
9 whole new set of response spectra. The spectra used in the
10 analyses were developed from the spectra in Chapter 4 of the
11 Hosgri Report in the manner shown in Figure 8-2 of the
12 Hosgri Amendment. The damping used is tabulated in Table
13 5-1 of the Hosgri Report.

14 Dead load analysis can be done either by simplified
15 techniques or by detailed computer analysis. The objective
16 is to assign support locations on the piping that supports
17 the pipe for all sustained loads and are located in an
18 accessible area for construction.

19 Parallel with this work, the thermal expansion
20 analysis is used to determine the flexibility requirements,
21 anchor locations, and whether rigid or spring supports
22 should be used to control the dead load. The analysis
23 techniques used are generally by detailed computer analysis.
24 PGandE has used techniques identical to those used on Diablo
25
26

1 Canyon for dead load and thermal analysis on approximately
2 20 power generating units. Experience has shown reliable
3 results.

4 Seismic analyses have been accomplished by one of
5 two methods: either by detailed computer analysis or by a
6 "rigid" free span spacing criteria. Chapter 3.7 of the FSAR
7 and Chapter 8 of the Hosgri Amendment describe in detail how
8 each technique is used.

9 The computer analysis is a modal superposition
10 spectral analysis involving both the horizontal and vertical
11 response spectra. Hosgri response spectra are applied along
12 the North-South and East-West directions. A description of
13 the computer programs used in the Hosgri analysis is found
14 in Chapter 8 of the Hosgri Report.

15 The alternate analysis technique is a span length
16 method based on the size of the pipe involved. Chapter 8 of
17 the Hosgri Report describes that for each run of pipe,
18 supports are placed at a distance which will generate a
19 natural frequency of the pipe between supports at 15 Hertz,
20 or higher. This technique was used for piping whose
21 temperatures will not exceed 200 degrees Fahrenheit at
22 diameters up to 6 inches. The supports themselves are
23 arranged so that: (a) lateral translation of the pipe at
24 each support is fixed, (b) each length longer than one span
25 is fixed axially, and (c) concentrated loads (such as valves)
26 are supported directly. Consequently, the response of the

1 piping to seismic excitement will be well within the
2 allowables prescribed by the Codes without requiring
3 detailed seismic analysis. The parameters used for this
4 spacing criteria were checked against the Hosgri spectra by
5 making several detailed computer models of actual plant
6 piping and supports. The piping stress levels and support
7 loads were found to be significantly lower than the predicted
8 stresses and loads used for design purposes. Piping systems
9 designed by this method were, therefore, adequate for the
10 seismic loads.

11 A major step for piping design is the execution of
12 detailed design of the component supports. Component supports
13 can be segregated into categories: springs, snubbers,
14 constant supports, rigids, and anchors. Their use depends
15 upon the degrees of freedom that the engineer intends to
16 control. Standard supports are used wherever possible to
17 reduce specialized design.

18 The stress criteria described were utilized in the
19 analysis of piping systems. The complete results of these
20 Hosgri analyses are tabulated in Chapter 8 of the Hosgri
21 Report as a comparison of the Hosgri pipe stress to the
22 available seismic allowable. Table 8-3 of the Hosgri Report
23 verifies that the Hosgri calculated pipe stresses are all
24 lower than the code allowable stresses. Substantial
25 modifications were required in the supports of the piping
26 systems to accomplish a satisfactory stress state. The

1 modifications are documented in Chapters 8 and 13 of the
2 Hosgri Report: Approximately 900 of 5000 piping supports
3 have been or are being modified.
4 These analyses have verified that piping systems
5 which are required to maintain the reactor coolant pressure
6 boundary to shut down the plant, to maintain it in a safe
7 condition, or to mitigate the consequences of accidents will
8 be available to provide flow and will retain their pressure
9 integrity in case of a postulated seismic event.

10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

mpbl 1 MR. NORTON: The panel is available for cross-
2 examination.

3 CROSS-EXAMINATION

4 BY MR. KRISTOVICH:

5 Q Okay, Mr. Bacher, directing your attention to
6 page 1, lines 14 to 17, you state that these piping systems
7 are designed to meet all the requirements of 10 CFR 50 and
8 10 CFR 100, and the applicable related codes and standards.

9 First of all, what are the applicable codes and
10 standards?

11 A (Witness Bacher) B31.1, ANSI B31.1.

12 Q And what are the appropriate requirements you're
13 referring to?

14 MR. NORTON: Excuse me, Mrs. Bowers.

15 The sentence says:

16 "...the appropriate requirements of

17 10 CFR Part 50, 10 CFR Part 100..."

18 Is he asking him to go through those two sections
19 of the codes and detail each and every requirement from the
20 code that is a requirement?

21 MR. KRISTOVICH: Well, I'll narrow it to:

22 BY MR. KRISTOVICH:

23 Q What specific sections of 10 CFR Part 50 are you
24 referring to here?

25 A (Witness Esselman) Repeat your question, I'm

mpb2

1

sorry.

2

3

Q Which appropriate sections of 10 CFR Part 50
are you referring to?

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

md
ADELON
RELOOM
ws (1C)

A There are a variety of places where requirements
apply to piping. One would be 10 CFR 50.55A, which requires
-- which would specify the general codes. The General Design
criteria would be used. 10 CFR Part 100 specifies that
systems must remain integral in order to perform a shutdown
function, et cetera.

There's a variety of places.

1C
RB/agbl

C7

Q Mr. Bacher, what was the floor response spectra that was used?

A (Witness Bacher) The floor response spectra used was the one that we received from the Blums organization.

Q And was that the one that had been reduced from 1.15 peak instrumental acceleration to 0.75 effective acceleration and then further reduced for tau effect and damping?

MR. NORTON: Mrs. Bowers, every panel has been asked this question and every panel refers to the ones that were supplied. These people are not seismologists. They were supplied with a floor response spectra that's been identified as Chapter Four of the Houszi Report.

These people don't -- you know, they may have sat here and heard that it was this, that and the other thing but they're not experts in that area and they don't know how that floor response spectra was derived.

MRS. BOWERS: Mr. Kristovich, do you want to respond to the objection?

MR. KRISTOVICH: No, I think Mr. Norton just testified and gave us the answer.

MRS. BOWERS: Are you withdrawing the question.

MR. KRISTOVICH: No.

MRS. BOWERS: Well the objection is sustained. These people have said it's not within their expertise.

MR. KRISTOVICH: I never heard that from this panel.

WRB/agb2

MRS. BOWERS: They said they were given the information. They did not develop it themselves.

MR. NORTON: I'll object insufficient foundation and let Mr. Kristovich establish that these people have the expertise to establish a floor response spectra if he thinks he can, however, they stipulate that they can't.

MR. KRISTOVICH: That's not necessary. It's only if they cannot answer the question, if they don't have the knowledge, they can say so. They do not have to look to you to have you tell us they don't know it, they can tell us that and it would be a lot quicker if they did that.

MRS. BOWERS: Well, go ahead with your questioning on it but we certainly think it should be brief.

BY MR. KRISTOVICH:

Q The question is a yes or no question.

Do you remember the question or do you want me to repeat it?

A (Witness Gormly) Yes, I wish you'd repeat the question.

Q Fine.

Mr. Bachar, was this floor response spectra the spectra that started out originally as 1.15g peak instrumental acceleration and was then reduced to 0.75g effective acceleration and then further reduced for tau effect and damping?

A (Witness Gormly) Let me start here at this end

WRB/agb3

1 of the table and we will all answer it.

2 So we do not know and we do not have the expertise
3 to determine that. We are given spectra, they are listed in
4 Chapter Four of the Hosgri Report. We used the appropriate
5 floor spectra for the place where the analysis is being con-
6 ducted.

7 Q Thank you.

8 Mr. Bacher, what damping values were used?

9 Or Mr. Esselman, do you have something to add
10 to Mr. Gormly's comment?

11 A (Witness Esselman) I think Mr. Gormly's statements
12 would apply for the rest of the panel.

13 Q Mr. Bacher?

14 A (Witness Bacher) Indeed,

15 Q Mr. Gangloff?

16 A (Witness Gangloff) I agree.

17 Q -- I don't want to leave you out.

18 A Thank you.

19 Q Mr. Bacher, what damping values were used in the
20 piping systems which your testimony addresses?

21 A (Witness Bacher) May I ask for which earthquakes?

22 Q For the safe shutdown earthquake.

23 A For the Hosgri earthquake, we used 2 percent and
24 3 percent, per Reg. Guide 1.62.

25 Q Do you mean 1.61?

WRB/agb:1

1 A 1.61, I'm sorry.

2 Q And what did you use for the OBE analysis?

3 A Half percent.

4 Q And was that in accordance with Reg. Guide 1.61?

5 A No, it's far less.

6 A (Witness Gormly) That's 50 percent of Reg. Guide
7 allowable. And I think 25 percent, isn't it, Rich, for
8 piping over 12?

9 We used half percent all the way through, is that
10 correct?

11 A (Witness Bacher) Yes.

12 A (Witness Gormly) So it is 50 percent, 25 percent
13 of allowable Reg. Guide damping.

14 Q Mr. Bacher, how were the seismic stresses combined
15 with normal operating loads and stresses?

16 A (Witness Bacher) The seismic stresses, as they're
17 combined, are described in the testimony, namely that the
18 dead load stress plus the pressure stress plus the seismic
19 stress are added together absolutely and then they are com-
20 pared to an allowable.

21 Q Is this method for combining loads in accordance
22 with Reg. Guide 1.92?

23 MR. TOURTELLOTT: I'll object to that question,
24 because it's not really relevant. 1.92 doesn't have anything
25 to do with the subject matter at all.

WRB/agb5

1 MRS. BOWERS: Mr. Kristovich?

2 MR. KRISTOVICH: I haven't heard a reason yet
3 why it doesn't have anything to do with the subject matter.

4 MRS. BOWERS: Well could you tell us why it does?

5 MR. KRISTOVICH: I think that's what the expert
6 witnesses are here for.

7 MR. NORTON: Mrs. Bowers, there's an objection
8 pending and Mr. Kristovich's manner of handling objections
9 is to let the witness answer the question and that'll somehow
10 take care of the objection. Thus it doesn't make a very good
11 ruling on the objection.

12 MR. KRISTOVICH: Mrs. Bowers, Mr. Norton objects
13 because it's not relevant because it has nothing to do with
14 this. I say it is relevant because it has something to do
15 with this.

16 MRS. BOWERS: I think Mr. Tourtallothe objected.

17 MR. KRISTOVICH: Excuse me.

18 MRS. BOWERS: Mr. Norton, who do you agree with?

19 MR. NORTON: Well I don't know what Reg. Guide
20 1.92 says so I can't take a position until I look at it.

21 I've got to get it. Unfortunately the witnesses have it.

22 Mrs. Bowers, I would think the matter could be
23 handled very quickly by Mr. Kristovich saying does Reg.
24 Guida 1.92 apply to the piping, and they could answer yes
25 or no.

NRB/agb6

1 MRS. BOWERS: Well you're following his idea.

2 (Laughter.)

3 MR. NORTON: Well they've got the Reg. Guide
4 in front of them and I don't, and they're capable of reading
5 it and I think they could answer that question.

6 MRS. BOWERS: Let's go back to Mr. Tourtelotte.

7 Why do you think it's not applicable?

8 MR. TOURTELLOTTE: It doesn't apply to the com-
9 bination of normal loads with other loads, that's why it
10 doesn't apply. And my understanding --

11 MR. NORTON: Excuse me, Mr. Tourtelotte. To
12 short-circuit this, the witnesses are all shaking their heads
13 yes and agreeing with what Mr. Tourtelotte said.

14 MR. TOURTELLOTTE: I was going to say I'm
15 not sure that I agree with the way Mr. Norton would phrase
16 the question. The question could be asked of these witnesses
17 as to whether or not 1.92 does apply to the subject matter
18 of their testimony. I guess if they have the Reg. Guide in
19 front of them, they can read the title and it'll explain why
20 it doesn't apply.

21 MRS. BOWERS: Well the objection to the earlier
22 question is sustained.

23 Now if you'll lay a foundation for this, Mr.
24 Kristovich.

25 BY MR. KRISTOVICH:

WRB/agb7

Q Mr. Bachar, does Reg. Guide 1.92 apply to the piping?

A (Witness Bachar) No, sir.

Q Why not?

A (Witness Esselman) We were not required to meet this Regulatory Guide in the analysis of the piping. It post-dated the piping criteria and the implementation allows for substitution of alternative methods of analysis.

Q So then, if I understand you correctly, Reg. Guide 1.92 is applicable to piping, but you just used a different method?

A (Witness Gangloff) No, I believe what he said was the implementation section of the Reg. Guide spells out the plants to which this Regulatory Guide is applicable, and Diablo Canyon is not one of those.

Q I thought that's what I had said.

MR. KRISTOVICH: May I have a moment, please?

MRS. BOWERS: Surely.

(Pause.)

BY MR. KRISTOVICH:

Q Mr. Esselman, does Reg. Guide 1.92 apply to piping?

MR. TOURTELLOTT: That question has been asked and answered, Mrs. Bowers. The answer is yes, it applies to piping, but it doesn't apply to Diablo and it also doesn't

WRB/agb8

1 apply to combined and other loads.

2 MRS. BOWERS: Well can you move off 1.92, since
3 it doesn't apply to --

4 MR. KRISTOVICH: Since I can't move to strike
5 counsel's testimony, I'll move on.

6 (Laughter.)

7 MR. NORTON: I don't think a lawyer reading the
8 Reg. Guide, which I suggest Mr. Kristovich do, is testimony.

9 BY MR. KRISTOVICH:

10 Q Mr. Bacher, how are the stress limits determined?

11 A (Witness Bacher) The allowable stress limits
12 that we designed to?

13 Q Yes.

14 A They were determined by code values.

15 Q B-31.1?

16 A That's one of them, yes.

17 Q And what were the other ones?

18 A We also used a portion of Section Three because
19 B-31.1 does not allow any guidance for what is known as the
20 faulted condition.

21 Q How about B-31.7?

22 A 31.7 was not used for design.

23 Q Were measured material properties utilized in
24 the analysis?

25 A No.

WRB/agb¹

2 Q Mr. Bacher, in some cases, did the Hosgri loads
3 turn out to be less than the original DDE loads?

4 A Excuse me, would you repeat that again, please?

5 Q In some cases, did the Hosgri loads turn out to
6 be less than the original DDE loads?

7 A You did say stresses, Hosgri stresses?

8 MR. NORTON: No, he said loads.

9 WITNESS BACHER: Yes, there are places where
10 Hosgri loads were less than the DDE loads.

11 BY MR. KRISTOVICH:

12 Q Can you give us some examples?

13 A (Witness Bacher) No, I can't. I don't try to
14 memorize where they're located.

15 Q Do you know what percent of the times this
16 occurred?

17 A It's a small percentage.

18 Q Can you give us a number for small?

19 A Not logically, no.

20 Q Well could you explain why this occurs, why in
21 some cases the Hosgri loads would be less than the original
22 double design earthquake loads.

23 A The output load from the analysis is the result
24 of the response of the piping to the input spectra and due
25 to the same set of curves themselves, there are times when
the excitation of the pipe creates a different array of loads

WRB/agblc

1 at the support points.

2 Q Was an OBE analysis performed for the piping
3 systems?

4 A Yes.

5 Q And was the OBE controlling or limiting anywhere?

6 A There may be a few instances where it was,
7 stress values in the pipe.

8 andlc
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 Q Could you give us those examples?

2 A No, sir. Again, I don't memorize that. The
3 stress levels are below the allowables that we need to judge
4 the pipe against. And that's kind of where it ends.

5 Q Do you have a percentage of how many times that
6 occurred?

7 A No, sir, but it would probably be small.

8 Q When you say "small," do you mean less than
9 five percent?

10 A Well, the same as before: it's very difficult
11 to put any kind of numerical value on it. It's little.

12 Q Were the input spectra to the OBE analysis of
13 the piping based on a vertical dynamic analysis?

14 A Excuse me, sir. Mr. Gangloff was speaking to me
15 and I missed your question.

16 Q I'll repeat.

17 Were the input spectra to the OBE analysis of
18 the piping based on a vertical dynamic analysis?

19 A Yes, we had vertical spectra in our analysis.

20 Q Well was this accelerated up by elevations, or
21 did you use the floor level at all elevations?

22 A Well the derivation of the vertical spectrum was
23 used two-third of the floor. --excuse me; two-thirds of the
24 horizontal; excuse me, I'm sorry.

25 Q Of the horizontal at the floor?

1 A (Witness Esselman) For much of the piping the
2 vertical spectra used was two-thirds of ground. For some of
3 the piping the vertical spectra that was used was two-third
4 of the floor acceleration.

5 Q Mr. Eacher, are there any pipe snubbers in these
6 piping systems?

7 A Yes, sir.

8 Q How was snubber failure included in the models,
9 in the seismic models?

10 A The seismic models we did for our piping analysis
11 did not include snubber failure.

12 Q Directing your attention to page 2, line 15,
13 how do you class A, B and C piping systems referred to in
14 FSAR Section 3.2 to correspond to design class 1 and 2?

15 A (Witness Gormly) Mr. Kristovich, let me help
16 hRichard here. He doesn't do that.

17 Q Could you answer, Mr. Gormly, then, or could
18 one--

19 A We had a panel here before where we discussed
20 how systems are selected and which become vital systems and
21 which piping systems must be used. That panel, the people on
22 that panel provide the guidance for the piping group in
23 selection of what classification they would then use. Then
24 based on, given the classification he would take over and
25 do the analysis and evaluate it against the appropriate stress

1 levels for that class of piping. He would not determine
2 whether a pipe ought to be a Class A or a Class B pipe.

3 Q Maybe I was unclear in the question. I just want
4 to know -- and any panel member can answer this: Is there a
5 correlation between Class A, B and C piping systems and design
6 Class 1 and 2?

7 A (Witness Esselman) Yes, sir. Class A, B and C
8 piping make up the Design Class 1.

9 Q So they're all Design Class 1?

10 A Yes, sir.

11 Q Directing your attention to page 3 of the
12 written testimony, at line 13, you begin a sentence on that
13 line and you state, "Generally the deadload bending stresses
14 are kept below 1500 psi per the recommendation of B-31.1."
15 And I'm a little unclear by your use of the term "generally."
16 Do you mean in every case?

17 A (Witness Bacher) There's a recommendation in
18 B-31.1 to maintain the deadload bending stress at approximately
19 less than 1500 psi. But the requirements of the code are that
20 the deadload stress plus the pressure stress be less than or
21 equal to the term S_h which Dr. Esselman described yesterday.

22 Q I'd like to direct your attention to page 4 of
23 the written testimony at line 7. You state, "The K factor
24 is 2.4 for the Hosgri event." And then at page 8-8 of the
25 Hosgri Report....

1 Do you have that there?

WRB/wb4 2 A (Witness Esselman) Will you repeat the page
3 again, please?

4 Q 8-8.

5 Under Section 2 on page 8-3, the second sentence
6 states, "The allowable combined stresses were currently
7 accepted values for faulted conditions, 2.4 S_h for Class B
8 and C piping per ASME Code Case 1606-1, and 3.6 S_h for Class A
9 piping, unchanged from the FSAR Table 5.2-13."

10 Could you explain this apparent contradiction?

11 MR. NORTON: Excuse me, Mrs. Bowers. That's the
12 second time Mr. Kristovich has said "this apparent contra-
13 diction." It may not be an apparent contradiction to engineers
14 who understand the terminology. It may be an apparent
15 contradiction only to Mr. Kristovich. And I think it's an
16 improper question. I haven't objected to it before, but the
17 question can be asked in a way which will prove whether or
18 not there's a contradiction.

19 MR. KRISTOVICH: I'll rephrase the question.

20 MRS. BOWERS: Well the objection is sustained.
21 You need a foundation here.

22 BY MR. KRISTOVICH:

23 Q Is there a contradiction between these two
24 statements that were read?

25 A (Witness Esselman) No, sir. This was discussed

1 WRB/agbl

2 flwsWRB/wb4

3 yesterday and the criteria is correctly stated on Page 8-8 of
4 the Hosgri Report. The testimony indicates that we did not
5 exceed a value of 2.4 S_h .

6 Q Mr. Bacher, are there any cases where the pipe
7 is allowed to go into the inelastic mode?

8 A The piping codes that were used have stress limits
9 which do exceed the yield stress. These are allowed by the
10 codes that were used.

11 Q I'd like to direct your attention to page 7,
12 lines 8 and 9.

13 How did you verify that piping will retain their
14 pressure integrity in case of a postulated seismic event?

15 A The piping codes that we use assure this. By
16 meeting the codes which are designed to protect the structure
17 integrity of the piping, we assure that the pressure integrity
18 of the piping will be maintained.

19 Q Mr. Bacher, was aging accounted for in the Hosgri
20 re-analysis of piping?

21 MR. NORTON: Same objection as before, there's no
22 foundation that aging is a requirement. I thought Mr. Gormly
23 and Dr. Esselman laid that to rest on the last panel.

24 MRS. BOWERS: Well the objection is sustained,
25 and primarily because of the use of the word "aging." Now
you may be able to get where you want to go.

BY MR. KRISTOVICH:

WRB?agb2

1 Q Mr. Bacher, is aging required as part of the Hosgri
2 re-analysis?

3 A (Witness Bacher) No.

4 Q Is a re-analysis valid for 40 years?

5 A Yes.

6 Q Could you describe how service life of the piping
7 is taken into consideration?

8 A (Witness Esselman) As we described in the dis-
9 cussion on this subject from the last panel, this code,
10 as well as other codes, have built into it in the stress limits
11 and in the way the loads are combined and in the stresses
12 that need to be compared to the loads, a protection against
13 cyclic service, cyclic life and transients over the life of
14 the plant. Protection against that event is inherent in the
15 codes that we used.

16 MR. KRISTOVICH: No further questions.

17 MRS. BOWERS: Mr. Tourtellotte?

18 MR. TOURTELLOTT: No questions.

19 EXAMINATION BY THE BOARD

20 BY MR. BRIGHT:

21 Q I just have a minor clarification.

22 On Page Seven, you say:

23 "At least 900 to 5000 piping supports
24 have been or are being modified."

25 Is it fair to assume that, at most, the 4100 that

WRB/agb3

1 are not being modified did not need to be modified and were
2 shown to not need it because of your analysis?

3 A (Witness Gormly) I think those numbers came out
4 of the first-day testimony. And I think what we're saying
5 is that all these pipe supports have been evaluated, they
6 have been verified, they do meet the criteria. We have to
7 modify at least 900 of them to meet the Hosgri-type loading.

8 Q But not the other 4100?

9 A Well I think that's right, yes, not the other
10 4100. They have been verified, we don't think we have to
11 modify them.

12 Q All right. Thank you.

13 MRS. BOWERS: The Board has no further questions.

14 Mr. Norton?

15 MR. NORTON: No redirect.

16 MR. KRISTOVICH: No further questions.

17 MRS. BOWERS: Mr. Tourtellotte, did the Board's
18 questions stimulate you to vigorous further cross-examination?

19 MR. TOURTELLOTTE: Well it certainly stimulated
20 me, but not to vigorous further cross-examination.

21 (Laughter.)

22 MRS. BOWERS: Is that the last word?

23 MR. TOURTELLOTTE: I hope so.

24 (Laughter.)

25 MR. NORTON: Mr. Tourtellotte is a man easily

WRB/agb4

1 stimulated, I can see.

2 (Laughter.)

3 MRS. BOWERS: Mr. Norton, this appears to end
4 the panel.

5 MR. NORTON: No, we have one more panel,
6 Electrical Equipment and Instrumentation.

7 MRS. BOWERS: Oh, yes.

8 MR. NORTON: We'd like to take five minutes while
9 we change panels.

10 MRS. BOWERS: When you say five minutes, I hope
11 you mean five minutes. Everybody seems to go over-
12 looking.

13 MR. NORTON: I mean it, but I have no control over
14 the others.

15 (Witness panel excused.)

16 MRS. BOWERS: Well, we'll take a five-minute
17 recess.

18 (Recess.)

19
20
21
22
23
24
25

1 MRS. BOWERS: Can we proceed? May I have your
2 attention, please? We'd like to proceed.

3 MR. NORTON: Mrs. Bowers, I don't want to get into
4 a protracted discussion, but I thought we were going to hear
5 about Dr. Brune. It really doesn't do us any good to not hear
6 about Dr. Brune until Monday sometime, because we have to get
7 our people here and we have to notify them so they can make
8 plane reservations, and so on.

9 Based on yesterday, we called last night and told
10 them it looks like you should be here Tuesday late afternoon
11 or Tuesday evening, because Dr. Brune will go on Wednesday
12 morning. And unless we get a change now, we certainly can't
13 call and notify them on Monday to be here Monday.

14 MRS. BOWERS: Mr. Kristovich?

15 MR. KRISTOVICH: Mrs. Bowers, Mr. Fleischaker made
16 efforts yesterday afternoon and evening. He tried to contact
17 Dr. Brune's office and could not reach the secretary.

18 He contacted Dr. Brune's home. Dr. Brune's wife
19 wasn't there. Mr. Fleischaker spoke to his child who did not
20 know where Dr. Brune was.

21 MRS. BOWERS: I thought Dr. Brune was in Texas.

22 MR. KRISTOVICH: But we're trying to figure out
23 where in Texas, and Mr. Fleischaker wasn't able to ascertain
24 that. So as of now, the situation is still the same.

25 MR. NORTON: I thought Mr. Fleischaker said he had

wel 2

1 talked to Dr. Brune yesterday, or day before yesterday, when
2 he was in Texas.

3 MR. KRISTOVICH: I think it was before he went
4 to Texas.

5 MR. NORTON: Oh, okay.

6 MR. KRISTOVICH: So Mr. Fleischaker tried, but
7 there's no change.

8 MR. NORTON: Well, then, we assume Dr. Brune will
9 be here Wednesday morning and we'll have our people here
10 Tuesday. Because, you know, there's no way we can --

11 MRS. BOWERS: Was he going to continue to try to
12 reach Dr. Brune?

13 MR. KRISTOVICH: I'm sure he will. But as of now,
14 I can only say the situation is the same.

15 MR. NORTON: Our problem, Mrs. Bowers, is that if
16 we don't notify them now, there's no way they can get here
17 Monday to be ready for Tuesday morning.

18 MRS. BOWERS: Well, he's in Houston?

19 MR. KRISTOVICH: I believe so. He's in Texas.

20 (Laughter.)

21 MRS. BOWERS: Well, so many of the scientific
22 assemblies are at the Shamrock Hilton in Houston. And of
23 course at a meeting like that I'm sure there's a bulletin
24 board for messages.

25 Well, you know, keep trying, and if you are able

wel 3

1 to get in touch, do you know how to contact Mr. Norton?

2 MR. NORTON: I'm in California.

3 (Laughter.)

4 MR. NORTON: All right. This is the final panel,
5 Electrical Equipment and Instrumentation. It is the same
6 three gentlemen we've had before. In addition, we have R.
7 Alyn Young as the panel member who is going to summarize the
8 testimony.

9 MRS. BOWERS: Is he the same person as Robert A.
10 Young?

11 MR. NORTON: Yes. That's Alyn.

12 (Laughter.)

13 WITNESS YOUNG: May I comment that that's Alyn with
14 a "y."

15 Whereupon,

16 H. JAMES GORMLY

17 THOMAS C. ESSELMAN

18 WILMER C. GANGLOFF

19 and

20 ROBERT A. YOUNG

21 were called as witnesses on behalf of the Applicant and,
22 having been previously duly sworn, were examined and testified
23 as follows:

24 DIRECT EXAMINATION

25 BY MR. NORTON:

WEL 4

1 Q Alyn, would you summarize the testimony, please?

2 A (Witness Young) The purpose of the testimony is to
3 summarize the programs undertaken by Pacific Gas & Electric
4 Company and Westinghouse to qualify the electrical equipment
5 for service at Diablo Canyon.

6 The equipment included in the program ranged from
7 power handling equipment, such as large circuit breakers and
8 transformers, through safety function controlling equipment,
9 motor starters, et cetera, and instrumentation and alarming
10 systems.

11 In 1968 and 1969 PG&E was preparing specifications
12 for equipment that included seismic qualifications which we
13 felt were appropriate at the time.

14 We have lived always in a seismic zone, and have
15 always been aware of seismic concerns.

16 Westinghouse at that time was also developing
17 programs to qualify electrical equipment.

18 Around 1973 and 1974 the IEEE was developing a
19 new standard upgrading to current technological standards, and
20 included the advancements in technology to more adequately and
21 realistically qualify the equipment.

22 The new procedures in general included multi-
23 frequency, multi-axis testing, more detailed monitoring and
24 more documentation.

25 When the Hosgri reevaluation program began, both

wel 5

1 PG&E and Westinghouse undertook to reevaluate the existing
2 documentation to ascertain its relevance to the new situation
3 and what qualifications it did provide.

4 These programs basically were conducted in two
5 phases. The first phase was to review the existing documenta-
6 tion in light of the Hosgri requirements, and if found lacking
7 a program was undertaken to demonstrate the adequacy of the
8 equipment, using later technology and programs.

9 Part of the Westinghouse included justifying all
10 of the existing testing which they had done previously. This
11 was done generally under the scrutiny or observance of the
12 NRC to demonstrate or to show that the testing that they had
13 done was, indeed, adequate.

14 The second phase of their program included
15 verification to the NRC that their tests did, indeed, provide
16 qualification for the equipment specifically installed at
17 Diablo Canyon.

18 Most of this work has all been reviewed by the
19 NRC Staff. They conducted thorough audits at both our
20 facilities and at Westinghouse to verify this program and
21 the results.

22 In addition to testing the electrical equipment,
23 we reanalyzed the supports for our raceway system, which sort
24 of makes the system complete, so that we felt we could, indeed,
25 demonstrate that the total electrical equipment and

wel 6

1 appurtenances would be satisfactory.

2 The conclusions of all of this reevaluation we
3 feel demonstrates that the equipment is suitable for service
4 at Diablo Canyon.

5 Q Mr. Young, are there any corrections to the
6 testimony?

7 A No, sir.

8 Q Does each member of the panel adopt the testimony
9 as their own?

10 A (Affirmative indications from all panel members.)

11 MR. NORTON: Let the record show that they all
12 said yes.

13 Mrs. Bowers, at this time we'd ask that the
14 testimony entitled, "Electrical Equipment and Instrumentation"
15 be physically placed in the record as though read, and the
16 panel is passed for cross-examination.

17 MR. KRISTOVICH: No objection.

18 MRS. BOWERS: Mr. Tourtellotte, the testimony has
19 been offered.

20 MR. TOURTELLOTTE: No objection.

21 MRS. BOWERS: The testimony will be physically
22 incorporated within the transcript as if read.

23 (Document follows:)

24

25

1 TESTIMONY OF
2 THOMAS C. ESSELMAN
3 AND
4 ROBERT A. YOUNG
5 ON BEHALF OF
6 PACIFIC GAS AND ELECTRIC COMPANY
7 DECEMBER 4, 1978
8 DOCKET NOS. 50-275, 50-323

9 ELECTRICAL EQUIPMENT AND INSTRUMENTATION

10 The purpose of the testimony is to briefly summarize
11 the content and extent of the work performed by Pacific Gas
12 and Electric Co. and Westinghouse Electric Corporation to
13 qualify the safety-related electrical equipment in the
14 Diablo Canyon Nuclear Power Plant for the postulated Hosgri
15 earthquake. A program was undertaken to use current technology
16 to seismically qualify all safety-related electrical equipment.
17 This seismic qualification program and associated activities
18 meet the applicable requirements of 10 CFR 50 and 10 CFR 100.
19 The program included various categories of equipment such as
20 power handling equipment (i.e. circuit breakers, power
21 transformers), power and safety function controlling equipment
22 (i.e. motor control, reactor control and protection systems),
23 instrumentation, including sensors, transmitters and indicators,
24 as well as emergency lighting and warning and alarm equipment.
25 A complete list is shown in Figure 1. The details of the
26 qualification program are provided in Section 10 of the
Hosgri Report.

Background

In the late 1960's, PGandE engineering began writing specifications for electrical equipment for Diablo Canyon. Specifications written at that time included requirements for seismic qualifications of all safety-related equipment. Specifications were written in a manner reflecting the state of the art for seismic qualification at that period in time. At approximately the same time, when the need to demonstrate the seismic adequacy of electrical equipment became an industry wide requirement, Westinghouse initiated the development of test methods to seismically qualify this class of equipment. The methods developed by Westinghouse ultimately became the national IEEE-344-1971 Standard and were adopted throughout the industry as the method used to qualify equipment for nuclear power plant applications.

Electrical equipment and instrumentation furnished with the Nuclear Steam Supply System (NSSS) and similar equipment and instrumentation in the balance of plant was subjected to tests consisting of vibration testing of representative types of each major category of equipment -- such as switchgear, process control cabinets, transmitters, etc. The test inputs were severe, single frequency, single axis inputs using a sine beat wave form.

The procedure for demonstrating seismic adequacy of the Diablo Canyon equipment was to take the peak floor

1 acceleration in units of "gravity" (g's) at the equipment
2 mounting location and compared that value to the largest
3 test acceleration input applied near the building dominant
4 resonant frequency. If the test acceleration was higher
5 than the original Double Design Earthquake, the equipment
6 was considered qualified. Figure 2 shows a comparison for
7 the original seismic requirements at Diablo Canyon. Other
8 equipment was considered qualified to the original requirements
9 as a result of various testing and analytical methods employed
10 at that time.

11 In late 1973 and early 1974 the Institute of
12 Electrical and Electronics Engineers began a major rewrite
13 of Standard 344 and the revised standard was formally issued
14 as IEEE Standard 344-1975. The revised standard reflects
15 the advancement of the technology in the area of seismic
16 qualification by test which occurred between 1969 and 1975.
17 Briefly, the new requirements include: 1) multi-frequency,
18 multi-axis inputs which envelope the required response
19 spectra; 2) more elaborate and sophisticated electrical
20 circuit monitoring during the test; and 3) extensive docu-
21 mentation for both the generic tests and later for the
22 application of the generic tests to specific plant require-
23 ments. The major differences are summarized on Figure 3.

24 Hosgri Evaluation

25 As a result of the NRC requirements related to the
26 postulated Hosgri event, PGandE and Westinghouse undertook a



1 re-evaluation of all safety related equipment to current
2 seismic standards. This re-evaluation was done in two
3 phases. This is shown in Figure 4. Phase I consisted of
4 reviewing the documentation which had been originally
5 furnished by vendors to demonstrate seismic adequacy. This
6 review consisted of comparing the existing documentation
7 with the new requirements generated as a result of detailed
8 structural analysis of the building and structures for the
9 postulated Hosgri spectra (Chapter 4 of the Hosgri Report).
10 This phase of the re-evaluation also included some in-situ
11 testing at the plant.

12 Phase II of the re-evaluation program consisted of
13 seismically testing in a laboratory that equipment for which
14 adequate qualification could not be demonstrated by review
15 of previously available documentation. Equipment was removed
16 from Unit 2 at Diablo Canyon and delivered to a testing
17 laboratory. Typical components representative of equipment
18 installed at Diablo Canyon were included in this program.
19 Types of equipment included in this program varied from
20 4,000 volt switchgear to dc batteries to control board push
21 buttons. Approximately 25 different components were included
22 in the test program. These components were divided into
23 seven groups and each group was tested to the required
24 response spectrum which was derived from the analysis of the
25 various buildings and structures at Diablo Canyon and were
26



1 representative of the location of the equipment in the
2 plant. Figure 5 shows the equipment and groupings.

3 This re-testing program was conducted in accordance
4 with current standards for seismic qualification testing
5 which are IEEE Standard 344-1975, and Regulatory Guide
6 1.100. Each piece of equipment was mounted on a shake table
7 in a manner representative of its actual mounting configuration
8 in the plant and subjected to multi-frequency, multi-axis
9 test input vibrations. The response spectra of the shake
10 table motion enveloped the required response spectra which
11 was generated by the computer analysis of the plant structures
12 and is representative of the expected floor motion at the
13 location in the plant where the equipment is located. Each
14 piece of equipment was subjected to five tests simulating
15 the operating base earthquake (OBE) and two tests simulating
16 the postulated Hosgri earthquake and was then rotated 90
17 degrees on the table and the tests repeated. During all of
18 these tests the equipment was monitored for proper electrical
19 operation. After this series of tests, each piece of equipment
20 was checked and verified to be in correct operating condition
21 before being re-installed in the plant. The guidelines for
22 this post test check-out are shown in Figure 6.

23 Prior to the Hosgri re-evaluation program and as a
24 result of revision to IEEE Standard 344, the NRC began a
25 supplemental review of all phases of the previous generic
26 qualification tests performed to IEEE Standard 344-1971.

1 The questions raised included: adequacy of the previously
2 used single frequency and single axis tests, adequacy of the
3 monitoring of electrical circuits during the tests, and also
4 the application of the tests to individual plant requirements.
5 To resolve the first two issues which apply to the generic
6 test methods applicable to any site, Westinghouse proceeded
7 with a supplemental seismic qualification program, which was
8 started in the spring of 1975 and completed in May of 1976.
9 The program, which is summarized in Figure 7, re-established
10 the adequacy of the prior generic tests as meeting the
11 intent of IEEE Standard 344-1975. However, the NRC did
12 require an additional effort to establish the adequacy for
13 an individual plant application, such as Diablo Canyon.
14 This was applied for equipment qualified by the "existing
15 documentation" option of Figure 4. The additional require-
16 ments were that the prior tests, in terms of test response
17 spectrum (frequency content and amplitude), be adequate for
18 the Diablo Canyon requirements. A comparison of the test
19 response spectra and the required response spectra was made
20 and the results for each equipment design are summarized in
21 Section 10 of the Hosgri Report. Figure 8 presents a typical
22 comparison that shows the severity of the generic qualification
23 levels relative to the Hosgri requirements. The generic
24 qualification in general is greater by a factor of 2 at the
25 peak of the required floor response spectrum.
26

1 In addition to the past generic reviews, for the
2 Diablo Canyon equipment designs, a special review was conducted
3 by the NRC Staff. . This special review consisted of a new
4 review of the past qualification reports and a review of the
5 plant specific comparison of the test response spectrum for
6 each equipment design. Also, in January, 1978, the NRC
7 Staff performed a detailed audit on specific equipment
8 designs which involved a detailed review of actual test data
9 and calculations. A summary of both the generic and plant
10 specific program for NSSS scope equipment for the Diablo
11 Canyon Plant was presented at the ACRS Subcommittee Meeting
12 held in Los Angeles in June of 1977, and by the NRC Staff at
13 the August, 1978 ACRS Subcommittee Meeting.

14 In addition to the testing and qualification
15 program which we have just outlined for electrical equipment
16 and instrumentation, we analyzed the capability of the
17 supports for electrical raceways to withstand the postulated
18 Hosgri earthquake. As a result of such analyses, modifica-
19 tions were made to 19 out of approximately 600 electrical
20 raceway support details.

21 The conclusions from all of these various technical
22 reviews and the various testing programs conducted to the
23 latest industry standards are that it has been demonstrated
24 that the equipment can perform its intended safety function
25 both during and after the occurrence of the postulated
26

1 Hosgri earthquake and that the qualification conforms with
2 the regulatory requirements.

3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26

FIGURE 1

SUMMARY - SEISMIC QUALIFICATION OF CLASS IE INSTRUMENTATION AND ELECTRICAL EQUIPMENT

PARAGRAPH IN HOSGRI REPORT	ITEM	EQUIPMENT
10.3.1	1.	ANNUNCIATOR, MAIN
10.3.2	2.	AUXILIARY SAFEGUARDS
10.3.3	3.	BATTERY CHARGERS
10.3.4	4.	STATION BATTERY BATTERY RACKS
10.3.5.1 10.3.5.2	5.	DC MOTOR CONTROL CENTER SWITCHGEAR
10.3.6	6.	DIESEL GENERATORS
	6a.	EXCITATION CABINET
	6b.	ENGINE CONTROL CABINET
10.3.7	7.	ELECTRICAL PENETRATIONS
10.3.8	8.	FIRE PUMP CONTROLLER
10.3.9	9.	HOT SHUTDOWN PANEL (FISHER CONTROLLER)
10.3.10	10.	STATIC INVERTER
10.3.11	11.	INSTRUMENT AC PANEL (BREAKERS)
10.3.12	12.	INSTRUMENT PANELS PIA, B&C
10.3.13	13.	LOCAL INSTRUMENT PANELS (INCLUDES SOLENOID VALVES)
10.3.14	14.	LOCAL STARTERS
10.3.15	15.	MAIN CONTROL BOARD
	15a.	SWITCHES AND INDICATORS



FIGURE 1 (CONT'D)
SUMMARY - SEISMIC QUALIFICATION OF
CLASS IE INSTRUMENTATION
AND ELECTRICAL EQUIPMENT

PARAGRAPH IN HOSGRI REPORT	ITEM	EQUIPMENT
10.3.16	16.	NUCLEAR INSTRUMENTATION SYSTEM
10.3.17	17.	P & Δ P TRANSMITTERS
10.3.18	18.	P & Δ P TRANSMITTERS
10.3.19	19.	PROCESS CONTROL & PROTECTION EQUIPMENT
10.3.20	20.	REACTOR TRIP SWITCHGEAR
10.3.21	21.	SAFEGUARDS RELAY BD.
10.3.22	22.	SOLID STATE PROT. SYSTEM
10.3.23	23.	VENTILATION CONTROL, LOGIC
10.3.24	24.	VENTILATION CONTROL, RELAY PANEL
10.3.25	25.	VITAL LOAD CENTER
	25a.	AUXILIARY RELAY PANEL
	25b.	FAN COOLER STARTER
	25c.	4160 - 480 VAC TRANSFORMER
10.3.26	26.	VITAL SWITCHGEAR (4.16KV)
10.3.27	27.	RESISTANCE TEMP. DETECTORS
10.3.28	28.	SAFEGUARDS TEST CABINET
10.3.29	29.	CABLE TRAYS
10.3.30	30.	LIMIT SWITCHES
10.3.31	31.	POTENTIAL TRANSFORMERS
10.3.32	32.	EMERGENCY LIGHT BATTERY PACK

FIGURE 2
EQUIPMENT MOUNTING HORIZONTAL ACCELERATION
VERSUS FREQUENCY FOR TESTING - PG&E PLANTS




FIGURE 4
REQUALIFICATION PROGRAM




FIGURE 5
PHASE II REQUALIFIED EQUIPMENT BY TEST GROUP
COMPOSITION BY GROUPS

GROUP I

4.16KV Switchgear
Safeguard Relay Board
Emergency Light System

GROUP II

Diesel Generator Excitation Cubicle
Diesel Generator Control Panel Door
Diesel Generator Control Cabinet Sub-Panel with the following items mounted on the panel:

1. Differential Pressure Switch (two)
2. Contactor (one)
3. Switching Tachometer (one)
4. Time Delay Relays (two)
5. Relays (four)
6. Industrial Control Relays (four)

GROUP III

Ventilation System Relay Sub-Panel
Ventilation System Printed Circuit Board and Power Supply
Annunciator Components (11)

GROUP IV

DC Distribution Panel
Battery Charger
Turbine Lube Oil Starter
Fire Pump Controller
Local Starter (LPF 37)
Battery Cells (two)

GROUP V

Vital Load Center (480v)
Fisher Controller
Local Starter (LPG66)
100amp Breakers (two)
Starters (seven)
Auxiliary Relay Panel (480v Bus 2H)
Auxiliary Relay Panel (Bus G)

GROUP VI

Local Starter (LPF 36)
Snap-Lock Limit Switch (two)

GROUP VII

Switches (six)
Ammeter

FIGURE 6

GUIDELINES FOR POST TEST CHECK OUT

The following guide lines were implemented prior to the Reinstallation of equipment which was seismically tested in off-site laboratories.

All non-functional portions of equipment were checked and, when necessary, repaired for any of the following which may have occurred during testing or shipping:

1. Check for any deformation of equipment or housing.
2. Check for indications of broken welds, such as cracked paint.
3. Check all screws and bolts for tightness.
4. Check for any frayed wire near sharp edges.
5. Check for any wires which may have loose terminations or are disconnected.

All functional portions of equipment were checked and tested as described below:


1. Check trip settings of all relays.
2. Check calibrations on all meters and instruments.
3. Check physical operation of all switches.
4. Check that all relays and printed circuit boards are properly connected in their sockets.
5. Do any special testing as required by the engineers (i.e., 8 hour discharge test on batteries)
6. Perform a Dry-Run-Test and Start-up test as a final check to assure that all equipment is fully operational in its' plant function.
7. Document everything which was checked, found in error (including the actual setting value) and all corrective actions taken.

FIGURE 7

SUPPLEMENTAL QUALIFICATION PROGRAM FOR GENERIC EQUIPMENT

- **DEMONSTRATE THE ADEQUACY OF THE 10 CYCLE PER BEAT SINE-BEAT**
- **NRC STAFF FIELD INSPECTION OF "AS-INSTALLED" EQUIPMENT**
- **DEMONSTRATION TEST PROGRAM**
 - **STATIC INVERTER AT 85% POWER WITH BI-AXIAL SINE-BEATS (1975)**
 - **FOXBORO PROCESS CONTROL EQ. BI-STABLES MULTI-FREQ. & AXIS (1975-76)**
 - **WCID 7100 PROCESS CONTROL EQ. BI-STABLES MULTI-FREQ. & AXIS (1975-76)**
 - **WCID 7300 PROCESS CONTROL EQ. BI-STABLES MULTI-FREQ. & AXIS (1975-76)**
 - **NIS CABINETS BI-STABLES MULTI-FREQ. & AXIS (1975-76)**
 - **TYPICAL RELAY REPORT**
- **COMPARISON OF SINE-BEAT RESPONSE SPECTRA TO ACTUAL INDIVIDUAL PLANT REQUIREMENTS FOR PLANTS REQUIRING CERTIFICATION TO IEEE-344-1975**

FIGURE 8
RESPONSE SPECTRA COMPARISON -
NUCLEAR INSTRUMENTATION SYSTEMS AND SSPS



wel 7

1 MRS. BOWERS: Mr. Kristovich?

2 CROSS-EXAMINATION

3 BY MR. KRISTOVICH:

4 Q Mr. Young, directing your attention to page 7, line
5 13, of the written testimony, what August 1978 ACRS Subcom-
6 mittee meeting are you referring to?

7 A (Witness Young) That was the one held in Washington,
8 D. C.

9 Q Could it possibly have been in July, June or July,
10 maybe?

11 A Possibly. There were like three meetings right in
12 close proximity there.

13 MR. NORTON: So what?

14 BY MR. KRISTOVICH:

15 Q Directing your attention to page 5 of the written
16 testimony at line 15, could you describe the OBE values
17 utilized in the testing?

18 A (Witness Young) The OBE value used in the testing
19 was taken to be 60 percent of the SSE value.

20 Q And how did you arrive at the figure 60 percent?

21 A It was felt by the specialist at the testing
22 laboratory to be an adequate value, and we concurred.

23 Q What was the basis for your concurrence?

24 A It's my understanding that a 50 percent value is
25 an adequate one. So 60 seemed to be even better.

wel 8

1 Q And what is the basis for the 50 percent figure
2 being adequate?

3 A The 'SSE' value for which we took the 60 percent was
4 the floor response spectrum developed by the Blume organiza-
5 tion. And certainly 50 percent, or even 60 percent, was an
6 adequate value to represent an OBE.

7 Q Were DDE loads in some cases greater than Hosgri
8 loads?

9 A I don't understand that particular question. We
10 didn't evaluate the system on the basis of loads.

11 Q Mr. Young, were the DDE response spectra in some
12 cases greater than the Hosgri response spectra?

13 A I cannot answer that question. I was given the
14 response spectra that we used for the test by the Blume
15 organization.

16 Q Can any other panel member answer that?

17 A (Witness Esselman) For this equipment, I can't
18 answer that without going back and reviewing it. I don't
19 have that information here.

20 Q Mr. Gormly?

21 A (Witness Gormly) To my knowledge, I can't answer
22 the question any better than Bob did. No, I really don't
23 know.

24 A (Witness Gangloff) I think there may be a problem
25 with the question. Inasmuch as this equipment was tested to

wel 9

1 a required response spectrum early on in the game, and then
2 that required response spectrum is compared with the floor
3 spectrum for whatever earthquake.

4 In some cases it was found necessary in the Hosgri
5 reevaluation to retest to a new higher required response
6 spectrum. That means that the floor response was higher not
7 only than the DDE, but also than the required response spectrum
8 used in the original test.

9 It's very difficult at this juncture for us to
10 remember whether or not the particular floor spectra were
11 higher. In some cases we had to change the test basis, and
12 in other cases the original test basis was suitably conserva-
13 tive.

14 Now, whether that was because the DDE was higher
15 than the Hosgri, or whether it was because we were sufficiently
16 above the original DDE, it's difficult to answer that.

17 A (Witness Gormly) I might add, I think I like Wil's
18 answer better than mine.

19 What you're trying to say is that the response
20 spectra was enveloping what any of these test spectra these
21 people use, is that what you're saying?

22 A (Witness Gangloff) That's right. More or less.

23 (Laughter.)

24 We specified originally for the electrical
25 equipment a required response spectrum which would hopefully

1 envelope all the earthquakes associated with this, and in the
2 case of Westinghouse equipment a bunch of other plants. When
3 you get to a particular plant with a particular earthquake
4 you look at the floor response spectrum and say, is the input
5 required now higher or lower than the test input? If it's
6 lower, you say, fine, I'm qualified. If it's above, you say,
7 I need to test to a higher test response spectrum.

8 In some cases we had to retest equipment for the
9 Diablo Canyon plant when we came upon the Hosgri earthquake.
10 In other cases, we did not.

11 It's difficult for us to sit here and say whether
12 the cases where we did not have to retest it was because the
13 Hosgri spectrum was lower than the DDE, or it was because our
14 envelope that we originally selected was sufficiently above
15 the DDE that even though the Hosgri was higher, it still was
16 within the envelope.

17 Q Mr. Young, directing your attention to page 7,
18 line 17, -- well, actually lines 14 through 18, you talk
19 about raceway supports.

20 Are some raceway supports currently being reexamined
21 due to the possibility of inadequate material certifications
22 for the support material?

23 A (Witness Young) I have no knowledge of that.

24 Q Mr. Gormly?

25 A (Witness Gormly) I'm not aware of any investigation

wel 11

1 of that nature.

2 Q Directing your attention to page 7 of the written
3 testimony, line 23, with regard to latest industry standards
4 which you mentioned there, does the seismic testing program
5 include the aging requirements as described in IEEE-323, 1974?

6 A (Witness Young) No, it does not.

7 Q Still on page 7 at line 23, and at the same time
8 I'd like you to get out SER Number 8, page 3-41, and on page
9 3-41 I guess I'm concerned with the last three lines of that
10 page.

11 On page 7 of the written testimony, beginning on
12 line 21, you state:

13 "The conclusions from all of these various
14 technical reviews and the various testing
15 programs conducted to the latest industry
16 standards are that it has been demonstrated
17 that the equipment can perform its intended
18 safety function..."

19 and then you continue.

20 And I'm wondering if, by the term "demonstrated"
21 you mean that various items are yet to be resolved by -- and
22 then on page 3-41, SER-8, "submittal of additional information
23 or if necessary additional testing, or if necessary modifica-
24 tion or replacement of the equipment."

25 A It's quite a complex question. Can we shorten it

wel 12

1 up, or put it all together?

2 Q Sure. I guess I'm asking: Does "demonstrated" as
3 you use it mean outstanding matters can be resolved by sub-
4 mittal of additional information or additional testing or
5 modifications?

6 A Yes, it does.

7 MR. KRISTOVICH: No further questions.

8 MRS. BOWERS: Mr. Tourtellotte?

9 MR. TOURTELLOTTE: No questions.

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

3WEL/mpbl

1

MRS. BOWERS: The Board has no questions.

2

MR. NORTON: No redirect.

3

MRS. BOWERS: May the panel be excused?

4

(Laughter.)

5

MRS. BOWERS: I mean, are you asking?

6

MR. NORTON: Yes, yes to both questions.

7

MRS. BOWERS: You're the one that knows whether

8

some of them are going to be in attendance.

9

MR. NORTON: No. That concludes our direct case.

10

The ball is now in Intervenor's court.

11

MRS. BOWERS: The witnesses are excused.

12

Any objection, Mr. Kristovich?

13

MR. KRISTOVICH: No objection.

14

MRS. BOWERS: Mr. Tourtellotte, any objection?

15

MR. TOURTELLOTTE: Certainly not.

16

(The panel excused.)

17

MRS. BOWERS: Is there any other matter that we

18

could take up at this time?

19

MR. NORTON: I don't believe so.

20

MR. TOURTELLOTTE: Have we decided what we're

21

going to do next week, then? Are we going to start out with

22

Mr. Hubbard Monday morning?

23

MR. KRISTOVICH: That's our intention.

24

MR. TOURTELLOTTE: And then ever how long that

25

takes, we'll go to Dr. Brune, if and whenever he gets here?

WEL/mpb2

1 MR. NORTON: Am I to understand that we're going
2 to start with Mr. Hubbard Monday morning and then we only
3 have Mr. Hubbard until Wednesday morning? I mean, then we
4 have Dr. Brune and there's nothing in between?

5 MR. KRISTOVICH: That's our understanding.

6 MR. NORTON: Well, we're going to have a lot of
7 dead time.

8 MRS. BOWERS: It's not dead time for us. We're
9 going to be preparing for cross-examination of Staff witnesses.

10 Well, we suggested that there might be a possib-
11 ility that Dr. Brune, if contacted, could get here earlier
12 than Wednesday morning.

13 MR. KRISTOVICH: Well, I have nothing to add to
14 what I said before.

15 MRS. BOWERS: And the Staff is still of the opin-
16 ion that they want to proceed with their entire case without
17 interruption?

18 MR. TOURTELLOTT: Well, we're really in a posi-
19 tion where we have none available on those days, Monday
20 and Tuesday.

21 The one person that we discussed having available
22 with Mr. Fleischaker, although Mr. Fleischaker didn't really
23 know whether he even had any questions for him, was Dennis
24 Allison, and he has pneumonia, and I can't do anything about
25 that. It's a little late in the game to change project

mpb3 1 managers for purposes of getting the SER in the record.

2 And I asked David yesterday, David Fleischaker,
3 if there were any questions for Dennis, because we have
4 actually stipulated that the SER is in the record. So if
5 he has no questions for Dennis, that has some bearing upon
6 who I put on first.

7 There's no reason to put Dennis on if there are
8 no questions, unless the Board wants him on, or the Applicant
9 wants him on.

10 So I really have to --

11 MRS. BOWERS: But he won't be here until Wednesday
12 anyway, right?

13 MR. TOURTELLOTTE: Right.

14 The doctor told him not to travel until Wednesday.
15 And he agreed, however, that he would be here Tuesday night
16 anyway, against his doctor's orders. So he will be here and
17 available on Wednesday.

18 MRS. BOWERS: I don't know what else to do except
19 plan to start out with Mr. Hubbard Wednesday morning, and then
20 hopefully contact can be made with Dr. Brune and he can pull
21 up a day or so, a day anyway, on his appearance.

22 But of course, Mr. Horton and Mr. Tourtellotte
23 need to be informed if that's possible.

24 MR. KRISTOVICH: Fine.

25 MR. TOURTELLOTTE: And another thing is, like, if

WEL/mpb4

1 Dr. Brune comes on Tuesday, I have some technical people who
2 will be in Las Vegas, and they will have to cancel out of
3 their meetings in Las Vegas.

4 If, on the other hand, he's not going to be here
5 on Tuesday, they won't cancel out of their meetings. So
6 it's important to --

7 MR. NORTON: Yes, that's the same with us. Our
8 people have other things to do, of course, but they will stop
9 doing those things and be here if Dr. Brune is going to be
10 here. But we've got to know that. We can't tell them to
11 cancel and then come here and sit and wait for Dr. Brune for
12 two days.

13 MRS. BOWERS: I don't know that anything further
14 can be accomplished now.

15 But you will get in touch if you find that the
16 schedule changes for Dr. Brune.

17 MR. KRISTOVICH: Yes.

18 MRS. BOWERS: Is there any other matter before we
19 recess for the day?

20 (No response.)

21 MRS. BOWERS: Mr. Norton, any other matter?

22 MR. NORTON: No.

23 MRS. BOWERS: Mr. Kristovich?

24 MR. KRISTOVICH: We have no other matters.

25 MRS. BOWERS: Mr. Tourtellotte?

WEL/mpb5

MR. TOURTELLOTT: No.

MRS. BOWERS: We will recess for the day.

And I didn't check, but I think we can leave our things here for the weekend.

(Whereupon, at 11:35 a.m., the hearing in the above-entitled matter was adjourned, to reconvene at 8:30 a.m., January 8, 1979.)

