

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

BEFORE THE ATOMIC SAFETY AND LICENSING BOARD

In the Matter of )  
PACIFIC GAS AND ELECTRIC COMPANY )  
Diablo Canyon Nuclear Power )  
Plant Units Nos. 1 and 2 )

---

Docket No. 50-275  
Docket No. 50-323  
(Low Power Test Proceeding)

PROPOSED FINDINGS OF FACT  
AND  
CONCLUSIONS OF LAW

Submitted By  
PACIFIC GAS AND ELECTRIC COMPANY  
June 1, 1981

DS03  
s  
0/1





TABLE OF CONTENTS

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

	<u>Page</u>
I FINDINGS OF FACT . . . . .	1
A. Prehearing Proceedings . . . . .	1
B. Evidentiary Hearing . . . . .	1
C. The Emergency Planning Issue . . . . .	4
1. Factual Background . . . . .	5
2. Risks at Low-Power Operation vs. Full-Power Operation . . . . .	8
3. Comparison of PGandE's Plan With the Standards of 10 C.F.R. 50.47 . . . . .	15
D. The Valve Issue . . . . .	21
1. Pressurizer Safety Valves . . . . .	21
2. Pressurizer Power-Operated Relief Valves .	23
3. Block Valves . . . . .	26
4. Evaluations of Postulated Valve Failures .	27
5. Compliance with GDC's . . . . .	28
6. Electric Power Research Institute (EPRI) Test Program . . . . .	28
7. Conclusion . . . . .	32
E. Legal Argument . . . . .	32
F. Summary . . . . .	33
II. CONCLUSIONS OF LAW . . . . .	35



1 I

2 FINDINGS OF FACT

3 A. Prehearing Proceedings


4 On July 15, 1980, Pacific Gas and Electric Company  
5 (PGandE) filed a motion to permit it to load fuel at its  
6 Diablo Canyon Power plant and conduct tests up to 5% of  
7 rated power. The motion generated successive waves of  
8 pleadings and responses thereto by the Joint Intervenors,  
9 Governor Brown as the representative of an interested state  
10 under 10 CFR 2.715(c) 1/, the Staff and PGandE. Various  
11 orders of the Licensing Board ultimately resulted in a  
12 pre-noticed public hearing in San Luis Obispo, commencing  
13 May 19, 1981, to consider two contentions advanced by the  
14 Joint Intervenors. These contentions are set forth in haec  
15 verba in the discussion below.

16 B. Evidentiary Hearing


17 The hearing was held in San Luis Obispo May 19  
18 through May 22, 1981. At the hearing, the following  
19 exhibits were numbered for identification and, where  
20 indicated, received into evidence:

21 ///

22 \_\_\_\_\_  
23 1/ Governor Brown was admitted to this proceeding as the  
24 representative of an interested state pursuant to 10  
25 CFR 2.715(c) by virtue of an ASLB order dated Novem-  
26 ber 16, 1979. For reasons known only to themselves,  
attorneys for Governor Brown continually misrepresent  
his status in this proceeding. (Tr. 10704, 10705; see  
also the first sentence of the opening statement of  
Byron Georgiou [Tr. 10580].)



	<u>Exhibit No.</u>	<u>PGandE</u>	<u>In Evidence</u>
1			
2			
3	66	View Graph - On Site Monitoring Stations	10772
4	67	View Graph - Off Site Monitoring Stations	10772
5	68	View Graph - Real Time Instruments On Site	10772
6			
7	69	View Graph - Real Time Instruments Off Site	10772
8			
9			
10		<u>Joint Intervenors</u>	
11			
12	<u>Exhibit No.</u>		<u>In Evidence</u>
13	111	PGandE Supplemental Answers to J.I. Interrogatories 9A, 11A	10619
14	112	FES pp. 7-1 through 7-7	
15	113	Proposed forms of low power licenses for Units 1 and 2	
16	114A	Kemeny Com. Report § "Overview"	
17	114B	Kemeny Com. Report § "Commission Findings and Recommendations"	
18	115	Rogovin Com. Report pp. 147 through 152	
19			
20	116	Misc. Agreements with State and Local Agencies	
21	117	Letter R.L. Tedesco to M.H. Furbush 12/16/80	11059
22			
23	118	Risk Assessment Review Group Report pp. viii through x	11107
24			
25	///		
26	///		





1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26


Governor Brown

<u>Exhibit No.</u>		<u>In Evidence</u>
1	Memo - J.W. Macy to J.W. McConnell 3/12/80	11078
2	Letter and Report entitled "EPRI PWR Safety and Relief Valve Test Program"	
3	FEMA-NRC Memo of Understanding 1/11/80	11276
4	Letter to Harold Denton from John McConnell dated February 14, 1980.	11276
5	Letter from Harold Denton to John McConnell dated February 14, 1980	11276
6	Letter to Harold Denton from John McConnell dated March 12, 1980	11276

NRC Staff

<u>Exhibit No.</u>		<u>In Evidence</u>
18	SER Supp. 7	11050
19	SER Supp. 8	11050
20	SER Supp. 9	11050
21	SER Supp. 10	11050
22	SER Supp. 11	11050
23	SER Supp. 12	11050
24	SER Supp. 13	11050
25	SER Supp. 14	11050

///  
///



1 ASLB


2 <u>Exhibit No.</u>		3 <u>In Evidence</u>
4 5	Sheriff's LPZ Evacuation Plan entitled "Standard Operating Procedures for the Nuclear Power Plant Emergency Response"	11329

6 In addition, the Board took official notice of a document  
7 entitled "SECY-81-188-Emergency Preparedness" transmitted  
8 from S.J. Chilk to William Dircks, dated April 22, 1981,  
9 the report of the Kemeny Commission (Exhibits 114A and B),  
10 and the Rogovin Report (Exhibit 115) (Tr. 11269, 11339).

11  
12 C. The Emergency Planning Issue

13 Contention 4. Numerous studies arising out of the accident  
14 at TMI Nuclear Power plant have shown the need for upgrading  
15 emergency response planning. Based upon these studies, the  
16 Commission promulgated revised emergency planning  
17 regulations effective November 3, 1980. The Applicant has  
18 failed to demonstrate that the combined Applicant, State and  
19 local emergency response plans for Diablo Canyon comply with  
20 those revised regulations ("Final Regulations on Emergency  
21 Planning," 45 Fed. Reg. 55402 (August 19, 1980)).

22 Dr. William K. Brunot and Messrs. James D.  
23 Shiffer, Steven M. Skidmore, Will Kaefer, and Robert  
24 Patterson presented evidence on this contention on behalf of  
25 PGandE. Messrs. Bart Buckley, John Sears, and Norm Lauben  
26 testified on behalf of the NRC staff. Governor Brown  
presented the testimony of Robert E. Paulus, Howard  
Mitchell, M.D., and Jeffrey Jorgensen. Joint Intervenors  
chose not to present any direct testimony, although they and  
the other parties conducted cross-examination.



1     1. Factual Background


2             In January 1980 the NRC and the Federal Emergency  
3 Management Agency (FEMA) 2/ issued a joint document  
4 NUREG-0654/FEMA-REP-1 entitled "Criteria for Preparation and  
5 Evaluation of Radiological Emergency Plans and Preparedness  
6 in Support of Nuclear Power Plants - For Interim Use and  
7 Comment."

8             Shortly thereafter, PGandE submitted to the NRC  
9 staff Revision 2 of the Diablo Canyon Power Plant Emergency  
10 Plan. Included as Appendices to that Plan were: (1) the  
11 San Luis Obispo County "Nuclear Power Plant Emergency  
12 Response Plan," (2) the San Luis Obispo County "Nuclear  
13 Power Plant Emergency Evacuation," and (3) the State of  
14 California "Nuclear Power Plant Emergency Response Plan."

15             In February 1980 discussions were had between FEMA  
16 and NRC regarding the applicable criteria for determining  
17 the necessary level of emergency planning for plants con-  
18 sidering low-power testing up to 5% of rated power. These  
19 discussions resulted in a memorandum from the FEMA/NRC  
20 Steering Committee to Harold R. Denton of NRC and  
21 John W. McConnell of FEMA concluding that ". . . in view of  
22 the minimal nature of the potential hazard, the development

23     ///


24 \_\_\_\_\_  
25 2/ On December 7, 1979, President Carter assigned to FEMA  
26 the responsibility for assessing and determining the  
adequacy of state and local radiological emergency  
plans..



1 of specific low power testing criteria [was] not warranted."  
2 The memorandum also concluded that ". . . for purposes of  
3 low-power testing (up to 5% power) at new commercial nuclear  
4 facilities that the public health and safety [would be]  
5 adequately protected if such facility [was] located in a  
6 state which had received a concurrence under the previous  
7 voluntary concurrence program . . . [and] that operator  
8 plans . . . [were] consistent with both the [then] existing  
9 NRC Appendix E to 10 C.F.R. Part 50 and NRC Regulatory Guide  
10 1.101. . . ." The agreement went on to note that California  
11 was a concurrence state and that the Diablo Canyon emergency  
12 plans were in compliance with Appendix E and consistent with  
13 Regulatory Guide 1.101. 3/ (Gov. Brown Ex. 1, Tr. 10946-A).

14 In June 1980 the Commission published NUREG-0694  
15 "TMI-Related Requirements for New Operating Licenses," which  
16 set forth the requirements for fuel-loading and low-power  
17 testing. NUREG-0694, III.A.1.1 and III.A.1.2. The NRC  
18 staff determined in SER Supp. 10 (NUREG-0675) issued in  
19 August 1980 that PGandE met all requirements for low-power  
20 operation according to NUREG-0694. (Staff Ex. 21, Tr.  
21 11050). In August 1980 the NRC issued a new 10 C.F.R. 50.47  
22 together with a revised Appendix E effective November 3,  
23 1980. 45 Fed. Reg. 55402.

24  
25 3/ The then effective Appendix E of 10 C.F.R. Part 50 was  
26 promulgated December 24, 1970, 35 Fed. Reg. 19518 and  
amended January 11, 1973, 38 Fed. Reg. 1272. The NRC  
retains authority over on-site emergency plans.






1           In November 1980 the Commission issued NUREG-0737,  
2 "Clarification of TMI Action Plan Requirements" which among  
3 other matters listed the new emergency planning requirements  
4 including the requirement that licensee applicants comply  
5 with the requirements of the new Appendix E to 10 C.F.R.  
6 Part 50 prior to fuel load. An accompanying letter to  
7 NUREG-0737, signed by Darrell G. Eisenhut and dated  
8 October 31, 1980, directed that an applicant seeking relief  
9 from any element of the new criteria should submit a request  
10 for relief, along with supporting justification. By letter  
11 dated February 27, 1981, PGandE requested relief from Items  
12 III.A.1.1 and III.A.2 of Enclosure 2 to NUREG-0737. The  
13 staff granted that request for relief. (NRC Staff Ex. 21,  
14 pp. III-2, III-3).

15           On April 22, 1981, the Nuclear Regulatory  
16 Commission by a 4-0 vote approved SECY-81-188-Emergency  
17 Preparedness. (Tr. 11269.) By that action, the Commission  
18 clarified the emergency planning requirements for fuel load  
19 and low power testing of NUREG-0737. In that document the  
20 Commission explicitly stated that an applicant for a fuel  
21 load and low-power testing license need not meet each  
22 emergency planning standard of 10 C.F.R. 50.47.  
23 [SECY-81-188, pp. 2-3.]

24           PGandE takes the position that the present level  
25 of emergency preparedness is sufficient to warrant issuance  
26 of a fuel-load and low-power testing license even though it



1 does not meet all the standards and criteria of 10 C.F.R.  
2 50.47 and Appendix E thereto. PGandE relies on the  
3 provisions of 10 C.F.R. 50.47(c)(1) that permit an applicant

4 an opportunity to demonstrate to the  
5 satisfaction of the Commission that  
6 deficiencies in the [emergency] plans  
7 are not significant for the plant in  
8 question, that adequate interim compen-  
sating actions have been or will be  
taken promptly, or that there are other  
compelling reasons to permit plant  
operation


9 to support its application for fuel load and low power  
10 testing authorization.

11 The staff supports PGandE's application on the  
12 grounds that: (1) the FEMA/NRC Steering Committee has  
13 specifically approved the emergency preparedness at Diablo  
14 Canyon for low-power testing and (2) if an accident occurred  
15 during low-power testing, it would release only a fraction  
16 of the small fission product inventory which would produce  
17 insignificant off-site doses and require only minimal  
18 off-site protective actions which are already in place.

19 The Joint Intervenors and Governor Brown oppose  
20 the application contending that all the requirements of 10  
21 C.F.R. 50.47 and Appendix E must be met prior to fuel-load  
22 and low-power testing and that the existing off-site  
23 emergency response plans are unworkable.

24 2. Risks at Low-Power Operation vs. Full-Power Operation

25 PGandE has proposed a series of eight tests to be  
26 conducted at no greater than five percent of rated power.




1 Pursuant to the test program profile submitted by PGandE the  
2 tests would be conducted for no longer than one month and in  
3 actuality would probably take no more than eighteen days.  
4 [Tr. 10726-10728.] During this period four of the tests  
5 would be conducted at around three percent power, two tests  
6 at about one and one-half percent of power and two tests at  
7 shutdown or zero-zero power levels. [Tr. 10727.]

8 Relying, in part, on the foregoing information,  
9 Dr. Brunot concluded that based upon his analysis of the  
10 large reductions of risk during low-power testing in both  
11 the probability and consequences of a wide range of  
12 accidents which are considered possible at full-power  
13 operation, the potential exposures due to design basis  
14 accidents do not require emergency planning for distances  
15 much beyond the site boundary and certainly not beyond the  
16 low population zone (LPZ) (six miles) for plume exposure or  
17 ingestion pathway exposure. [Brunot Testimony following  
18 Tr. 10595, p. 21.]

19 Dr. Brunot based his conclusion with regard to the  
20 reduced potential risks at Diablo Canyon on the following  
21 factors:

- 22 1. Lower fission product inventories.
- 23 2. Reduced decay heat after shutdown.
- 24 3. Time available for emergency  
25 actions.
- 26 4. Reduced hydrogen production rate.



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

- 5. No spent fuel pool accidents.
- 6. Lack of activated corrosion products.
- 7. Lack of radioactive inventory in waste systems.
- 8. Lack of radioactive inventory in the steam generators and secondary systems.
- 9. Few "wear out" problems.

[Ibid. pp. 6, 7.]

In addition to the foregoing risk reduction factors the following factors were considered by Dr. Brunot which tend to increase the risk of an accident during the initial testing period:


- 1. Break-in failures.
- 2. Plant modifications. 4/
- 3. Emergency plan arrangements.
- 4. Uncertainties in performances parameters for components and systems.

[Ibid. p. 8; Tr. 10625, 10626.]

///  
///  
///

---

4/ At the hearing, Dr. Brunot withdrew this risk increasing factor. [Tr. 10623, 10624.]






1 Dr. Brunot evaluated the specific decreases and  
2 increases in overall risk due to each of those factors and  
3 concluded that during low power testing (1) the factors  
4 which decrease overall risk are much greater than those  
5 which tend to increase risk, and (2) that the overall risk  
6 of events leading to accidental releases, as well as the  
7 quantity of radioactive materials involved, is greatly  
8 reduced. [Brunot Testimony following Tr. 10595, pp. 6-9.]

9 Utilizing accident evaluations previously  
10 conducted by PGandE and the staff for full-power operation  
11 pursuant to 10 C.F.R. Part 100, 10 C.F.R. Part 50, and 10  
12 C.F.R. Part 20 predicated upon full-power isotope  
13 inventories and reducing these inventories by a factor of 20  
14 to 400 for low-power testing, Dr. Brunot determined that  
15 comparing these full power accident scenarios with those  
16 that might occur at low power, the exposure risk at both the  
17 site boundary and the LPZ would fall well within permissible  
18 prescribed Environmental Protection Agency and State of  
19 California exposure limits. Additionally, he concluded that  
20 if the many other risk reduction factors at low power as  
21 well as the actual power profile for low-power testing are  
22 also considered, there would be an even further reduction in  
23 any accident dose exposures. [Ibid. pp. 9-11.]

24 Thus, the size of the plume exposure and ingestion  
25 exposure zones which would be appropriate for emergency  
26 response should an accident occur at Diablo Canyon during




1 low-power tests would be much smaller than those required  
2 for full-power operation under 10 C.F.R. Part 50.47. [Tr.  
3 10855-10858.]

4 Dr. Brunot's testimony in this regard is also  
5 supported by the testimony of Mr. Shiffer discussing the  
6 risk reduction factors of (1) additional operator time  
7 available to take necessary action to mitigate any accident  
8 conditions, and (2) the reduced isotopic inventories  
9 produced during low power testing. In his testimony,  
10 Mr. Shiffer indicated that more than three hours would be  
11 available to take action to prevent loss of adequate core  
12 cooling under the accident scenarios developed by the  
13 Westinghouse safety analysis. [See Shiffer, et al.  
14 Testimony following Tr. 10604, pp. 33-37.]

15 Additional testimony on risk reduction was given  
16 by the NRC staff witness Mr. G. Norman Lauben. According to  
17 Mr. Lauben, the NRC staff has carefully examined the  
18 relative risks associated with low-power testing and full  
19 power operation. The conclusion they reached was that three  
20 major factors contribute to a substantial reduction in risk  
21 for low-power testing as compared to full-power operation.  
22 Those three factors are:

- 23 1. Additional time available for  
24 operators to correct loss of  
25 important safety systems.

26 ///




1                   2.    The reduction in risk associated  
2                               with significant postulated events  
3                               during low-power testing.

4                   3.    Reduction in required capacity for  
5                               mitigating systems at low power.

6                               [Lauben Testimony following  
7                               Tr. 11014, p. 2.]

8                   Mr. Lauben examined a number of dominant accident  
9                   scenarios, i.e., small break LOCAs, transients with total  
10                   loss of feedwater, and failure of double check valves  
11                   between the reactor coolant system (high pressure) and the  
12                   residual heat removal system (low pressure) which result in  
13                   a LOCA outside containment. He estimated an overall reduc-  
14                   tion in risk to the public of a factor 400 to 1,500 for a  
15                   plant operated at 5% power from initial start-up for six  
16                   months compared to continuous full power operation.  
17                   Furthermore, based upon his understanding of the actual  
18                   power history of other reactors conducting low-power testing  
19                   at a peak power of 3-4% for a maximum of 20 days, he  
20                   concluded that the public risk is further reduced by a  
21                   factor of about 400-3,000 as compared with long-term full  
22                   power operation. [Ibid. pp. 2-4.]


23                   Additionally, he testified that analyses by Sandia  
24                   Laboratories for LOCAs with severely degraded ECCSs showed  
25                   that a large amount of time would be available at 5% power  
26                   for diagnosis and corrective action to prevent significant



1 core damage. For example, a small four-inch cold-leg break  
2 LOCA would not produce a boil-off condition<sup>1</sup> for about one  
3 hour and core uncover<sup>y</sup> would be delayed until about three  
4 hours. Furthermore, severe core damage would not occur  
5 until 15 hours. For similar conditions at Diablo Canyon, he  
6 testified that uncover<sup>y</sup> would not occur until about four to  
7 five hours, and 20 hours would elapse before significant  
8 core damage would occur based upon extrapolations from  
9 maximum power and duration profiles for actual low-power  
10 testing at the Sequoyah facility. [Ibid. p. 6.]

11 For other transients, i.e., turbine trip, loss of  
12 feedwater, steam line break, steam generator tube rupture,  
13 rod ejection, and ATWS events, Mr. Lauben testified the  
14 total risk reduction is about 1,000 to 20,000 lower compared  
15 to full-power operation. He stated further that even in the  
16 highly unlikely event of a total loss of feedwater and a  
17 failure of the reactor system to scram, it would take 45  
18 minutes to complete boil-off of water in the steam  
19 generators. This amount of time would still allow for  
20 corrective action to terminate the event before the onset of  
21 severe core damage. [Ibid. pp. 7-9; Tr. 11126-11131.]

22 Based on the risk reduction factors enumerated  
23 above, Mr. Lauben concluded that (1) abundant time (at least  
24 20 hours) is available to take corrective action to mitigate  
25 or terminate the most likely accident scenarios during  
26 low-power testing, (2) for some sequences of concern at full





1 power no action would be required at low power, and (3) the  
2 risk to the public is so small at low power that there is  
3 virtually no need for a qualified emergency plan. [Ibid.  
4 p. 9; Tr. 11120-11122.]

5 Thus, the collective judgment of Dr. Brunot and  
6 Messrs. Lauben and Shiffer, who were the only witnesses to  
7 testify on this issue, was that the overall risk to the  
8 public from accidents during low power testing was greatly  
9 reduced as compared to full power operation. Further, they  
10 all concluded that the level of emergency planning as well  
11 as the area for which such planning was required was  
12 substantially reduced or virtually unnecessary when compared  
13 to the requirements of 10 C.F.R. 50.47 for full power  
14 operation.


15 3. Comparison of PGandE's Plan With  
16 the Standards of 10 C.F.R. 50.47.

17 PGandE presented testimony on the sixteen (16)  
18 planning standards enumerated in 10 C.F.R. 50.47(b) as they  
19 are discussed in Revision 2 of its Emergency Plan. 5/  
20 [Shiffer Testimony following Tr. 10604, pp. 4-32; Tr.  
21 10823-10862.]

22 ///


23 ///

24 \_\_\_\_\_  
25 5/ At the Board's request, applicant identified those  
26 parts of its prepared testimony on the Emergency Plan  
which pertained to the 16 emergency planning standards  
of 10 C.F.R. 50.47(b).



1           This testimony outlined the Company's organiza-  
2 tional structure [ibid, pp. 4-6], facilities [ibid pp.  
3 7-10], communications system including dedicated telephone  
4 lines to the County Emergency Operations Center at the  
5 Sheriff's office, the State office of Emergency Services and  
6 the NRC [ibid. pp. 12-15], radiological monitoring  
7 capability [ibid. pp. 16-20; Tr. 10755-10786], and  
8 post-accident sampling capability [ibid pp. 21-23] which  
9 would be available to response to any radiological emergency  
10 during low power testing. The arrangements for medical  
11 services for injured and contaminated personnel [ibid. pp.  
12 24-25] as well as the training sessions and drills held  
13 during the past few years for emergency response personnel  
14 [ibid. pp. 30-31] were identified. Additionally, PGandE  
15 outlined the additional training, drills and exercises  
16 scheduled to commence in June 1981 and expected to culminate  
17 in a full-scale Company, state and local exercise in August  
18 1981 [ibid. pp. 31-32]. Finally, the emergency procedures  
19 for prompt notification of the Sheriff by site personnel in  
20 situations where an evacuation of the LPZ would be  
21 recommended and the response plans of the Sheriff were  
22 identified and discussed [ibid. pp. 33, 38-39].

23           The major areas of deficiency in Revision 2 which  
24 were noted by the NRC in its review of the Plan for full  
25 power operation were identified as items (b)(5) and (b)(7)  
26 which require a fast public alerting system (15 minute .




1 public notification capability) and a public information  
2 program. (Tr. 10837-10844; Sears Testimony following Tr. at  
3 10604, p. 26.]

4 While the public notification system has not yet  
5 been installed and the public information program has not  
6 been implemented as required by 10 C.F.R. 50.47 work is  
7 ongoing in these areas. Permits for installation of the  
8 notification system are expected soon and a draft of the  
9 revised county plan has been completed which should permit  
10 work on the public information program to proceed. [Shiffer  
11 Testimony following Tr. 10604, p. 26; Tr. 10696, 10800,  
12 10818-10819]

13 However, these deficiencies are not significant in  
14 the context of low power operation. The fast alert system  
15 is not a problem since there is abundant time to notify  
16 residents within the LPZ should there be an accident during  
17 low power testing requiring any protective action including  
18 evacuation. There is in effect a County Evacuation Plan for  
19 these approximately 65 residents of the LPZ to be evacuated  
20 upon notification by the Sheriff according to a prearranged  
21 set of detailed plans on file at the Sheriff's office. [Tr.  
22 10839-10841; Board Exhibit 5.] 6/ This plan calls for the  
23 ///


24 \_\_\_\_\_  
25 6/ Inexplicably, Joint Intervenors and Governor Brown  
26 attempted to prevent introduction of this evidence on  
rebuttal after arguing previously that such information  
was the most important issue in the case. (Tr. 11245.)



1 Sheriff to send units to residents located within the LPZ  
2 and also to assist the Department of Parks and Recreation in  
3 an evacuation of Montana De Oro State Park north of the  
4 plant. [Tr. 10839-10841, Board Exhibit 5.]

5 Additionally, PGandE has committed to give  
6 appropriate evacuation information to residents within the  
7 LPZ prior to fuel load. The precise information and  
8 instructions will be based upon the then existing  
9 notification system and will be coordinated with the  
10 Sheriff's Department. [Tr. 10842.]

11 Governor Brown's witnesses, Messrs. Paulus,  
12 Mitchell and Jorgensen, gave testimony concerning several  
13 elements of the PGandE and County Emergency Response Plans.  
14 Mr. Paulus in his prepared testimony outlined several  
15 deficiencies regarding the back-up fire-support to be  
16 furnished by the California Department of Forestry ("CDF")  
17 at Diablo Canyon which caused CDF to cancel its letter of  
18 agreement with PGandE in April of this year. [Paulus  
19 Testimony following Tr. 10895, pp. 2-4.] However, in his  
20 oral testimony, he admitted: (1) that there were no  
21 equipment deficiencies for CDF personnel, (2) that adequate  
22 radiological protection training for CDF personnel would be  
23 completed during the week of May 25, 1981, and (3) that a  
24 CDF internal fire pre-plan would be completed by June 5,  
25 1981, and probably be tested within two weeks assuming  
26 PGandE's cooperation. [Tr. 10908-10909, 10937-10939,






1 10990-10993.] Accordingly, he felt that by July 1, 1981,  
2 CDF would have resolved the major problems it previously  
3 foresaw in furnishing backup fire support for Diablo Canyon  
4 and a new fire support agreement would be executed  
5 supplanting the February 1979 agreement that had been  
6 recently cancelled. [Tr. 10909, 10957.]

7 Dr. Mitchell stated in his prepared testimony  
8 concerns regarding the County's ability to respond to and  
9 effectively monitor a radiological emergency at Diablo  
10 Canyon as well as the number and overall adequacy of medical  
11 care facilities for the treatment of injured persons. Dr.  
12 Mitchell also expressed concern regarding notification  
13 procedures for the evacuation of residents from the LPZ.  
14 [Mitchell Testimony following Tr. 10898, pp. 1-2.]

15 However, in his oral testimony, Dr. Mitchell  
16 admitted that he was pleased with PGandE's expansion of its  
17 off-site monitoring capability as well as its training of  
18 county health personnel, although he still had some concerns  
19 with the response capabilities of his personnel due mainly  
20 to communication problems. He indicated that he had  
21 recently attended an interesting and effective course at Oak  
22 Ridge, Tennessee, concerning treatment of radiation  
23 injuries. As for hospital facilities, he merely stated that  
24 he would like more facilities in addition to French Hospital  
25 to be prepared to treat any injured or contaminated persons.  
26 [Tr. 10909-10913, 10960-10963.]




1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26

Mr. Jorgensen stated in his prepared testimony that the current county emergency plans were inadequate in the areas of training of personnel, equipment, public information, and medical facilities. [Jorgensen Testimony following Tr. 10901, pp. 2-3; Tr. 10899-10901.]

During his oral testimony, however, he admitted that his prepared testimony did not address issues concerning county emergency response capabilities within the LPZ, which is the area of concern for low power testing. [Tr. 10981.] Moreover, he testified that while the Sheriff has a responsibility under the existing County Emergency Plan to evacuate the LPZ in an emergency he was unaware of any detailed plans of the Sheriff to accomplish this task. [Tr. 10970-10975, 10983-10985.]

This question of the responsibility for, and ability of, the Sheriff to evacuate the LPZ was resolved when the County Sheriff, George Whiting, testified that he has the responsibility to evacuate the LPZ and that he has detailed plans to accomplish that action if and when called upon. Those plans call for dispatch of units to homes in the LPZ and assisting in the evacuation of Montana De Oro State Park. [Tr. 11321-11324, 11329; Tr. 11329 Board Exhibit 5.]

///  
///  
///



1           D.    The Valve Issue

2    Contention 24. Reactor coolant system relief and safety  
3    valves form part of the reactor coolant system pressure  
4    boundary. Appropriate qualification testing has not been  
5    done to verify the capabilities of these valves to function  
6    during normal, transient and accident conditions. In the  
7    absence of such testing and verification, compliance with  
8    GDC 1, 14, 15 and 30 cannot be found and public health and  
9    safety are endangered. 7/

10                   NUREG 0737 requires that pressurized water reactor  
11    licensees and applicants shall conduct testing to qualify  
12    the reactor coolant system relief and safety valves under  
13    expected operating conditions for design-basis transients  
14    and accidents. (NUREG 0737 at II.D.1-1.) The tests for  
15    relief and safety valves are to be completed by July 1,  
16    1981. (NUREG 0737 at II.D.1-3.) NUREG 0737 also requires  
17    "verification of block valve functionability" by July 1,  
18    1982. (NUREG 0737 at II.D.1-2.)

19                   The Diablo Canyon reactor coolant systems contain  
20    three types of valves: safety valves; power operated relief  
21    valves (PORVs); and block valves.

22    1. Pressurizer Safety Valves


23                   The pressurizer of each unit of the Diablo Canyon  
24    plant is equipped with three pressurizer safety valves.

25    Under normal operating conditions, the safety valves remain

26    ///

---


7/ PGandE presented four witnesses whose testimony  
addressed this contention and the staff produced two.  
Neither the Joint Intervenors nor Governor Brown pro-  
duced a witness on this contention.



1 closed. Under most postulated accident conditions, the  
2 pressurizer safety valves are not called upon to operate.  
3 In those FSAR accidents analyzed for the Diablo Canyon  
4 plant, the safety valves will not open if the PORVs function  
5 as designed. If the safety valves were required, the  
6 capacity of two safety valves is sufficient to mitigate  
7 system overpressure; the capacity of the third safety valve  
8 provides redundancy. [Gottshall-Muench Testimony following  
9 Tr. 11157, p. 1.]

10 The valves supplied to Diablo Canyon for this use  
11 were designed and manufactured by Crosby Valve and Gage Co.  
12 and are identified as Crosby safety valves model HB-BP-86  
13 (6M6). These safety valves are designed to meet the  
14 requirements of the ASME Boiler and Pressure Vessel Code,  
15 Section III, 1968 Edition. The valve pressure boundary parts  
16 were designed in accordance with USAS-B16.5-1968, Steel Pipe  
17 Flanges and Flange Fittings. In addition to meeting the  
18 requirements of USAS-B16.5-1968 and the ASME Code, Section  
19 III, the safety valves were qualified to continue to operate  
20 during and after the postulated Hosgri seismic event  
21 accelerations. (Ibid. pp. 1, 2; Tr. 11189.)

22 Prior to shipment to the plant, each of the valves  
23 was inspected and subjected to testing. All surfaces of  
24 pressure retaining forgings, castings, finished welds, and  
25 machined surfaces were liquid penetrant inspected. The body  
26 and nozzles were hydrostatically tested. All of the Diablo





1 Canyon safety valves successfully completed these tests.

2 [Ibid. p. 2; Tr. 11187.]

3 As part of the design verification process, valves  
4 of the same design, but with a different inlet, were  
5 successfully tested at PGandE's Contra Costa plant in a  
6 configuration that was representative of the actual Diablo  
7 Canyon plant configuration and at the temperatures and  
8 pressures for which the valves were designed to function.

9 [Ibid. p. 2; Tr. 11187, 11192.]

10 Westinghouse has conducted a survey of Westing-  
11 house designed operating plants in the United States to  
12 determine the number of times that pressurizer safety valves  
13 have actuated during plant operations. No instances of  
14 failure of pressurizer safety valves were reported by the  
15 owners of Westinghouse designed plants in the United States.  
16 This survey covered plants with a total of 181 reactor years  
17 of operation through October 1980. In addition, no  
18 instances of failure have been reported for Westinghouse  
19 plants since the time of the survey. [Ibid. p. 3.]

20 2. Pressurizer Power-Operated Relief Valves

21 The pressurizer of each unit of the Diablo Canyon  
22 Plant is equipped with three pressurizer PORVs. These  
23 valves are designed to relieve steam to limit the maximum  
24 pressure in the reactor coolant system during full load  
25 rejection transients without reactor trip. Under normal  
26 conditions, the PORVs remain closed. In the FSAR accident




1 analyses for the Diablo Canyon plant, credit has not been  
2 taken for the automatic actuation of the PORVs. If  
3 automatic PORV actuation had been considered in the  
4 analyses, the calculated consequences would have been less  
5 severe. Under actual transient conditions the PORVs would  
6 actuate prior to the safety valves since the PORV setpoint  
7 is lower. [Ibid. p. 3.]

8 The valves supplied to Diablo Canyon for this use  
9 were designed and manufactured by Masoneilan International  
10 and are identified as Masoneilan Model 20000 series. The  
11 valves are designed to be leak tight at the hydrostatic test  
12 pressure. The valve bodies, bonnets and flanges were  
13 designed and built to USAS-B16.5-1968 and MSS-SP-61. In  
14 addition to the requirements of these standards, the PORVs  
15 were qualified to continue to operate during and after the  
16 postulated Hosgri seismic event accelerations. [Ibid. p. 4;  
17 Tr. 11189.]

18 Prior to shipment to the plant, each of the valves  
19 was inspected and subjected to testing. All pressure  
20 boundary cast steel parts were radiographed and liquid  
21 penetrant inspected. All forged parts were liquid penetrant  
22 inspected. Tests on the assembled valves included a  
23 hydrostatic test, as well as backseat and seat leakage  
24 tests. All of the Diablo Canyon PORVs successfully  
25 completed these tests. [Ibid. p. 4.]


26 ///



1           As part of the design verification process, valves  
2 of the Model 20000 series were successfully tested in a  
3 thermal test loop at 2485 psig and 550°F. [Ibid. p. 4; Tr.  
4 11188.]

5           After installation in the Diablo Canyon plant,  
6 these valves were successfully tested during hot functional  
7 testing. In addition, Masoneilan Model 20000 series valves  
8 are installed in six Westinghouse designed operating plants  
9 in the United States and have also been successfully tested  
10 during hot functional testing. [Ibid. p. 5.]

11           Westinghouse has conducted a survey of Westing-  
12 house designed operating plants in the United States to  
13 determine the number of times that pressurizer PORVs have  
14 been opened during plant operations. This survey covered  
15 plants with a total of 181 reactor years of operation  
16 through October 1980. Responses to the survey indicated  
17 that there were 163 occurrences of PORV openings with no  
18 failures to close. Of these occurrences, 59 of them  
19 involved Masoneilan Model 20000 series valves. In addition,  
20 there have been no known failures of these valves in these  
21 plants since October 1980. [Ibid. p. 5.] There has been  
22 one instance of a PORV failure to close in a foreign plant  
23 which was associated with the failure of a yoke. The yoke  
24 which failed is not the same as those used at Diablo Canyon  
25 and has no bearing on Diablo valves. [Tr. 11185, 11189,  
26 11212.]



1       3.    Block Valves


2                   The pressurizer of each unit of the Diablo Canyon  
3 plant is equipped with three block valves.  These valves are  
4 located upstream of the pressurizer PORVs and are provided  
5 to isolate the inlets of the PORVs for maintenance and  
6 testing.  [Ibid. p. 5.]

7                   The block valves supplied to Diablo Canyon for  
8 this use were designed and manufactured by Velan Engineering  
9 Companies and are identified as Velan Model B10-354B-13MS.  
10 The valve pressure boundary parts are designed in accordance  
11 with USAS-B16.5-1968.  The block valves were qualified to  
12 withstand loading due to the Hosgri seismic event  
13 accelerations in addition to normal operating and deadweight  
14 loads.  [Ibid. pp. 5, 6; Tr. 11189.]

15                   Prior to shipment to the plant, each of the valves  
16 was inspected and subjected to testing.  All surfaces of  
17 pressure containing cast parts were radiographed and liquid  
18 penetrant inspected.  Tests on the assembled valves included  
19 a hydrostatic test, as well as backseat and seat leakage  
20 tests.  All of the Diablo Canyon block valves successfully  
21 completed these tests.  [Ibid. p. 6.]

22                   Velan-manufactured block valves are installed in  
23 twenty-one Westinghouse designed operating plants in the  
24 United States.  There have been no known failures of these  
25 valves in these plants.  [Ibid. p. 6; Tr. 11189.]

26    ///






1     4.     Evaluations of Postulated Valve Failures

2             Westinghouse has performed analyses of postulated  
3     loss of coolant accidents (LOCAs) in the pressurizer vapor  
4     space for a plant substantially identical to the Diablo  
5     Canyon plant.  These analyses were performed for 100 percent  
6     power level.  The conclusions which follow are valid and  
7     conservative for five percent power level.  [Ibid. p. 7; Tr.  
8     11189-11191.]

9             Analyses performed included the extremely unlikely  
10    case that all three pressurizer PORVs of the size installed  
11    at Diablo Canyon were postulated to have stuck completely  
12    open.  These analyses were performed with the NRC approved  
13    evaluation model, which includes the assumption of minimum  
14    safeguards.  No core uncovering was predicted to occur.  
15    Therefore, if all three of the pressurizer PORVs failed  
16    completely open at Diablo Canyon, no core uncovering would be  
17    expected.  [Ibid. p. 7.]

18            It should be noted that these PORV LOCA analyses  
19    also assume that the pressurizer block valves failed to  
20    close.  Therefore, if all of the pressurizer PORVs failed  
21    completely open and if all three block valves failed to  
22    close at Diablo Canyon, no core uncovering would be expected.  
23    [Ibid. pp. 7, 8.]

24            Similarly, analyses performed enveloped the  
25    extremely unlikely case that all three pressurizer safety  
26    valves of the size installed at Diablo Canyon were




1 postulated to have stuck completely open. These analyses  
2 were performed with the NRC approved evaluation model, which  
3 includes the assumption of minimum safeguards. No core  
4 uncovering was predicted to occur. Therefore, if all three of  
5 the pressurizer safety valves failed completely open at  
6 Diablo Canyon, no core uncovering would be expected. [Ibid.  
7 p. 8.]

8 5. Compliance with GDC's

9 Based on the information presented above, the  
10 PGandE and NRC witnesses concluded that the pressurizer  
11 safety valves, PORVs, and block valves, which are part of  
12 the reactor coolant pressure boundary, comply with the  
13 applicable regulatory requirements, including GDC's 1, 14,  
14 15, and 30. [Ibid. p. 8; Cherny Testimony following Tr.  
15 11216, pp. 6, 7.]

16 6. Electric Power Research Institute (EPRI) Test Program

17 In August 1979, the TMI Ad Hoc Nuclear Oversight  
18 Committee requested EPRI to develop a generic valve testing  
19 program responsive to the recommendation contained in  
20 NUREG-0578, Section 2.1.2 "Performance Testing for BWR and  
21 PWR Relief and Safety Valves," which is now Item II.D in  
22 NUREG-0737. Such a program was developed by EPRI and  
23 submitted to the NRC July 8, 1980. The total program cost  
24 is approximately \$18,000,000 and is supported by  
25 contributions from 41 electric utilities with pressurized  
26 water reactors, including PGandE. Under the program, safety




1 and relief valve testing is scheduled to be completed by  
2 July 1, 1981 which is prior to fuel loading. As stated  
3 previously (supra, p. 21) under NUREG-0737 block valve  
4 testing must be completed by July 1, 1982 (Carey-Auble  
5 Testimony following Tr. 11159, pp. 1, 2; Cherny Testimony  
6 following Tr. 11216, pp. 5, 6; Tr. 11165.)

7 The current EPRI program covers the testing of  
8 safety and relief valves. The qualification of associated  
9 control circuitry, piping and supports as required in  
10 NUREG-0737 will be covered in a report to be filed shortly  
11 by PGandE. [Tr. 11173, 11225.]

12 The overall objective of the EPRI PWR Safety and  
13 Relief Valve Test Program is to obtain full scale data on  
14 the operational performance of pressurized water reactor  
15 primary system relief and safety valves under expected  
16 operating conditions for design basis transients and  
17 accidents by July 1, 1981. It is expected that PWR  
18 utilities will utilize this data to support plant specific  
19 submittals in response to safety and relief valve test  
20 requirements, first identified in NUREG 0578 and subse-  
21 quently clarified in NUREG 0737, Item II.D.1A. [Carey-Auble  
22 Testimony following Tr. 11159, pp. 2, 3.]

23 Ten PORVs and nine safety valves have been  
24 selected for testing. The valves selected for testing are  
25 identified in Table 1 of the Carey-Auble testimony. The PWR  
26 Valve Test Program was developed so that the valves selected




1 for testing are representative of relief and safety valve  
2 designs in use or planned for use in PWR's. [Ibid. p. 3;  
3 Tr. 11170.]

4 The Masoneilan Model No. 20000 series valve being  
5 tested by EPRI is believed to be fully representative of the  
6 valves utilized as PORVs in the Diablo Canyon Nuclear Power  
7 Plant. [Ibid. p. 3; Cherny Testimony following Tr. 11216,  
8 p. 11; Tr. 11171, 11172.] The Masoneilan valve passed all  
9 of the performance screening criteria and performed  
10 successfully under steam conditions at the Marshall  
11 facility. [Carey-Auble Testimony following Tr. 11159, pp.  
12 5-6.] The remaining tests on the Masoneilan valve will be  
13 completed in June 1981. [Ibid.]

14 The Crosby model HB-BP-86 safety valve being  
15 tested by EPRI is believed to be fully representative of the  
16 safety valves utilized in the Diablo Canyon Nuclear Power  
17 Plant. [Carey-Auble Testimony following Tr. 11159 p. 4.]  
18 The Crosby valve is scheduled for testing at the Combustion  
19 Engineering facility in June 1981. [Ibid., p. 7.]

20 The conditions under which the relief and safety  
21 valves are being tested envelope the expected operating and  
22 accident conditions as prescribed in the final safety  
23 analysis reports (FSARs) for pressurized water reactors. In  
24 addition, the conditions resulting from cold pressurization  
25 transients and transients resulting from the extended

26 ///






1 operation of the high pressure liquid injection system will  
2 be enveloped. [Ibid. p. 4; Tr. 11167, 11174, 11126.]

3 The test conditions for safety and relief valves  
4 include steam, subcooled water, water seal, and steam to  
5 water transition discharge conditions. [Ibid. p. 4; Tr.  
6 11168, 11169, 11201.]

7 A formal program for testing block valves  
8 responsive to NUREG 0737, Item II.D.1B, is not part of the  
9 EPRI test program scope. Discussions concerning a block  
10 valve test program have been held by EPRI and a PWR owners  
11 group. PGandE has committed to qualifying its block valves  
12 by July 1982 whether there is an EPRI program or not.  
13 [Ibid. p. 7; Tr. 11220, 11221.]

14 Furthermore, in addition to the ten (10) relief  
15 valves tested at Marshall, seven (7) block valves were also  
16 tested. The block valves tested are identified in Table 2  
17 to the Carey-Auble testimony. Two block valves manufactured  
18 by Velan were tested at Marshall and performed satisfactori-  
19 ly. Of these two, the Velan valve which is believed to be  
20 fully representative of the block valve model utilized in  
21 the Diablo Canyon Plant was cycled in excess of 21 times,  
22 and satisfactorily fully opened and fully closed each cycle.  
23 [Ibid. p. 7; Tr. 11181-11183.] There were no failures of  
24 any valves which might have some bearing on the operation of  
25 valves at Diablo Canyon. [Tr. 11185 and 11231.] In  
26 addition, the block valve which was representative of those




1 used at Diablo Canyon was successfully closed against  
2 somewhat higher flow than it could ever see at Diablo  
3 Canyon. [Ibid. p. 7; Tr. 11181-11183.]

4 7. Conclusion

5 Based on the design and analysis of, as well as  
6 testing applicable to, the pressurizer safety, relief, and  
7 block valves at Diablo Canyon, these valves are expected to  
8 function as required during any condition of normal  
9 operation, including anticipated operational occurrences.  
10 As discussed above, even in the hypothetical case of the  
11 pressurizer safety, relief, and block valves failing to  
12 close, the public health and safety would not be endangered.  
13 Accordingly, completion of additional testing of safety  
14 valves, PORVs, and block valves is not required prior to  
15 fuel load, low power testing, or full power operation at  
16 Diablo Canyon. [Gottshall-Muench Testimony following Tr.  
17 11157, p. 8; Cherny testimony following Tr. 11216, pp. 13,  
18 14.]

19 E. Legal Argument

20 During the hearing, the Board questioned PGandE  
21 regarding which of the 16 planning standards of 10 C.F.R.  
22 50.47(b) it was seeking an exemption for purposes of  
23 obtaining a low power testing license. During the  
24 proceedings, staff counsel furnished to the Board a copy of  
25 SECY-81-188-Emergency Preparedness which was approved by the  
26 Commission on April 27, 1981. The Commission's action




1 negated Joint Intervenors' and Governor Brown's legal  
2 argument that PGandE had to comply with every facet of  
3 emergency planning contained in 10 C.F.R. 50.47. Instead  
4 the Commission chose to retain the flexibility of 10 C.F.R.  
5 50.47(c) to allow case-by-case analysis of emergency  
6 preparedness. In the context of low power testing, the  
7 Commission reaffirmed its previous position in NUREG-0694  
8 that it is unnecessary to require extensive offsite  
9 emergency capability because of the low potential for  
10 significant offsite releases. Accordingly, it is  
11 unnecessary for PGandE to seek exemptions from the planning  
12 standards. Rather all that is required is for PGandE to  
13 demonstrate reasonable compliance with those standards which  
14 are reasonably related to low power testing. PGandE has so  
15 presented this testimony as set forth in C (3) above.

16 (Supra pp. 15-20.)

17 F. Summary

18 From the foregoing testimony and evidence, the  
19 Board finds that the risks from fuel load and low power  
20 testing are considerably reduced from that of full-power  
21 operation of Diablo Canyon. Further, that this risk  
22 reduction is based upon a variety of factors including a  
23 lower fission product inventory and a greater amount of time  
24 for operator response to mitigate and/or terminate an  
25 accident condition.

26 ///




1           The Board further finds that these factors reduce  
2 dramatically the size of the area which might be affected by  
3 a radiological emergency and for which emergency planning  
4 measures must be taken and the level of emergency response  
5 preparedness which would have to be in place.

6           The Board finds that the Federal Emergency Manage-  
7 ment Agency has found that the state and local emergency  
8 response preparedness for low power operation of the Diablo  
9 Canyon facility is adequate.

10          The Board finds that the current PGandE, county  
11 and state emergency plans demonstrate a sufficient level of  
12 emergency preparedness to respond effectively to any  
13 radiological emergency which might reasonably be expected to  
14 occur during low power testing.

15          The Board further finds that the current level of  
16 emergency preparedness meets NRC requirements as set forth  
17 in 10 C.F.R. 50.47 and NUREG-0737 as recently amended by the  
18 Commission on April 22, 1981 in SECY-81-188 in that any  
19 deficiencies in the PGandE, local and state plans are not  
20 significant for operation of Diablo Canyon at power levels  
21 not to exceed 5% power.

22          The Board also finds that NUREG-0737 requires only  
23 that testing of relief and safety valves need be completed  
24 by July 1, 1981 and of block valves by July 1, 1982. The  
25 Board further finds that failure to successfully complete  
26 this testing by fuel load does not result in a failure to





1 comply with GDC 1, 14, 15 and 30 or otherwise endanger the  
2 public health and safety.

3 II

4 CONCLUSIONS OF LAW

5 The Board has given careful consideration to all  
6 the documentary and oral evidence produced by the parties.  
7 Based upon our review of the entire record in this  
8 proceeding and upon the foregoing findings of fact, the  
9 Board concludes as follows:

10 (a) Construction of the facility has been sub-  
11 stantially completed in conformity with the construction  
12 permit and the application as amended, the provisions of the  
13 Atomic Energy Act of 1954, as amended, and the rules and  
14 regulations of the Commission; and


15 (b) The facility will operate in conformity with  
16 the application as amended, the provisions of the Act, and  
17 the rules and regulations of the Commission; and

18 (c) There is reasonable assurance (i) that the  
19 activities authorized by the fuel load and low-power testing  
20 (up to 5%) license can be conducted without endangering the  
21 health and safety of the public, and (ii) that such  
22 activities will be conducted in compliance with the  
23 Commission's regulations; and

24 ///

25 ///

26 ///



1 (d) PGandE is technically and financially  
2 qualified to engage in the activities authorized by the fuel  
3 load and low-power testing license in accordance with the  
4 Commission's regulations; and


5 (e) The applicable provisions of 10 C.F.R. Part  
6 140 will be satisfied prior to fuel load; and

7 (f) The issuance of a fuel load and low power  
8 testing license will not be inimical to the common defense  
9 and security or to the health and safety of the public.

10 WHEREFORE, IT IS ORDERED in accordance with the  
11 Atomic Energy Act of 1954, as amended, and the Commission's  
12 regulations, and based on the findings and conclusions set  
13 forth herein, that the Director of Nuclear Reactor  
14 Regulation is authorized to issue a license, consistent with  
15 the terms of the Initial Decision, to authorize fuel load  
16 and low power testing up to 5% of rated power generally in  
17 the form submitted by PGandE in support of the motion.

18 [J.I. Ex. 113.]

19 IT IS FURTHER ORDERED, in accordance with Sections  
20 2.760, 2.762, 2.764, 2.785 and 2.786 of the Commission's  
21 Rules of Practice, that this Initial Decision shall not  
22 become effective until 10 days from the date this decision  
23 is transmitted to the Commission and shall constitute the  
24 final action of the Commission subject to review thereof  
25 under the above-cited rules. Exceptions to this Initial  
26 Decision may be filed by any party within 10 days after the



1 service of this Initial Decision. A brief in support of the  
2 exceptions shall be filed within 30 days thereafter (40 days  
3 in the case of the staff). Within 30 days after the service  
4 of this brief of the appellant (40 days in the case of the  
5 staff), any other party may file a brief in support of, or  
6 in opposition to, the exceptions.

7 Respectfully submitted,

8  
9 MALCOLM H. FURBUSH  
10 PHILIP A. CRANE, JR.  
11 RICHARD F. LOCKE  
12 Pacific Gas and Electric Company  
13 P.O. Box 7442  
14 San Francisco, California 94106  
15 (415) 781-4211


13 ARTHUR C. GEHR  
14 Snell & Wilmer  
15 3100 Valley Center  
16 Phoenix, Arizona 85073  
17 (602) 257-7288

16 BRUCE NORTON  
17 3216 N. Third Street  
18 Suite 300  
19 Phoenix, Arizona 85012  
20 (602) 264-0033

19 Attorneys for  
20 Pacific Gas and Electric Company

21 By   
22 Richard F. Locke

23 DATED: June 1, 1981.  
24  
25  
26



UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of )  
 )  
PACIFIC GAS AND ELECTRIC COMPANY )  
 )  
Units 1 and 2 )  
 )  
Diablo Canyon Power Plant )  
\_\_\_\_\_ )

Docket No. 50-275  
Docket No. 50-323  
(Low Power Test Proceeding)

CERTIFICATE OF SERVICE

The foregoing document of Pacific Gas and Electric Company has been served today on the following by deposit in the United States mail properly stamped and addressed:

\*Judge John F. Wolf  
Chairman  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mrs. Sandra A. Silver  
1760 Alisal Street  
San Luis Obispo, California 93401

Mr. Gordon Silver  
1760 Alisal Street  
San Luis Obispo, California 93401

\*Judge Glenn O. Bright  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

\*John Phillips, Esq.  
Joel Reynolds, Esq.  
Center for Law in the Public Interest  
10203 Santa Monica Drive  
Los Angeles, California 90067

\*Judge Jerry R. Kline  
Atomic Safety and Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

\*David F. Fleischaker, Esq.  
1735 Eye Street, N.W.  
Suite 709  
Washington, D. C. 20006

Mrs. Elizabeth Apfelberg  
C/o Nancy Culver  
192 Luneta Drive  
San Luis Obispo, California 93401

\*Arthur C. Gehr, Esq.  
Snell & Wilmer  
3100 Valley Bank Center  
Phoenix, Arizona 85073

Janice E. Kerr, Esq.  
Public Utilities Commission  
of the State of California  
5246 State Building  
350 McAllister Street  
San Francisco, California 94102


\*Bruce Norton, Esq.  
Norton, Burke, Berry & Junck  
3216 North Third Street  
Suite 300  
Phoenix, Arizona 85012

Mrs. Raye Fleming  
1920 Mattie Road  
Shell Beach, California 93449

Chairman  
Atomic Safety and Licensing  
Board Panel  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Frederick Eissler  
Scenic Shoreline Preservation  
Conference, Inc.  
4623 More Mesa Drive  
Santa Barbara, California 93105

\*Deposited in Federal Express mail for delivery June 2, 1981





Chairman  
Atomic Safety and Licensing  
Appeal Panel  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Secretary  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Attn.: Docketing and Service Section

\*William J. Olmstead, Esq.  
Charles Barth, Esq.  
Edward G. Ketchen, Esq.  
Lucinda Low Swartz, Esq.  
Office of Executive Legal Director  
BETH 042  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Richard B. Hubbard  
MHB Technical Associates  
1723 Hamilton Avenue, Suite K  
San Jose, California 95125

Mr. Carl Neiberger  
Telegram Tribune  
P. O. Box 112  
San Luis Obispo, California 93402


\*Herbert H. Brown, Esq.  
Lawrence Coe Lanpher, Esq.  
Christopher B. Hanback, Esq.  
Hill, Christopher & Phillips  
1900 M Street, N.W.  
Washington, D. C. 20036

Byron S. Georgiou, Esq.  
Deputy Legal Affairs Secretary  
Governor's Office  
State Capitol  
Sacramento, California 95814

Richard S. Salzman, Esq.  
Chairman  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. W. Reed Johnson  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. John H. Buck  
Atomic Safety and Licensing  
Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

  
Philip A. Crane, Jr.  
Attorney  
Pacific Gas and Electric Company

Date: June 1, 1981

