

MAC 84

## REGULATOR INFORMATION DISTRIBUTION SYSTEM (RID'S)

ACCESSION NBR: 8302010431    DOC. DATE: 83/01/19    NOTARIZED: NO    DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga. 05000275  
 '50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga. 05000323  
 AUTH. NAME                    AUTHOR AFFILIATION  
 CRANE, P.A.                 Pacific Gas & Electric Co.  
 RECIP. NAME                 RECIPIENT AFFILIATION  
 KNIGHTON, G.W.              Licensing Branch 3

SUBJECT: Forwards "Wave Effects on Intake Structure" & "Investigation of Seawater Ingestion Into Auxiliary Saltwater Pump Room Due to Splash Runup During Design Flood Events at Diablo Canyon."

DISTRIBUTION CODE: B001S COPIES RECEIVED: LTR 6 ENCL 40 SIZE: 2+42  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett icy PDR Documents. 05000275  
 J Hanchett icy PDR Documents. 05000323

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
INTERNAL:	NRR/DL/ADL	1 0	NRR LB3 BC	1 0
	NRR LB3 LA	1 0	BUCKLEY, B. 01	1 1
	ELD/HDS2	1 0	IE FILE	1 1
	IE/DEP EPDS 35	1 1	IE/DEP/EPLB .36	3 3
	NRR/DE/AEAB	1 0	NRR/DE/CEB 11	1 1
	NRR/DE/EQB 13	2 2	NRR/DE/GB 28	2 2
	NRR/DE/HGEB 30	1 1	NRR/DE/MEB 18	1 1
	NRR/DE/MTEB 17	1 1	NRR/DE/QAB 21	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SEB 25	1 1
	NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/OLB 34	1 1	NRR/DL/SSPB	1 0
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/ICSSB 16	1 1	NRR/DSI/METB 12	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	REG FILE 04	1 1
	RGNS	3 3	RM/DDAM1/MIB	1 0
EXTERNAL:	ACRS 41	6 6	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	2 2	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1
NOTES:		1 1		

18. 8. 1907. — **Санкт-Петербург**. — **Санкт-Петербург**.

• 1970 • 1971 • 1972 • 1973 • 1974 • 1975 • 1976 • 1977 • 1978 • 1979 • 1980 • 1981 • 1982 • 1983 • 1984 • 1985 • 1986 • 1987 • 1988 • 1989 • 1990 • 1991 • 1992 • 1993 • 1994 • 1995 • 1996 • 1997 • 1998 • 1999 • 2000 • 2001 • 2002 • 2003 • 2004 • 2005 • 2006 • 2007 • 2008 • 2009 • 2010 • 2011 • 2012 • 2013 • 2014 • 2015 • 2016 • 2017 • 2018 • 2019 • 2020 • 2021 • 2022 • 2023 • 2024 • 2025 • 2026 • 2027 • 2028 • 2029 • 2030 • 2031 • 2032 • 2033 • 2034 • 2035 • 2036 • 2037 • 2038 • 2039 • 2040 • 2041 • 2042 • 2043 • 2044 • 2045 • 2046 • 2047 • 2048 • 2049 • 2050 • 2051 • 2052 • 2053 • 2054 • 2055 • 2056 • 2057 • 2058 • 2059 • 2060 • 2061 • 2062 • 2063 • 2064 • 2065 • 2066 • 2067 • 2068 • 2069 • 2070 • 2071 • 2072 • 2073 • 2074 • 2075 • 2076 • 2077 • 2078 • 2079 • 2080 • 2081 • 2082 • 2083 • 2084 • 2085 • 2086 • 2087 • 2088 • 2089 • 2090 • 2091 • 2092 • 2093 • 2094 • 2095 • 2096 • 2097 • 2098 • 2099 • 20100

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E +

77 BEALE STREET, SAN FRANCISCO, CALIFORNIA 94106  
P.O. BOX 7442, SAN FRANCISCO, CALIFORNIA 94120

TELEPHONE (415) 781-4211  
TELECOPIER (415) 543-7813

ROBERT OHLBACH  
VICE PRESIDENT AND GENERAL ATTORNEY

CHARLES T. VAN DEUSEN  
PHILIP A. CRANE, JR.  
HENRY J. LA PLANTE  
JOHN B. GIBSON  
ARTHUR L. HILLMAN, JR.  
CHARLES W. THISSELL  
DANIEL E. GIBSON  
JACK F. FALLIN, JR.  
JOSEPH I. KELLY  
HOWARD V. GOLUB  
GLENN WEST, JR.  
ASSISTANT GENERAL COUNSEL

GILBERT L. HARRICK  
DAVID GRAVES-HARROCK  
JAMES C. LOBBISON  
ROBERT L. BORDON  
PETER W. HANSCHEK  
RICHARD F. LOKE  
DONALD R. MCGOWAN  
WILLIAM H. EDWARDS  
J. MICHAEL REIDENBACH  
IVON E. BAMSON  
BOB BROWN  
PATRICK Q. GOLDEN  
RICHARD H. MOSS  
LOUIS E. VINCENT

SENIOR COUNSEL

EDWARD J. MCGRANNEY  
BERNARD J. PELLA BANTA  
JOSHUA SABREY  
JOSEPH B. ENHOLTY, JR.  
ROBERT L. HARRIS  
DOUGLAS A. ODESSY  
ULRICH R. SCHARTNER  
JOHN H. FAYE  
ROBERT R. RICKETT  
DAVID J. WILLIAMSON  
BRUCE A. WILMINGTON  
RICHARD O. MEISS  
JACK W. SHUCK

DAVID W. ANDERSON  
CRAIG M. BUCHBAUM  
LEONARD C. CHAPMAN  
AUDREY J. DAINES  
DONALD D. ERICKSON  
DAVID C. GILBERT  
THOMAS G. GOLDBECK  
RICHARD C. JONES  
HARRY W. LONG, JR.  
JOHN R. LOW  
ROBERT B. MOLENAN  
ROGER J. PETERS  
JO ANN SHAFFER

ATTORNEYS

JATHAN T. ANNAND  
STEVEN D. BURKE  
RONALD C. DELILLE  
GARY P. ENCINA  
DAVID H. FLEIBIG  
GAIL A. GREENLY  
JOAN M. HALL  
MICHAEL E. LIPSON  
JESSICA LORING  
A. KIRK MCKENZIE  
KENNETH D. OLESON  
SHIRLEY A. SANDERSON  
KENNETH YANG

January 19, 1983

Mr. George W. Knighton, Chief  
Licensing Branch No. 3  
Division of Licensing  
Office of Nuclear Reactor Regulation  
US Nuclear Regulatory Commission  
Washington DC 20555

Re: Docket No. 50-275, OL-DPR-76  
Docket No. 50-323  
Diablo Canyon Units 1 and 2  
Breakwater Studies

Dear Mr. Knighton:


The enclosed reports complete PG&E's investigations of the potential consequences of degradation of the Diablo Canyon breakwater. These reports, which provide an analysis of the data compiled from model tests, are entitled:

1. "Effects of Wave Forces on the Intake Structure" by Edward Matsuda, January, 1983.
2. "Investigations of Seawater Ingestion into the Auxiliary Saltwater Pump Room Due to Splash Run-up During the Design Flood Events at Diablo Canyon" by Patrick J. Ryan, January, 1983.

PG&E believes that these reports, together with those submitted to the NRC Staff on July 1, 1982 and January 10, 1983, should permit resolution of the full power licensing matter identified both in Section 2.4 of Supplement 13 of NUREG-0675 (Safety Evaluation Report for Diablo Canyon Units 1 and 2) and at a meeting September 25, 1981 between the NRC Staff and PG&E.

8302010431 830119  
PDR ADDOCK 05000275  
P

3001  
1/AD



Mr. George W. Knighton

January 19, 1983  
page 2

From the results of the investigations, assuming that the entire breakwater is degraded to mean lower low water (MLLW), PGandE concludes that:

1. The intake structure, with minor modifications completed, is capable of withstanding the forces of waves resulting from the postulated design flooding events, thereby assuring continuous protection to the Auxiliary Saltwater (ASW) pumps.
2. The extended ASW pump ventilation shafts preclude the ingestion of seawater to the extent that the operation of the ASW pumps would not be impaired during the postulated design flooding events.
3. The probability of large vessels (greater than 250 tons) crossing the degraded breakwater and impacting the intake structure is acceptably low. With respect to the safety-related function of the ASW pumps, the impact of vessels less than 250 tons on the intake structure would be inconsequential.

Following the Staff's review of the consequences of breakwater degradation in relation to full power plant operation, PGandE plans to submit a request for an amendment to the Technical Specifications which will define surveillance requirements and limiting conditions for operation related to the breakwater.

Kindly acknowledge receipt of the above material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Very truly yours,

*Philip A. Crane, Jr.*

Enclosures

cc w/encls: Service List

