REGULATORY NFORMATION DISTRIBUTION S EM (RIDS)

	iablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga	DOCKET # 05000275
AUTH,NAME CRANE,P,A, RECIP.NAME	- AUTHOR AFFILIATION Pacific Gas & Electric Co. RECIPIENT AFFILIATION	
EISENHUT, D.G.	Division of Licensing	

SUBJECT: Forwards project pressure & temp transient analysis results in plant Areas GE/GW of auxiliary bldg resulting from main stream line break in Area GW.Calculations & results reflect current as-built conditions.

DISTRIBUTION CODE: BOOIS COPIES RECEIVED:LTR / ENCL / SIZE:

NOTES: J Hanchett 1cy PDR Documents.

RECIPIENT COPIES RECIPIENT COPIES ID CODE/NAME L'TTR' ENCL ID CODE/NAME LTTR ENCL NRR/DL/ADL NRR LB3 BC NRR LB3 LA BUCKLEY, B. INTERNAL: ELD/HDS2 IE FILE IE/DEPER/EPB 36 IE/DEPER/IRB 35 IE/DEQA/QAB NRR/DE/AEAB NRR/DE/CEB NRR/DE/EHEB · 2 NRR/DE/EQB NRR/DE/GB NRR/DE/HGEB 30 NRR/DE/MEB .1. . 1 NRR/DE/SAB NRR/DE/MTEB .1 . 1 NRR/DE/SGEB NRR/DHFS/HFEB40 NRR/DHFS/LQB 32 NRR/DL/SSPB NRR/DSI/AEB NRR/DSI/ASB NRR/DSI/CPB NRR/DSI/CSB NRR/DSI/METB 12 NRR/DSI/ICSB 16 NRR/DSI/PSB NRR/DSI/RAB NRR/DSI/RSB REG FILES RM/DDAMI/MIB RGN5 BNL (AMDTS ONLY) EXTERNAL: ACRS DMB/DSS (AMDTS) FEMA-REP DIV 39 .1 LPDR NRC PDR NSIC NTIS

NOTES:

TOTAL NUMBER OF COPIES REQUIRED: LTTR 56 ENCL 49

en fala) 🚛 elekar an ne 🖉 el a 💭 el a 💭 el a 👘 elemente de la composición de la composicinde la composicinde la composición de la com

· CRATING UNDER AN AUGUST AND THE AND A THE AN

		ы Компонії П. К. 11 К. м. 11 К. – П. К.				
	£	Jud i s 4 t sul				
	ł.		•	4 ,		ει) · ζι σ · τη, · · · · ·
1	,			,n.		· · · · · · ·
K	*	ាត្រី វ	н١	8		en in the second
8	1	·"行 《诗秋》:1111日书:"你	Ð	¢,	(1 ¹	· The Fill Fill Fill And State
64	0 11	Pres to By Carlo B. 19	1	si,	Nr.	¹ L ¹ δ − Γ − δ − R
K	*	រៀលនេះ ស្តែវិទ្វាបា ។	8	я.	8 8	CAN BE WE BE
. 9	(₎	AT A CONTRACT OF	r,	5		1 💊 1 🗞
l	I.	AND IT A PARTIC	R	М		No. A. C.
Ī	Ř	The MARKER AND A	Ŷ	8	V P	
Ж	ł	CONTRACTOR SHOULD		i)	r ¹ i	i i n i h
81	R	HAMILIAN A THE SHI	R	×.		"N. 1 N. 1
8	٢	HANKE BURGER	íÞ.	15 1	4. ^{4.}	
ľ	ļt	ATT RELAXED BY TO BE	R	4	₩ K	
¥	ř.	TR OF PARTIES AND	n	25 1		A A A
ŝ		The first the state of the second	łi.	13 K		
Ŕ	ņ	18.1 18.14 1	P	e K		1 N K C W
	P	ITE INE THEY A	į,	/\ /	۰ ر۴	
			,	,		
X	P	在武县 中于 第二回行为 "	1	. 1	× £	ور لا ا
Ħ	i.	17 WX . Here it 1				· vit . 🔪
-	R	ful ef the t		•		
Ĭ.	()	€1 ⊼ ¥		×.		• א ^{ַ 1}

Ĉ

*

.

PACIFIC GAS AND ELECTRIC COMPANY

₽G⊯E

1

77 BEALE STREET, SAN FRANCISCO, CALIFORNIA 94106 P.O. BOX 7442, SAN FRANCISCO, CALIFORNIA 94120

SENIOR COUNSEL

TELEPHONE (415) 781-4211 TELECOPIER (415) 543-7813

ROBERT OHLBACH VICE PRESIDENT AND GENERAL ATTORNEY

CHARLES T. VAN DEUSEN PHILIP A. CRANE, JR, HENRY J. LAPLANTE JOHN B. GIBSON ARTHUR L. HILLMAN, JR, CHARLES W. THISSELL DANIEL E. GIBSON JACK F. FALLIN, JR, JOSEPH 1. KELLY HOWARD V. GOLUB GLENN WEST, JR, ASSISTANT GEMERAL COUNSEL GILEERT L. HARRICK DAN GRAYSDA LUSEOCK JANES G. LOOSOON ROBERT L. BORDON PETER W. MANSCHEN RICHARD F. LOCKE DAVID L. LUDVISSON WILLIAM H. COWARDS J. DE C. SANFGION NAACH J. DE C. SANFGION NAACH J. DE C. SANFGION BHIRLYJA, WOD PATRICK G. GOLDEN RICHARD H., MOSS LOUIS E. VINCENT

EDWARD J. MCGANNEY BERNARD J. DELLA BANTA JOBHUA SR-LEY JOBECT B. ENGLIST JAN DOUGLAS A. GOLESSY J. FITES BAUHGARINER JOHN N. FRYE ROBERT R. RIGKETON BRUDE R. WORTHINGTON RIGHARD L. MEIBS JACK W. SWUCK

DAVID W. ANDERSON CRAID M. BUCHBAUM LEUDIE J. CASSIDE LEUDIE J. CASSIDE DONALD D. ENICKED DONALD D. ENICKED DONALD D. ENICKED BY BY RICHARD C. JONES HORM R. LOW C. JONES MOREN J. PETERS JO ANN BY RESE

IATHAN T, ANNANO BTEVEN JF, BURKE PAMELA GHAPPELLE GARY JF, ENGINAS DAVID M, FLEISIG GUAN M, JATO MERKE E, LIPBON JESICA LORING A, KIRK MEKENZIE KENNETH Ø. OLEBON SHIELEY AJ BANGERON ATTORNYT SANS

April 13, 1983

Mr. D. G. Eisenhut, Director Division of Licensing Office of Nuclear Reactor Regulation U.S. Nuclear Regulatory Commission Washington, DC 20555

> Re: Docket No. 50-275, OL-DPR-76 Diablo Canyon Unit No. 1 Pressure and Temperature Data for Pipe Break Outside Containment

Dear Mr. Eisenhut:

Pursuant to PGandE's letter dated March 22, 1983, enclosed are the Diablo Canyon Project pressure and temperature transient analysis results in areas GE/GW of the auxiliary building resulting from a main steam line break in area GW. As described in Enclosure 1, the information responds to the NRC letter dated January 19, 1983. It is our understanding that this information will be used by the NRC to determine temperature and pressure profiles for comparison with IDVP results.

The blowdown input data is for dry steam and was furnished by Westinghouse Electric Corporation. The calculations and results reflect the current plant as-built conditions. We are currently evaluating these results to determine any impact on the plant.

Very truly yours, Nas G-Ughs


for

Philip A. Crane, Jr.

Rool

Enclosure

cc: Service List (w/o enc.)



, н , ,

المی اللہ ہے۔ اس میں اللہ ہے ہوئے ہیں ہے۔ اور اللہ ہے ہوئی ہے ہیں ہے۔

n de la companya de l La companya de la comp

a . . . **(4**,

<u>,</u>

т. "Д не

Т

Enclosure 1

This submittal contains the following four attachments:

1. Summary - Discussion

- 2. Pressure and Temperature Curves and Tables for Area GE/GW
- 3. CHTG Calculation No. 15320-2203-0
- 4. FLUD Code Description

and and a second se

.

The following table correlates the attachments with the requested NRC information:

	January 19, 1983, ter Request	Date Previously Submitted	Location in this Submittal (Attachment No.)
1.	With respect to the pipe to be broken:		
	a. type of fluid (water or steam)	2/25/83	3
	b. temperature	2/25/83	3
	c. pressure	2/25/83	3
	d. source of the fluid	2/25/83	3
	e. flow rate (or assumed flow rate) as a function of time	2/25 and 3/4/83	3
	f. enthalpy as a function of time	2/25 and 3/4/83	3

т., т.

a second s

đ

, , ~~,

. .

.

and the second second

•

• - بر ۲۰٫۹۰٬۰۰۰ ۲. ۲. ۲. ۲. ۲.

,

Enclosure 1 (Continued)

D

NRC January 19, 1983, Letter Request			Date Previously Submitted	Location in this Submittal (Attachment No.)
2.	With respect to the compartments being analyzed:			
	a.	number of compartments analyzed	2/25/83	3 (Notes 3 and 4)
	b.	for each compartment:		
		(1) initial temperature	2/25/83	3
		(2) initial pressure	2/25/83	3
		(3) initial humidity	2/25/83	3
		(4) Floor area including floor space taken by equipment (square feet)	2/4 and 2/25/83	3 (Notes 3 and 4)
		(5) number of vents and vent areas (square feet) for each vent	2/4 and 2/25/83	3 (Notes 3 and 4)
		(6) compartment wall height (feet)	2/4/83	3 (Note 3)
	с.	simple compartment and interconnection diagram	2/4 and 2/25/83	2 (Notes 3 and 4)
3.	All assumptions used, including but not limited to:		, ,	
	a.	orifice coefficient	2/25/83	3 (Note 4)
	b.	fluid expansion factor	2/25/83	3 (Note 4)
	c.	heat transfer coefficient for heat through the walls	2/25/83	3 (Note 4)

te de la companya de la comp

at the same same at spectrum at a

th Kagan tagan An tagan t

x - x

* ,

an the second •

× 4.,74 1

1 J €7. ç v ь к 11

.

r -

· · · ·

Enclosure 1 (Continued)

NRC January 19, 1983, Letter Request			Date Previously Submitted	Location in this Submittal (Attachment No.)
4.	Res	ults of Diablo Canyon Project analysis:		
	a.	temperature versus time curve (peak temperature specified)	-	2
	b.	pressure versus time curve (peak pressure specified)	-	2
	c.	humidity versus time curve (Peak humidity specified)	-	Note 2
5.		R references to above information appropriate.	2/25/83	Note 5

Notes:

٤.

- 1. Attachment 2 is a summary of Attachment 3. Therefore, information contained in Attachment 2 is also provided in Attachment 3.
- 2. Humidity is 100%
- 3. Basic reference data were previously submitted in Calculation Nos. M-222 and M-287.
- 4. This information supercedes previously submitted information due to a change in modelling.

لى ا

5. The correct FSAR references are Section 3.6.4 and Appendix 3.6.

t

ه دهر ... منگ ۲

•

. . na an an Anna a Anna an Anna an

to a the sign of the state of the

ATTACHMENT 1

M. L.

SUMMARY - DISCUSSION

Main Steam Line Break Pressure and Temperature Transient Analysis (without water entrainment) in Area GE/GW of the Auxiliary Building

The Diablo Canyon Project has completed the auxiliary building area GE/GW pressure and temperature transient analysis. The Bechtel computer code FLUD 6 was used to predict the pressure and temperature transients. There were 8 cases considered; 17, 18, 19, 20, 33, 34, 35, and 36 from Westinghouse blowdown data. Cases 17, 18, 19, and 20 were main steam line split breaks with power levels at 102%, 70%, 30% and 0% respectively. Cases 33, 34, 35, and 36 were main steam line double-ended ruptures with power levels at 102%, 70%, 30% and 0% respectively. The worst compartment peak temperatures were generated by split break cases, while the worst compartment peak pressures were generated by double-ended rupture cases.

The computer model was based on PGandE equipment location drawings and was confirmed by an as-built walkdown. In order to avoid flow oscillations between the north pipeway and the south pipeway, the split break model was modified by combining the north pipeway and the south pipeway into one pipeway compartment. The effect of this modification on compartment temperature was negligible. Please note that only compartment temperatures were of concern for split break cases.

The results for all cases, i.e. the tables of peak pressure and temperature, the pressure and temperature curves for each compartment, and the maximum and minimum pressures and temperatures, are extracted from Calculation No. 2203, Rev.0, and included in Attachment 2. Attachment 3 contains a complete copy of Calculation No. 2203, Rev.0.

The FLUD 6 Code Description is included as Attachment 4.

`й **,** та з



۹

• "# , " • • • • • • • • • • •

• ·

,

.

.