

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8308010446 DOC. DATE: 83/07/26 NOTARIZED: NO DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275  
 AUTH. NAME AUTHOR AFFILIATION  
 COOPER, W.E. Teledyne Engineering Services  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H.R. Office of Nuclear Reactor Regulation, Director  
 MARTIN, J.B. Region 5, Office of Director  
 MANEATIS, G.A. Pacific Gas & Electric Co.

SUBJECT: Reviews independent design verification program resolution re disposition of EOI Files 8018 & 8047. Technical concerns properly investigated & satisfactorily resolved.

DISTRIBUTION CODE: D013S COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2  
 TITLE: Diablo Canyon (50-275) Independent Design Verification Program

NOTES: J Hanchett 1cy PDR Documents. 05000275

	RECIPIENT ID CODE/NAME	COPIES		RECIPIENT ID CODE/NAME	COPIES	
		LTR	ENCL		LTR	ENCL
	NRR LB3 BC	1	1	NRR LB3 LA	1	1
	BUCKLEY, B. 06	1	1			
INTERNAL:	ELD/HDS2	1	0	IE/DEPER DIR	1	1
	IE/DEPER/EPB 11	1	1	IE/DGASIP DIR	1	1
	NRR SCHIERLING	1	1	NRR/DE/CEB 12	1	1
	NRR/DE/eqB 13	1	1	NRR/DE/GB 14	1	1
	NRR/DE/MEB 15	2	2	NRR/DE/QAB 16	1	1
	NRR/DE/SGEB	1	1	NRR/DSI/ASB 18	1	1
	NRR/DSI/ICSB	1	1	NRR/DSI/PSB	1	1
	REG FILE 04	1	1	RGNS 08	2	2
	RM/DDAMI/MIB	1	0			
EXTERNAL:	ACRS 19	16	16	LPDR 03	2	2
	NRC PDR 02	1	1	NSIC 05	1	1
	NTIS	1				
NOTES:		1				



Very faint, illegible text at the top of the page, possibly a header or title.

Very faint, illegible text in the upper middle section of the page.

Very faint, illegible text in the middle section of the page.

Very faint, illegible text in the lower middle section of the page.

Very faint, illegible text in the lower section of the page.

Very faint, illegible text in the lower section of the page.

Very faint, illegible text in the lower section of the page.

Very faint, illegible text in the lower section of the page.

Very faint, illegible text in the lower section of the page.

Very faint, illegible text in the lower section of the page.

Very faint, illegible text at the bottom of the page.

023  
72A

**TELEDYNE  
ENGINEERING SERVICES**

130 SECOND AVENUE  
WALTHAM, MASSACHUSETTS 02254

(617) 890-3350 TWX (710) 324-7508

July 26, 1983  
5511-468

50-275

Mr. G. A. Maneatis, Executive Vice-President  
Pacific Gas and Electric Co.  
77 Beale Street  
San Francisco, California 94106

Mr. H. R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. J. B. Martin, Regional Administrator  
Region V  
U. S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

**UNCONTROLLED COPY**

Subject: Review of IDVP Resolution to EOI File 8018 and 8047.

Gentlemen:

During the review of some documents prepared by the IDVP, the NRC Staff raised questions about the dispositions of EOI Files 8018 and 8047. The questions were discussed in telephone conversations between the IDVP, PGandE, and the NRC during the week of July 18, 1983. The IDVP has reviewed those dispositions and considers that the files were adequately and properly addressed.

In the initial investigation for EOI 8018 which was performed in accordance with the NRC approved Program Management Plan, the IDVP stated that flow control valves, FCV-37 and 38, were installed in a Class I steam line and that their associated instrumentation and control devices were designated as Class II. The IDVP interest in these valves was restricted to their function with respect to the AFW system, the fluid system which was included in the initial sample. In ITR-27 this item is considered technically adequate since the licensing commitment to maintain a safe shutdown capability was satisfactorily demonstrated. This resolution was supported by information from Westinghouse (thru PGandE) providing an analyses of various conditions which concluded that the valves were acceptably classified for the AFW System.

These valves have an additional function as part of the containment isolation system. The valves' function was included in the FSAR description of the containment isolation system. However, the licensing commitments of DCNPP-1 specific to the containment isolation system were not reviewed. If an unresolved issue had been identified with these valves as part of the initial sample, the IDVP program would have been expanded and may have included these valves in their containment isolation function. Since such conclusions were absent from the initial sample, the IDVP program was not expanded. The concern with respect to the containment isolation function is being evaluated by PGandE in response to recently expressed staff comments. PGandE has committed to report its evaluation.

8308010446 830726  
PDR ADOCK 05000275  
PDR

ENGINEERS AND METALLURGISTS

DO 13  
1/0



Handwritten scribbles and marks in the top right corner.

Main body of the document containing faint, illegible text and markings.

Messrs. Maneatis, Denton and Martin  
5511-468  
July 26, 1983  
Page 2

In the investigation for EOI 8047, which was also done in accordance with the NRC approved Program Management Plan, the IDVP concern was that a non-safety relay device could prevent the automatic closure of the steam generator blowdown valves and that this may not have been properly accounted for in the various accident analyses. Discussion of the details of the resolution of this file are presented in ITR-27. In the FSAR Chapter 15 accident scenario, the AFW blowdown valves are tripped by safety grade trip signals from other sources, such as safety injection, assuring that the blowdown valves will receive diverse safety grade trip signals and shut automatically in accordance with the Westinghouse accident analysis assumptions.

Based on the aforementioned discussion the IDVP considers that the technical concerns for these two files were properly investigated and technically resolved in a satisfactory manner.

Sincerely,

TELEDYNE ENGINEERING SERVICES



*for* W. E. Cooper  
Project Manager

WEC/jmc

cc: H. E. Schierling (NRC)  
R. R. Fray (PGandE)  
E. Denison (RLCA)  
R. F. Reedy (RFR)  
F. Sestak (SWEC)  
M. J. Strumwasser, Esq.  
D. F. Fleischaker, Esq.  
J. Reynolds, Esq./J. R. Phillips, Esq.  
B. Norton, Esq.  
A. C. Gehr, Esq.  
R. B. Hubbard  
J. Roesset  
M. Axelrad

... ..

... ..

...

...

...

...

...