

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8310120404 DOC. DATE: 83/10/06 NOTARIZED: NO DOCKET #
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga 05000275
 AUTH. NAME AUTHOR AFFILIATION
 SCHUYLER, J.O. Pacific Gas & Electric Co.
 RECIP. NAME RECIPIENT AFFILIATION
 EISENHUT, D.G. Division of Licensing

SUBJECT: Provides clarification for certain designations in FSAR figures & tables re steam generator blowdown isolation per SSER 18. Classification & installation of relays will be completed prior to full power operation.

DISTRIBUTION CODE: B0015 COPIES RECEIVED: LTR ENCL SIZE: 2
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cy PDR Documents.

05000275

	RECIPIENT ID CODE/NAME	COPIES L TTR ENCL	RECIPIENT ID CODE/NAME	COPIES L TTR ENCL
	NRR/DL/ADL	1 0	NRR LB3 BC	1 0
	NRR LB3 LA	1 0	SCHIERLING, H 01	1 0
INTERNAL:	ELD/HDS2	1 0	IE FILE	1 0
	IE/DEPER/EPB 36	3 3	IE/DEPER/IRB 35	1 1
	IE/DEQA/QAB 21	1 1	NRR/DE/AEAB	1 0
	NRR/DE/CEB 11	1 1	NRR/DE/EHEB	1 1
	NRR/DE/EQB 13	2 2	NRR/DE/GB 28	2 2
	NRR/DE/MEB 18	1 1	NRR/DE/MTEB 17	1 1
	NRR/DE/SAB 24	1 1	NRR/DE/SGEB 25	1 1
	NRR/DHFS/HFEB40	1 1	NRR/DHFS/LQB 32	1 1
	NRR/DHFS/PSRB	1 1	NRR/DL/SSPB	1 1
	NRR/DSI/AEB 26	1 1	NRR/DSI/ASB	1 1
	NRR/DSI/CPB 10	1 1	NRR/DSI/CSB 09	1 1
	NRR/DSI/ICSB 16	1 1	NRR/DSI/METB 12	1 1
	NRR/DSI/PSB 19	1 1	NRR/DSI/RAB 22	1 1
	NRR/DSI/RSB 23	1 1	REG FILE 04	1 1
	RGNS	3 3	RM/DDAMI/MIB	1 1
EXTERNAL:	ACRS 41	6 0	BNL (AMDTS ONLY)	1 1
	DMB/DSS (AMDTS)	1 1	FEMA-REP DIV 39	1 1
	LPDR 03	2 2	NRC PDR 02	1 1
	NSIC 05	1 1	NTIS	1 1
NOTES:		1 1		

TOTAL NUMBER OF COPIES REQUIRED: LTR 55 ENCL 48

CONFIDENTIAL
This document contains information that is classified as CONFIDENTIAL. It is intended for the use of authorized personnel only. It is not to be distributed outside the organization.

The information contained herein is for your information only. It is not to be used for any other purpose. It is not to be distributed outside the organization.

CONFIDENTIAL

CONFIDENTIAL

Item No.	Description	Quantity	Unit	Value
1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100

PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

J. O. SCHUYLER
VICE PRESIDENT
NUCLEAR POWER GENERATION

October 6, 1983

Mr. D. G. Eisenhut, Director
Division of Licensing
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275, OL-DPR-76
Diablo Canyon Unit 1
Steam Generator Blowdown Isolation

Dear Mr. Eisenhut:

On September 9, 1983, PGandE provided a response to Diablo Canyon SSER 18, Appendix C, Section 4.2.3.1 concerning use of a single relay to isolate steam generator blowdown on automatic initiation of the Auxiliary Feedwater System (AFWS). In this response, PGandE committed to installation of a redundant relay as shown in FSAR Figure 7.2-1. The existing and additional relays will be classified as safety-related. This classification and installation will be completed prior to full power operation.

The "S" designation in FSAR Figure 6.2-14, Sheets 1 and 2, for initiating signals to steam generator blowdown, main steam, and feedwater supply isolation is misleading in these particular cases since the signals are not safety injection signals. There is no distinct FSAR designation for the steam line and feedwater isolation signals, which are defined by items 3 and 4 of FSAR Table 6.2-25. To better clarify signal sources, the "S" designations for steam line isolation and feedwater line isolation signals shown on FSAR Figure 6.2-14, Sheets 1 and 2, will be changed to "M" and "F" designations respectively. This change will also require definition of "M" as the Main Steam Isolation Signal and "F" as the Feedwater Isolation Signal in Figure 6.2-13, Sheet 2. Associated changes will be made in Table 6.2-24, Sheet 3. Figure 7.2-1, Sheet 13, will be changed to show that the feedwater pumps are tripped by train B signals and the feedwater isolation valves are closed by train A signals. In addition the FSAR will be reviewed for other changes needed to clarify the signals related to steam line isolation and feedwater line isolation. Any changes arising from this review and those discussed above will be made in the next FSAR Update.

8310120404 831006
PDR ADOCK 05000275
E PDR

Boo
/10


1960

1960

D. G. Eisenhut
October 6, 1983
Page 2

Kindly acknowledge receipt of this letter on the enclosed copy and return it in the enclosed addressed envelope.

Sincerely,


For J. O. Schuyter

cc: R. L. Cloud, RLCA
W. E. Cooper, TES
J. B. Martin, NRC
H. E. Schierling, NRC
F. Sestak, Jr., S&W
Appeal Board
Service List

11-11-68

Dear Mr. [Name]:

[Faint, illegible text]

[Faint, illegible text]