



REFERENCES:
 OP-1 (2)-5128

NOTE A:
 ⊗ DIGITAL METAL IMPACT MONITORING SENSOR LOCATIONS:

REACTOR VESSEL
 2 SENSORS ON R.V. HD.
 2 SENSORS ON R.V. LOWER HD. INSTRUMENT GUIDE TUBES

STEM. GEN.'S 1, 2, 3 AND 4
 1 SENSOR ABOVE TUBE SHEET
 1 SENSOR BELOW TUBE SHEET

NOTE B:
 SYSTEM LINEUP SHOWN FOR NORMAL OPERATION. VALVE POSITIONS ARE NOT GOVERNED BY THE UFSAR FIGURES BUT RATHER BY STATION PROCEDURES (EXCEPT VALVES WITH LOCKED OR SEALED, AND FAILURE POSITIONS AS INDICATED).

21 REVISED PER UCR-1788, UCR-1812.		
DATE	DESCRIPTION	APPRO.
REVISIONS		
FILENAME: fsar-fig-4.2-1-1 21.dgn (raster file: fsar-fig-4.2-1-1 21.ctb)		
THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UPON CONDITION THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR FURNISHING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP., OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.		
INDIANA MICHIGAN POWER COMPANY		
DONALD C. COOK		
NUCLEAR PLANT		
BRIDGMAN	MICHIGAN	
REACTOR COOLANT UNIT NO. 1		
DWG. NO. FSAR FIG. 4.2-1-1		
ARCH	ELEC	MECH STR
SCALE:	DR:	
DATE:	CH:	
DESIGN ENGINEERING DIVISION		
AEP AMERICAN ELECTRIC POWER		AEP SERVICE CORP. RIVERSIDE PLAZA COLUMBUS, OH 43215