

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIOS)

ACCESSION NUMBER: 8110260214 DOC. DATE: 81/10/22 NOTARIZED: NO DOCKET #  
 FACILITY: 50-275, Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Gas 05000275  
 AUTH. NAME: CRANE, P. A. AUTHOR AFFILIATION: Pacific Gas & Electric Co.  
 RECIP. NAME: MIRAGLIA, F. J. RECIPIENT AFFILIATION: Licensing, Branch 3

SUBJECT: Forwards review of design, qualification & installation of plant instruments to determine changes necessary for compliance w/Reg. Guidel 1.97, Revision 2; requirements. Work will be completed prior to June 1983.

DISTRIBUTION CODE: A048S COPIES RECEIVED: LTR 6 ENCL 1 SIZE: 12  
 TITLE: Equipment Qualification (OR & PRE-OL)

NOTES: 1 cy: J Hanchetti (Region V). LPDR: 2cys 05000275

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LITR	ENCL	ID CODE/NAME	LITR	ENCL
ACTION:	LIC BR #3, BC 12	6	6	BUCKLEY, B.	01	1
INTERNAL:	DIR/DOL	1	1	ELD	20	1
	EQUIP: QUAL BR07	5	5	I&E	18	3
	OGCI	1	1	<u>REG. FILE</u>	04	1
	WILLIAMS, M.H. 06	1	1			
EXTERNAL:	ACRS	23	16	LPDR	03	2
	NRCI PDRI	02	1	NSIC	05	1
	NTIS	1	1			

OCT 28 1981

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 40 RG

THE UNIVERSITY OF CHICAGO  
DEPARTMENT OF CHEMISTRY  
5800 S. UNIVERSITY AVENUE  
CHICAGO, ILLINOIS 60637

RECEIVED  
JAN 15 1964

TO: DR. J. H. GOLDSTEIN  
FROM: DR. J. H. GOLDSTEIN

RE: [Illegible text]

# PACIFIC GAS AND ELECTRIC COMPANY



P. O. BOX 7442 • 77 BEALE STREET, 31ST FLOOR, SAN FRANCISCO, CALIFORNIA 94106  
TELEPHONE (415) 781-4211 TELECOPIER (415) 543-7813

ROBERT OHLBACH  
VICE PRESIDENT AND GENERAL ATTORNEY

CHARLES T. VAN DEUSEN  
PHILIP A. CRANE, JR.  
HENRY J. L&PLANTE  
JOHN B. GIBSON  
ARTHUR L. HILLMAN, JR.  
CHARLES W. THISELL  
DANIEL E. GIBSON  
JACK F. FALLIN, JR.  
JOSEPH I. KELLY  
ASSISTANT GENERAL COUNSEL

GILBERT L. HARRICK  
GLENN WEST, JR.  
HOWARD V. GOLUB  
JAMES C. LOSSON  
ROBERT L. BORDON  
PETER W. HANDBORN  
RICHARD F. LOCKE  
DAVID L. LUDVIGSON  
WILLIAM H. EDWARDS  
F. RONALD LAUPHEIMER  
ROBERT R. RICKETT  
DAVID J. WILLIAMSON  
BRUCE R. WORTHINGTON

EDWARD J. MCGANNEY  
DAN GRAYSON LUBBOCK  
BERNARD J. DELLABANTA  
JOSHUA BAR-LEVY  
JOSEPH S. ENGLERT, JR.  
ROBERT L. HARRIS  
DOUGLAS A. DOLESSEY  
J. PETER BAUMGARTNER  
JOHN N. FRYE  
J. MICHAEL REIDENBACH  
IVOR E. SAMSON  
SHIRLEY A. WOOD

SENIOR COUNSEL

DAVID W. ANDERSON  
DIANA BERGHAUSEN  
LEIGH B. CASSIDY  
AUDREY DAINES  
DONALD G. ERICSON  
PATRICK G. GOLOEN  
PAULA Y. HAYNES  
RICHARD G. JONES  
HARRY W. LONG, JR.  
JOHN R. LOW  
ROBERT S. MCLENNAN  
RICHARD H. MOSS  
SHIRLEY A. SANDERSON  
JACK W. SHUCK  
KENNETH YANO

ITZHAK T. ANHARD  
STEVEN P. BURKE  
PAMELA CHAPPELLE  
GARY P. ENGINAS  
DAVID C. GILBERT  
STEVEN F. GREENWALD  
JUAN M. JAYO  
MEREC E. LIPSON  
JESSICA LORING  
A. KIRK MCKENZIE  
RICHARD L. MEISS  
ROGER J. PETERS  
JOHN SHAFER  
LOUIS E. VINGENT

ATTORNEYS

October 22, 1981

Mr. Frank J. Miraglia, Jr., Chief,  
Licensing Branch No. 3  
Division of Licensing  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Re: Docket No. 50-275  
Diablo Canyon Unit 1  
License No. DPR-76  
License Condition-Compliance  
with R/G 1.97



Dear Mr. Miraglia:

Pursuant to Item 2.C(7) of the License we have reviewed the design, qualification and installation of instruments at the Diablo Canyon Power Plant to determine what changes are needed to comply with the Regulatory Guide 1.97, Revision 2. The Regulatory Guide lists 69 separate variables which need to be reviewed. (Some variables are listed more than once in the Regulatory Guide.)

PGandE's review of these items is summarized in Tables 1 through 5 attached. Table 1 lists the 48 variables which comply with the Regulatory Guide. The work required to bring 21 remaining variables into compliance has been categorized as follows:

8110260214 811022  
PDR ADOCK 05000275  
A PDR

*Handwritten:* A048  
5/11



Mr. Frank J. Miraglia, Jr.

- 2 -

October 22, 1981

Table 2: Eleven variables which require qualification of the existing equipment.

Table 3: Four variables which require changing the ranges.


Table 4: One variable which requires upgrading of the indication loop.

Table 5: Five variables which require new indication loops.

We will complete this work prior to the June, 1983 implementation date established in the Regulatory Guide.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

  
for Philip A. Crane, Jr.

Enclosure .

cc(w/enc.): Service List




TABLE 1

<u>VARIABLE</u>	<u>FUNCTION</u>	<u>CORRECTIVE ACTION</u>
1) Control Rod Position	1) Reactivity Control Type B, Category 3	None.
2) RCS Soluble Boron Concentration	1) Reactivity Control Type B, Category 3	None.
3) RCS Pressure	1) Core Cooling Type B, Category 1	None.
	2) Maintaining Reactor Coolant System Integrity Type B, Category 1	
	3) Reactor Coolant Pressure Boundary Type C, Category 1	
	4) Containment Type C, Category 1	
4) Core Exit Temperature	1) Core Cooling Type B, Category 3	None.
	2) Fuel Cladding Type C, Category 1	
5) Coolant Level in Reactor	1) Core Cooling Type B, Category 1	None.
6) Degrees of Subcooling	1) Core Cooling Type B, Category 2	None.
7) Containment Sump Water Level	1) Maintaining Reactor Coolant System Integrity Type B, Category 2(NR) Category 1 (WR)	None.
	2) Reactor Coolant Pressure Boundary Type C, Category 2(NR) Category 1(WR)	






TABLE 1 (Cont'd.)

<u>VARIABLE</u>	<u>FUNCTION</u>	<u>CORRECTIVE ACTION</u>
8) Containment Pressure	1) Maintaining Reactor Coolant System Integrity Type B, Category 1	None.
	2) Maintaining Containment Integrity Type B, Category 1.	
	3) Reactor Coolant Pressure Boundary Type C, Category 1	
	4) Containment Type C, Category 1	
9) Containment Isolation Valve Position	1) Maintaining Containment Integrity Type B, Category 1	None.
10) Analysis of Primary Coolant (Gamma Spectrum)	1) Fuel Cladding Type C, Category 3	None.
11) Containment Area Radiation	1) Reactor Coolant Pressure Boundary Type C, Category 3	None.
	2) Containment Radiation, Type E, Category 1	
12) Effluent Radioactivity Noble Gas Effluent from Condenser Air Removal System Exhaust	1) Reactor Coolant Pressure Boundary Type C, Category 3	None.
13) Containment Hydrogen Concentration	1) Containment Type C, Category 1	None.
14) Containment Effluent Radioactivity - Noble Gases from Identified Release Points	1) Containment Type C, Category 2	None.




TABLE 1 (Cont'd.)

VARIABLE	FUNCTION	CORRECTIVE ACTION
15) Effluent Radioactivity Noble Gases (inside buildings or areas)	1) Containment Type C, Category 2.	None.
16) Accumulator Isolation Valve Position	1) Safety Injection System Type D, Category 2	None.
17) Refueling Water Storage Tank Level	1) Safety Injection System Type D, Category 2	None.
18) Reactor Coolant Pump Status	1) Primary Coolant System, Type D, Category 3	None.
19) Primary System Safety Relief Valve Positioners (including PORV and code valves) or flow through or pressure in Relief Valve Lines	1) Primary Coolant System, Type D, Category 2	None.
20) Pressurizer Level	1) Primary Coolant System, Type D, Category 1	None.
21) Pressurizer Heater Status	1) Primary Coolant System, Type D, Category 2	None.
22) Quench Tank Level	1) Primary Coolant System, Type D, Category 3	None.
23) Quench Tank Pressure	1) Primary Coolant System, Type D, Category 3	None.
24) Steam Generator Level	1) Secondary System Type D, Category 1	None.




TABLE 1 (Cont'd.)

VARIABLE	FUNCTION	CORRECTIVE ACTION
25) Safety/Relief Valve Positions on Main Steam Flow	1) Secondary System Type D, Category 2	None.
26) Main Feedwater Flow	1) Secondary System Type D, Category 3	None.
27) Auxiliary or Emergency Feedwater Flow	1) Auxiliary Feedwater Type D, Category 2	None.
28) Condensate Storage Tank Water Level	1) Auxiliary Feedwater Type D, Category 1	None.
29) Component Cooling Water Temperature to ESF System	1) Cooling Water System Type D, Category 2	None.
30) Component Cooling Water Flow to ESF System	1) Cooling Water System Type D, Category 2	None.
31) High-Level Radioactive Liquid Tank Level	1) Radwaste System Type D, Category 3	None.
32) Radioactive Gas Hold-Up Tank Pressure	1) Radwaste System Type D, Category 3	None.
33) Emergency Ventilation Damper Position	1) Ventilation System Type D, Category 2	None.
34) Status of Standby and other Energy Sources Important to Safety (hydraulic, pneumatic)	1) Power Supplies Type D, Category 2	None.
35) Radiation Exposure Rate (inside buildings on areas where access is required to service equipment important to safety)	1) Area Radiation Type E, Category 2	None.
36) Noble Gases and Vent Flow Rate (Common Plant Vent Discharging Any of Above Releases if containment purge is included,	1) Airborne Radioactive Materials Released from Plants Type E, Category 2	None.




TABLE 1 (Cont'd.)

VARIABLE	FUNCTION	CORRECTIVE ACTION
37) Noble Gases and Vent Flow Rate (Vent from Steam Generator Safety Relief Valves or Atmospheric Dump Valves)	1) Airborne Radioactive Materials Released from Plants Type E, Category 2	None.
38) Noble Gases and Vent Flow Rate (All other Identified Release Points)	1) Airborne Radioactive Materials Released from Plants Type E, Category 2	None.
39) Radiation Exposure Meters (continuous indication at fixed locations)	1) Environs Radiation and Radioactivity Type E	None.
40) Airborne Radiohalogens and Particulates (portable sampling with onsite analysis capability)	1) Environs Radiation and Radioactivity Type E, Category 3	None.
41) Plant and Environs Radiation (portable instrumentation)	1) Environs Radiation and Radioactivity Type E, Category 3	None.
42) Plant and Environs Radioactivity (portable instrumentation)	1) Environs Radiation and Radioactivity Type E, Category 3	None.
43) Wind Direction	1) Meteorology Type E, Category 3	None.
44) Wind Speed	1) Meteorology Type E, Category 3	None.
45) Estimation of Atmospheric Stability	1) Meteorology Type B, Category 3	None.
46) Primary Coolant and Sump	1) Accident Sampling Capability (Analysis capability on Site) Type E, Category 3	None.






TABLE 1 (Cont'd.)

<u>VARIABLE</u>	<u>FUNCTION</u>	<u>CORRECTIVE ACTION</u>
47) Containment Air	1) Accident Sampling Capability (Analysis Capability on Site) Type E, Category 3	None.
48) Particulates and Halogens (All Identified Plant Release Points. Sampling with Onsite Analysis Capability)	1) Airborne Radioactive Materials Released from Plant Type E, Category 3	None.




TABLE 2

<u>VARIABLE</u>	<u>FUNCTION</u>	<u>CORRECTIVE ACTION</u>
1) Neutron Flux	1) Reactivity Control Type B, Category 1	Qualify the equipment
2) RHR System Flow	1) Residual Heat Removal Type D, Category 2	Qualify the transmitter
3) RHR Heat Exchanger Outlet Temperature	1) Residual Heat Removal Type D, Category 2	Qualify the transmitter
4) Accumulator Tank Level	1) Safety Injection System, Type D, Category 2	Qualify the transmitter
5) Accumulator Tank Pressure	1) Safety Injection System, Type D, Category 2	Qualify the transmitter
6) Boric Acid Charging Flow	1) Safety Injection System, Type D, Category 2	Qualify the transmitter
7) Flow in HPI System	1) Safety Injection System, Type D, Category 2	Qualify the transmitter
8) Flow in LPI System	1) Safety Injection System, Type D, Category 2	Qualify the transmitter
9) Makeup Flow-In	1) Chemical and Volume Control System Type D, Category 2	Qualify the transmitter
10) Letdown Flow-Out	1) Chemical and Volume Control System Type D, Category 2	Qualify the transmitter
11) Volume Control Tank Level	1) Chemical and Volume Control System Type D, Category 2	Qualify the transmitter



TABLE 3

<u>VARIABLE</u>	<u>FUNCTION</u>	<u>CORRECTIVE ACTION</u>
1) RCS Cold Leg Water Temperature	1) Reactivity Control Type B, Category 3  2) Core Cooling Type B, Category 1	Change the present range of 0° - 700°F. to 50° - 750°F. There is no span change.
2) RCS Hot Leg Water Temperature	1) Core Cooling Type B, Category 1	Change the present range of 0° - 700°F to 50° - 750°F. There is no span change.
3) Quench Tank Temperature	1) Primary Coolant System Type D, Category 3	Change the range from 50° - 300°F to 50° - 750°F.
4) Steam Generator Pressure	1) Secondary System Type D, Category 2	Change the range from 0 - 109% of safeties to 1320 psig.




TABLE 4

<u>VARIABLE</u>	<u>FUNCTION</u>	<u>CORRECTIVE ACTION</u>
1) Containment Atmosphere Temperature	1) Containment Cooling System Type D, Category 2	Upgrade the indication loop. Replace the existing loop with a new one that meets the requirement.






TABLE 5

VARIABLE	FUNCTION	CORRECTIVE ACTION
1) Radioactivity Concentration on Radiation Level in Circulating Primary Coolant	1) Fuel Cladding Type C, Category 1	Add new indication loops
2) Radiation Exposure Rate (inside buildings or areas, e.g., auxiliary building, reactor shield building annulus, fuel handling building, which are in direct contact with primary containment where penetrations and hatches are located)	1) Containment Type C, Category 2	Add new indication loops (Monitors at the penetration area and the Fuel Handling Building)
3) Containment Spray Flow	1) Containment Cooling Systems Type D, Category 2	Add new indication loops
4) Containment Sump Water Temperature	1) Containment Cooling Systems Type D, Category 2	Add new indication loop
5) Heat removal by the Containment Fan Heat Removal System	1) Containment Cooling Systems Type D, Category 2	Add new indication loops

