



**INDIANA AND MICHIGAN POWER  
D. C. COOK NUCLEAR PLANT  
UPDATED FINAL SAFETY ANALYSIS REPORT**

Revised: 26.0  
Table: 9.8-4B  
Page: 1 of 1

**Nominal Design Flow Rates for Alternate Configuration of NESW Directly To  
Containment AHUs:**

Containment Ventilation: Unit No. 1 Upper Units	320
Containment Ventilation: Unit No. 1 Lower Units	1760
Containment Ventilation: Unit No. 2 Upper Units	320
Containment Ventilation: Unit No. 2 Lower Units	1760
Unit No. 1 Instr. Room Vent	50
Unit No. 2 Instr. Room Vent	50
Unit No. 1 RCP Motor Air Coolers	440
Unit No. 2 RCP Motor Air Coolers	440
Unit No. 1 Steam Generator Blowdown Sample Heat changer	11
Unit No. 2 Steam Generator Blowdown Sample Heat Exchanger	11
Unit No. 1 Steam Generator Blowdown Heat Exchanger	160
Unit No. 2 Steam Generator Blowdown Heat Exchanger	160

With less than design temperature NESW, actual flow rates may be lower and still provide adequate cooling.