



- O DENOTES FIRE HOSE CONN
- NOTE 1, E/S, K/5
MEZZ GEN END
SPRINKLER ALARM VALVE
- NOTE 2, F/S, K/5
BASEMENT GEN END
SPRINKLER ALARM VALVE
- NOTE 3, F/S, J/4
MEZZANINE TURBINE END
SPRINKLER ALARM VALVE
- NOTE 4, F/S, J/5
BASEMENT TURBINE END
PIPING SPRINKLER ALARM
VALVE
- NOTE 5, G/5, J/5
AUXILIARY FEED PUMP
SPRINKLER ALARM VALVE.
- NOTE 6, C/5
SERVICE BLDG. SPRINKLER
ALARM VALVE
- NOTE 7, C/5
OFFICE BLDG. SPRINKLER
ALARM VALVE.
- NOTE 8, C/6
MISC. OIL ROOM,
SPRINKLER ALARM VALVE.
- NOTE 9, C/6
AUX. BOILER SPRINKLER
ALARM VALVE
- NOTE 10, C/6
BOTTLE SHED DELUGE
VALVE
- NOTE 11, C/6
OFFICE BUILDING ROAD
OVERHANG DELUGE VALVE
- NOTE 12, J/6, U/6, G/6, E/6
CABLE RACK 1 OIL PIPING
SPRINKLER ALARM VALVES
- NOTE 13, J/4
UNIT 2 CONTROL RM. CABLE
VAULT, TEMPORARY SPRINKLER
ALARM VALVE

REFERENCES:

OP-1 (21-5182C
OP-1 (21-5182B
OP-1 (21-5183B
OP-1 (21-5183D
OP-1 (21-5183H)

NOTE:
VALVE POSITIONS ARE NOT
GOVERNED BY THE UFSAR
FIGURES BUT RATHER BY
STATION PROCEDURES
(EXCEPT VALVES WITH LOCKED
OR SEALED, AND FAILURE
POSITIONS AS INDICATED).

18.0 Revised Per UCR 1592

DATE	NO.	DESCRIPTION	APPR.
REVISIONS			
FILENAME: 600-10-2-1-1143 (PARTIAL FILE: 600-10-2-1-1143.d)			
THIS DRAWING IS THE PROPERTY OF THE AMERICAN ELECTRIC POWER SERVICE CORP. AND IS LOANED UNDER AGREEMENT THAT IT IS NOT TO BE REPRODUCED OR COPIED, IN WHOLE OR IN PART, OR USED FOR REPRODUCING INFORMATION TO ANY PERSON WITHOUT THE WRITTEN CONSENT OF THE AEP SERVICE CORP., OR FOR ANY PURPOSE DETRIMENTAL TO THEIR INTEREST, AND IS TO BE RETURNED UPON REQUEST.			
INDIANA MICHAEL POWER COMPANY DONALD C. COOK NUCLEAR PLANT			
FIRE PROTECTION WATER UNITS 1 & 2			
DWG. NO. FSAR FIG. 9.8-1			
ARCH	ELEC	MECH	STR
DATE	ON		
BY: [Signature]			
FOR: [Signature]			
AEP SERVICE CORP. 1 INVERNESS PLAZA COLUMBUS, OH 43260			

SEE DISCREPANCY FOR MISSING INFO. CONTAINMENT RCP & CHARCOAL FILTERS,
CABLE TUNNEL HOSE REELS, AUX BLDG. 500, 604 & 605 PREACTION SPRINKLERS, DIESEL FIRE PUMP
SPRINKLERS, TECH. SUPPORT SPRINKLER, CHARCOAL FILTER, OFFICE BLDG. HEADER CONN.
TO OUTSIDE LOOP, NEW OFF. BLDG. SPRINKLER, STORAGE ROOM, RACK SPRINKLERS, MISC. VARS
BUILDING SPRINKLER SYSTEMS, CONNECTIONS TO FIRE WATER STORAGE TANKS, FIRE PUMP DATA...
MISC. HOSE STATION ADDITIONAL.

A-2 500 GPM WEST DIESEL DRIVEN FIRE PUMP
B-2 500 GPM EAST DIESEL DRIVEN FIRE PUMP
C-2 500 GPM MOTOR DIESEL DRIVEN FIRE PUMP
D-50 GPM PEGGING PUMP

ENGINE DRIVEN PUMP
ABANDON IN PLACE
NOT AVAILABLE FOR SERVICE

ENGINE DRIVEN PUMP
ABANDON IN PLACE
NOT AVAILABLE FOR SERVICE