

## REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8103180489    DOC. DATE: 81/03/09    NOTARIZED: NO    DOCKET #  
 - FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga    05000275  
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga    05000323

AUTH. NAME	AUTHOR AFFILIATION
CRANE, P.A.	Pacific Gas & Electric Co.
RECIP. NAME	RECIPIENT AFFILIATION
ENGELKEN, R.H.	Region 5, San Francisco, Office of the Director

SUBJECT: Final deficiency rept re Hagan Model 118 low level  
 amplifiers indicating improper output voltages, initially  
 reported on 810206. Transistors 2N699 in Location Q14 will be  
 replaced. Technical analysis encl.

DISTRIBUTION CODE: B019S    COPIES RECEIVED: LTR    ENCL    SIZE: 16  
 TITLE: Construction Deficiency Report (10CFR50.55E)


NOTES: 1 cy:J Hanchett (Region V)	05000275
1 cy:J Hanchett (Region V)	05000323

	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR	COPIES ENCL
ACTION:	A/D LICENSNG 04	1	1	MIRAGLIA, F. 05	1	1
	LEE, J. 06	1	1	BUCKLEY, B. 07	1	1
INTERNAL:	AD/RCI/IE 17	1	1	ASLBP/J. HARD	1	1
	D/DIR HUM FAC15	1	1	EDO & STAFF 19	1	1
	EQUIP QUAL BR11	1	1	HYD/GEO BR 22	1	1
	I&E 09	1	1	LIC QUAL BR 12	1	1
	MPA 20	1	1	NRC PDR 02	1	1
	OELD 21	1	1	PROG/TST REV 13	1	1
	QA BR 14	1	1	REG FILE 01	1	1
	RUTHERFORD, W. IE	1	1	STANDRDS DEV 21	1	1
EXTERNAL:	ACRS 16	16	16	LPDR 03	1	1
	NSIC 08	1	1			

MAR 19 1981

TOTAL NUMBER OF COPIES REQUIRED: LTTR 39  
 ENCL 39

RE



**COPY**


PACIFIC GAS AND ELECTRIC COMPANY

PG&E

P. O. BOX 7442 • 77 BEALE STREET, 31ST FLOOR, SAN FRANCISCO, CALIFORNIA 94106  
TELEPHONE (415) 781-4211

TELECOPIER (415) 543-7813

March 9, 1981



Mr. R. H. Engelken, Director  
Office of Inspection and Enforcement  
Region V  
U. S. Nuclear Regulatory Commission  
1990 N. California Boulevard  
Walnut Creek Plaza, Suite 202  
Walnut Creek, CA 94596

Re: Docket No. 50-275  
Docket No. 50-323  
Diablo Canyon Units 1 and 2

Dear Mr. Engelken:

This letter is being submitted to the NRC as a final report on a situation at Diablo Canyon Units 1 and 2 pursuant to 10 CFR 50.55(e). Initial notification was made to Dennis Kirsch on February 6, 1981.

During recent testing of the delta T input to the Reactor Protection System, the output of four of seven Hagan Model 118 low level amplifiers was noted to be approximately 60% of full scale when the input was open-circuited (simulated open RTD) rather than full scale as intended.


The problem has been narrowed down to the chopper section of these Hagan modules. Signal tracing on one of the failed amplifiers showed that the demodulated output of the chopper section was not operating as desired.

An amplifier, operating properly, should have a voltage of approximately -0.5 VDC at the output of the chopper section with an RTD connected and at Reactor Coolant System operating temperature. When this RTD is open-circuited, the output of the chopper section goes to approximately -.6 VDC causing the amplifier to saturate and drive the indication off scale thereby indicating an equipment problem.

B019  
S  
11

8103180489

S



# COPY

Mr. R. H. Engelken

-2-

March 9, 1981

The chopper stage on the problem modules produced an output voltage of approximately -.005 VDC both during proper RTD operation and when the RTD was open-circuited. With the RTD open-circuited, the chopper stage transistor (Q14), would not conduct sufficiently to shift the signal at its emitter to produce the proper negative value to force the proper module output.

The problem modules all had 2N699 transistors as Q14. The modules which functioned properly had Sprague 2N4383 transistors. Both transistors are the devices originally installed by the manufacturer.

The safety implications of this problem involve the Reactor Protection System reactor coolant delta T and T AVG inputs, the RCS overpressurization temperature inputs, and the pressurizer vapor temperature protection input. Since modules within similar loops may be interchanged, any of the problem modules could have been used in any of the similar temperature loops. The attached table shows all the Reactor Protection System inputs that could be affected and provides an analysis of the specific safety implications.

The present solution to the problem is to replace all 2N699 transistors in the Q14 location with 2N4383 transistors or an approved equivalent. In the interim Westinghouse is supplying Diablo Canyon Power Plant with enough Sprague 2N4383 transistors to replace the applicable 2N699 transistors in all Class IA installations. However, the 2N4383 device is no longer in production and Sprague has recommended an equivalent device, the TP4384, as a replacement. Westinghouse is presently reviewing this problem for an ultimate solution. We will notify you if the permanent solution differs from the solution outlined above.

A detailed technical analysis of this situation is attached to provide sufficient information to permit analysis and evaluation of this deficiency by the staff. If you have any questions, please contact our licensing staff.


Sincerely,

Philip A. Crane, Jr.

#### Attachments

CC w/attachments: Director  
Office of Inspection and Enforcement  
U. S. Nuclear Regulatory Commission  
Washington, DC 20555


Service List



**SAFETY IMPLICATION TABLE**


<u>Module</u>	<u>Service</u>	<u>Safety Function(s) Affected</u>	<u>Safety Implication</u>
TM-411A	Hot Leg	1) Over Power $\Delta T$ Reactor Trip	Note 1
TM-421A	Manifolds	2) Over Temperature $\Delta T$ Reactor Trip	Note 2
TM-431A	$\Delta T$ Protection	3) Feedwater Isolation	Note 3
TM-441A			
TM-411B	Cold Leg	1) Over Power $\Delta T$ Reactor Trip	Note 1
TM-421B	Manifolds	2) Over Temperature $\Delta T$ Reactor Trip	Note 2
TM-431B	$\Delta T$ Protection	3) Feedwater Isolation	Note 3
TM-441B			
TM-413B	RCP 1-1 Discharge to Loop 1 Cold Leg	Interlock with Reactor Coolant High Press' to Open PORV	Failure of the associated RTD could prevent automatic opening of'PORV on RCS overpressure
TM-423B	RCP 1-2 Discharge to Loop 2 Cold Leg	Interlock with Reactor Coolant High Press' to Open PORV	Failure of the associated RTD could prevent automatic opening of'PORV on RCS overpressure
TM-454	Pressurizer Vapor Temperature Protection	Interlock with RC Press to Open/Block RHR pp Suction Valve	Failure of the associated RTD could prevent automatic opening of RHR pumps suction valve

RCHowe  
3/6/81




NOTES

1. Failure of the associated RTD could prevent a reactor trip in response to reactor overpower operation.
2. Failure of the associated RTD could prevent a reactor trip in response to reactor coolant overtemperature.
3. Failure of the associated RTD could prevent feedwater isolation on low coolant leg  $T_{avg}$  causing an excessive reactor vessel cooldown rate.



**ATTACHMENT**

**Technical Analysis of  
Two Hagen Model 118 Low Level Amplifier Chopper Sections**



TEST SEQUENCE

- ① TEST TM-41A TM-41B OUTPUT WITH VIDEO RESISTANCE AND SIMULATED OPEN RTD.
- ② USE ONE 2N699 AND ONE 2N4383 AND ALTERNATELY INSTALL IN EACH MODULE IN G14 POSITION.
- ③ REPEAT ITEM 1 AND TAKE PHOTOS.
- ④ SWAP THE TWO TRANSISTORS WHILE HOLDING OTHER CONNECTIONS UNCHANGED.
- ⑤ REPEAT ITEM 1 AND TAKE PHOTOS.

411 A

↓  
Q14 = 2N699 (MITS?)

↓  
TAKE DATA  
# PHOTOS

411 B

↓  
Q14 = 2N4383 (SCHNEIDER)

↓  
TAKE DATA  
# PHOTOS

SWAP  
Q14

↓  
TAKE DATA  
# PHOTOS

↓  
TAKE DATA  
# PHOTOS

OR SIMPLY  
CONNECT WIRE

↓  
TAKE DATA  
# PHOTOS

↓  
TAKE DATA  
# PHOTOS

↓  
RETURN

↓  
RETURN

↓  
SERVICE

↓  
SERVICE

- ⑥ TAKE SIMILAR DATA & PHOTOS USING SPANNER MODULE S/N E325 1512 RCM 2N699 IN R14 POSITION.

SUPV.	DIAGNOSIS DATA	B/M
DSGN.	MV/I OPEN RTD OUTPUT PROBLEMS	DWG. LIST
CWN.		SUPSDS
CHKD.	REF: OCC-81-TI-PCC-3 & NCR 81-TI-C01	SUPSD BY
C.K.		SHEET NO. / SHEETS
DATE	PACIFIC GAS AND ELECTRIC COMPANY	DRAWING NUMBER / REV.
3-19-81	SAN FRANCISCO, CALIFORNIA	REF #
SCALE		663230-3




TEST DATA

MODULE	S/N	INPUT NORMAL	INPUT OPEN	DATE	TESTER
SPARE E-305		2.61	-5.37	▲ 6.43	G14-RCA 2N693
TM-411A E-257		2.63	-5.23	* 3.62	G14-(MFG) 2N693
TM-411A E-239		2.67	-6.02	6.43	G14-SPRINGS 2N4383
TM-411B S22		2.76	-6.27	6.92	↓ SAME Y-SISTER
TM-411C E-39		2.65	-5.21	* 3.12	↓ SAME Y-SISTER

\* OUTPUT DOES NOT SWING IN OPEN INPUT MODES OPEN

▲ PEAKING ADJUSTABLE - SEE PICTS



CHOPPER CIR


Floating pot sig common

SM	
SUPV.	
DSGN.	
CWN.	
CHKD.	
O.K.	
DATE 2-19-51	SCALE

MU/I PAGE 6

BIM  
DWG. LIST  
SUPSDS  
SUPSD BY  
SHEET NO. 2 SHEETS  
DRAWING NUMBER REV.

PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA



SM	
SUPV.	
DSGN.	
TEST	
CHKC.	
O.K.	

DATE

SCALE

CIRCUIT ANALYSIS  
MATERIAL TEST CURRENT PROBLEMS/N E-289 (USING HIGH B 2N4383  
IN Q14 POSITION)

17M-411A

SOME MARKINGS USING Q14

2N699 (T)

GND REF

500mV

200μS

SPRAGUE 2N4383

Q14 Emitter Open

S/N E-289

DATE

SCALE



PACIFIC GAS AND ELECTRIC COMPANY

SAN FRANCISCO, CALIFORNIA

MATERIAL

DRAWING NUMBER

REV.






The output waveform at the emitter of transistor Q14 indicating that the x-section is conducting due to a positive voltage at its base. The conductance of Q14 shifts the average value of the chopper waveform negative with respect to floating pot sig common. The demodulated signal (waveform) is then filtered, producing a negative voltage across C8 and C9 which is fed to the high frequency differential amplifier section (Q15). This imbalance drives the module output high.

17M-411A  
S/N E-289 (USING 2N699 WITH B ≈ 40  
IN Q14 POSITION -  
ORIGINAL TRANSISTOR)  
The waveform at the emitter of Q14 indicate no average value shift.

The waveform (clipping) at the base of Q14 strongly suggests that some base current is present. (See photos next page.)

To test whether sufficient drive could be obtained from the 2N699, resistor R22 was paralleled with another resistor to produce the conditions shown on the left. An equivalent resistance of 6kΩ appeared to work adequately, although the maximum Emitter-Base Voltage (5V @ 25°C) was being approached.





Base drive waveform -  
Q14 using 2N637  
S/N E-289

Drive waveform  
using 2N637  
S/N E-289


Base drive waveforms to  
Q14 using 2N 4383  
S/N E-289


B/M	
S/PV.	
DSGN.	
CAT.	
CHKD.	
C.K.	
DATE	SCALE
2-19-81	

MIN/I PROBLEM


PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

B/M	
CWG. LIST	
SUPSDS	
SUPSD BY	
SHEET NO. / SHEETS	
DRAWING NUMBER / REV.	





2N 699 (T)



SPRAGUE 2-N-4383

SPRAGUE 2-N-4383  
DISTRICT - X-511112 K012 Q14

17m - 411B  
S/N 588


Emitter waveform for Q14  
using 2N4383. NOTE  
shift in waveform envelope  
1ra/10.

Emitter waveform for Q14  
using 2N699. Again in sufficient  
using base drive is suggested.

44	
SUPV.	
DSGN.	
EN.	
CHKD.	
C.R.	
DATE	SCALE
2-19-81	

PROBLEM  
PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

B.M	
DWG. LIST	
SUPSDS	
SUPSD BY	
SHEET NO. 5 SHEETS	
DRAWING NUMBER REV.	



Q14 BASE  
INPUT OPEN  
411B S/N 588

2N699 (T)

Q14 BASE  
INPUT OPEN  
411B S/N 588

SPPAGUE 2N4383

17M11-411B  
S/N 588  
DIFFERENT X-S1:20K FOR Q14

17M - 411B  
S/N 588


Base of new waveform from Q14  
using 2N4383.  
using 2N699.



GM	
SUPV.	
DSGN.	
DW.	774
CHKD.	
O.K.	
DATE	2-17-51
SCALE	

17M/2 PAC583

PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

B:M	
DWG. LIST	
SUPSDS	
SUPSD BY	
SHEET NO. 2	2 SHEETS
DRAWING NUMBER	REV. C





SPRAGUE AVERAGE USING  
DIFFERENT X-SIGNAL FOR: Q14.

1711-4118  
S/N 588

Output waveform from Q13  
Collector which is fed across  
Q14 to Q14 (2N 4383)

1711-4118

S/N 588

Output waveform from Q13  
Collector which is fed across  
Q14 to Q14 (2N 4383)

These waveforms appear to be identical and unaffected by Q14.


S/M
SJFV.
DSGN.
OWN. TCH
CHKD.
O.K.
DATE 2-17-78
SCALE



MICROFILM

10

S/M
SJFV.
DSGN.
OWN. TCH
CHKD.
O.K.
DATE 2-17-78
SCALE

PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA






The information obtained in the construction of Q13  
indicates that the base drive signal and the  
emitter signal is of +14



S/N: 2 N699 S/N E-305

GM
SUPV.
DSGN.
C.W.
CHKD.
O.K.
DATE
SCALE

MU/T PRELIM  
PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

B:M
DWG. LIST
SUPSDS
SUPSD BY
SHEET NO. 3 SHEETS
DRAWING NUMBER REV.





Both those waveforms were observed at the emitter of Q14. The first hole measurement taken at the input indicated that input resistance is opened in the second reference point after 1.5 sec. This characteristic produces no such delay and negligible marginal performance. No such waveform was observed in those modes, whence a 2N2363 was tested from 1.74.


This conclusion is further supported by the fact that an RCA 2N699 was installed in T174/14 and appeared to function normally on the bench. However, installation in the HAGAN rack did little right, the output was not stimulated often. The 2N699 was simulated as open.



SPV.	
DSGN.	
EWL. FCL	
CHKD.	
C.K.	
DATE 2-12-81	SCALE

M.V/I - PROBLEMS

PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

B/M	
DWG. LIST	
SUPSDS	
SUPSD BY	
SHEET NO. / SHEETS	
DRAWING NUMBER / REV.	





Please drive transistor Q14 with an input waveform of 1/2 sine wave. The output waveform was obtained using a d.c. the module.


Mr. Jerry Springer 2N4383 Transistor circuit revision Q14.



Sample module S/N 2N699

GM.	
SUPV.	
DSGN.	
D.W.	
CHKD.	
O.K.	
DATE	SCALE
2-19-91	

PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

B/M	
DWG. LIST	
SUPSDS	
SUPSD BY	
SHEET NO. /	1 SHEETS
DRAWING NUMBER	REV.





CM	
SUPV.	
DSGN.	
CIV. 7-18	
CHKD.	
C.K.	
DATE 2-12-77	SCALE

PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO, CALIFORNIA

Q14 emitter test from scope with  
the monitor off and  
input resistance of 433 ohms.

There was no observable difference in the Q14 operation  
when the monitor was either on or off with the input resistance of 433 ohms.  
The input of monitor was 473 ohms.

TMH-111 B3 S/N 588

SPARE: normal S/N 6-305

B/M
DWG. LIST
SUPSDS
SUPSD BY
SHEET NO. 11 SHEETS
DRAWING NUMBER REV.

