

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7905210172 DOC. DATE: 79/05/17 NOTARIZED: NO DOCKET #
 FACIL: 50-275 DIABLO CANYON NUCLEAR POWER PLANT, UNIT 1, PACIFIC GA ~~0500275~~
 50-323 DIABLO CANYON NUCLEAR POWER PLANT, UNIT 2, PACIFIC GA 05000323
 AUTH. NAME AUTHOR AFFILIATION
 CRANE, P.A. PACIFIC GAS & ELECTRIC CO.
 RECIP. NAME RECIPIENT AFFILIATION
 STOLZ, J.F. LIGHT WATER REACTORS BRANCH 1

SUBJECT: FORWARDS ADDL INFO ON CONTAINMENT ELECTRICAL PENETRATIONS
 IN RESPONSE TO NRC QUESTIONS.

DISTRIBUTION CODE: B001B COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3
 TITLE: PSAR/FSAR AMDTS AND RELATED CORRESPONDENCE.


NOTES: J. Hanchett w/1 cy all matl

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL		ID CODE/NAME	LTR
	05 PM B. Buckley	1	1	AD VASSALLO	1	0
	BC Lwr #1	1	0	LA Lwr #1	1	0
INTERNAL:	01 <u>REG FILE</u>	1	1	02 NRC PDR	1	1
	06 I & E	2	2	08 OPERA LIC BR	1	1
	09 GEOSCIEN BR	1	1	10 QAB	1	1
	11 MECH ENG BR	1	1	12 STRUC ENG BR	1	1
	13 MATL ENG BR	2	2	15 REAC SYS BR	1	1
	16 ANALYSIS BR	1	1	17 CORE PERF BR	1	1
	18 AUX SYS BR	1	1	19 CONTAIN SYS	1	1
	20 I & C SYS BR	1	1	21 POWER SYS BR	1	1
	22 AD SITE TECH	4	4	26 ACCDNT ANLYS	1	1
	27 EFFL TRT SYS	1	1	28 RAD ASMT BR	1	1
	29 KIRKWOOD	1	1	AD FOR ENG	1	0
	AD PLANT SYS	1	0	AD REAC SAFETY	1	0
	AD SITE ANLYSIS	1	0	DIRECTOR NRR	1	0
	MPA	1	0	OELD	1	0
EXTERNAL:	03 LPDR	1	1	04 NSIC	1	1
	30 ACRS	10	10			

LTR
 Moore
 EPB #1 BC
 S. Kirslis
 EPB #1 LA

MAY 22 1979

TTAC
 CCP



PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY
VICE PRESIDENT AND GENERAL COUNSEL

MALCOLM H. FURBUSH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN
PHILIP A. CRANE, JR.
HENRY J. LAPLANTE
RICHARD A. CLARKE

JOHN B. GIBSON
ARTHUR L. HILLMAN, JR.
ROBERT OHLBACH
CHARLES W. THISSELL
ASSISTANT GENERAL COUNSEL

May 17, 1979

GILBERT L. MARRICK
DILENN WEST, JR.
DAN DRAYSON LUSBOCK
JACK F. FALLIN, JR.
BERNARD J. DELLABANTA
SENIOR COUNSEL

JOSHUA BAR-LEV
DIANE BROTHAUSSEN
STEVEN P. BURCK
PAMELA CHAPPELLE
BRIAN B. DENTON
WILLIAM H. EDWARDS
JOSEPH S. ENOLET, JR.
JOHN N. FAYE
PATRICK G. GOLDEN
ROBERT L. HARRIS
KERRIT R. KUBITZ
THEODORE L. LINDBERG, JR.
NICHARD F. LUCEE
ROBERT B. MCLENNAN
RICHARD M. MOSE
RODER J. PETERS
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JO ANN SHAFFER
DAVID J. WILLIAMSON
BRUCE R. WORTHINGTON

EDWARD J. MCGANNEY
DANIEL C. DIBSON
JOSEPH J. KELLY
HOWARD V. GOLDS
JAMES C. LOSSBOM

J. PETER BAUMBARTNER
ROBERT L. BROWN
LEIGH S. CASSIDY
HEATHER B. CIBBNA
MICHAEL G. DEWARAIS
DARY P. LUCINAS
DONALD ERIKSSON
DAVID C. GILBERT
PETER W. HANSCHEM
JUAN M. JAYO
F. RONALD LAUPHEIMER
MELIS E. LIPSON
HARRY W. LOND, JR.
RICHARD L. MEISS
DOUGLAS A. OGLESBY
J. MICHAEL REIDENBACH
IVOR E. SANDSON
SUE ANN LEVIN SCHIFF
JACK W. SHUCK
SHIRLEY A. WOOD

ATTORNEYS

Mr. John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275-OL
Docket No. 50-323-OL
Diablo Canyon Units 1 & 2

Dear Mr. Stolz:

The attached additional information on containment electrical penetrations is submitted in response to questions from the Staff.

Five copies of this letter have been sent directly to Mr. Bart Buckley.

Kindly acknowledge receipt of the above material on the enclosed copy of this letter and return it to me in the enclosed addressed envelope.

Very truly yours,

Philip A. Crane, Jr.

Attachments (40)
CC w/attachment:

Mr. Bart Buckley
Elizabeth S. Bowers, Esq.

7905210 172

BOOL
SE 1/1



11

CONTAINMENT ELECTRICAL PENETRATIONS

The following additional information is submitted regarding containment electrical penetrations:

Temperatures in High Voltage Penetrations

Thermal tests were conducted on an energized 18 inch High Voltage Power Penetration Assembly similar in construction to the 24 inch penetrations at Diablo Canyon. The test results (Test #EPAQ-035) are summarized below:

Maximum Conductor Temperature Rise (°C)	Δ T	14	16	23	31
Current (amps)	I	600	675	750	850

The above data is related ($\pm 10\%$) by $I_1^2 : I_2^2 :: \Delta T_1 : \Delta T_2$

Using the above relationship, the expected temperature rise of the conductors carrying 400 amps (the maximum current allowed by overcurrent protection through the high voltage penetrations) would be $6.22^\circ \text{C} \pm 10\%$, the maximum temperature rise at 300 amps would be $3.5^\circ \text{C} \pm 10\%$ and at 266 amps (the normally connected load) would be $2.75^\circ \text{C} \pm 10\%$. Since the tests were conducted on an 18 inch diameter penetration the temperature rise expected in the Diablo Canyon 24 inch high voltage penetrations would be $\frac{1}{2}$ less than on the penetration tested because the larger surface area would provide for greater heat transfer. Furthermore GE has determined the maximum allowable heat load for various penetration sizes. The allowables are summarized below:

MAXIMUM ALLOWABLE

EFFECTIVE HEAT LOAD

Nominal Size of Penetration	Containment Temperature			
	70°C	60°C	50°C	40°C
	<u>Maximum Allowable Watts/Foot</u>			
12"	12	18	25	32
10"	10	15	21	27
8"	8	12	17	21



Extrapolation of the above data suggests that at a Containment Temperature of 70°C, a 24 inch penetration would be allowed to safely generate 24 watts/ft. Calculations show however, that at 400 amps the heat loads would only be 8.4 watts/ft. and at 300 amps 4.7 watts/ft. This data demonstrates sufficient margin for 10 and 12 inch penetrations. The margin for the 24 inch penetration is nearly 3:1.

From the above data it can be concluded that LOCA qualification test results of the penetrations were not adversely effected by not energizing the penetration to the rated loads because actual operating heat loads are very small when compared with acceptable heat loads and actual temperature rise is very small when compared with allowable temperature rise.

Epoxy in Containment Electrical Penetrations

The following is submitted to clarify the responses of October 11, 1978 and March 7, 1979, on containment electrical penetrations.

Type XR5126 epoxy is used in both the high and low voltage penetrations used at Diablo Canyon, Unit 1. The type XR5126 epoxy is the epoxy in the penetrations tested and is chemically identical to both the high and low voltage penetrations used at Diablo Canyon, Unit 1.



10

PACIFIC GAS AND ELECTRIC COMPANY

PG&E + 77 BEALE STREET, 31ST FLOOR • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211

JOHN C. MORRISSEY
VICE PRESIDENT AND GENERAL COUNSEL

MALCOLM H. FURBUSH
ASSOCIATE GENERAL COUNSEL

CHARLES T. VAN DEUSEN

PHILIP A. CRANE, JR.

HENRY J. LAPLANTE

RICHARD A. CLARKE

JOHN B. GIBSON

ARTHUR L. HILLMAN, JR.

ROBERT OHLBACH

CHARLES W. THISSELL

ASSISTANT GENERAL COUNSEL

May 17, 1979

GILBERT L. HARRICK
GLENN WEST, JR.
DAN DRAVEDN LUSBOCK
JACK F. FALKIN, JR.
BERNARD J. DELLASANTA

SENIOR COUNSEL

JOSHUA BAR-LEV
DIANE BERGHAUSEN
STEVEN P. BURKE
PAOLA CHAPPELLE
BRIAN B. DENTON
WILLIAM H. EDWARDS
JOSEPH S. ENGLERT, JR.
JOHN N. FRYE
PATRICK G. GOLDEN
ROBERT L. HARRIS
KERNY R. KUBITZ
THEODORE L. LINDBERG, JR.
RICHARD F. LOCKE
ROBERT S. MCLENNAN
RICHARD H. MOSES
ROGER J. PETERS
ROBERT R. RICKETT
SHIRLEY A. SANDERSON
JO ANN SHAFFER
DAVID J. WILLIAMSON
BRUCE R. WORTHINGTON

EDWARD J. MCDANNEY
DANIEL E. GIBSON
JOSEPH F. KELLY
HOWARD V. GOLUS
JAMES C. LOOSDON

J. PETER BAUMBARTNER
ROBERT L. BORDON
LEIGH B. CASSIDY
HEATHER S. CIBSNA
MICHAEL G. DESHARAIS
DARY P. ENGINAS
DONALD ERICKSON
DAVID G. GILBERT
PETER W. HANSCHEM
JUAN M. JAYO
F. RONALD LAUPHEIMER
MEREK E. LIPSON
HARRY W. LOND, JR.
RICHARD L. MEISS
DOUGLAS A. OLESBY
J. MICHAEL REIDENBACH
IVOR E. SAMSON
SUE ANN LEVIN SCHIFF
JACK W. SHUCK
SHIRLEY A. WOOD

ATTORNEYS

Mr. John F. Stolz, Chief
Light Water Reactors Branch No. 1
Division of Project Management
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Re: Docket No. 50-275-OL
Docket No. 50-323-OL
Diablo Canyon Units 1 & 2

Dear Mr. Stolz:

The attached additional information on contain-
ment electrical penetrations is submitted in response to
questions from the Staff.

Five copies of this letter have been sent
directly to Mr. Bart Buckley.

Kindly acknowledge receipt of the above material
on the enclosed copy of this letter and return it to me in
the enclosed addressed envelope.

Very truly yours,

Philip A. Crane, Jr.

Attachments (40)
CC w/attachment:

Mr. Bart Buckley
Elizabeth S. Bowers, Esq.

DUPE

Good
SE 1/1

7905240172

CONTAINMENT ELECTRICAL PENETRATIONS

The following additional information is submitted regarding containment electrical penetrations:

Temperatures in High Voltage Penetrations

Thermal tests were conducted on an energized 18 inch High Voltage Power Penetration Assembly similar in construction to the 24 inch penetrations at Diablo Canyon. The test results (Test #EPAQ-035) are summarized below:

Maximum Conductor Temperature Rise (°C)	ΔT	14	16	23	31
Current (amps)	I	600	675	750	850

The above data is related ($\pm 10\%$) by $I_1^2 : I_2^2 :: \Delta T_1 : \Delta T_2$

Using the above relationship, the expected temperature rise of the conductors carrying 400 amps (the maximum current allowed by overcurrent protection through the high voltage penetrations) would be $6.22^\circ C \pm 10\%$, the maximum temperature rise at 300 amps would be $3.5^\circ C \pm 10\%$ and at 266 amps (the normally connected load) would be $2.75^\circ C \pm 10\%$. Since the tests were conducted on an 18 inch diameter penetration the temperature rise expected in the Diablo Canyon 24 inch high voltage penetrations would be $\frac{1}{2}$ less than on the penetration tested because the larger surface area would provide for greater heat transfer. Furthermore GE has determined the maximum allowable heat load for various penetration sizes. The allowables are summarized below:

MAXIMUM ALLOWABLE

EFFECTIVE HEAT LOAD

Nominal Size of Penetration	Containment Temperature			
	70°C	60°C	50°C	40°C
<u>Maximum Allowable Watts/Foot</u>				
12"	12	18	25	32
10"	10	15	21	27
8"	8	12	17	21



Extrapolation of the above data suggests that at a Containment Temperature of 70°C, a 24 inch penetration would be allowed to safely generate 24 watts/ft. Calculations show however, that at 400 amps the heat loads would only be 8.4 watts/ft. and at 300 amps 4.7 watts/ft. This data demonstrates sufficient margin for 10 and 12 inch penetrations. The margin for the 24 inch penetration is nearly 3:1.

From the above data it can be concluded that LOCA qualification test results of the penetrations were not adversely effected by not energizing the penetration to the rated loads because actual operating heat loads are very small when compared with acceptable heat loads and actual temperature rise is very small when compared with allowable temperature rise.

Epoxy in Containment Electrical Penetrations

The following is submitted to clarify the responses of October 11, 1978 and March 7, 1979, on containment electrical penetrations.

Type XR5126 epoxy is used in both the high and low voltage penetrations used at Diablo Canyon, Unit 1. The type XR5126 epoxy is the epoxy in the penetrations tested and is chemically identical to both the high and low voltage penetrations used at Diablo Canyon, Unit 1.



[Faint, illegible handwritten marks]