

ROUTING AND TRANSMITTAL SLIP

ACTION

1 TO (Name, office symbol or location) To Diablo Canyon Units 1 & 2 Docket Files	INITIALS	CIRCULATE
	DATE	COORDINATION
2 50-323	INITIALS	FILE
	DATE	INFORMATION
3	INITIALS	NOTE AND RETURN
	DATE	PER CONVERSATION
4 REGULATORY DOCKET FILE BODY	INITIALS	SEE ME
	DATE	SIGNATURE

REMARKS

The attached is an unsolicited PG&E response to I&E Bulletin 79-06A.

cc: Service List  
NRC PDR  
Local PDR

7908170596


Do NOT use this form as a RECORD of approvals, concurrences, disapprovals, clearances, and similar actions

FROM (Name, office symbol or location) Bart C. Buckley, Project Manager Light Water Reactors Branch No. 1	DATE
	PHONE

7/24/79

28355

AD 2  
50



Mr. John C. Morrissey

Mr. John C. Morrissey  
Vice President & General Counsel  
Pacific Gas & Electric Company  
77 Beale Street  
San Francisco, California 94106

cc: Philip A. Crane, Jr., Esq.  
Pacific Gas & Electric Company  
77 Beale Street  
San Francisco, California 94106

Janice E. Kerr, Esq.  
California Public Utilities Commission  
350 McAllister Street  
San Francisco, California 94102

Mr. Frederick Eissler, President  
Scenic Shoreline Preservation  
Conference, Inc.  
4623 More Mesa Drive  
Santa Barbara, California 93105

Ms. Elizabeth E. Apfelberg  
1415 Cazadero  
San Luis Obispo, California 93401

Ms. Sandra A. Silver  
1792 Conejo Avenue  
San Luis Obispo, California 93401

Mr. Gordon A. Silver  
1792 Conejo Avenue  
San Luis Obispo, California 93401

Paul C. Valentine, Esq.  
321 Lytton Avenue  
Palo Alto, California 94302

Yale I. Jones, Esq.  
19th Floor  
100 Van Ness Avenue  
San Francisco, California 94102

Mr. Richard Hubbard  
MHB Technical Associates  
1723 Hamilton Avenue  
Suite K  
San Jose, California 95125

Mr. John Mairs  
Managing Editor  
San Luis Obispo County  
Telegram - Tribune  
1321 Johnson Avenue  
P. O. Box 112  
San Luis Obispo, California 93406

Elizabeth S. Bowers, Esq., Chairman  
Atomic Safety & Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Mr. Glenn O. Bright  
Atomic Safety & Licensing Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Tolbert Young  
P. O. Box 219  
Avila Beach, California 93424

Richard S. Salzman, Esq., Chairman  
Atomic Safety & Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555


Dr. W. Reed Johnson  
Atomic Safety & Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Alan S. Rosenthal, Esq.  
Atomic Safety & Licensing Appeal Board  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Ms. Raye Fleming  
1746 Chorro Street  
San Luis Obispo, California 93401

Brent Rushforth, Esq.  
Center for Law in the Public Interest  
10203 Santa Monica Boulevard  
Los Angeles, California 90067

Arthur C. Gehr, Esq.  
Snell & Wilmer  
3100 Valley Center  
Phoenix, Arizona 85073



Mr. John C. Morrissey

Mr. James O. Schuyler, Nuclear  
Projects Engineer  
Pacific Gas & Electric Company  
77 Beale Street  
San Francisco, California 94106


Bruce Norton, Esq.  
3216 North 3rd Street  
Suite 202  
Phoenix, Arizona 85012

Mr. W. C. Gangloff  
Westinghouse Electric Corporation  
P. O. Box 355  
Pittsburgh, Pennsylvania 15230

Michael R. Klein, Esq.  
Wilmer, Cutler & Pickering  
1666 K Street, N. W.  
Washington, D. C. 20006

David F. Fleischaker, Esq.  
1025 15th Street, N. W.  
5th Floor  
Washington, D. C. 20006

Dr. William E. Martin  
Senior Ecologist  
Battelle Memorial Institute  
Columbus, Ohio 43201




1979 23, 1979

Dear Dr. Matson:

Thank you for meeting with me yesterday. We will undertake to do as you suggested. For your information, I have included a copy of our unsolicited response to 79-06A. As the staff clarifies its position, we will continue to be responsive.

Sincerely,

*H. J. Gormly*  
H. J. Gormly





## INTRODUCTION

IE Bulletin 79-06A requested holders of operating licenses for Westinghouse pressurized water reactors to respond to 13 issues resulting from the Three Mile Island incident. Though we do not yet have operating licenses for Diablo Canyon Units 1 and 2, we have elected to reply to Bulletin 79-06A.

The information in this letter comes from studies by PGandE and by Westinghouse, our NSSS supplier. The studies address the Diablo Canyon system transient response, plant equipment features, and operating procedures, with respect to the Three Mile Island events.

As these studies and the resulting plant modifications progress, we will send supplementary information. Commitments made in this and future letters will be implemented before power operation of the plant.



## BULLETIN ITEM 1

Review the description of circumstances described in Enclosure 1 of IE Bulletin 79-05 and the preliminary chronology of the TMI-2 3/28/79 accident included in Enclosure 1 to IE Bulletin 79-05A.


- a. This review should be directed toward understanding: (1) the extreme seriousness and consequences of the simultaneous blocking of both auxiliary feedwater trains at the Three Mile Island Unit 2 plant and other actions taken during the early phases of the accident; (2) the apparent operational errors which led to the eventual core damage; (3) that the potential exists, under certain accident or transient conditions, to have a water level in the pressurizer simultaneously with the reactor vessel not full of water; and (4) the necessity to systematically analyze plant conditions and parameters and take appropriate corrective action.
- b. Operational personnel should be instructed to: (1) not override automatic action of engineered safety features unless continued operation of engineered safety features will result in unsafe plant conditions (see Section 7a.); and (2) not make operational decisions based solely on a single plant parameter indication when one or more confirmatory indications are available.
- c. All licensed operators and plant management and supervisors with operational responsibilities shall participate in this review and such participation shall be documented in plant records.

## PGandE. RESPONSE

We have reviewed the available information from the Three Mile Island incident. Information and training sessions are being scheduled and will be documented for all operators and for supervisors with operational responsibilities.

The sessions will present a detailed discussion and analysis of the events at Three Mile Island, emphasizing the serious effects of having both trains of auxiliary feedwater secured, the consequences of operator actions early in the event, the apparent operating errors, and the information available from other control room instrumentation during the transient.

Training will be provided to assure that operating personnel know the consequences of overriding safety functions, the necessity to use all available instrumentation before making an operating decision, and of the circumstances under which it is possible to have a low water level in the reactor without low pressurizer level.



## BULLETIN ITEM 2

Review the actions required by your operating procedures for coping with transients and accidents, with particular attention to:

- a. Recognition of the possibility of forming voids in the primary coolant system large enough to compromise the core cooling capability, especially natural circulation capability.
- b. Operator action required to prevent the formation of such voids.
- c. Operator action required to enhance core cooling in the event such voids are formed. (e.g., remote venting)

## PGandE RESPONSE

We are revising the emergency operating procedures to discuss the possibility of void formation in the vessel, how to recognize such a condition, and the steps necessary to maintain core cooling with voids.

We are working with Westinghouse to decide whether additional analyses of other transients and accidents are needed, to prepare and carry out training programs to assure increased operator understanding of the variation of key plant parameters following transient and accidents, and to identify any needed modifications in plant equipment or procedures.

The procedures will be revised to specify that the primary system pressure must be maintained above saturation. If primary system pressure drops below saturation, it will be increased as quickly as possible, and the pressurizer vented to the relief tank as necessary. Also, instrumentation will be installed in the control room which will continuously display the difference between primary system pressure and saturation pressure. An alarm will actuate when saturation pressure is being approached.

It must also be recognized that under some LOCA conditions there is no operator action that will prevent the formation of voids in the system. The ECCS is designed to recover and adequately cool the core following various degrees of primary system voiding, depending on the break size and location.

## BULLETIN ITEM 3

For your facilities that use pressurizer water level coincident with pressurizer pressure for automatic initiation of safety injection into the reactor coolant system, trip the low pressurizer level setpoint bistables such that, when the pressurizer pressure reaches the low setpoint, safety injection would be initiated regardless of the pressurizer level. The pressurizer level bistables may be returned to their normal operating positions during the pressurizer pressure channel functional surveillance tests. In addition, instruct operators to manually initiate safety injection when the pressurizer pressure indication reaches the actuation setpoint whether or not the level indication has dropped to the actuation setpoint.



#### PGandE RESPONSE

The pressurizer low level safety injection bistables will be placed in the tripped condition in operating modes 1, 2, and 3, except during functional testing and calibration of pressurizer level channels. Only one level channel at a time may be placed in the normal condition. Also, we are instructing all our operating personnel to manually initiate safety injection on low pressurizer pressure regardless of level.

These interim changes will be replaced when permanent solutions are identified which will enhance safety and be reliable. Westinghouse is designing a system using revised logic to give the desired control response.

#### BULLETIN ITEM 4

Review the containment isolation initiation design and procedures, and prepare and implement all changes necessary to permit containment isolation whether manual or automatic, of all lines whose isolation does not degrade needed safety features or cooling capability, upon automatic initiation of safety injection.

#### PGandE RESPONSE

The containment isolation systems isolate all nonsafety-related fluid systems penetrating the containment on a Phase A or Phase B containment isolation signal. Phase A is initiated by actuation of the safety injection system and isolates all nonessential process lines but does not affect safety injection, containment spray, component cooling, and steam and feedwater lines. Phase B is initiated by actuation of the containment spray system and isolates all remaining process lines except safety injection, containment spray, and auxiliary feedwater. In addition, the containment purge valves close on a high radiation or safety injection signal.

Containment isolation does not automatically reset by elimination or resetting of the actuation signal. For example, resetting safety injection will not clear containment isolation; the isolation signal can only be cleared by manual controls on the main control board.

The containment isolation valves have the following control features:

1. The valves will remain closed if the containment isolation signal is reset.
2. The containment isolation signals override all other automatic control signals.
3. Each valve can be opened or closed manually after the containment isolation signals are reset.





#### BULLETIN ITEM 5

For facilities for which the auxiliary feedwater system is not automatically initiated, prepare and implement immediately procedures which require the stationing of an individual (with no other assigned concurrent duties and in direct and continuous communication with the control room) to promptly initiate adequate auxiliary feedwater to the steam generator(s) for those transients or accidents the consequences of which can be limited by such action.

#### PGandE RESPONSE

The auxiliary feedwater system at Diablo Canyon is initiated automatically.

#### BULLETIN ITEM 6

For your facilities, prepare and implement immediately procedures which:

- a. Identify those plant indications (such as valve discharge piping temperature, valve position indication, or valve discharge relief tank temperature or pressure indication) which plant operators may utilize to determine that pressurizer power operated relief valve(s) are open, and
- b. Direct the plant operators to manually close the power operated relief block valve(s) when reactor coolant system pressure is reduced to below the set point for normal automatic closure of the power operated relief valve(s) and the valve(s) remain stuck open.

#### PGandE RESPONSE

These valves have position indicating lights on the main control board. However, we are revising our procedures to emphasize the other available indications from which an open pressurizer power relief valve may be inferred. These include: relief valve discharge line temperature and pressurizer relief tank level, pressure, and temperature. Our procedures will include instructions to close the motor-operated stop valves ahead of the relief valves whenever the relief valves fail to close automatically. The pressurizer power relief valves have a completely redundant automatic interlock signal that will close the valves if the pressure drops to 2185 psig.

#### BULLETIN ITEM 7

Review the action directed by the operating procedures and training instructions to ensure that:

- a. Operators do not override automatic actions of engineered safety features, unless continued operation of engineered safety features will result in



b. We are revising our procedures to meet the intent of this requirement. For example, Westinghouse has recommended the following criteria for terminating high-head safety injection following a small-break LOCA:

- A. Wide range RCS pressure  $> 2000$  psi, and
- B. Wide range RCS pressure increasing, and
- C. Narrow range level indication in at least one steam generator, and
- D. Pressurizer level  $\geq 50\%$ .

These criteria, which require that certain system parameters be carefully monitored, assure that the primary system is at least  $50^{\circ}$  subcooled and stable before safety injection can be terminated. Thus, the intent of Bulletin Item 7.b. is met without making subcooling a direct consideration in the procedures.

For those LOCA conditions where both the high-head and low-head safety injection systems would operate and deliver water to the primary system, the Procedures will call for continued operation of both systems.

c. We are working with Westinghouse on this matter.


Westinghouse has not fully evaluated all of the cases covered by the NRC recommendation. Although Westinghouse recommends that the emergency operating procedures for LOCA and steam break accidents remain unchanged and that all reactor coolant pumps be tripped, we have explained more clearly in the procedures the conditions under which the pumps should be manually tripped.

These conditions are that the safety injection pumps are operational, that the primary system pressure is decreasing, and that the pressure is below the safety injection actuation setpoint.

The procedures have also been changed to say that the pumps should be tripped because of certain containment isolation or ECCS sequencing actions (for example, isolation of component cooling).

It should be noted that all design basis accident analyses assume loss of off-site power causing loss of all reactor coolant pumps.

d. Existing procedures and training emphasize that operators should not rely upon a single parameter to terminate safety injection. Also, we are evaluating modified procedures provided by Westinghouse which require checking of several parameters during an accident.



### BULLETIN ITEM 8

Review all safety-related valve positions, positioning requirements and positive controls to assure that valves remain positioned (open or closed) in a manner to ensure the proper operation of engineered safety features. Also review related procedures, such as those for maintenance, testing, plant and system startup, and supervisory periodic (e.g., daily/shift checks,) surveillance to ensure that such valves are returned to their correct positions following necessary manipulations and are maintained in their proper positions during all operational modes.

### PGandE RESPONSE

We have reviewed the procedures covering the positioning of safety-related valves and have found the procedures adequate. They include the following features:

- a. Critical manual valves are sealed in position and a check list is used for inspection.
- b. When the Engineered Safety Features System operates, the misalignment of any remotely-operated critical valve in the system will be shown by a monitor light on the main control board.
- c. All safety-related valves which are operated remotely and whose purpose is to open or close (rather than throttle flow) have position indicating lights on the main control board. Valves with power removed from their motor operators during normal operation have continuously energized position indicating lights on the main control board which are redundant to those in b. above.
- d. All surveillance test procedures include checklists for returning the system to normal.
- e. A surveillance test is required after all maintenance to show that the valves work.
- f. Quality Control procedures require that any safety-related operations performed on one shift are verified on the following shift.

### BULLETIN ITEM 9

Review your operating modes and procedures for all systems designed to transfer potentially radioactive gases and liquids out of the primary containment to assure that undesired pumping, venting or other release of radioactive liquids and gases will not occur inadvertently.



In particular, ensure that such an occurrence would not be caused by the resetting of engineered safety features instrumentation. List all such systems and indicate:

- a. Whether interlocks exist to prevent transfer when high radiation indication exists, and
- b. Whether such systems are isolated by the containment isolation signal.
- c. The basis on which continued operability of the above features is assured.

PGandE RESPONSE

Any safety injection signal causes Phase A containment isolation (see response to Item 4). Resetting the safety injection signal will not cause automatic resetting of the containment isolation signal. The containment isolation signal can only be reset manually by the operator. Plant procedures will instruct the operator to prevent automatic starting of unwanted systems when he resets manually the containment isolation signal.

The table below lists all the systems which can move potentially radioactive gases and liquids out of containment. It also shows whether these systems are isolated by a high radiation signal or a containment isolation signal. Each system shown will be tested periodically to verify that it works properly.

SYSTEM	HI RAD SIGNAL	CONT ISO SIGNAL
Steam Generator Blowdown	Yes	Yes-A
Steam Generator Sample	Yes	Yes-A
Main Steam	No	Yes-B
RCS Samples	No	Yes-A
Pressurizer Samples	No	Yes-A
CVCS Normal Letdown	No	Yes-A
CVCS Excess Letdown	No	Yes-A
RCP Seal Leakoff	No	Yes-A
Accumulator Samples	No	Yes-A
SIS Test	No	Yes-A
CCW From RCP's	No	Yes-B
CCW from Vessel Support Coolers	No	Yes-B
CCW from Excess Letdown HX	No	Yes-A
Containment Sump Discharge	No	Yes-A
RCDT Discharge	No	Yes-A
Containment Purge Exhaust	Yes	Yes-A
RCDT & PRT Gas to Vent Header	No	Yes-A
RCDT & PRT Gas to Analyzer	No	Yes-A





3

BULLETIN ITEM 10

Review and modify as necessary your maintenance and test procedures to ensure that they require:

- a. Verification, by test or inspection, of the operability of redundant safety-related systems prior to the removal of any safety-related system from service.
- b. Verification of the operability of all safety-related systems when they are returned to service following maintenance or testing.
- c. Explicit notification of involved reactor operational personnel whenever a safety-related system is removed from and returned to service.

PGandE RESPONSE

We have reviewed our maintenance and test procedures and are making minor revisions to ensure that, before a safety-related component is removed from service, the redundant system is operable. This will be accomplished through checklists in the test procedures and in the clearance request procedures.

The procedures require the Shift Supervisor to give written authorization before equipment is removed from service and to acknowledge in writing its return to service.

Tests to show that equipment works properly after maintenance are also required (see answer to item 8).


BULLETIN ITEM 11

Review your prompt reporting procedures for NRC notification to assure that NRC is notified within one hour of the time the reactor is not in a controlled or expected condition of operation. Further, at that time, an open continuous communication channel shall be established and maintained with NRC.

PGandE RESPONSE

We are revising our Administrative and Emergency procedures to provide the notification requirements contained in I E Bulletin 79-06A.

The Resident NRC Inspector at Diablo Canyon has a separate direct communication link with Region V headquarters.



## BULLETIN ITEM 12

Review operating modes and procedures to deal with significant amounts of hydrogen gas that may be generated during a transient or other accident that would either remain inside the primary system or be released to the containment.

### PGandE RESPONSE

The methods for removing hydrogen from the reactor coolant system are:

1. Hydrogen can be stripped from the reactor coolant to the pressurizer vapor space by pressurizer spray operation if the reactor coolant pump is operating.
2. Hydrogen in the pressurizer vapor space can be vented by power-operated relief valves to the pressurizer relief tank.
3. Hydrogen can be removed from the reactor coolant system by the letdown line and stripped in the volume control tank where it enters the waste gas system.
4. In the event of a LOCA, hydrogen would vent with the steam to the containment.

The principal means of dealing with hydrogen in the primary system continues to be the prevention of hydrogen generation by the many design features and operating limits which limit the operating pressures and temperatures in the system. We are reviewing our operating procedures and training to be certain that hydrogen in the primary system is carefully considered.

As we receive more detailed information on hydrogen formation in the primary system at Three Mile Island, we will continue to evaluate the plant equipment and procedures.

We have reviewed the systems and procedures related to hydrogen in the containment building. These are described and evaluated in Chapters 6 and 15 of the Diablo Canyon Final Safety Analysis Report. The preliminary information from Three Mile Island shows no long-term rate of hydrogen production and accumulation in the containment exceeding the amounts for which our containment control system was designed. This is true even though the preliminary estimates of clad reaction at Three Mile Island significantly exceed those upon which the Diablo Canyon design criteria were based. This supports the expected-case calculations of long-term hydrogen production in our Safety Analysis Report.

Our preliminary conclusion is that the Three Mile Island accident has not shown that additional containment hydrogen control systems are needed at Diablo Canyon. We will continue to review our systems and procedures as we get more complete information.



BULLETIN ITEM 13

Propose changes, as required, to those technical specifications which must be modified as a result of your implementing the above items and identify design changes necessary in order to effect long-term resolutions of these items.

PGandE RESPONSE

The only Technical Specification changes required will be those involved with implementation of item 3 of this Bulletin. We will submit proposed changes when a permanent solution has been identified.

