REGULATOR INFORMATION DISTRIBUTION STSTEM (RIDS)

ACCESSION NBR:8502190283 DOC.DATE: 85/02/06 NOTARIZED: NO DOCKET # FACIL:50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga 05000323 AUTH.NAME AUTHOR AFFILIATION SHIFFER,J.D. Pacific Gas & Electric Co. RECIP.NAME RECIPIENT AFFILIATION KNIGHTON,G.W. Licensing Branch 3

SUBJECT: Addresses recent anonymous allegations involving calculations performed by Bechtel-Gaithersburg personnel/per NRC 850117 request.Method of calculating weld shear stresses & results of calculations acceptable.Related info encl.

DISTRIBUTION CODE: BOO1D COPIES RECEIVED:LTR _ ENCL 40 SIZE: 33 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: J Hanchett 1cy PDR Documents.

	RECIPIENT ID CODE/NAME		COPIE LTTR	ES ENCL	RECIPIENT ID CODE/NAME	COP1	TES ENCL
	NRR LB3 LA		1	0	SCHIERLING, H 01	1	1
INTERNAL:	ACRS	41	6	6	ADM/LFMB ¹	1	O
*	ELD/HDS2		1	0	IE FILE	1	1
	IE/DEPER/EPB	36	1	1	IE/DQASIP/QAB21	1	1
	NRR ROE, M.L		1	1	NRR/DE/AEAB	1	0
	NRR/DE/CEB	11	1	1	NRR/DE/EHEB	1	1
	NRR/DE/EQ8	13	2	2	NRR/DE/GB 28	2	2
	NRR/DE/MEB	18	1	1	NRR/DE/MTEB 17	1	1
	NRR/DE/SAB	24	1	1	NRR/DE/SGEB 25	1.	1
	NRR/DHFS/HFEB	40	1	1	NRR/DHFS/LQB 32	1	1
	NRR/DHFS/PSRB		ĩ	ĩ	NRR/DL/SSPB	1	Õ
	NRR/DSI/AEB	26	ĩ	ĩ	NRR/DSI/ASB	1	1
	NRR/DSI/CPB	10	ĩ	1	NRR/DSI/CSB 09	1	ĩ
	NRR/DSI/ICSB	16	1	ĩ	NRR/DSI/METB 12	1	1
	NRR/DST/PSB	19	1	1	NRR/DST/RAB 22	1	1
	NRR/DST/RSB	23	1	1	REG FILD 04	1	1
	RGN5		3	3	RM/DDAMI/MIB	1	ō
EXTERNAL:	BNL (AMDTS ONL	Y)	1	1	DMB/DSS (AMDTS)	1	1
	LPDR	03	ž	Ž	NRC PDR 02	1	1
	NSIC	05	1	ĩ	' PNL GRUEL,R	1	1
NOTES:			1	1	' :		

a ha ha the second and the second sec

Te . 1 1.1 1 r 🗾 🗸

6 . • • • • •

Star is a starting

The state of the second sec EREAD IN SO TRAITS IN READ THE ERE THE AREA A PARTIC SPECTAL AREA AREAS AND A PARTIC SPECTAL

n a a'

REAL STREAMENT OF THE INTERVIEW ROOM STREAMENT ROOMSTREAMENT

APPARE , I BE TO A BE AND THE PROPERTY AND

15

	"T x *.*	新 中丞 同 ¹¹ 19		8 i e 1	R . M . K. A
ł	- 4 5 1	х · ъ, н ж	į i , i	,) (*	rs v _a (t. ⇔ p ²) s a t
		للاير الألاية ∰ي. بين ي	1	ĥ.	 I South Back and Compared and C
X		≸ γ ri k Ni≵ ≵Þ		ě	, ⊈ ' <i>j</i> - 2
	ŝ	, ¹⁰ e 🔬 🔏	r	h	北京 そうに考えてい かん の考え へ
8		±.,∀.≱ T	rh.	х	er r≜j∜in Me
	ŧ	Algeria (N. 1966) N. 68	P	4	e - 18 🐜 18 - et 🖌 🛔
		the second se	k	K.	No. Contraction (1996)
X		N	ę	P.	, 🕺 — — ма ж. — ма на на на
	0	الإيلام والمحمد الم	ŕ	1 4	$e_{1}^{(\mu)}$ (1) $\sum_{i=1}^{n} e_{i} \sum_{j=1}^{n} e_{i} \sum_{j=1}^{n$
4	1	\mathbf{X} is the second s	2	6	κ^{-1} ($\lambda_{\mu} = -\lambda_{\mu}^{-1}$ (λ_{μ}
×	19	en 🔨 💦 🔨 🥆	•	8	$\mathbf{w}^{(1)}$ () $\mathbf{N} = \mathbf{N}^{(1)}$ () $\mathbf{w}^{(1)}$ ()
	k.	and the North States of the	1) 1	**	KY, AL S. P. N. P.
۴,		Star X & NOR	۲	*	Section (March 1997) And Section
1	k	e A 🔨 🕅 📉 🔪 Auro	ť,	*	CARLE A REAL AND ARE
λ	£	t 🗴 hand the 🔪 👘 the state of the the	Ĩ	¥	with the Nation N
A.	4.5 1	No. Re. NY S. New	k	*	Soft of Skale Notes
×	ş	Sec. Sec. No. Sec.	ſ	٨	V A Star Nation No. Contraction
و.	P	et konstruktion 👌 👔 🗍 👘 🙀	*	×	$\mathcal{N}^{*} = \mathcal{N}^{*} \mathcal{P}^{*} \mathcal{N}^{*} \mathcal{N}^{*} \mathcal{N}^{*} \mathcal{N}^{*}$
N j	1 13	e de 🔨 🖁 👘 e service 🐐	4_*	(,	$\boldsymbol{\rho}^{(1)} = 1^{-1} + 1$
ĸ	ſ	K R MAR A MAR O	f	Ă	KX, H H A A J Martin C Martin States
لمد	I	ł		9	e R tigte g
×	₽	Sec. # Record	t	a	4 Ko No. 1
	·		Å	X	2 e) ² 前 H

¥ ч 4 ° 4 9 х,

S

PACIFIC GAS AND ELECTRIC COMPANY

PG=E -- 77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

, ⁸

JAMES D. SHIFFER VICE PRESIDENT NUCLEAR POWER GENERATION

February 6, 1985

PGandE Letter No.: DCL-85-053

Mr. George W. Knighton, Chief Licensing Branch No. 3 Division of Licensing Office of Nuclear Reactor Regulation U. S. Nuclear Regulatory Commission Washington, D.C. 20555

> 8502190283 850206 PDR ADOCK 05000323

Re: Docket No. 50-323 Diablo Canyon Unit 2 Anonymous Allegations Relating to Bechtel-Gaithersburg

Dear Mr. Knighton:

On January 17, 1985, the NRC Staff requested that PGandE address a recent allegation regarding shear stress calculations for Diablo Canyon Unit 2 pipe support welds. The allegation involves calculations performed by Bechtel-Gaithersburg, Eastern Power Division (EPD) personnel who used Bechtel-San Francisco procedures. It is alleged that calculations based on these procedures are less conservative than those based on procedures normally used by EPD.

The subject allegation raised the following two items:

PDR

- a. Incorrect weld shear stress calculations based on the EPD Diablo Canyon Project (DCP) method, provided in Appendix G of DCP Project Procedure P-6, "Procedure for Assembling Pipe Support Calculation Packages," (Bechtel-San Francisco)
- b. Incorrect shear stress calculations of structural members; calculations were not in accordance with the AISC Code

The first item is addressed in Enclosure 1. In summary, the EDP Diablo Canyon Project method of calculating weld shear stresses in accordance with the DCP Procedure P-6 is correct and acceptable. A sample study performed by EPD personnel indicated that the difference between the maximum stresses calculated by the DCP Procedure P-6 criteria and the more conservative method normally utilized by EPD personnel is insignificant. The results of this study are included in Enclosure 1. The results were discussed in an EPD Diablo Canyon Project group meeting on December 19, 1984, as noted in Enclosure 2 to this letter. , , -

b/ •

Mr. G. W. Knighton February 6, 1985 Page 2

An additional survey was performed at EPD to supplement the above study. Since the shear components of the weld stresses and their effects on the resultant weld stresses are the main points of concern, a short cantilever is the ideal subject for this survey. Eight short cantilever pipe supports were selected for evaluation. The resultant weld stresses were calculated using two methods. The first method used the total weld area to resist the shear force, while the second used only the portion of the weld area that is parallel to the direction of the shear force being considered. The conclusions of the short cantilever survey are as follows:

- a. The shear component of the weld stress does not govern. The moment component is always greater than the shear component.
- b. The increase in the resultant weld stresses using the second method is insignificant. In all cases, the stresses are within the allowable stresses.

The results of this study are contained in Enclosure 3.

The second item, that of incorrect shear stress calculations for structural members, was also addressed in the sample study. The conclusion of the study as indicated in Enclosure 1 is that member shear stresses were found to be acceptable in accordance with AISC, 7th Edition.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

Sincerely,

Shiffer

Enclosures

cc: R. T. Dodds K. Manoly, NRC Region I J. B. Martin H. E. Schierling Service List

. .

* * * * : :

ſ

.

PGandE Letter No.: DCL-85-053

ENCLOSURE 1

₹. 5×

•

a Transa and the second second

· · ·

,

x v v

INCLOSURE |



To

(

Bechtel Power Corporation

Interoffice Memorandum

G. V. Cranston

Date December 7, 1984

EPD - 5A4

Subject Design Deficiency/Mismanagement Diablo Canyon Project Unit No. 2 Bechtel Job No. 15320-003

G. K. Wang Project Engineering

From

01

At

- Copies W. N. Adams
 - D. L. Brannen
 - H. S. Kassel
 - T. J. McDonald
 - K. Y. Lee
 - S. Bokhari

We have received an IOM dated November 15, 1984 from concerned engineers (Attachment No. A) regarding:

1. Incorrect shearing stress calculation of welds in the project procedure, and

2. Mismanagement of the project group by the group supervisor.

Both statements are incorrect. The project method of shearing stress calculation of welds, which is given in the Appendix G of DCPO Procedure P-6, is acceptable.

This method is described in detail in the book, Design of Weld Structures, by Omer W. Blodgett. There appears to be some confusion between this method and a more conservative method recommended by EPD Hanger Engineering Standard HES-005A and B, of which all the EPD pipe support engineers are familiar with. Both methods are approximate methods and both are considered acceptable. Hence, both methods are listed as references in the EPD Diablo Canyon Project Procedure for pipe support weld calculation. The technical details of these two methods are explained in our IOM to Mr. K. Y. Lee, Civil Structure Chief, Engineer of EPD, dated December 7, 1984. A copy is attached as Attachment No. 2.

Mr. Bokhari is one of the most capable supervisors in EPD, both technically and managerially. This is evident from the quality of the EPD work which has been reviewed constantly by DCPO and audited by NRC. The EPD project under Mr. Bokhari's supervision has been meeting project schedule and allocated budget. Overtime is only used to support project schedule with prior DCPO approval. Mr. Bokhari is an eleven-year veteran of Bechtel. I think his personal records and his previous performance evaluations will speak for him.

, · · · . .

• •

1 ,

,

5

`

w

,

10H: G. V. Cranston Bechtel Job No. 15320-003

If you have any questions, please do not hesitate to let me know.

femt. Wang

Glenn/K. Wang EPD Project Engineer

GKW:mfa

£

Attachments: A. IOM to Kenneth Lee, dated November 15, 1984 B. IOM to K. Y. Lee from G. K. Wang, dated December 7, 1984



• • • • •

61.75 125 125

* _____ * ** * ~_____ * ____

, T

TTACHMENT-

Bechtel Power Corporation

Interoffice Memorandum

Kenneth Les.

Den Nov. 15, 1984

From Engineers Soon Design Deficiency/Mismanagement Diablo Canyon Project Unit No. 2 Job No. 15320

Engineering

Gaithersburg

Copies W.N. Adams. T.C. McDonald G.K. Wang

> In Light of public safety and the mismanagement of the Diablo Canyon Unit 2 pipe support group supervised by Syed Bokhari, we can not but report to you that the pipe support group has been incorrectly designing and analyzing the welds as well as structural members by using the least conservative approach which is quite inconsistent with the reference material as specified in the design standards (see attached copies) and which is also not in accordance with the A.I.S.C. codes.

The total length of weld or the total area of steel member should not be taken fully to calculate the shear stresses as this will adversely affect the structural adequacy especially for tubing, angle and wide flange shapes. The actual factor of safety for shear can significantly be reduced to $\frac{1}{2}$ (half) of the value for square tubing and angle. Therefore, it will make the structure unsafe.

This incorrect approach has currently and continuously been used since the beginning of the unit 2 project, as of to-date a couple of thousands of pipe supports or more are probably affected by this design approach and the case is considered to be serious and reportable.

Syed Bokhari, the group supervisor and his design supervisors --have been constantly reminded and notified about this design deficiency and the engineers were warned and told without further questions to proceed making design packages like in a factory assembly line.

Yair recognition for job accomplishments has never been given to the deserving employees, Syed Bokhari seems enjoying the work achivements and rewards at the expense of his hard working fellow workers. This is totally unfair and unprofessional in any respect.

). . . , ,

x

۲۰ ۲۰ ۲۰ ۲۰ ۲۰ ۲۰ ۲۰

·

.

Syed Bokhari has never attempted, participated or involved in any technical decisions or professional discussions when important circumstances occur, and the responsible engineers always have to make most of the job decisions sometimes very ineffective with a very limited structural knowledge and design background, and they frequently intimidate their subordinates using force-ranking evaluation as a tool to get the work done, a specified work quota is assigned weekly to everyone without considering the complexity and urgency of the problems, overtime is usually given to those preferred people who seldom work or do not usually work hard at all.

At the meeting people were indirectly advised and encouraged to look for new opportunities and new jobs. Checking of late attendance in the morning and noon has never been enforced. Syed Bokhari usually comes late after lunch hour.

In addition, most people feel very often uninformed and frustrated and new people coming to the group like strangers have never been introduced to other co-workers. There is no orientation at all for new people.

In the best interest of the company, we solemnly report this to you for your attention and input.

Enclosed are copies as marked for your reference.

Your full understanding, thorough investigation and corrective actions are required.

Concerned Engineers

CONFIDBNTIAL

~



۶ ۸ ۴ ۲

. , ,

· 7

· .

۰ ,

i.

ACTFIC CAS AND FLECTRIC CONPANY	
ABLO CANYON NUCLEAR POWER PLANT UNITNANGER NO	. •
DI ST: BATE CALC. SEQ. NO RET	
LCLID BY:	
PIPE SUPPORTS HAVE BEEN DESIGNED DE ACCORDANCE WITH THE POLLON DE REVERENCES:	
CODES AND STANDARDS FOR DESIGN	
2. DEAS 351.1 CODE, POWER PIPING, 1967 EDITION W/ADDENDA	
2. DEAS 231.7 CODE, MUCLEAR POWER PIPING, 1969 EDITION W/1970 ADDENDA	
3. AISC MANUAL OF STEEL CONSTRUCTION, Teh EDITION	
4. DCH H-9 "GUIDELINES FOR DESIGN OF CLASS I PIPE SUPPORTS, REV. 9"	
5. STD. PIPE SUPPORTS FOR DESIGN CLASS I PIPING 2" AND SHALLER DIABLO CANYON, PACIFIC GAS AND ELECTRIC DRAWING NO. 049243 REV. 14	
(. OFFICE AND FIELD ENG. USERS MANUAL FOR ROUTING AND SUPPORTING TWO INCH AND UNDER PIPING, BECHTEL, GPD DOCUMENT NO. H-18.	
DISIGN DATA SOURCES	
3. STRESS ISOMETRIC DRAWING FOR APPLICABLE LINE	
2. APPLICABLE RESPONSE SPECTRA: DCH-C-17 REV. 8, DCH C-25 REV. 3, DCH C-30 REV. 5	
3. CRITERIA FOR HAXDADH BLDG, DISPLACEDEDATS DCH C-28 REV. 4	
HANTYACTURER'S CATALOGS AND STANDARDS	
8. CADATEL SINE PANGERS, CATALOG VE74, VE76, VE79, VE81	
2. CREDOTLL LOAD CAPCITY DATA SELLTS	
S. C. DOIZLL MANGER STANDARDS OTHER SOURCES	
4. PACIFIC SCIENTIFIC CATALOG 2. DESIGN OF WELDED STRUCTURES, BY OHER W. RLODGETT.	•
S EPS DEDUSTRIES CATALOG 2. BECHTEL, GPD HANGER ENGINEERING .	
6. WEI FLUCAND, SP-SI ER-SI MIANDARDS REV. 13	
J PIPE SUPPORT COMPUTER PROCRAMS 3. DECHTEL, GPD PIPE SUPPORT GROUP, MCUSLETTERS	
1. CE 301 - STRUDL PROGRAM REV. 3 OF USER'S MANUAL	
4. EE 035 - BASE FLATE IL FROGRAM REV. I OF USER'S MANUAL	

الم مد ق م مد ق م م مد م

EALCULATION SHEET CALC NO BES-DOSB___ REV.NO __O PILLE CHECKED ____ DATE ____ CT_HANGER ENGINEERING STANDARD D MES-0058 Rev. 0 SHEET ND 2 of 16 SUBJECT WELD CALCULATION Combining Properties and Applied Forces To Get Total Force on Weld _The following pomenclature and equations have been developed for the purpose of simplifying and establishing a uniform approach for performing weld calculations: MONENCLATURE . La = Effective length of weld carrying shear in "a" direction. 2 1b = Effective length of weld carrying shear in "b" direction. Ic = Effective length of weld carrying tension in "c" direction SHA - Section Modulus "a" axis. 10 SYD = Section Modulus "b" axis. 31 THI = Polar Moment of Inertia 12 Ca = "C" fiber distance measured in "a" direction. 12 Cb = "C" fiber distance measured in "b" direction. 14 fr = Maximum total vector force on weld (usually kip/inch) 15 fa = Force per inch of weld acting in "a" direction. 18 To = Force per inch of weld acting in "b" direction. 17 fc = Force per inch of weld acting in "c" direction. 13 19 20 TQUATION FOR FINDING Fr 21 22 $fr = \sqrt{(f_{\rm A})^2 + (f_{\rm b})^2 + (f_{\rm c})^2}$ 23 24 $fa = \int_{La}^{Ta} + \int_{R}^{M_{c}} \frac{Cb}{PH_{1}}$ SIZE = 25 ALLOWABLE STRESS 35 $s_{b} = \begin{pmatrix} y_{b} \\ y_{b} \end{pmatrix} + \begin{pmatrix} y_{c} & c_{a} \\ y_{h1} \end{pmatrix}$ 27 3 23 $g_{c} = \frac{P_{c}}{L_{c}} + \frac{N_{s}}{SN_{s}} + \frac{N_{b}}{SN_{b}}$ 30 31 The equations for fa, fb, and fc have terms or produce forces in each of the three 22 directions which are added directly and then the total force is found by taking 2 the square root sum of the squares of the three forces. 34 35 A standard celculation sheet, and an example for the use of that sheet follows. 35

GPD-2706 8:76 ED-6"

.

)

۰. ۲

.

ı.

.

``

I 4 I



SHAPE	LA	LI	Lt	SHA	SHI	Pat	EA .	<u>()</u>
T5212	4.00	4.00	8.44	5.33	5.33	19.47	1.10	1.09
TS2.5X2.5	5.00	5.00	10.00	8.33	8.33	20.83	1.25	1.25
TS3XJ	6.09	6.99	12.00	\$2.00 =	12.00	36.00	1.50	1.50
T53.5X3.5	7.00	7.00	14.00	16.33	14.33	57.17	1.75	1.75
TS4X4	8.00	8.00	14.00	21.33	21.33	\$5.33	2.00	2.40
T\$5X5	10.00	10,00	20.00	33,33	33.33	144.47	2.50	2.59
T56X6	• 17.00	17.00	24.00	48.00	48.90	218.00	3.09	. 1.10 -
T\$7X7	14.00	14.00	28.00	63.33	65.33	457.13	3.50	3.50
TSBXS	16.00	16.00	32.00	85.33	85,33	612.67	4.00	4.00
7510X10	20.00	20.00	40.00	133.33	133.33	1313.31	5.00	3.00
T\$12X12	24.99	24.09	41,10	172.00	172.00	2304.00	6.01	8.09 s.s.

. . •



WELD	PROPERT	nes	
POR:	EQUAL	LZC	ANGLES
WELD	CROUP,	ALL	AROUND

NES-0058, NEV. 0 8/13/82 Sheet 9 of 16

.

5 m A

SITE	LA	L	LC	SHA	SHI	PIT	C	11
1	2.00	2.00	4.00	.54	.56	.83	.75	.75
1-1/2	3.00	3.00	6.00	1.25	1.25.	2.01	1.13	1.13
2	4.00	4.90	8.00	2.22	2.22	6.67	1.50	1.54
2-1/2	5.00	5.00	10.00	3.47	3.47	13.02	1.18	1.11
3 .	4.00	6.00 -	12.00	5.00	5.00	22.59	2.25	2.25
3-1/2	7.00	7.00	14.00	6.81	4.01	35.73	2.63	2.63
4	· 5.00	· .8.00	16.00		8.89	51.13	3.00	3.00
5	10.00	10.00	20.00	13.87	13.87	104.17	3.75	1.75
6	12.00	12.00	24.00	20.00	20.00	180.00	4.50	^ 4.50
7	. 14.00	14.00	28.09	27,22	27.12	295.03	5.23	3.25
8	16.00	16.99	32.00	33.54	33.56	426.67	6.90 .	♦.♥0



. , , ,

х .

, ,

ACHMENT-B (11 R geo)



Bechtel Power Corporation

Interoffice Memorandum

K. Y. Lee

Date December 7, 1984

Subject Shearing Stress Calculation of Welds From G. K. Wang Diablo Canyon Project Unit No. 2 01 Bechtel Job No. 15320-003 . .

Project Engineering

14 EPD - 5A4

Copies	W.	N. Adams	H.	s.	Kassel	File
	D.	L. Brannen	T.	J.	McDonald	
	s.	Bokhari	L.	F.	Sirianni	
	P.	Perks				

.

A concern was raised recently that the method used by EPD Diablo Canyon Project in calculating the shearing stresses in welds may not be correct, and therefore may result in unsafe structures.

The EPD Diablo Canyon project method (refer to as the DCPO method), which is given in the Appendix G of DCPO Project Procedure P-6, is different from the method used in other EPD projects (as recommended in the EPD Pipe Support Hanger Engineering Standard, HES-005A and B and is referred to as the HES method) in the shearing stress calculation of welds. For example, for an all-around weld of 4" x 4" tube steel TS 4 X 4, the shearing stresses in the welds are calculated as:



where Fa and Fb are applied shear forces along a- and b-axis, respectively

ź

`Х • •

•

.

. . -.

,

v

K. Y. Lee IOM: Bechtel Job 15320-003

The differences were recognized at the beginning of the EPD Diablo Canyon Project. The DCPO method was adapted because it was based on a commonly used method in the industry described in the book, Design of Welded Structures, by Omer W. Blodgett. A copy of the relevant page is attached as Attachment No. 1. Both methods are considered as acceptable and are listed as references, Items 1 and 3, respectively, under "Other Sources" in EPD Diablo Canyon Project Procedure for pipe support weld calculation.

Since the shearing stress generally does not control pipe support design, a sampling study was made to show that the differences in the design margin between the two approximate methods are indeed insignificant. Neither one has resulted in unsafe structures. The sampling technique and results are attached as Attachment No. 2.

Based on the discussion above, we plan to continue to accept the DCPO method as well as the HES method in the project calculations. If there are any questions, please let us know.

G. K. Wang Project Engineer

GKW:mfa

Attachments: 1. Page 7.4-6, Design of Welded Structures, by Omer W. Blodgett

> 2. Results of 5 Percent Hanger Sample for Comparison of Weld Stresses Calculated by DCPO and HES methods

F

۰,

r N , " • • • • • • • • • •

r ru tu tu

TACHMENT 🗭 1

· 7.4-6 / Joint Design and Production

🗿 TABLE 4—Determining Force on Weld



& - area contained within motion line. (4) mention to closed tobolar section only.

SIMPLE TENSILE, COMPRESSIVE OR SHEAR LOADS ON WELDS

For a simple tensile, compressive or shear load, the given load is divided by the length of the weld to arrive at the applied unit force, lbs per linear inch of weld. From this force, the proper leg size of fillet weld or throat of groove weld may be found.

7. BENDING OR TWISTING LOADS ON WELDS

The problem here is to determine the properties of the welded connection in order to check the stress in the weld without first knowing its leg size. Some design texts suggest assuming a certain weld-leg size and then calculating the stress in the weld to see if it is overstressed or understressed. If the result is too far off, then the weld-leg size is readjusted.

This has the following disadvantages:

1. Some decision must be made as to what throat section is going to be used to determine the property of the weld. Usually some objection can be raised to any throat section chosen.

2. The resulting stresses must be combined and, for several types of loading, this can be rather cominted.

In contrast, the following is a simple method to determine the correct amount of welding required for adequate strength. This is a method in which the weld is treated as a line, having no area, but a

DESIGN OF WELDED STRUCTURES" by OMER W. BLODGETT.

definite length and outline. This method has the following advantages:

1. It is not necessary to consider throat areas because only a line is considered.

2. Properties of the welded connection are easily found from a table without knowing weld-leg size.

3. Forces are considered on a unit length of weld instead of stresses, thus eliminating the knotty problem of combining stresses.

4. It is true that the stress distribution within a fillet weld is complex, due to eccentricity of the applied force, shape of the fillet, notch effect of the root, etc.; however, these same conditions exist in the actual fillet welds tested and have been recorded as a unit force per unit length of weld.

8. DETERMINING FORCE ON WELD

Visualize the welded connection as a single line, having the same outline as the connection, but no crosssectional area. Notice, Figure 14, that the area (A_{-}) of the welded connection now becomes just the length of the weld.

Instead of trying to determine the stress on the weld (this cannot be done unless the weld size is known), the problem becomes a much simpler one of determining the force on the weld.



FIG. 14 Treating weld as a line.

By inserting the property of the welded connection treated as a line into the standard design formulaused for that particular type of load (see Table 4). the force on the weld may be found in terms of lbs per linear inch of weld.

Example: Bending

Standard design formula	Same formula used for weld
(bending stress)	(treating weld as a line)
$\sigma = \frac{M}{S} = \frac{lbs}{in.*} \frac{stress}{stress}$	$f = \frac{M}{S_{\sigma}} = \frac{lbs}{in.}$ force

,

ب سر ۱ ۱ ۲

· · · ۰.

PACIFIC GAS AND ELECTRIC COMPANY BECHTEL POWER CORPORATION SHEET NO ____ OF 14 DIABLO CANYON PROJECT CALC. NO. ____ CALCULATION SHEET REV.NO. CENECT DIABLO CANNON UNIT 2 SIRVEY OF WELD AREAS RESISTING SHEAR DATE 1215 A4 CHECKED BY DATE 12/6/04 JOB NO. 15320 MADE BY ... THE PURPOSE OF THIS SURNEY 16 TO COMPARE AND ENALURTE WELD CALCULATIONS AS PREFORMED ON PROSECT, IN GATTHERSBURG. THE MAIN CONCERN IS THE USE OF THE TOTAL WELD LENGTH, AW, FOR RESISTING SHEAR FORCES. A MORE CONSERVATIVE APPROACH IS TO USE LENGTHS OF WELD; LA, LB, PARALLEL TO THE LINE OF SHEAR.

และเลของสังร์ เอง เรต นัก แก่สี่งง

THE REGULTS OF THE SURNEY IN DICATE THAT IN ALL (SAMPLES, THE ACTUAL WELD STRESSES ARE LESS THAN THE ALLOWABLE STRESSES, FURTHER, THE MASORITY OF THE HAD AN INCREASE IN ACTUAL STRESSES OF LESS GAMPLES THAN 5%

WHEN REVIEWING THE DATA, REASE NOTE THE FOLLOWING:

- NOTED OTHER WISE, THE MAXIMUM OR ENVELOPE AONAL 1.) WIESS 15 COMPARED TO THE LOADCASE I OR NORMAL STRESS ALLOWABLE STRESS.
- ARE COMPARED 2.) CERTAIN LOADCASES IN CASES WHERE HIGHER LOADCASE ALLOWABLES BEMAINING THE WITH LOADCASES HAVE BEEN REVIEWED AND FOUND TO BE ALEPTABLE.

Ł

- "

- đ

**

.

- •* • 6 1 1
- - •
 - "

and the second	uning and the second state and the second	generation and a second s
	PACIFIC GAS AND ELECTRIC COMPANY	
	BECHTEL POWER CORPORATION	SHEET NO _2_ OF _14_
	DIABLO CANYON PROJECT	CALC. NO
(SJECT DIABLO CAN	YON UNIT 2	REV.ND.
EVENEY OF WEL	D AREAS REGISTING SHEAR	
MADE BY	DATE CHECKED BY DA	TE 12/6/84 JOB NO. 15320
	•	ай — н ания

- 3) THE AMOUNT OF SUPPORTS REVIEWED REPRESENTS APPROXIMATELY 5% OF THE TOTAL NUMBER ASSIGNED TO GAITHERSBURG. EVERY TWENTIETH SUPPORT FROM THE PIPE SUPPORT STATUS LOG WAS SELECTED FOR REVIEW, UNLESS THAT EUPPORT WAS DELETED, ASSIGNED TO DOPD, OR N THE PROLEGS OF REVIEW FOR NEW LOADS OR AS-BUILT CONDITION. IN THESE CASES, THE NEXT SUPPORT ANLABLE IN THE FILES WAS SELECTED FOR THIS SURVEY.
 - 4.) ALL STRUCTURAL MEMBERS WERE REVIEWED FOR MEMBER SHEAR STRESSES AND FOUND TO BE ALLEPTAPLE PER THE APPLICABLE CODES AND PROJECT SPECIFICATIONS.
- 5.) A TOTAL NUMBER OF 109 SUPPORTS ARE INCLUDED IN THE SURVEY. 31 SUPPORTS CONTAIN TUBE STEEL WITH WELDED CONNECTIONS .

to the second s.,

- - ¢ in a s

 - 2 v · ·
 - · · · · · ·
 - 1
 - ۰ ۲
 - ,

,

- - , •



•

۲ #۱

ĩ

. .

· . ·





•	r.	4 Z	a a	. ¥	• . *		ε		
							ų	•	
						*			

,

ter - Ter - Huga - A

, .

• • • • • • •

~

e e a companya de la c .



C

2.

. .

·

. . .

STRESS ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	VE STR. ED WITH LA.LB.LC	ALLOWABLE STRESS(PSI)	COMMENTS	SUE		
G-002-01	35N/42A	1	Jare	11 8603	6603	9500 I		WEX		
6.002.03	4131 526N	1	\checkmark	2987	2987	9450	RULOUT ONLY	FWE	CANY	4 N
6-002-05	50 26V	J	J	1107	1107	8770	· · ·	D AR		د ب جي 1 بر ا
6-002-07.	413/105L	Ĵ	\checkmark	4017	4017	19900		EAS R	172	
G -002-07	50132R		\checkmark	3347	3187	19300		ESIST	CA	ACIFIC O
G-003-02	413/2135L		J	3089	3425	19900		THUS S	LCULA	TEL POWE
6-003-02	413/7752		J	12341	12487	19900		HECKED	TION S	ELECTRI
G-03-02	481 182	ſ	, J	278 '	278	9450	PULLOUT ONLY		NECT HEET	
G-003-02	481494	J	1	10440	10440	19900	•	8	i	
G • 003-03	22 34	1	J	1700	1700	9450	PULOUT ONLY	DATE		
G-003-04	22/102	J	J	1019	1019	9450	PULLOUT ONLY	12/2/	7 0	
.6.03-05	24/402	1	J	III- EGALS	26425	26467 ^{III}	•	Ser 20	ALC. NO. EV. NO.	HEET NO.
G -003.06	1547-42		J	2772.	৫৯৯৩	19900		NO.		6
6-003-06	78/1185L		1	4527	4544	18000		15320		р Т Т Т Т

,

۰. (

₩ J

16

· · ·								• " -	
STRESS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	ED WITH	ALLOWABLE STRESS(PSI)	COMMENTS		
G-003-08	22/172	J	1	1358	1358	9450	PULLOUT ONLY	ABLO VEY 0	
G • 003 • 07	415 / 715L	•	J	3293	3612	9450	•	WEL	
6-004-02	413/59R	1	J	1867	1867	9450	PULLOUTONLY	D ARE	
G-004-06	413/175R	1		-	. —	-	strudl	AS R	
G • 005 • 01	948/4R	J	:	-	-	-	STEUDL	ESISTI	BECHTIC O.
6-005-03	940/752		\checkmark	19363	19363	19570	LUG 0.5	NG SI	LO CAN
G •005-04	413153R	1	1	3949	3949	19900		IEAR	ICONPOR
6-005-04	481402	1	J	11160	11160	14100			NECL NECL
G +006-01	23127R	1	1	6479	6929	19900		8.	ب الم
6-006-01	77/1562	1	J	3082	3882	8200	PULLOUT ONLY	DATE -	
				•			- -		5 ¥ .
							· · · ·	V.NO.	LC. NO.
								NO.	70
								5320	4

.

R

.

.....

.

. ۲۰۰۰ ۲۰۰۰ مانی ۲۰۰۰ مانی ۲

ζ. .

•

تعريب م دور

STRESS ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	ED WITH	ALLOWABLE STRESS(PSI)	COMMENTS	SUR	ָ	
G-007-01	23/39R		J	17148	17232 .	19900		VEYO	ABLO	
G-007-01	46114R		V	5743	6520	19900	•	WE	CANY	*
G-001-01	923-52		1	274-	377	19900		D AR	DN UN	* - - - -
G-007-04	949-297	· /	1.	1943	1943	19900		EAS R	1172	
G-008-01	24/47R			-			CALC.5 3.5K/M ALLON & Q'S' BY JUDGENT LOADS LIK	ESIST	CA	DIAE
G-008-02	47/91A	/	PIPE	4400 I 5530 I 9420 II	4400 8530 9420	7350 I 6770 II 15250 II		ING S	CULA	EL POME
G-008-02	47/136R	~	1	2561	2561	19900		HEAR	rion st	ELECTRIC R CORPOI
G-008-04	413/74R		1	15846	16436	19900		N - A	JEET	DIECT.
G-009-01	947/193A		J	mx 8506	18706	· エ いっちつつ	(PIPE W STIMMERS)	6		२ •
G-୦୦୨-୦ ୩ -	415/5335L	~	1	3922	3922	9450	WELD ON 2 SIDES REAR BRACKET:	DATE		
6-009-05	512/412	~	1	610	610	9450	PULOUT ONLY	ielli.	7	De enter
G-011-01	947/8R		1	1124	1128	19900		SX S	EV. NO.	HEET NO.
G-011-01	947-3		J	1641	1646	19900		NO,		ba
G-012-02	948/80R		.1	5805	5816	19900		6320		4

and the second se

•

:

.

•

.

.

- , . **A** 4 '
- All a se se
- ---
- - - 6v.

- .

STRESS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	P-6	CRITICAL V CALCULAT AW ONLY	EL WITH	ALLOWABLE STRESS(PSI)	COMMENTS	SUR		
G-012-03	949/3R	1	1	6192	6192	19900	8538 4 1.75 = 6192	VEYO		
G-012-04	949-539	~	J DIDE	6408	6408	7350 .	× .	WEL	CANY	۴ ۲
6-012-05	4131104R		1	MAX 9716	%%0	II. 13970		D AR		• 7
G-012-05	949/207R	Ĭ	1	3821 ^I	3821	19900 I		DATE _	1172	
6-013-01	404/25R		J	20230	20280	26500 III		ESIST		DECHT
G-014-01	413/3605L		1	10836	10868	19900		BA C	LO CAN	AS AND E
G-014-01	50/90R	~	1	5400	5400	19900		HEAR	TION ST	LECTRIC
G-014-01	50/122R	~	J	4340	4340	9450	WELD ON E SIDES	N A		ATION .
G-014-01	50/123R	<	J	6002	6002	9450	weld on 2 51025	8	ı	. .
G-016-01	413/3675L		1	5382	6000	9450		DATE -		
G-016-02	413 /313R	· J ·			-	<u> </u>	.:	19/21	22	¥
G-016-02	413/33AR	1	J	1075	1075	9450	WELD ON & SIDES	or 7.6	ILC. NO.	IEET NO.
G-016-02	413/427R		1	13736	13867	19900	TUBE, ABOUME A' WELD NOT FLAT, OK NEW REACH	NO.		6
G-017-02	404/42R	~	1	3200	3200	19900	WELD ON I SIDES ONLY	6320		¥ 4

ŀ

.

•

•

. . i

100

** ****

1 . . .

v

Ę,

Ľ

•

•

4

--- 17 . • • .

· · ·

1 - + 12

,

						7		110 Z	$\overset{\cdot \cdot \cdot}{\frown}$		
STRESS ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	P-6	CRITICAL V CALCULAT AW ONLY	ME J STR. ED WITH LA.LB,LC	ALLOWABLE STRESS(PSI	COMMENTS	ADE BY	ີ້ມເຕ D		
G-018-01	990/81R		\checkmark	1631	1638	19900		WEX C	IABLO		
6-018-02	948154R		1	7508	7576	9450	,	WE	CANY		*6
6-018-05	512130R			17878	19241	19900	· · · ·		IN NO.	•	1
G-018-05	949-411	1				-	13/16/274	EAS F	NIT2	•_	G
6-019-01	49/182R	-	J	19604	19692	19900		RESIST	CA	DIA	PACIFIC
G-017-02	49/189R	1	1	5794	5194	19900	WELD ON 2 SIDES	PAG 2	LCULA	BLO CA	DAS AND
6-019-02	1550-62	1	J	576	576	8770		HEAR	TIONS	NON PR	ELECTAI
G-019-04	413/1142	~	J	I086 I	1086	9450 I	PULLOUT ONLY	₹	HEET	DECT	C COMPA
G-019-07	413 132R	\checkmark	1	9035	9035	.19900	WELD ON 2 SIDES	1		۰.	AK
6-019-07	413/35R	~	J	4315	4315	19900	WELD PATTERN IS PRINCIPAL AKIS ANGUR 34 %	DATE			
								int		ф ш	
					-	•	•	ay so	EV. NO.	HEET ND	
								N N O N		ā	5
								15320		۲ 4	-

.,

Envel N

ş

, ne

δα . ° τ

,x# en en e

.

	•	~		•		•		•	•••	· • •
<u> </u>	•				<u>~</u>	`				• •
ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	VELD STR. ED WITH LA,LB,LC	ALLOWABLE STRESS(PSI	COMMENTS	SUR		
G-020-01	413/17R		1	384-7	3958	19900		VEY		j j
G-021-04	1548-68	1	1	3061	3061	19900	weld on ? sides			-
G-021-07	1548-55	-	-				Fx = 631bs, Fe = 631bs	D AR		
·G•023-02	50/49R	1		-		-	HES-005,	EAS R	17 5	
6-023-02	413/62A	~	V PIPE	2661	2661	11190	PULLOUT ONLY	ESIST	CAI	BECHI
G-023-06	76/75L	~		-	-	-	425-005	NG S		IL POWE
G-024-03	413/14252		1	14750	14-150	19900	WELD ON & SIDES	HECKED	TION S	ELECTRI
G-024-04	413 575R		J .	II 0003	7599	I 9450			HEET	ATION
G-025-04	35N/68N	1	J	3053	3053	9450	RULOUT ONLY		•	- -
G-025-07	47 194 _.	~	J	6637	6637	9450	PULOUT ONLY	DATE		
6-025-07	74/1452		J	2890	2901	9450		15/11	3 0	
6-025-07	404/11R	\checkmark	J _	101	701	8170	RULDUT OWN	N N	ALC. NO.	HEET NO.
G-026-01	23/18R	1					. Strudl	ð		=
6-026-01.	47/5V	1	1	2966	2966	94-50	PULLOUT ONLY	15320		ы Г

diam'r.

. 3 ŗ, **t** . ţ ٩. • ÷ ٠ :

:

ì • . •

and and a second a second and a

.

> : ۲. . .

> > , •, •

• 5

.

~

• ₩2 • • • • •

ν,¥μ, ος ς τ εγις ' *«*.

,

• •

Ale i i l vage

i.

van state state t

STRESS ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	VEC) STR. EU WITH LA.LB.LC	ALLOWABLE STRESS(PSI)	COMMENTS	SUR			
G-026-01	413/109R		J	Max 8853	16280	II. 23070		VEY	ABLO		
G-016-02	23/9R		J	6110	6734	9450			CANY		,
6-026-03	47/LOR	~	J	4028	402B	19900			ON UN	•	
6-016-03	404/42	-	J	6319 MAK	6370	31 10400		DATE -	1172		
G-026-05	413/1052	~	J	3508	350B	9450	ALLOUT ONLY	ESIST		DIAB	BECHT
G -028-02	4131372R	~	J	8663	8665	9450	PULLAUT ONLY			CULA	EL POWE
G -029-01	413/550R		J	255B	2537	0110 _.		HEAR		YON PR	R CORPO
G-029-02	2023/11R		J	12424	12795	18000	రా			HEET HEET	NATION
G.a.	2032/652	1	1	9780	9780	11340	PULAT and			ı	•
G-023-04	413 /462N	~	J	9362	9362	19900	FL, Sh YERY SMOLL	DATE			(
G -050-01	43/553R		.1	2739	2810	8770	•	12/61	2	2	9
6-030-02	413/205R	1	PIRE	2058	2058	8770		02 76	EV. NO.	ILC. NO.	EET NO.
6-030-02	2035/2552		J	MAX 18200	18545	IN9000		NO			12
6-031-02	2033/2356		1	17954	18100	II.		5320			¥ A

CIFIC GAS AND ELECTRIC

2 J .

:

l.

بلغم فالمنظلم معينة من الم المعلمة م فالمام عالما المعمد الماعين ما المام أن ÷ •

ł

*

ŝ

۰.

. :





ž. .

se s ₁s s' *

45

-• • • • • • **«د**

.

* * * * * * * * ** *

STRES ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	D STR. ED WITH	ALLOWABLE STRESS(PSI	COMMENTS			e E	
G-031-03	1550-156	1					STRUDL	WEY	ABLO		
6-032-05	413/2682	1					STRUDI	WE	CANY		1
G-092-05	413/303R		J.	7443	7481	9450		LD AR	IN NO.		
G-032-05	2040/11	Ì	1	1536	.7536	9450	PULOUT OVER	DATE -	VIT2		G
6-032-05	zoosliv.	~	J :	7409	7409	9450	ANLAT ANT	ESIST	5	DIA	BECH
6-032-02	2040/2352	~	J	2032.	2032	IT.	• a				TEL PONI
G-071-01	949/2092	~	1	2654	2654	19900	WELD ON ZSIOFS	HEAR		TON PR	ELECTRI
G-081-01	413/2172	~	J	2017	2017	9450	RUDUT ONN	N N	7661	NECL	RATION
6-081-01	1548-16		J	4016	4258	9500		ß		ı'	• •
6-08.05	413/494R	~	J	19204	19204	19900		DATE			
G-086-07	413/506R	-	-	 .	-	-	Fy = 1511 110, FLAT = 34, 730	<u>, 12</u>		0	•
G-102- 01	1547-157		7	5644	5891	6360	<u>جر</u>	ar ne	EV. NO.	ALC. NO.	HEET NO
6-107-01	413/359R	/	v	6115	6115	9450	PULAUT ANLY	NO.			5
6-107-01	2004/265	~	· v	22.62	2262	21600	Prior Pily	15320			r 14

*

у^{*}. C#3.0 N ¢.

و ٦ **2**]: - 1

K.

ł

•

-• • • .

.

I. a . .

•

• \$

۴

STRESS ANALYSIS	SUPPORT NUMBER	ANALYS STRUDL HES-5B	IS MTD. P-6	CRITICAL V CALCULAT AW ONLY	MEL STR. EL WITH LA,LB,LC	ALLOWABLE STRESS(PSI)	COMMENTS		
G-107-01	2007/265	1	1	6382	6382	94-50	ALLOUT ONLY	A BLO	
6-107-02	413/451	~	1	<u> </u>	3969	' 9450	•	DIF WEI	
G-108-01	2015 131	~	-	6773	6773	9450	RULOUT ONLY		
G-108-01	2018/34	1	J .	8724	8724	9450	FULLOUT and	EAS F	
G- 128-01	413/4481	. ✓	J	300	300	· 9500		ESIST	ACIFIC BECH CA
•								ING S	ILCULA
								HEAR	ELECTRI R CORR TION PR
								R I	C COMPA MATION NOLECT
						•		2	A
								DATE	
	•		-			·	· · ·	12/11	· ·
								all a	HEET NO
1								NO.	4
								16320	4

1

. ſ

•

.

ENCLOSURE 2

0088S/0026K

à.

-

, .

۲ × ı

. 14

• к

•

ENCLOSURE 2

Bechtel Power Corporation

Interoffice Memorandum

To	W. N. Adams	Dete	January 2, 1985
Subject	Design Deficiency/Mismanagement Diablo Canyon Project	From Of	K. Y. Lee Engineering
۴		At	Gaithersburg
Copies	US. Wang T. McDonald	File	

The attached memo from a concerned engineer to me, dated November 15, 1984, raised two issues; one technical and one personal. The purpose of this memo is to inform you of the action taken to resolve these issues.

The technical issue addresses the method used by Diablo Canyon project (DCP) in calculating the shearing stresses in welds. The method was jointly reviewed by the Gaithersburg and San Francisco offices and found to be an acceptable approach. The method was based on Blodgett's "Design of Welded Structures" which is commonly used by the industry.

A comparison was also made between the DCP method and a more conservative method as recommended in the EPD Hanger Engineering Standard, HES-DO5A and B. A total of 109 supports, which represents 5% of supports assigned to EPD, were chosen. In all cases the calculated weld stresses using the more conservative method are within the code allowables. Furthermore, a majority of the samples have an increase in calculated stresses of less than 5% by using the more conservative method.

Results of the above study were presented to the entire DCP group on December 19, 1984. In that meeting, Tom McDonald and I stressed that it is company policy to encourage employees to bring opinions, criticisms and problems into the open. There was no additional concern raised.

Regarding the personal criticisms on Syed Bokhari, we have no way to dispute or verify the accusations since the source is unknown to us. As a supervisor, Syed has been successful in meeting project schedule and budget. Throughout his eleven years with Bechtel, his performance has been rated "Exceeds Job Requirement". He often coordinated with me and the staff following his Junch hour, which might account for the reason why he was often late after Junch. His performance will solely be judged by his performance reviews.

K. Y. Lee

BECHTEC POWER CORP. RECEIVED

IAN 7 1985 JOB NO. 15320-003

KYL:aes

Attachment

(

. ſ •

· · ·

•

.

• ·

ENCLOSURE 3

0088S/0026K

. ٨ ` · · · .

ENCLOSURE 3

ź

۰,

STRESS ANALYSIS	SUPPORT Number	ANALYSIS METHOD P-6	CRITICAL WELD STRESS CALCULATED WITH AW ONLY L _A ,L _B ,L _C (Method 1) (Method 2)		ALLOWABLE STRESS (PSI)	COMMENTS
G-003-02	413/561R	X	5,504*	6,227*	6,780	*Conservative since min. t _e is used; i.e., along sides of process pipe
G-016-01	413/365SL	x -	2,045	2,120	19,900	
G-01 6-02	41 3/321 R	x	15,263	15,610	19,900	2°
G-018-05	512/30R	x	17,878	19,236	19,900	In another weld, the stress changed from 2,587 (AW) to 4,519 (LA, LB, LC)
G-025-07	75/2SL	x	4,927	5,721	19,900	
G-025-07	404/35R	x	617	872	19,900	
G-026-01	413/584R	x	10,823	11,562	21,500 LC III 11,340 LC II	Load Case I and II are OK by comparison of loads and allowables
G-032-07	413/620R	x	23,440 Max 19,221 II	23,812 Max 19,526 II	26,500 II & IV 19,900 I & II	

Notes:

AW: Total length

 $L_A\colon$ Effective length of weld carrying shear in "a" direction

LB: Effective Length of weld carrying shear in "b" direction

L_C: Effective Length of weld carrying shear in "c" direction

I, II, III, and IV: Load cases as defined in DCM M-9 for normal, upset, emergency, and faulted contition, respectively.

0088S/0026K

• · · · · ·

•