

# REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8509110121 DOC. DATE: 85/09/06 NOTARIZED: YES DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Gas 05000275  
 50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Gas 05000323  
 AUTH. NAME: AUTHOR AFFILIATION  
 SHIFFER, J. D. Pacific Gas & Electric Co.  
 RECIP. NAME: RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director.

SUBJECT: Forwards application for amends to Licenses DPR-80 & DPR-82,  
 consisting of License Amend Request 85-09, changing combined  
 Units 1 & 2 Tech Spec 3/4.2.1 to implement relaxed axial  
 offset control for Unit 1. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 3 ENCL 36 SIZE: 1713  
 TITLE: OR Submittal: General Distribution

NOTES:

05000275

OL: 09/22/81

	RECIPIENT ID CODE/NAME		COPIES LTTR ENCL		RECIPIENT ID CODE/NAME		COPIES LTTR ENCL
	NRR LB3 BC	01	7	7			
INTERNAL:	ACRS	09	6	6	ADM/LFMB		1 0
	ELD/HDS2		1	0	NRR/DE/MTEB		1 1
	NRR/DL DIR		1	1	NRR/DL/ORAB		1 0
	NRR/DL/TSRG		1	1	NRR/DSI/METB		1 1
	NRR/DSI/RAB		1	1	<u>REG. FILE.</u>	04	1 1
	RGN5		1	1			
EXTERNAL:	24X		1	1	EG&G. BRUSKE, S		1 1
	LPDR	03	2	2	NRC. PDR	02	1 1
	NSIC	05	1	1			

*Rec'd w/ check \$150.00  
 #0991519*

11

62

4

SECRET

11/10/93

100

5

11

# PACIFIC GAS AND ELECTRIC COMPANY

PG&E



77 BEALE STREET • SAN FRANCISCO, CALIFORNIA 94106 • (415) 781-4211 • TWX 910-372-6587

JAMES D. SHIFFER  
VICE PRESIDENT  
NUCLEAR POWER GENERATION

September 6, 1985

PGandE Letter No.: DCL-85-295

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
U. S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
License Amendment Request 85-09, Technical Specification 3/4.2.1 -  
Relaxed Axial Offset Control for Unit 1

Dear Mr. Denton:

Enclosed are three (3) signed and thirty-seven (37) conformed copies of an application for amendment to Facility Operating License Nos. DPR-80 and DPR-82.

This License Amendment Request (LAR) proposes changes to the combined Units 1 and 2 Technical Specification 3/4.2.1 to implement relaxed axial offset control (RAOC) for Unit 1 after 8000 MWD/MTU burnup in Cycle 1. The proposed revision adds Technical Specification 3/4.2.1.1, "Axial Flux Difference," to include RAOC for Unit 1, and modifies the existing Technical Specification 3/4.2.1, "Axial Flux Difference," to be applicable to Unit 2 only.


Unit 1 is expected to reach 8000 MWD/MTU burnup by early November 1985. The requested license amendment should be made effective upon reaching that level of burnup, and PGandE will implement the added Technical Specification 3/4.2.1.1 for Unit 1 only after reaching 8000 MWD/MTU burnup for Unit 1. Existing Technical Specification 3/4.2.1 for Unit 2 will be renumbered at that time to 3/4.2.1.2. PGandE intends to perform a similar analysis to assess RAOC for Unit 2. When completed, PGandE will determine if a similar LAR for Unit 2 would be appropriate.

Pursuant to 10 CFR 170.12(C), an application fee of \$150 is enclosed.

Kindly acknowledge receipt of this material on the enclosed copy of this letter and return it in the enclosed addressed envelope.

8509110121 850906  
PDR ADDCK 05000275  
PDR

Sincerely,



cc: R. T. Dodds  
G. W. Knighton  
J. B. Martin  
H. E. Schierling  
J. O. Ward

A001  
3/36

Rec'd w/ check \$150.00  
#0991519

