

MONTHLY NARRATIVE REPORT  
OF OPERATION  
AND MAJOR MAINTENANCE EXPERIENCE

This report describes the operating and major maintenance experience for the month of May, 1988. This narrative report was prepared by the plant staff and is submitted in accordance with Section 6.9.1.7 of the Units 1 and 2 Technical Specifications.

Narrative of Daily Significant Plant Events

- On May 1, 1988            Unit 1 started the month at 0% power in a refueling outage which began on March 6, 1988. Unit 2 started the month at 100% power.
- On May 12, 1988        A 10CFR50.72(b)(2)(ii) Non-Emergency 4-hour report was made regarding the Unit 1 Fuel Handling Building Ventilation System being automatically transferred into the Iodine Removal Mode when RM-58 alarmed due to electronic noise.
- On May 22, 1988        10CFR50.72(b)(1)(iv) Non-Emergency 1 hour reports were made regarding potential design or installation problems on Units 1 and 2 Containment Purge Supply and Exhaust Isolation Valves.
- On May 31, 1988        Unit 1 ended the month at 0% power and Unit 2 ended the month at 100% power.

Summary of Plant Operating Characteristics, Power Reductions and Unit Shutdowns

Unit 1 operated this month with a unit availability factor of 0% and a unit capacity factor of -0.3% due to a refueling outage.

Unit 2 operated this month with a unit availability factor of 100% and a unit capacity factor of 99.7%.

Summary of Significant Safety-Related Maintenance

Significant safety-related maintenance for Unit 1 consisted of completely tensioning the reactor vessel head and conducting a containment integrated leak rate test. There was no significant safety-related maintenance for Unit 2.

8806270275 880615  
PDR ADOCK 05000275  
R PDR



Handwritten marks and symbols in the top right corner, including several small dots and a cluster of faint, illegible characters.

Actuations of Steam Generator Safety Valves  
or Pressurizer Power Operated Relief Valves

No challenges to the steam generator safety valves or pressurizer power operated relief valves were made.

Report of Breakwater Inspections Required  
by Technical Specification 4.7.13.1

The breakwaters were inspected during the months of November to April in accordance with Technical Specification 4.7.13.1 and 4.7.13.2. Results from this year's survey were verified against the survey performed during 1984. Changes in the positions of the breakwater survey monuments are given below:

Easting coordinates	= -0.3 feet
Northing coordinates	= -0.3 feet
Elevation	= -0.4 feet

These differences are so small as to be considered negligible and indicative that no appreciable breakwater displacement or settlement has occurred. Breakwater survey results and pictures taken during the survey are provided in Enclosures 1 and 2.



11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

OPERATING DATA REPORT

DOCKET NO. 50-275  
 DATE 06/08/88  
 COMPLETED BY P. Bedesem  
 TELEPHONE (805)595-4097

OPERATING STATUS

1. Unit Name: Diablo Canyon Unit 1
2. Reporting Period: May 1988
3. Licensed Thermal Power (Mwt): 3338
4. Nameplate Rating (Gross MWe): 1137
5. Design Electrical Rating (Net MWe): 1086
6. Maximum Dependable Capacity (Gross MWe): 1124
7. Maximum Dependable Capacity (Net MWe): 1073.4
8. If changes occur in capacity ratings (Items Number 3 through 7) since last report, give reasons:

\_\_\_\_\_ N/A \_\_\_\_\_

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any: N/A

	This Month	Year to Date	Cumulative
11. Hours in Reporting Period	<u>744.0</u>	<u>3647.0</u>	<u>26901.3</u>
12. Number Of Hours Reactor Was Critical	<u>0.0</u>	<u>1531.6</u>	<u>21273.0</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>0.0</u>	<u>1523.3</u>	<u>20831.0</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated	<u>0.0</u>	<u>4020604</u>	<u>62985064</u>
17. Gross Electrical Energy Generated	<u>0.0</u>	<u>1355000</u>	<u>21205832</u>
18. Net Electrical Energy Generated	<u>-2117</u>	<u>1269211</u>	<u>20081243</u>
19. Unit Service Factor	<u>0.0</u>	<u>41.8</u>	<u>77.4</u>
20. Unit Availability Factor	<u>0.0</u>	<u>41.8</u>	<u>77.4</u>
21. Unit Capacity Factor (Using MDC Net)	<u>-0.3</u>	<u>32.4</u>	<u>69.5</u>
22. Unit Capacity Factor (Using DER Net)	<u>-0.3</u>	<u>32.1</u>	<u>68.7</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>3.8</u>	<u>4.9</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each)			

25. If Shut Down At End Of Report Period, Estimated Date of Startup: 06/27/88



11/11/11

OPERATING DATA REPORT

DOCKET NO. 50-323  
 DATE 06/08/88  
 COMPLETED BY P. Bedesem  
 TELEPHONE (805)595-4097

OPERATING STATUS

1. Unit Name: Diablo Canyon Unit 2
2. Reporting Period: May 1988
3. Licensed Thermal Power (MWt): 3411
4. Nameplate Rating (Gross MWe): 1164
5. Design Electrical Rating (Net MWe): 1119
6. Maximum Dependable Capacity (Gross MWe): 1137
7. Maximum Dependable Capacity (Net MWe): 1087
8. If changes occur in capacity ratings (Items Number 3 through 7) since last report, give reasons:

N/A

9. Power Level To Which Restricted, If Any (Net MWe): N/A
10. Reasons For Restrictions, If Any:

N/A

	This Month	Year to Date	Cumulative
11. Hours in Reporting Period	<u>744.0</u>	<u>3647.0</u>	<u>19460.0</u>
12. Number Of Hours Reactor Was Critical	<u>744.0</u>	<u>3580.2</u>	<u>16495.9</u>
13. Reactor Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
14. Hours Generator On-Line	<u>744.0</u>	<u>3579.6</u>	<u>16064.5</u>
15. Unit Reserve Shutdown Hours	<u>0.0</u>	<u>0.0</u>	<u>0.0</u>
16. Gross Thermal Energy Generated	<u>2530899</u>	<u>12003439</u>	<u>51265423</u>
17. Gross Electrical Energy Generated	<u>846300</u>	<u>4005500</u>	<u>16993199</u>
18. Net Electrical Energy Generated	<u>806210</u>	<u>3811247</u>	<u>16074749</u>
19. Unit Service Factor	<u>100.0</u>	<u>98.2</u>	<u>82.6</u>
20. Unit Availability Factor	<u>100.0</u>	<u>98.2</u>	<u>82.6</u>
21. Unit Capacity Factor (Using MDC Net)	<u>99.7</u>	<u>96.1</u>	<u>76.4</u>
22. Unit Capacity Factor (Using DER Net)	<u>96.8</u>	<u>93.4</u>	<u>73.8</u>
23. Unit Forced Outage Rate	<u>0.0</u>	<u>1.9</u>	<u>5.6</u>
24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each)			

Unit 2 is scheduled to begin a 70 day second refueling outage Sept. 15

25. If Shut Down At End Of Report Period, Estimated Date of Startup: N/A



Small, illegible handwritten marks or characters in the top right corner.



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	<u>50-275</u>
UNIT	<u>1</u>
DATE	<u>06/08/88</u>
COMPLETED BY	<u>P. BEDESEM</u>
TELEPHONE	<u>(805)595-4097</u>

MONTH: MAY 1988

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	-4	17	-4
2	-3	18	-3
3	-2	19	-3
4	0	20	-3
5	-3	21	-3
6	-3	22	-3
7	-3	23	-2
8	-3	24	-1
9	-3	25	-3
10	-2	26	-3
11	-3	27	-3
12	-3	28	-3
13	-3	29	-3
14	-3	30	-3
15	-3	31	-3
16	-3		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

The Average Monthly Electrical Power Level for MAY 88 = -2.85 MWe-Net



AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO.	<u>50-323</u>
UNIT	<u>2</u>
DATE	<u>06/08/88</u>
COMPLETED BY	<u>P. BEDESEM</u>
TELEPHONE	<u>(805)595-4097</u>

MONTH: MAY 1988

DAY	AVERAGE DAILY POWER LEVEL	DAY	AVERAGE DAILY POWER LEVEL
1	1089	17	1088
2	1096	18	1088
3	1084	19	1088
4	1087	20	1084
5	1087	21	1063
6	1088	22	1084
7	1063	23	1083
8	1087	24	1083
9	1092	25	1089
10	1083	26	1088
11	1083	27	1088
12	1087	28	1067
13	1079	29	1088
14	1068	30	1084
15	1083	31	1084
16	1088		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.

The Average Monthly Electrical Power Level for MAY 88 = 1083.62 MWe-Net



UNIT SHUTDOWNS AND POWER REDUCTIONS  
Page 1 of 1

DOCKET NO. 50-275  
 UNIT NAME Diablo Canyon Unit 1  
 DATE 06/08/88  
 COMPLETED BY D.D.MALONE  
 TELEPHONE (805)595-4859

REPORT MONTH MAY 1988

No.	Date	1 Type	Duration (Hours)	2 Reason	3 Method of Shutdown	Licensee Event Report #	4 System Code	5 Component Code	Cause & Corrective Action to Prevent Recurrence
1	5/1/88	S	744	C	4	N/A	N/A	N/A	N/A

1	2	3	4
F: Forced	Reason:	Method	Exhibit G - Instructions
S: Scheduled	A-Equipment Failure (Explain)	1-Manual	for Preparation of Data
	B-Maintenance or Test	2-Manual Scram	Entry Sheets for Licensee
	C-Refueling	3-Automatic Scram	Event Report (LER) File
	D-Regulatory Restriction	4-Continuation from	(NUREG-1022)
	E-Operator Training & License Examination	previous month	
	F-Administrative	5-Power reduction	5
	G-Operational Error (Explain)	6,7,8-N/A	Exhibit I - Same Source
	H-Other (Explain)	9-Other	



Handwritten marks and dots in the top right corner.

Faint handwritten marks or text in the bottom left area.

Faint handwritten marks or text in the bottom right area.

UNIT SHUTDOWNS AND POWER REDUCTIONS  
Page 1 of 1

DOCKET NO. 50-323  
UNIT NAME Diablo Canyon Unit 2  
DATE 06/08/88  
COMPLETED BY D.D. MALONE  
TELEPHONE (805) 595-4859

REPORT MONTH MAY 1988

No.	Date	1 Type	Duration (Hours)	2 Reason	Method of Shutdown	3 Licensee Event Report #	System Code	Component Code	5	Cause & Corrective Action to Prevent Recurrence
-----	------	-----------	---------------------	-------------	-----------------------	------------------------------------	----------------	-------------------	---	---

None


1	F: Forced S: Scheduled	2	Reason: A-Equipment Failure (Explain) B-Maintenance or Test C-Refueling D-Regulatory Restriction E-Operator Training & License Examination F-Administrative G-Operational Error (Explain) H-Other (Explain)	3	Method 1-Manual 2-Manual Scram 3-Automatic Scram 4-Continuation from previous month 5-Power reduction 6,7,8-N/A 9-Other	4	Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-1022)	5	Exhibit I - Same Source
---	---------------------------	---	---	---	---	---	---	---	-------------------------





ENCLOSURE 1

DIABLO CANYON  
BREAKWATER SETTLEMENT SURVEY



(T. 315.R. 10E. M.D.B. & M.)  
SW1/4, OF SW1/4, SEC. 24

CALIFORNIA STATE PLANE COORDINATES  
ZONE 2


NAME	COORDINATES		ELEV.
	NORTHING	EASTING	
COVE	633,367,836	1,146,416,283	58.465
PT A	633,428,337	1,146,621,668	53.18
PT B	633,428,572	1,147,134,468	58.55
PT C	633,846,618	1,147,470,485	64.23
PT D	633,224,623	1,148,107,631	74.24

NOTES:


- 1.) ALL ELEVATIONS ARE M.L.L.M.
- 2.) BASIS OF ELEV., PG. U.S.C. & G.S. BRASS DISC STAPPED  
"COVE", SET IN ROCK.  
ELEV. = 53.863' U.S.C. & G.S. DATUM 26485 M.L.L.M.
- 3.) REFERENCE POINT SAN LUIS 7 1/2' QUAD
- 4.) FOR SETTLEMENT DATA SEE 34971 D.S. 2
- 5.) THE DIFFERENCE SHOWN BETWEEN MEAN LOWER  
LOW WATER (M.L.L.W.) AND MEAN SEA LEVEL  
(M.S.L.) IS BASED UPON THE RELATIONSHIP  
PUBLISHED BY THE UNITED STATES COAST  
AND GEODETIC SURVEY, MAY 1953 FOR  
AVILM SEA LEVEL DATUM (S.L.D.) 1929  
GENERAL ADJUSTMENT. THE DIFFERENCE BE-  
TWEEN MEAN LOWER LOW WATER AND MEAN SEA  
LEVEL AS SHOWN ON THIS MAP MAY NOT RE-  
PRESENT A CURRENT RELATIONSHIP FOR DE-  
TERMINATION OF THE BOUNDARY LINE OF AN  
UPLAND OWNER.  
ELEV. M.L.L.M. = ELEV. S.L.D. +2.8  
ELEV. S.L.D. = ELEV. M.L.L.M. -2.8
- 6.) T.B.M. = TIDAL BENCH MARK

LEGEND

- U.S.C. & G.S. MONUMENT
- REBAR & CAP
- △ STANDARD P.O.S.E. CO. BRASS DISC
- ▲ BRASS DISC
- ⊙ BRASS PIN
- BASELINE
- - - CONTROL LINE
- TRIANGULATION LINE
- ····· DISTANCE DETERM BY E.S.M.
- - - AZIMUTH MARK



RANCHO CAÑADA DE LOS OSOS  
Y PECHO Y ISLAY



DESCRIPTION	CHG.	DISTRIBUTION	CHG.	DATE	BY	REVISION	DATE	BY
11/15/86	3							


CH 54  
DIABLO CANYON  
BREAKWATER SETTLEMENT SURVEY  
PACIFIC GAS AND ELECTRIC COMPANY  
SAN FRANCISCO CALIFORNIA  
349070



10/10/10

[Faint, illegible text scattered across the page, possibly bleed-through from the reverse side.]





DCPP BREAKWATER SURVEY RESULTS

DATE	E - 1 COORDINATE			E - 3 COORDINATE			W - 3A COORDINATE			W - 5A COORDINATE		
	N	E	ELEV	N	E	ELEV	N	E	ELEV	N	E	ELEV
05/01/84	633001.02	1147550.91	19.63	633225.47	1147203.01	19.10	633423.53	1146891.05	18.85	633112.22	1146888.74	19.65
03/01/85	633001.03	1147550.93	19.63	633225.47	1147203.04	19.09	633423.54	1146891.06	18.83	633112.22	1146888.76	19.63
DIFF:	.01	.02	.00	.00	.03	-.01	.01	.01	-.02	.00	.02	-.02
04/08/86	633001.02	1147550.91	19.63	633225.48	1147203.02	19.09	633423.53	1146891.05	18.80	633112.20	1146888.74	19.60
DIFF	-.01	-.02	.00	.01	-.02	.00	-.01	-.01	-.03	-.02	-.02	-.03
03/30/87	633001.01	1147550.92	19.63	633225.45	1147203.00	19.09	633423.54	1146891.02	18.79	633112.21	1146888.70	19.59
DIFF	-.01	.01	.00	-.03	-.02	.00	.01	-.03	-.01	.01	-.04	-.01
04/25/88	633001.01	1147550.90	19.63	633225.46	1147203.00	19.09	633423.51	1146891.02	18.76	633112.19	1146888.70	19.56
DIFF	.00	-.02	.00	.01	.00	.00	-.03	.00	-.03	-.02	.00	-.03

DATE	E - 2 COORDINATE			W - 2A COORDINATE			W - 4A COORDINATE			W - 6A COORDINATE		
	N	E	ELEV	N	E	ELEV	N	E	ELEV	N	E	ELEV
05/01/84	633099.23	1147400.37	19.43	633499.74	1146880.05	19.29	633261.39	1146884.16	19.75	632990.07	1146932.06	19.81
03/01/85	633099.24	1147400.39	19.43	633499.74	1146880.05	19.27	633261.39	1146884.17	19.74	632990.08	1146932.08	19.80
DIFF:	.01	.02	.00	.00	.00	-.02	.00	.01	-.01	.01	.02	-.01
04/08/86	633099.23	1147400.38	19.43	633499.73	1146880.03	19.26	633261.38	1146884.16	19.73	632990.05	1146932.09	19.79
DIFF	-.01	-.01	.00	-.01	-.02	-.01	-.01	-.01	-.01	-.03	.01	-.01
03/30/87	633099.22	1147400.38	19.44	633499.73	1146880.01	19.25	633261.39	1146884.13	19.73	632990.08	1146932.05	19.79
DIFF	-.01	.00	.01	.00	-.02	-.01	.01	-.03	.00	.03	-.04	.00
04/25/88	633099.22	1147400.38	19.43	633499.71	1146880.01	19.21	633261.36	1146884.14	19.70	632990.05	1146932.05	19.77
DIFF	.00	.00	-.01	-.02	.00	-.04	-.03	.01	-.03	-.03	.00	-.02

NOTE: Survey Information for 1988



Small, faint, illegible marks or characters in the top right corner.

Handwritten scribbles or faint markings in the center of the page, possibly representing a signature or initials.



ENCLOSURE 2

DIABLO CANYON  
BREAKWATER PICTURES



1

2


3

4


D C P P E. BREAKWATER



April 1988 Annual  
Breakwater Survey.




DCPP E. Breakwater



April 1968 Annual  
Breakwater Survey.


DCPP E. Breakwater



April 1968 Annual  
Breakwater Survey




DCPP E.W. Breakwater



April 1988 Annual  
Breakwater Survey.

DCPP E. Breakwater



April 1988. Annual  
Breakwater Survey.



100-100000000


100-100000000

100-100000000

100-100000000




DCPP E&W Breakwater



April 1988. Annual  
Breakwater Survey.

DCPP E&W Breakwater




April 1988 Annual  
Breakwater Survey.




1952

D.C.P.P. W. Breakwater



April 1988, Annual.  
Breakwater Survey.

D.C.P.P. W. Breakwater



April 1988, Annual.  
Breakwater Survey.



Small, faint, illegible marks or characters in the top right corner.

Small, faint, illegible marks or characters in the middle left area.

Small, faint, illegible mark or character in the middle left area.

Small, faint, illegible marks or characters in the middle left area.

Small, faint, illegible mark or character in the middle left area.

Small, faint, illegible marks or characters in the middle left area.

Small, faint, illegible mark or character in the middle left area.

Small, faint, illegible mark or character in the middle left area.

Small, faint, illegible marks or characters in the bottom left area.

Small, faint, illegible marks or characters in the bottom center area.

Small, faint, illegible mark or character in the bottom center area.

Small, faint, illegible marks or characters in the bottom right area.

Small, faint, illegible marks or characters in the bottom left area.


Small, faint, illegible mark or character in the bottom center area.

D.C.P.P. W. Breakwater



FIG. A - W. Breakwater  
April 1988

D.C.P.P. W. Breakwater




April 1988. Annual.  
Breakwater Survey.




Small, faint, illegible markings or characters in the top right corner.

DCPP W. Breakwater



April 1988 Annual  
Breakwater Survey.

DCPP W. Breakwater



April 1988 Annual  
Breakwater Survey.

