

APPENDIX B

NOTICE OF DEVIATION

Pacific Gas and Electric Company
Diablo Canyon Nuclear Power Plant

Docket No. 50-275, 50-323
License No. DPR-80, DPR-82

During an NRC Inspection conducted January 9, 1989 through February 28, 1989, a deviation from your commitments to the NRC was identified. In accordance with the "General statement of policy and procedure for NRC Enforcement Actions," 10 CFR Part 2, Appendix C, the deviation is listed below:

UFSAR, Page 9.4-8 states in part, that:


"With complete recirculation of the ventilation air, the carbon dioxide buildup is not expected to exceed an acceptable concentration of 1% by volume in 40 hours with 20 persons in the Unit 1 and 2 control room complex. Information will be available to the operator on CO₂ buildup with more or fewer persons in the area so that appropriate measures may be taken..."

Contrary to the above, at the time of the inspection no information was available to the operators on CO₂ buildup.

This is a Deviation

Please provide to the U. S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, DC 20555 with a copy to the Regional Administrator, Region V, and a copy to the NRC Resident Inspector, within 30 days of the date of notice, the reason for the deviation, the corrective steps that have been taken and the results achieved, the corrective steps that will be taken to avoid further deviations, and the date when your corrective actions will be completed. Please inform us if you are unable to respond within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



J. B. Martin
Regional Administrator

Dated at Walnut Creek, California
this 21 day of March, 1989.

8904110138 890321
PDR ADOCK 05000275
Q PIC

