

DIABLO CANYON POWER PLANT

DIESEL GENERATOR

ALLOWED OUTAGE TIME STUDY

May 1989

PACIFIC GAS AND ELECTRIC COMPANY

8905170138 890511
PDR ADOCK 05000275
P PDC

Pacific Gas and Electric Company



of the...
...
...
...
...
...
...
...
...
...
...
...
...
...
...
...

...
...
...
...
...
...
...
...
...

...
...
...
...
...
...
...
...
...

EXECUTIVE SUMMARY

Pacific Gas and Electric Company (PG&E) has been implementing activities to enhance diesel generator (DG) reliability at Diablo Canyon. These activities include developing preventive maintenance procedures, providing personnel training, and using industry, NRC, and vendor DG reliability improvement recommendations. Further, PG&E is planning to install a sixth DG by the fourth refueling outage of Unit 2, scheduled for the fall of 1991, and has committed significant resources to this effort. As part of this overall effort, PG&E also determined an acceptable allowed outage time (AOT) for the DG system. An AOT determination study was performed based upon reliability, risk considerations, and the time necessary to perform required maintenance and testing. This report documents this study and is submitted in support of PG&E's application to amend its operating licenses to change the AOT for the DGs to seven days.

This report describes the DG system and the methods used to assess the benefits and impact of the proposed change in AOT. Two different risk calculation methods were used to perform these quantitative evaluations. The first method makes extensive use of the risk assessment models developed for the Diablo Canyon probabilistic risk assessment. The second method uses a reliability analysis, similar in approach to a recent NRC-approved license amendment for a DG AOT extension to seven days. This reliability method was also used to assess the relative and annual risk associated with the proposed AOT change at Diablo Canyon.

The results of these risk and reliability evaluations show that risk and reliability criteria are satisfied for a 7-day AOT for both the five and six DG configurations. These studies confirm that the risk levels during the 7-day AOT remain significantly less than the risk when not in the AOT period; that is, when all DGs are in their normal standby condition, and that the 7-day AOT results in an insignificant change in the risk frequencies. Finally, it was found that overall risk will be reduced over the plant life with a six DG configuration with the 7-day AOT.

SECRET

1. The first part of the document

2. The second part of the document

3. The third part of the document

4. The fourth part of the document

5. The fifth part of the document

6. The sixth part of the document

7. The seventh part of the document

8. The eighth part of the document

9. The ninth part of the document

10. The tenth part of the document

11. The eleventh part of the document

12. The twelfth part of the document

13. The thirteenth part of the document

14. The fourteenth part of the document

15. The fifteenth part of the document

16. The sixteenth part of the document

17. The seventeenth part of the document

18. The eighteenth part of the document

19. The nineteenth part of the document

20. The twentieth part of the document

21. The twenty-first part of the document

22. The twenty-second part of the document

23. The twenty-third part of the document

24. The twenty-fourth part of the document

25. The twenty-fifth part of the document

26. The twenty-sixth part of the document

27. The twenty-seventh part of the document

28. The twenty-eighth part of the document

29. The twenty-ninth part of the document

30. The thirtieth part of the document

SECRET

**DIABLO CANYON POWER PLANT
DIESEL GENERATOR ALLOWED OUTAGE TIME STUDY**

TABLE OF CONTENTS

1.0	SUMMARY
2.0	INTRODUCTION
	2.1 BACKGROUND
	2.2 SCOPE OF ANALYSIS
3.0	ELECTRIC POWER SYSTEM
	3.1 ELECTRIC POWER SYSTEM FUNCTION
	3.2 ELECTRIC POWER SYSTEM DESCRIPTION
	3.3 ELECTRIC POWER SYSTEM OPERATION
	3.4 DIESEL GENERATORS
	3.5 SUMMARY OF STATION BLACKOUT
4.0	PROBABILISTIC RISK ANALYSIS
	4.1 PRA CALCULATIONS
	4.2 DATA ANALYSIS
	4.3 DCPRA ELECTRIC POWER SYSTEM MODEL
	4.3.1 CALCULATION MODIFICATIONS
	4.4 CORE DAMAGE SEQUENCE MODELS
	4.4.1 DOMINANT SEQUENCE PRA MODEL
	4.4.2 NON-SEISMIC SEQUENCES
	4.4.3 SEISMIC SEQUENCES
	4.5 QUANTIFICATION OF CORE DAMAGE FREQUENCY
	4.5.1 ABSOLUTE RISK RESULTS
	4.5.2 RELATIVE RISK RESULTS
	4.5.3 SENSITIVITY TO SWING DIESEL IN MAINTENANCE
	4.6 INTERPRETATION OF RESULTS
5.0	RELIABILITY ANALYSIS
	5.1 DIESEL GENERATOR FAULT TREE
	5.1.1 SUCCESS CRITERIA
	5.1.2 ASSUMPTIONS AND BOUNDARY CONDITIONS
	5.1.3 FAULT TREE DEVELOPMENT
	5.1.4 QUANTIFICATION





31 40
11
A. 1902

TABLE OF CONTENTS (Cont.)

5.2	CALCULATION MODELS
5.2.1	SUCCESS CRITERIA
5.2.2	CALCULATION MODEL CRITERIA
5.2.3	CALCULATIONS
5.3	ALLOWED OUTAGE TIME ANALYSIS
5.4	RELIABILITY ANALYSIS RESULTS
5.4.1	RELATIVE RISK METHOD
5.4.2	AVERAGE ANNUAL RISK METHOD
5.4.3	RISK RESULTS
5.5	SENSITIVITY STUDY
6.0	SUMMARY OF RESULTS
7.0	CONCLUSIONS
8.0	REFERENCES
APPENDIX A:	DIESEL GENERATOR SYSTEM EQUATIONS
APPENDIX B:	REDUCED CORE DAMAGE SEQUENCE MODEL
APPENDIX C:	SEISMIC SEQUENCE ANALYSIS
APPENDIX D:	RELIABILITY ANALYSIS FAULT TREES



LIST OF FIGURES AND TABLES

<u>Figure</u>	<u>Title</u>
2-1	PROBABILISTIC RISK ASSESSMENT APPROACH
2-2	RELIABILITY ANALYSIS APPROACH
3-1	DIABLO CANYON ELECTRIC POWER SYSTEM
<u>Table</u>	<u>Title</u>
3-1	4.16 KV VITAL BUS AND ESF LOADS
3-2	DIESEL GENERATOR ALARMS
4-1	DEFINITION OF CALCULATIONS
4-2	DIESEL GENERATOR SPLIT FRACTION TRANSLATION TABLE FOR THE SCHEDULED MAINTENANCE QUANTIFICATION
4-3	DIESEL GENERATOR SPLIT FRACTION VALUES
4-4	ABSOLUTE FREQUENCY RESULTS
4-5	RELATIVE RISK RESULTS
5-1	DIABLO CANYON DIESEL GENERATOR RELIABILITY DATA BASE
5-2	FAULT TREE QUANTIFICATION RESULTS
5-3	DOMINANT CONTRIBUTORS TO DG 1-1 UNAVAILABILITY
5-4	RELIABILITY CASES ANALYZED
5-5	FRANTIC COMPONENT INPUTS
5-6	FRANTIC RESULTS
5-7	DIESEL GENERATOR OUTAGE TIMES
5-8	RELATIVE RISK ANALYSIS RESULTS
5-9	AVERAGE ANNUAL RISK RESULTS
6-1	ANALYTICAL RESULTS



**DIABLO CANYON POWER PLANT
DIESEL GENERATOR
ALLOWED OUTAGE TIME STUDY**

1.0 SUMMARY

PG&E has previously implemented activities to improve Diesel Generator (DG) reliability at Diablo Canyon Power Plant (DCPP). These activities involve preventive maintenance procedures, personnel training, and use of industry, NRC, and vendor DG reliability improvement recommendations. As part of this effort, PG&E has performed this study in support of the DGs' allowed outage time (AOT) revision. This report documents this study and provides the technical basis for License Amendment Request (LAR) 89-05, requesting a revision to the DCPP Technical Specifications (Ref. 1) for the emergency onsite power system DGs.

There are currently five DGs at DCPP Units 1 and 2. However, PG&E is planning to install a sixth DG by the fourth refueling outage of Unit 2 (scheduled for October 1991) as part of this DG reliability improvement effort and has committed significant resources to this effort. This study demonstrates that a 7-day AOT is both acceptable and practical for DCPP. This study focuses on the assessment of two issues: (1) the appropriateness of a 7-day AOT for the purposes of unplanned maintenance for the current five DG and future six DG configurations and (2) the impact of a 7-day AOT for preplanned Technical Specification required maintenance activities.

Two probabilistic evaluation methods were used to assess the benefits and impacts of the proposed AOT revision. Since PG&E had recently completed development of its plant specific PRA, it was used to assess absolute and relative risk values for these two issues. However, since the PRA calculates time-average risk values, a second method, a reliability analysis, was used to assess time dependent risk involved in an AOT for unplanned maintenance, which requires testing of the remaining DGs. Such time-dependent effects are important in the evaluation of the effect of testing on the availability and reliability of remaining DGs. Such a time-dependent methodology has been recently reviewed and approved by the NRC for Brunswick (Ref. 2).



Both of these methods were used to evaluate a relative risk criterion which was developed by Brookhaven National Laboratory, NUREG/CR-3082, "Probabilistic Approaches to LCO's and Surveillance Requirements for Standby Safety Systems," dated November, 1982 (Ref. 3), and which was previously reviewed and accepted by the NRC (Ref. 2). This criterion defines a relative risk ratio that should be less than one; that is, the risk level during the AOT is less than the risk level during the non-AOT period when all DGs are in their normal standby condition while the plant is in Modes 1 through 4.

The first method, referred to in this study as the probabilistic risk analysis, makes extensive use of the Diablo Canyon Probabilistic Risk Assessment (DCPRA) models developed for the DCPD Long Term Seismic Program (Ref. 4). The DCPRA is a full scope Level 1 risk assessment which includes both internal and external initiating events. For this study, use is made of the dominant accident sequence model to compute the impact of DG AOT changes on plant risk; risk is presented in terms of core damage frequency, and also relative risk. The probabilistic risk analysis provides a method to assess the relative risk and absolute risk (core damage frequency) associated with a 72-hour AOT and a 7-day AOT while accounting for both planned and unplanned maintenance. Acceptability is demonstrated by small changes in absolute risk and maintaining a relative risk ratio less than unity. Additionally, the results trend consistently with the reliability analysis results.

The second method is referred to as the reliability analysis. This reliability analysis is compatible with the probabilistic risk analysis by basing the reliability analysis on the DCPRA DG fault tree models and plant specific data. The DG fault trees in the reliability analysis have been extended beyond what is typically modeled in PRA DG system fault trees to include diesel subsystems as well as support systems. Thus this reliability model with its DG fault trees is designed to be a stand-alone model. In addition, the mission times are representative of current regulatory requirements for the Station Blackout Rule. The reliability analysis is similar to the Carolina Power & Light Company's (CP&L's) Brunswick time dependent, approach (Ref. 5). This approach has been previously approved by the NRC for Brunswick (Ref. 2).



In this study both the risk and reliability methods evaluate three cases for their impact on plant risk and reliability. The three cases consider the current plant configuration and the future plant configuration with six DGs and the effect of different AOTs for planned and unplanned maintenance activities. The risk analysis approach addresses both planned and unplanned maintenance, whereas the reliability approach addresses unplanned maintenance.

The base case considers the existing plant configuration with a 72-hour AOT on all DGs to perform unplanned maintenance. Once every 18 months, during the refueling outage of one unit, planned maintenance on the swing DG occurs with the other unit at power. Accomplishing this maintenance with a 72-hour AOT requires multiple outages. Operational experience indicates that four outages of approximately 72 hours each have been required for a planned maintenance activity that required approximately 10 days total to complete. Thus, the baseline duration for this maintenance is 10 days.

The second case is similar to the first except that the DGs are subject to a 7-day AOT for unplanned maintenance. Planned maintenance on the swing DG is also performed; however, with the longer AOT, swing DG maintenance can be performed within the 7-day AOT and multiple outages are not required.

The third case considers the planned plant configuration with six DGs and a 7-day AOT. Technical Specification required maintenance during power operation is no longer applicable since this maintenance can now be performed without affecting the other unit.

Using the relative risk criterion, both of the analyses methods confirm the appropriateness of a 7-day AOT for the purposes of performing unplanned maintenance for both the five and six DG configurations. In particular, the relative risk ratios for all cases were determined to be significantly less than one, that is, the risk level during the DG AOT was found to be significantly less than the risk level during the non-AOT period where all DGs are in a normal standby condition.



Further, the risk-based PRA evaluation also demonstrated that there is negligible change in risk associated with a 7-day AOT over a 72-hour AOT and there are quantitative benefits in performing Technical Specification required maintenance with a 7-day AOT. The PRA and the reliability evaluations both determined that addition of the sixth DG will have a positive impact on risk over the life of the plant. In total, quantitative and qualitative analyses confirm that the 7-day AOT along with addition of the sixth DG will improve overall DG system reliability, and will provide both short term and long term benefits to the safe operation of the plant.



2.0 INTRODUCTION

This report provides the information required to support a revision to the DCPD Technical Specifications for the emergency onsite power system DGs. The proposed revision is to change Technical Specification 3.8.1.1's AOT to seven days. The DCPD Technical Specification revision is supported by conclusions developed from the probabilistic risk analysis and the reliability analysis. System descriptions are provided for completeness. Additionally, the background and rationale for this revision are provided below. PG&E was assisted in the preparation of this report by Westinghouse Electric Corporation and Pickard, Lowe & Garrick, Inc.

2.1 BACKGROUND

The purpose of the preventive maintenance program is to minimize the likelihood of DG failures by maintaining the DGs in the best possible condition and thereby increasing DG reliability. The preventive maintenance procedures were developed using ALCO's guidelines "Engine Maintenance Schedule for Standby Engines (MI-11272)." Also, the development of the procedures considered DCPD operating experience. When a DG failure occurs, an investigation is conducted to determine the cause of the failure. When it is determined that additional maintenance would help prevent recurrence of the failure, the maintenance is incorporated into the procedures. Additionally, vendor information on preventive maintenance, surveillance programs and procedures is reviewed for application at DCPD.

Another aspect of the DG reliability improvement effort is personnel training. As part of the purchase of the sixth DG, a training program will be provided for PG&E maintenance personnel and engineers. Training has been provided by the DG supplier for PG&E maintenance personnel and engineers. Also, personnel have been involved in industry DG reliability improvement meetings, such as the EPRI Seminar in August 1987 on Diesel Generator Operations, Maintenance and Testing.

The program also uses industry, NRC, and vendor DG reliability improvement recommendations. For example, after reviewing NUREG/CR-0660 "Enhancement of Onsite Emergency Diesel Generator Reliability," PG&E found many of the recommendations included in this report were already implemented at DCPD, such as prelubing of the DG and personnel training.



PG&E has also implemented the recommendations of Generic Letter 84-15 (Ref. 6). Two of the concerns raised in Generic Letter 84-15 were cold fast starting of the DG and excessive testing. The DCPD Technical Specifications were revised to allow gradual acceleration and/or gradual loading of the DGs. Further, the Technical Specifications were revised to minimize the number of DG starts per LAR 85-12 (Ref. 7).

PG&E has also modified the DGs to improve reliability. Two examples of these modifications are the fuel oil priming system and the compressed air filtration and dehumidification system. The fuel oil priming system was added to enhance the starting reliability of the DGs. The compressed air filtration and dehumidification system was added to improve reliability of the solenoid valves and air motors by reducing corrosion. The air system modifications also improve DG starting reliability.

In addition, PG&E plans to install a sixth DG to the existing emergency DG system at DCPD. The sixth DG will also be an ALCO DG like the five existing DGs. With the sixth DG installed and operable, DCPD will have three dedicated DG for each unit rather than the current five DG configuration, with a swing DG, as discussed below. This arrangement will simplify the operation of the system. The net benefit of this arrangement will be an increase of maintenance scheduling efficiency and greater flexibility of plant operation.

As part of this effort to enhance the onsite power system, PG&E has also performed detailed risk and reliability analyses to determine an appropriate AOT for the DGs. These studies demonstrated that a 7-day AOT is appropriate for the DG Technical Specification. Accordingly, LAR 89-05 will request that a 7-day AOT be specified for Technical Specification 3.8.1.1 Action Statement b.

The current DCPD Technical Specifications provide a 72-hour AOT when a DG in a unit is inoperable with the unit in Modes 1 through 4. If a DG is taken out of service (becomes inoperable), the operability of the AC offsite sources must be demonstrated by performing surveillance requirement tests within one hour and at least once per eight hours thereafter. If the DG became inoperable due to a cause other than preventive maintenance or testing, the operability of the remaining DGs must be demonstrated within 24 hours (regardless of when the inoperable DG is




restored to operable status). Currently, the inoperable DG must be restored to operable status within the 72-hour AOT or action must be initiated to place the unit in Mode 5, where the subject Limiting Condition for Operation (LCO) no longer applies.

The proposed change to the Technical Specifications is to obtain a 7-day AOT so that corrective and preventive maintenance and inspection and post maintenance operability testing can be performed. PG&E has determined that in some instances, if a DG became inoperable, the maintenance, inspection, and operability testing can not be completed within the current 72-hour AOT.

Some examples of the maintenance, inspection, and acceptance testing of the DGs are as follows: inspection of the air inlet and exhaust manifolds; replacing the fuel pump drive belt; draining and inspecting the fuel oil day tank; inspecting the turbocharger; reconditioning the air-start motor; and disassembling the generator for cleaning and inspection. Most of this work could be performed during the existing 72-hour AOT. However, generator disassembly for cleaning and inspection, and subsequent reassembly, can require up to seven days to complete. Previously, rotational 72-hour maintenance periods had been utilized to perform this work requiring DG 1-3 to be re-assembled and tested several times to meet the 72-hour AOT. For example, during the Unit 1 first refueling outage, PG&E obtained a one-time license amendment, LAR 85-15 (Ref. 8) to perform maintenance on DG 1-3 for a period of 10 days. However, during the Unit 1 second refueling outage it was necessary to take DG 1-3 out of service for approximately 10 days, using four 72-hour AOT periods. Based on this experience and additional work scope for future outages, a 7-day AOT is required.

The 7-day AOT will improve DG reliability since technicians who perform the repair, maintenance, inspection and acceptance testing can perform such tasks under a less restrictive AOT. For activities that take more than 72 hours to complete, such as disassembly-inspection-reassembly of a DG, technicians will be able to perform the work within a 7-day AOT period without having to resort to a rotational 72-hour AOT. Therefore, the potential for personnel errors will be minimized by using a single AOT as apposed to several, rotational AOTs requiring disassembly and reassembly. As such, the 7-day AOT should improve the overall quality of repair,



maintenance and post-maintenance testing. This also allows the most experience maintenance personnel to perform the work. Additionally, DG failures, which could not be repaired within the 72-hour AOT but could be repaired within a 7-day AOT, will not cause unnecessary plant transients.

2.2 SCOPE OF ANALYSIS

The scope of both the probabilistic risk analysis and the reliability analysis is presented in the following paragraphs. Both of these analyses evaluate annual and relative risks. The relative risk is defined by the criterion in NUREG/CR-3082 (Ref. 3), "Probabilistic Approaches to LCOs and Surveillance Requirements for Standby Safety Systems," as follows:

"If the risk due to a DG AOT during an LCO is less than the risk during a baseline (non-LCO) period, then the risk due to the AOT is considered acceptable."

This criterion explicitly constrains the DG AOT duration by requiring that the risk during the AOT be less than the risk when not in the AOT period.

A. PRA Work Scope

Figure 2-1 shows a general flow chart for the PRA analysis approach. In particular, the analysis involves the following tasks:

1. Define impact of changing DG AOT on the DCPRA model (for both seismic and non-seismic events) and the impact of adding a sixth DG.
2. Utilize existing DCPRA DG model (with modifications as necessary) to re-evaluate DG failure probabilities for various sensitivity cases.
3. Evaluate impact on DCPRA model due to performing scheduled maintenance on DG 1-3 during power operation.
4. Collect and analyze maintenance data for plants with 7-day AOTs.



5. Quantify system and plant models to evaluate changes in core damage frequency.
6. Evaluate the absolute risk and relative risk based on core damage results.

B. Reliability Work Scope

Figure 2-2 shows a general flow chart for the reliability analysis approach. The specific reliability analysis tasks are defined below:

1. Qualitatively analyze the benefits of an AOT extension.
2. Define boundary conditions and acceptance criteria. This includes setting the success criteria and the mission times.
3. Collect and evaluate plant specific DG data. DCPD data are included for the 72-hour AOT cases. Additionally, data from a 7-day AOT plant (Palisades) which has the same DG manufacturer as DCPD, are included for the DG failure rates associated with the 7-day AOT cases.
4. Develop DG fault tree models for a single diesel. The models are quantified to determine the unavailability of a DG. The results are utilized below.
5. The reliability analysis develops fault tree models for the following cases:
 - a. Loss of Offsite Power (LOOP), and
 - b. Loss of Coolant Accident (LOCA) in one unit with a LOOP.

The DG unavailability is incorporated into the fault tree case models. The models are logically reduced to generate minimal cutsets representing DG unavailability at either unit. These cutsets are loaded into the FRANTIC-ABC computer code (Ref. 9). The FRANTIC-ABC code uses time-dependent models to calculate an average and a maximum unavailability for each case.



6. Calculate risk levels for the current 72-hour AOT and the proposed 7-day AOT. Risk is measured using two approaches for the licensing design basis; relative risk and average annual risk.


Both of the approaches were used to evaluate the following cases:

- 72-hour AOT for the five DG configuration, with the risk analysis addressing a total of 10 days for the outage (i.e., several 72-hour AOT periods),
- 7-day AOT for the five DG configuration, and
- 7-day AOT for the planned six DG configuration.

The detailed modeling and analyses, along with the results, are documented in Chapters 4 through 6 of this report. The conclusions of these evaluations are provided in Chapter 7.


PG&E is planning to install a sixth DG by the fourth refueling outage of Unit 2 and has committed significant resources to this effort. The analyses documented in this report include consideration of both the current five diesel configuration as well as the planned six diesel configuration. The 7-day AOT will be applicable to all DGs of both the current five and planned six DG configurations once LAR 89-05 is approved.





**FIGURE 2-1
PROBABILISTIC RISK ASSESSMENT APPROACH**





**FIGURE 2-2
RELIABILITY ANALYSIS APPROACH**





3.0 ELECTRIC POWER SYSTEM

This section describes the AC power system for DCPD and the design function, system operation, configuration, and support systems required for the operation of the DGs.

3.1 ELECTRIC POWER SYSTEM FUNCTION

The electrical power system at DCPD is designed to provide electric power to the necessary plant electrical equipment under all combinations of plant operation and electric power source availability. The various subsystems provide protection for electrical equipment during faulted conditions while maintaining maximum system flexibility and reliability.

The 4.16 kV distribution system supplies power to three vital buses supporting two trains of Engineered Safety Features (ESF) equipment. Any two of the three buses are adequate to serve the minimum required ESF for accident mitigation. The vital buses can also be cross-connected by operators so that the DGs can serve the loads normally connected to other buses; procedures already exist for such actions. Any two of the DGs and their associated vital buses per unit can supply sufficient power for operation of the required safeguards equipment for a design basis LOCA event coincident with a LOOP. It should be noted that fewer loads are required for mitigation of a LOOP than those required for a LOCA/LOOP, and that there is a substantially smaller likelihood of the LOCA/LOOP combination. In addition, the swing DG is designed to automatically align to the unit which first receives a safety injection signal (SIS).

The safety systems requiring electric power are:

1. Emergency core cooling system (ECCS) including centrifugal charging pumps, residual heat removal pumps, safety injection pumps, and motor driven auxiliary feedwater pumps,
2. Containment spray pumps,
3. Containment ventilation system including five fan cooler units,



4. Auxiliary saltwater system (ASWS),
5. Component cooling water system (CCWS), and
6. Chemical and volume control system (CVCS).

3.2 ELECTRIC POWER SYSTEM DESCRIPTION

DCPP has two offsite power sources, a 230 kV transmission system and a 500 kV transmission system. The plant is connected to the 230 kV transmission system for startup and standby power (which has two incoming transmission lines, one from the Morro Bay Power Plant and the other from the Mesa Substation), and to the 500 kV system for transmission of the plant's power output. The 500 kV connection also provides a backup offsite power source to the plant when the main generator and 230 kV power supplies are not available (Ref. 10 & 11). The offsite power system is shown in Figure 3-1.

The onsite power systems consist of all sources of electric power and their associated distribution systems. Included are the main generators, emergency DGs, and the vital and non-vital station batteries.

The system of interest in this study is the vital 4.16 kV system. The 4.16 kV loads are divided into five groups; two of these groups are not vital to the ESF buses and are connected to non-vital 4.16 kV Buses D and E. Each of the non-vital buses has two sources: one from the main generator and one from the 230 kV transmission system. The other three load groups are Class 1E and are connected to 4.16 kV vital buses F, G, and H. Each of these buses has three sources: two being the same as the non-vital buses and the third a diesel-driven generator. The loads on the vital buses are listed in Table 3-1.

The DCPP onsite power system consists of five DGs. Two DGs are dedicated to each unit. An additional DG is shared between units. This DG (DG 1-3) is referred to as the swing DG. The individual DGs are physically isolated from each other and from other equipment. DGs 1-1, 1-2 and 1-3 are physically located in Unit 1, while DGs 2-1 and 2-2 are located in Unit 2. Each DG supplies power only to its associated bus.



When the sixth DG is installed, it will be dedicated to Unit 2, and DG 1-3 will be dedicated to Unit 1 only.

3.3 ELECTRIC POWER SYSTEM OPERATION

Auxiliary power for normal plant operation is supplied by each unit's main generators through the unit auxiliary transformers, except during startups and shutdowns. Auxiliary power for startups and shutdowns is supplied by offsite power sources. If offsite power is unavailable, auxiliary shutdown power is furnished by the emergency DGs.

In the event of a loss of electrical power from the main generator, due to a unit trip, a safeguard signal, or a loss of voltage on the bus, the vital 4.16 kV buses are automatically disconnected from the main generator as a source. If power is available from the offsite standby source, the vital 4.16 kV buses are transferred to this source automatically after a short delay to allow for voltage decay on the motors that were running.

If bus voltage is not restored within 1 second following a loss of startup power, all of the DGs for the affected unit are started automatically and brought to a condition ready for loading. If only one bus is affected, then only the DG associated with that bus is started automatically.

The DGs are started automatically by the following signals:

1. A SIS, or
2. A 4.16 kV bus undervoltage (on respective bus) due to:
 - a. Less than 3600 V for greater than 9 seconds, or
 - b. Loss of startup feeder voltage for greater than 1 second, or
 - c. Loss of 4.16 kV bus voltage for 0.8 seconds.

Should there be a complete LOOP, when the DGs have reached breaker close-in voltage, all circuit breakers from the normal and offsite sources to these vital 4.16 kV buses are given a trip signal independently to make sure they are open (the



expected condition at this point). The 4.16 kV circuit breaker for each DG then closes automatically to restore power to the vital 4.16 kV bus, and consequently the 480 V and 120 V buses. Following the loading of the DGs onto the vital buses, additional individual loads are put into operation in a staggered sequence to reduce the effects of momentary loads and motor starting on the DGs.

3.4 DIESEL GENERATORS

The DG units are 2750 kW, 18 cylinder DGs supplied by ALCO Engine Division of White Industrial Power, Inc. Each DG supplies a vital bus, with the swing DG supplying either Unit 1 or Unit 2 vital bus F.

Each DG unit consists of a self-contained diesel engine directly connected to an alternating current generator. Each DG has its own fuel oil day tank along with its own lube oil, radiator cooled and self-contained jacket cooling water system, ventilation, dual-train starting air system and associated instrumentation and controls.

The DG is started by the engine start relay which energizes two solenoids that allow the starting air system to crank the diesel engine. When the DG start has been verified by jacket water pressure, the solenoids are deenergized, and the generator field is flashed. When proper speed and voltage have been reached, the DG feeder breaker closes onto the 4.16 kV vital bus, energizing the 480 V bus, if an undervoltage condition exists. Some permanently connected loads are energized immediately as the 480 V bus is energized. The remaining vital loads are connected at time intervals determined by individual load timers.

Fuel Oil System

The fuel oil system stores and supplies the DGs with fuel oil. Two 40,000-gallon fuel oil storage tanks with associated transfer pumps are shared by the diesels of both units. Each fuel oil transfer pump can be powered from a Unit 1 or Unit 2 vital 480 V AC power. Air-operated level control valves (LCVs) on the tanks regulate the level of fuel in the day tanks. Each diesel has its own day tank that supplies its respective engine-driven fuel oil booster pump. This booster pump maintains oil pressure in a



common header, which supplies fuel to the individual fuel oil injection pumps. There is one fuel oil injection pump and fuel injector per cylinder. These 18 injection pumps and injectors are the final delivery portion of the fuel oil system.

Lube Oil System

The lube oil system for each engine is entirely contained on that engine's baseplate. During engine operation, all required lubricating oil is drawn from the engine crankcase through a shaft-mounted oil pump to a lubricating oil filter with a built-in pressure relief device to bypass lubricating oil in the event that the filter becomes excessively dirty. The oil is then cooled in the jacket water-cooled heat exchanger and returned to the engine bearings through a duplex strainer. If the oil pressure drops below 60 psig a low oil pressure alarm is generated. If the oil pressure drops below 40 psig, the diesel will automatically shut down, and the generator breaker will trip open.

There is a motor-driven, precirculating lube oil pump that also takes suction from the crankcase reservoir. This pump is normally in continuous operation when the diesel is shut down to coat the critical parts of the engine with oil, thus reducing wear during the engine start period. When the diesel is started, the pump automatically stops when the engine jacket water pressure exceeds 10 psig. This pump is not necessary for successful DG operation.

The prelube pump does not function as an automatic back-up for the engine-driven lube oil pump, since the prelube pump will not automatically start on decreasing oil pressure.

Electric lube oil heaters, located in the recirculating pump's discharge path, maintain lube oil temperature at 90°-110°F to eliminate engine wear during startup.

From the heat exchanger, lube oil passes through a duplex lube oil strainer before reentering the engine and turbocharger. A pressure-regulating valve, located between the strainer and the heat exchanger, maintains engine header pressure



below 85 psig by bypassing a portion of the oil flow to the engine sump. Once the lube oil has completed its path through the engine, it is collected in the lube oil sump to be picked up by the pump again.

Jacket Cooling Water System

A closed loop jacket cooling water system is provided for each of the five DG engines. The jacket cooling water system controls the operating temperature of the diesel engine by removing diesel engine heat. The jacket water pump takes water from the lube oil cooler and the turbocharger aftercooler. Flow control orifices are used to ensure proper amounts of water flow through each heat exchanger. To compensate for any losses in the system and to account for thermal expansion, there is a 1-inch line connected from a 50-gallon expansion tank to the suction of the jacket water pump. The pump discharges water through the engine block and turbocharger to a common return line. The pump discharge line goes to a three-way, thermostatically controlled valve set to maintain engine water temperature at 170°F. If the engine discharge water temperature reaches the setpoint, the valve automatically directs the system water through the jacket water radiator where it is cooled by forced air. The jacket water pump is driven by the same crankshaft drive gear used to drive the lube oil pump. There are four pressure switches located on the discharge of the jacket water pump. Two of the switches supply signals to the starting circuitry. The other two provide a permissive indicating the engine is shutdown and as such input into the starting circuitry for the precirculating lube oil pumps and crankcase exhausters.

Cooling air is ambient air drawn by the fan from outside the building into the radiator-fan portion of the engine generator compartment. This closed system allows the DG unit to function in a self-contained manner, independent of outside cooling water systems and electric motor-driven fans.

Two sets of electric block heaters maintain the jacket water temperature between 90° and 110°F when the engine is in the standby condition.






Starting Air System

Each diesel engine is provided with two separate air-start systems. Each of the two air-start systems together with the turbo-assist air system is capable of starting the generator in less than 10-seconds. The starting air system supplies compressed air to the starting air motors. Starting air is supplied by two motor-driven reciprocating air compressors, pumped through individual air drying systems and stored in two starting air receiver tanks. Each air drying system consists of an aftercooler, a moisture separator, a prefilter, an oil filter, and an air dryer unit. It is important that moisture and oil be removed from the air so that they do not accumulate in the receiver tanks. This could cause the diesel to become inoperable.

Each receiver has the capability to perform several consecutive starts without recharging for a total of 45 seconds of cranking.



Each DG is equipped with four starting air motors. Each starting air receiver supplies two starting air motors. Air from receivers is fed through regulator valves and up to the starting air system solenoid valves. At the initiation of a start, the solenoid operated valves open, supplying air to the motors. The air supply is shut off after initiation has been sensed by pressure switches located on the discharge of the jacket water pump.

The starting air system also supplies air to the LCVs of the diesel fuel oil day tanks.

Turbo-Assist Air System

Each diesel engine is equipped with an engine turbocharger boost system. The turbocharger boost system serves two functions: it aids in acceleration of the large rotating mass of the turbocharger and it provides extra air to the engine to improve combustion during acceleration. The system consists of one turbo-air compressor, one starting air receiver tank, and an air dryer. Air is supplied from the receivers to the turbocharger unit on the diesel through two solenoid-operated shutoff valves, one in each line.



The diesel engine turbo-assist air controller is a solid-state device that controls the turbo-assist air supply in order to prevent a critical loss of speed when a sudden, large load increase occurs.

Crankcase Exhauster

Each diesel engine is equipped with two small, motor-driven crankcase exhauster fans. The fans are automatically started when jacket water pressure exceeds 10 psig. Their purpose is to prevent an overpressure condition in the crankcase by removing any vapors that may be present.


Engine Governor/Speed Control

The diesel uses a Woodward EG governor which controls the fuel delivery and therefore the engine's speed and generator output frequency to a predetermined value. The governor has electrical and mechanical controls both of which act through a hydraulic actuator to control the fuel supply.

The electrical section of the governor senses the generator speed & load and converts this information to a proportional change which acts upon the electrical portion of the hydraulic governor.

The mechanical section of the hydraulic actuator consists of centrifugal flyweights, linkage, and valves. The position of the flyweights changes with engine speed. This in turn moves linkages which, through the internal control oil system, convert the mechanical movement to a change in the fuel delivery rate. The mechanical control is generally set higher than the electrical control so that it becomes a back-up if the electrical control fails. When the electrical control fails, it goes to the full fuel position. As engine speed increases, the flyweight will take over before an overspeed condition occurs.

If both the mechanical and electrical sections were to fail, the engine is equipped with an automatic overspeed tripping device, consisting of a spring-loaded plunger that, during normal operation, is held within the carrier. When centrifugal force is great enough to overcome spring pressure (overspeed condition of 1085 to 1130 rpm), the plunger is forced outward and strikes a trip lever, releasing the spring-



loaded reset shaft. This shaft is directly coupled to the fuel pump control shaft. As the reset shaft spring unwinds, it causes rotation of the fuel pump control shaft, which moves the fuel pump racks to a shutoff position. An overtravel mechanism at the governor end allows the overspeed device to return the racks to OFF, even though the governor may remain at the full fuel demand position. There is no way for the operator to bypass this overspeed trip.

Controls and Instrumentation

Controls for engine generator functions are both local at the engine generator compartment and remote in the main control room. Each of the units may be manually started or stopped from either location to facilitate periodic testing. Each DG is normally controlled from the control room. A two-position local-remote switch is located at each DG to allow control from either the control room or the DG compartment. Each DG is provided with two independent start control circuits powered from three vital batteries in each Unit for redundancy.

The DGs are instrumented to monitor the important parameters and alarm abnormal conditions, both locally at the DG compartment and remotely in the control room. A listing of all alarms is provided in Table 3-2.

If the engine generator unit is started automatically on loss of standby power, safety injection, or both, the engine trip or shutdown functions are limited to engine overspeed, engine low lube oil pressure and generator current differential. The autostart signal initiates alarms in both the control room and the DG room.

The engine overspeed trip is a mechanical device relying on centrifugal force to release a spring that, by mechanical action alone, stops the flow of fuel and shuts down the engine.

Diesel Generator Output Breaker

The DG output breaker is the interface component between the DGs and the 4.16 kV vital AC bus distribution system. The DG output breakers (Figure 3-1) are listed as follows:



DG 1-1	Breaker 52-HH-7	DG 2-1	Breaker 52-HG-5
DG 1-2	Breaker 52-HG-5	DG 2-2	Breaker 52-HH-7
DG 1-3	Breaker 52-HF-7(U-1)	DG 1-3	Breaker 52-HF-7(U-2)

These breakers are controlled automatically or manually based on control board switch positions. The DG output breaker will shut automatically regardless of switch positions if all the following conditions are met:

1. The auxiliary feeder breaker is open,
2. The startup feeder breaker is open,
3. The auto interlock relay is energized,
4. The 4.16 kV undervoltage timer is timed out, and
5. The DG is at speed and voltage.

The operation of the output breaker for the swing DG requires special mention. Since this DG can feed both units, special precautions are taken to ensure that it preferentially feeds the first unit to receive a SIS or bus F undervoltage. Should a SIS on Unit 1 be received, the Unit 2 generator output breaker is prohibited from shutting on a 4.16 kV bus F undervoltage with no SIS present. However, if there is an undervoltage on Unit 2 bus F concurrently with a Unit 2 SIS, the Unit 2 output breaker will shut and the Unit 1 output breaker is prohibited from shutting regardless of the condition of bus F.

If the Unit 2 DG output breaker is already shut on a non-SI condition and a Unit 1 SIS is received, the Unit 2 DG output breaker will be tripped open. Should SIS be present on both units, the output breaker on the first unit to receive a 4.16 kV bus F undervoltage signal will automatically shut and stay shut regardless of subsequent conditions on the other unit's 4.16 kV bus F. When the sixth DG is added, the swing DG (1-3) will be dedicated to Unit 1 only, and the sixth DG will be dedicated to Unit 2.

Diesel Generator Support Systems

The DGs require 125 V DC power to start and control the operation of the diesels. The following are the normal and emergency power supplies for each DG's controls:



DG 1-1 (normal)	72-1313 Panel 13
DG 1-1 (alternate)	72-1219 Panel 12
DG 1-2 (normal)	72-1214 Panel 12
DG 1-2 (alternate)	72-1115 Panel 11
DG 2-1 (normal)	72-2214 Panel 22
DG 2-1 (alternate)	72-2115 Panel 21
DG 2-2 (normal)	72-2313 Panel 23
DG 2-2 (alternate)	72-2219 Panel 22
DG 1-3 (normal)	72-1116 Panel 11
DG 1-3 (alternate)	72-1318 Panel 13
Unit 1 4.16 kV bus F	72-1113 Panel 11
Unit 1 4.16 kV bus G	72-1213 Panel 12
Unit 1 4.16 kV bus H	72-1314 Panel 13
Unit 2 4.16 kV bus F	72-2113 Panel 21
Unit 2 4.16 kV bus G	72-2213 Panel 22
Unit 2 4.16 kV bus H	72-2314 Panel 23

The following is a list of 125 V DC loads for the DGs:

1. Diesel engine control panel
2. Generator regulator and exciter
3. Generator protection relays
4. Diesel engine protection relays
5. Output breaker controls and protection
6. Auto transfer and start circuits

480 V AC is required to supply power to the air compressors for the DG air start systems. There are two independent systems per diesel (trains A and B) with separate power supplies:

DG 1-1 compressor	train A 480 V 1H
	train B 480 V 1G
DG 1-2 compressor	train A 480 V 1G
	train B 480 V 1F





DG 1-3 compressor	train A 480 V 1F with backup 2F train B 480 V 1H with backup 2H
DG 2-1 compressor	train A 480 V 2G train B 480 V 2F
DG 2-2 compressor	train A 480 V 2H train B 480 V 2G

3.5 SUMMARY OF STATION BLACKOUT

A station blackout (SBO) evaluation was performed for DCPD (Ref. 12) which assessed the ability of the plant to cope with a station blackout event as required by 10 CFR 50.63 (Ref. 13). The assessment was conducted following the guidelines and technical bases contained in NUMARC 87-00, "Guidelines and Technical Bases for NUMARC Initiatives Addressing Station Blackout at Light Water Reactors."

Since DCPD is a multi-unit site with normally dedicated emergency AC power sources, where the combination of AC sources exceeds the minimum redundancy requirements for normal safe shutdown for all units, it is assumed that only one unit experiences a SBO while the other experiences a single active failure in its process of coming to safe shutdown conditions.

DCPD has never experienced a grid-related LOOP. The results of the SBO evaluation determined that the current five diesel configuration DCPD is required for a coping duration of four hours. The capacity of each of the six existing Class 1E station batteries at DCPD was determined to be adequate to supply the required loads during a four hour SBO event assuming no load stripping. For the planned six diesel configuration, preliminary analyses indicated that the coping duration is two hours.





TABLE 3-1

4.16 kV VITAL BUS AND ESF LOADS

BUS	DG	VITAL SAFETY-RELATED LOADS
F	1-3 (swing)	Centrifugal Charging Pump No. 1 Safety Injection Pump No. 1 Containment Fan Cooler Unit No. 2 Containment Fan Cooler Unit No. 1 Component Cooling Water Pump No. 1 Auxiliary Saltwater Pump No. 1 Auxiliary Feedwater Pump No. 3
G	1-2 (2-1)	Centrifugal Charging Pump No. 2 Residual Heat Removal Pump No. 1 Containment Fan Cooler Unit No. 3 Containment Fan Cooler Unit No. 5 Component Cooling Water Pump No. 2 Auxiliary Saltwater Pump No. 2 Containment Spray Pump No. 1
H	1-1 (2-2)	Safety Injection Pump No. 2 Residual Heat Removal Pump No. 2 Containment Fan Cooler Unit No. 4 Component Cooling Water Pump No. 3 Auxiliary Feedwater Pump No. 2 Containment Spray Pump No. 2





TABLE 3-2
DIESEL GENERATOR ALARMS

Annunciator

1. Engine generator on local control
2. Generator circuit breaker on local control
3. DC control undervoltage
 - a. Engine generator control
 - b. Circuit breaker control
4. Engine starting air pressure - low
5. Engine fails to start (overcrank)
6. Engine lube oil system trouble
 - a. Low lube oil pressure
 - b. Low lube oil level
 - c. High lube oil filter differential pressure
 - d. High lube oil temperature
 - e. Low lube oil temperature
 - f. Precirculating lube oil pump failure
7. Engine cooling system trouble
 - a. High jacket water temperature





TABLE 3-2 (Cont)
DIESEL GENERATOR ALARMS

Annunciator

- b. Low jacket water level
- c. High compartment air temperature
- d. High radiator discharge air temperature.

Annunciator


- 8. Engine fuel oil system trouble
 - a. High/low engine fuel oil tank level
 - b. High/low storage fuel oil tank level
 - c. Fuel oil transfer pump overcurrent
 - d. Low engine fuel oil priming tank level
- 9. Engine crankcase vacuum trouble
- 10. Generator stator temperature - high
- 11. Ground overcurrent
- 12. Generator negative sequence
- 13. Engine trip (shutdown relay tripped)
- 14. Engine generator circuit breaker trip



TABLE 3-2 (Cont)
DIESEL GENERATOR ALARMS

15. Auxiliaries undervoltage
16. Reverse power, loss of field, and overcurrent protection cut-in








FIGURE 3-1
DIABLO CANYON ELECTRIC POWER SYSTEM



4.0 PROBABILISTIC RISK ANALYSIS

This chapter describes the risk assessment of alternative AOTs for different DG configurations at DCP. The risk assessment is performed at each of three impact levels; i.e, the data level, the systems level, and the combined sequence frequency or core damage frequency level. For the purposes of this assessment, the risk results are provided in terms of the total (seismic and non-seismic) core damage frequency for Diablo Canyon Unit 1. Both absolute and relative risk measures are computed and presented. The absolute risk is the annual core damage frequency. The relative risk is the ratio of the risk of core damage during the AOT to the risk of core damage between DG outages. This ratio provides a measure of the change in the core damage frequency during the time a DG is inoperable compared to the time when all plant DGs are operable. Both the absolute and relative risk measures are described in NUREG/CR-3082 (Ref. 3). Relative risk ratios are assumed to be acceptable if they are less than unity; that is, the risk incurred during the AOT is less than the risk when not in the AOT (when all the DGs are operable) while the plant is in Modes 1 through 4. The absolute change in the mean core damage frequency is assumed to be acceptable if the change is small compared to the overall uncertainty in the core damage frequency.

The analysis makes extensive use of the DCPRA models developed previously in the Diablo Canyon Long Term Seismic Program (Ref. 14). Both seismic and non-seismic initiating events are analyzed. Chapter 6 of Reference 14 provides a summary of the DCPRA models and results. The current effort also makes use of the substantial DCPRA supporting documentation that had been previously submitted to the NRC.

The DCPRA is a full scope level 1 risk assessment. It includes an assessment of both internal and external initiating events; including an assessment of fires, floods and especially, seismic events. As a level 1 study, the DCPRA presents results in terms of the total core damage frequency. For the purposes of this study, use is made of the dominant sequence model from the DCPRA to compute the impact of changes to the AOT on plant risk. For the systems and data unaffected by such changes, results from the DCPRA are used as documented in Reference 14.

The DCPRA and the current study both present the risk for Unit 1 only. Unit 2 is sufficiently similar so that the Unit 1 risk is deemed to be applicable for Unit 2. For



systems shared between units (i.e., emergency AC power, control room ventilation, and auxiliary saltwater) both the DCPRA and the current study account for such interdependencies. For example, where appropriate, the swing DG is assumed aligned to Unit 1 only 50 percent of the time.

4.1 PRA CALCULATIONS

Several calculations are made to determine the impact on plant risk. The calculations are summarized in Table 4-1 and explained in more detail below. The calculations evaluate the current five DG configuration and the planned configuration with six DGs.

Two different AOTs are considered, the current 72-hour period for which a single diesel may be inoperable while the plant is at power, and a 7-day AOT. The five DG configuration is evaluated for both the 72-hour and 7-day AOTs. The six DG configuration is evaluated for the 7-day AOT only. An additional situation is considered for the current configuration in which no maintenance (scheduled or unscheduled) is performed on the DGs. This situation is used to compute the core damage frequency for the time period between DG outage events and is only used in the relative risk calculations. It is emphasized that this is not intended to represent an achievable risk level.

The scheduled 18 month maintenance interval (as prescribed by the DG manufacturer and required by the Technical Specifications) on the dedicated DGs are performed with the associated unit shutdown for both the five and six DG configurations. This also applies to the calculation for the six DG configuration. Contrary to what was previously assumed in the initial DCPRA model, recent operating experience has shown that scheduled maintenance on the swing DG occurs during Unit 1 refueling outages and with Unit 2 at power.

4.2 DATA ANALYSIS

In order to evaluate the impact of changing the AOT from 72-hours to 7-days, information is needed regarding maintenance practices under 7-day AOTs. The major source of information is industry data from plants which currently have 7-day



AOTs. This information is somewhat difficult to incorporate into the analysis because the maintenance philosophy at each plant can vary significantly.

Based upon maintenance practices at DCPD, the mean DG maintenance duration at DCPD is 10 hours, which is well below the current AOT of 72 hours. The fact that such a low maintenance duration has been achieved is indicative of PG&E's commitment to minimize DG unavailability.

In order to estimate how DG maintenance practices at DCPD might change under a 7-day AOT, the plant staff was consulted. It was the staff's consensus that very little change in the maintenance and operations practices and, consequently, the mean maintenance duration, is expected with a 7-day AOT. The following key observations support this conclusion:

- With a DG unavailable, the ability to perform maintenance on other systems is essentially precluded by Technical Specifications (discussed below). This restriction can have a significant impact on plant maintenance scheduling and planning. In general, other maintenance activities may be postponed until the DG is operable. Hence, there is significant motivation to return the DG to operable status as soon as possible.
- Technical Specification 3.8.1.1 Action Statement d, part 1 requires that if one DG is inoperable then verify that "All required systems, subsystems, trains, components and devices that depend on the remaining operable DG as a source of emergency power are also operable." If these conditions are not met, then action must be initiated within two hours to place the unit in Hot Standby. The plant maintenance staff must assure that this 2-hour Action Statement is met in order to avoid plant shutdown. Thus, unforeseen equipment failures provide incentive to complete any repair work on the inoperable DG.
- As part of its corporate goals and activities, PG&E has implemented the INPO performance indicator program. In this regard, PG&E management is committed to minimizing DG unavailability and monitors DG unavailability data to assure this commitment is implemented.



DG unavailability is a performance indicator parameter reported by PG&E to INPO on a quarterly basis and is reviewed by PG&E senior corporate and plant management. The data reported includes demand, start, load-run, out-of-service durations, and hour-of-operations data. This management commitment provides a further incentive to minimize DG unavailability time.

Based on these considerations, changing to a 7-day AOT is not expected to cause a significant increase in the mean DG maintenance duration. However, to use a conservative value, an increase of six hours is assumed. Thus, the mean maintenance duration would increase from 10 to 16 hours. Therefore, in the evaluation of the 7-day AOT, a mean DG maintenance duration of 16 hours is used.

Several other utilities in the nuclear industry have ALCO DGs and a 7-day AOT. The mean DG maintenance duration for these utilities is in the range of nine to 12 hours, based on a total of almost 50 DG years of experience. Thus actual maintenance experience demonstrates that the value of 16 hours used in this analysis is conservative.

4.3 DCPRA ELECTRIC POWER SYSTEM MODEL

The electric power systems modeled in the DCPRA include:

- the standby offsite power source,
- the three Unit 1 125 V vital DC power trains,
- the two Unit 1 non-vital 12 kV buses,
- the three Unit 1 4.16 kV vital buses,
- the three Unit 2 125 V vital DC and 4.16 kV AC power trains,
- the five diesel generators,
- the diesel fuel oil transfer system, and
- the Unit 1 vital instrument AC.

Of these systems, the one of interest for this analysis is the DG system model. Information on the electric power system models may be found in Reference 14. The following sections describe how the existing DCPRA DG model was utilized and modified to evaluate the effects of changing the DG AOT from 72-hours to 7-days.




4.3.1 CALCULATION MODIFICATIONS

In order to evaluate effects of scheduled maintenance, changes in AOTs, and the relative risk, the DG failure probabilities are re-evaluated. Two sets of quantifications are required for each calculation: one for non-seismic events and one for seismic events. All non-seismic results are mean values based on Monte Carlo quantification while the seismic results are point estimates. An additional difference between the two is the mission time. For non-seismic events, the DCPRA mission time has been assumed to be six hours and for seismic events it is 24 hours. The six hour mission time is conservative because within six hours it is very likely that offsite power will be recovered. The larger 24 hour mission time is assumed for seismic events because of the increased degree of difficulty believed to be associated with recovering offsite power following a seismic event. However, it should be noted that in the reliability analyses, documented in Chapter 5, a DG mission time of four hours is used based on the DCPD station blackout (SBO) evaluation with a five DG configuration. The reliability analysis uses the mission time of two hours for six DGs as determined by preliminary SBO analysis, but does not address seismic initiators.

Appendix A presents the DG system equations used in the DCPRA. This section describes the modifications of the DCPRA equations for each of the calculations listed in Table 4-1. Reference 4 provides a detailed discussion of the development of these equations. Calculations were performed to provide intermediate results and to support the assessment of the three cases of interest. These three cases are: (1) the base case (Case 1), the existing plant configuration with a 72-hour AOT; (2) Case 2, the existing plant configuration with a 7-day AOT; and (3) Case 3, the planned six DG configuration with a 7-day AOT. These calculations are described below.

Calculation 1A

This calculation corresponds to the model from the DCPRA and no re-quantification is necessary. The non-seismic and seismic results from the PRA are reproduced here and presented in the first two columns of Table 4-3. The results are presented mainly for reference and for use in the relative risk calculation. It is important to



note that the DCPRA model does not include scheduled maintenance on the swing DG during power operation of either unit.

Calculation 1B

This calculation is similar to Calculation 1A and no changes other than data are required to evaluate this situation. The same equations are used; however, the unscheduled maintenance duration of the DG is revised to reflect a change in the AOT from 72 hours to seven days. The equations are requantified using the updated mean maintenance duration of 16 hours. These results are also used in Calculations 3 and 4 and in relative risk calculations. The DG failure probabilities for this calculation are shown in the third and fourth columns of Table 4-3.

Calculations 2 and 3

Calculation 2 considers the existing five DG plant configuration with a 72-hour AOT on all DGs. However, the analysis also addresses that once every 18 months, during the refueling outage of one unit, scheduled maintenance on the swing DG occurs with the other unit at power. The duration of the scheduled maintenance is 10 days, which corresponds to recent operational experience in which four outages of approximately three days each were used to perform scheduled maintenance on the swing DG. This calculation is representative of DCP's current operating practices and is used as the base case or Case 1 for comparison purposes.

Calculation 3 is similar to Calculation 2 except that the DGs are subject to a 7-day AOT instead of 72-hours. Calculation 3 is used as Case 2 in the comparison with the base case. Scheduled maintenance on the swing DG is also performed; however, since the AOT is longer, all the maintenance can now be performed within the 7-day AOT instead of four 72-hour AOTs. The fact that the scheduled maintenance is performed in one outage results in greater maintenance efficiency and a shorter overall outage duration.

Both Calculations 2 and 3 require modifications, as discussed below, to the DG equations to evaluate the effects of performing scheduled maintenance on the swing DG once every 18 months while a unit is at power. In addition, for



Calculations 2 and 3, the results from Calculations 1A and 1B are also utilized in evaluating the plant risk.

The calculation of core damage for the period of time that the swing DG is unavailable as a result of scheduled maintenance is described in Section 4.4. Part of this core damage calculation requires the requantification of core damage sequences involving failure of the swing DG (i.e., Top Event GF). For these sequences, the failure probability for Top Event GF is set equal to 1.0. Subsequent DG failures (Top Events GG, GH, 2G and 2H) in these sequences are dependent on the failure of Top Event GF. The failure probabilities representing these failures must be replaced with the split fractions based on the swing DG being unavailable due to the maintenance event.

Only those DG split fractions that appear in the core damage sequences involving the failure of Top Event GF needed to be requantified. A list of these core damage sequences can be found in Appendix B. The DG split fractions in these sequences are replaced with split fractions that model the scheduled maintenance of the swing DG. These replacement split fractions are requantified to account for changes in the test and maintenance contributions to system unavailability. Specifically, the modeling of unscheduled maintenance, and DG operability tests given one diesel is out for maintenance were modified for the replacement split fractions. Table 4-2 lists the DG split fractions that appear in the core damage sequences involving the failure of the swing DG (Top Event GF). The new split fraction name is also listed along with the name of the DCPRA split fraction that was used as the basis for the new split fraction. For example, GG4 was quantified using the equations for GG3 with modifications to the test and maintenance contributions.

The modified equations for both non-seismic and seismic events are presented in Appendix A. More specifically, the unscheduled maintenance duration for a dedicated DG given the swing DG is inoperable is set equal to 8 hours. This is based on Technical Specification 3.8.1.1 Action Statement f, which requires operators to restore one of the two disabled DGs to an operable status within two hours or place the unit in Hot Standby within the next 6 hours. This eight hour duration replaces the distribution for DG maintenance duration.



The equation representing DG unavailability due to testing given one diesel is unavailable due to preventive maintenance has also been modified. It is set equal to zero since Technical Specifications do not require the other DGs to be tested if the cause of the DG outage is preventive maintenance.

The equations for variables TOT1, TOT2, TOT3 and TOT4, representing the total unavailability of 1, 2, 3, and 4 DGs, respectively, were modified as well. With one DG out for maintenance, the number of combinations of DG failures with other DGs in maintenance or testing are reduced. With the swing DG guaranteed unavailable due to maintenance, TOT1, TOT2, TOT3, and TOT4 now quantify the unavailability of 2, 3, 4, and 5 diesels, respectively. The variable TOT5 is not used for these calculations.

The DG split fraction results for quantifications of scheduled maintenance on the swing DG are summarized in Table 4-3, columns five and six. Again, the only difference between the non-seismic and seismic quantifications is the mission time which changes from 6 hours for non-seismic events to 24 hours for seismic events.

Calculation 4

Calculation 4 considers the planned plant configuration with six DGs and a 7-day AOT, and utilizes the results of Calculation 1B. Calculation 4 is used as Case 3 in the comparison with the base case (Case 1). Scheduled maintenance required by Technical Specifications during power operation is no longer applicable since this maintenance can now be performed on all of a unit's DGs while that unit is shut down. The only changes required to evaluate this situation occur in the dominant sequence model, which is discussed in Section 4.4.

For the six DG configuration, no redistribution of loads between buses is modeled. This is appropriate because each unit currently has three 4.16 kV buses. Adding the sixth DG simply permits both Unit's 4.16 kV vital F buses (i.e., one for each unit) to be powered by their respective DGs during a LOOP event. For the present five DG configuration, during a LOOP event, only the F bus that is aligned to the swing DG is powered by onsite emergency power.



Calculation 5

Calculation 5 analyzes the situation in which no maintenance (scheduled or unscheduled) is allowed on any of the DGs. This corresponds to the standby period in which none of the DGs is out for maintenance. These results are used in the relative risk calculation.

To support the relative risk calculations (see Section 4.5.2), the DG system equations were quantified under the condition that no DG maintenance is allowed. The system equations used to quantify this case are the same as the DCPRA system equations with the following exceptions. The term representing system unavailability due to unscheduled maintenance has been set to zero and the contribution to unavailability due to diesel tests performed while one diesel is in maintenance is also set to zero. A summary of these split fraction results are provided in the last two columns of Table 4-3.

Calculation 6

Calculation 6 evaluates the risk if the swing DG were unavailable for the entire year. This is not a realistic situation; however, the value is required for the relative risk calculation.

The calculation is similar to Calculations 2 and 3, where the effects on system unavailability during scheduled maintenance are evaluated. The same equations are used for this calculation as a conservative simplification. This calculation is performed assuming a 7-day AOT. This results in an overstatement of the relative risk for the 72-hour AOT. This overstatement, however, is not significant.

4.4 CORE DAMAGE SEQUENCE MODELS

The DCPRA quantified 50 initiating event categories, including six seismic levels. The key contributors to the core damage frequency at DCP are described in Chapter 6 of Reference 4. The same dominant sequence models are used here to evaluate the risk impacts of the various sensitivity cases.



4.4.1 DOMINANT SEQUENCE PRA MODEL

The dominant core damage sequences, other than those initiated by seismic events, have been summarized in Appendix B. Each key sequence is represented as the algebraic product of a single initiating event and the failure frequencies of failed systems under specific boundary conditions, or split fractions. These split fractions are defined and their numerical values are presented in Appendix B. Where appropriate, sequence specific recovery actions are also accounted for in this list of key sequences. Only the failed systems are included in the sequence representation. Normally the system success frequencies are very close to unity and can be conservatively omitted from the sequence frequency calculation. For sequences in which this is not the case, the system success frequencies have been included to avoid over-conservatism. For example, DG success frequencies are included. To account for the remaining, low frequency sequences that are not explicitly represented in the reduced sequence model, and to account for the system success terms which were omitted, a ratio has been applied to the total core damage frequency so that the reduced sequence model results match the detailed event tree quantification results of the DCPRA, which did account for each of these effects.

The dominant sequence model presented in Appendix B is used to evaluate the changes in the DCPD core damage frequency for each of the cases. Since the changes do not alter the intersystem dependencies reflected in the DCPRA event tree quantification, the reduced event sequence model presented in Appendix B is applicable to all of these cases. Therefore, it is not necessary to re-determine the key list of sequences from the complete DCPRA plant event tree models for each case.

Model for Scheduled Overhaul

Only the scheduled overhaul on the swing DG (performed once every 18 months) is considered to be performed with a reactor at power. The scheduled overhauls on the other two Unit 1 dedicated DGs are performed with Unit 1 shutdown. This situation introduces an asymmetry into the DG system model; whereas the DCPRA DG system model, which models the DGs of both units, assumed symmetry between the five DG trains.



Rather than revise the DCPRA DG system model to account for this asymmetry, an alternative approach is described as follows. The dominant sequence core damage model is divided into two parts, corresponding to periods of time in which the swing DG is or is not undergoing the scheduled 18 month overhaul.

For the period of time in which the swing DG is not undergoing the overhaul, the DCPRA system models apply without modification. For the period of time in which the swing DG is undergoing the scheduled overhaul, the DCPRA DG system model can be modified and then quantified separately. The modifications to the DG system models to reflect these changes were presented in Section 4.3.1. The changes made to the dominant sequence core damage model which reflect the two time periods are described below.

The modified dominant sequence model is constructed as the sum of two groups of sequences. The first group of sequences is the original dominant sequence model as presented in Appendix B, and is weighted by one minus the fraction of time that there is scheduled maintenance performed on the swing DG.

The second group of sequences are, conceptually, the same sequences as in the first group but with the DG system failure frequencies adjusted to reflect the swing DG being out for maintenance (i.e., maintenance on the other diesels is limited to eight hours pursuant to DCP Technical Specification 3.8.1.1 Action Statement f). This second term is then weighted by the fraction of time the swing DG is in scheduled maintenance.

This conceptual sum of the core damage frequency results is simplified for computational convenience. This simplification is done because it is easier to compute the increase in core damage frequency (i.e., CDF2), for the time spent while in the swing DG 18 month overhaul and to add this frequency, weighted by the fraction of time spent performing the overhaul, to the core damage frequency when not in the 18 month overhaul (i.e., CDF1). The increase in the core damage frequency, while in the overhaul, is conservatively approximated by the frequency of the core damage sequences which increase due to the scheduled maintenance. The frequency of these sequences when not in the scheduled overhaul is not subtracted off and is, therefore, conservatively double counted. The approach followed in the current study is represented by the equation below:



$$T = (1-F) \cdot CDF1 + F \cdot CDF2 \cong 1 \cdot CDF1 + F \cdot CDF2$$

where:

T = the total core damage frequency which includes the impact of swing DG schedule maintenance every 18 months.

CDF1 = the core damage frequency computed from the dominant sequence model developed in the DCPRA, including the results from seismic and other external initiating events.

CDF2 = the increase in core damage frequency while in the swing DG 18 month scheduled overhaul but computed as the total frequency of all sequences which increase in frequency during the overhaul alignment, and

F = the fraction of time spent while at power in the swing DG 18 month overhaul.

The calculational approach to determining the core damage frequency of those sequences which change as a result of the scheduled 18 month overhaul of the swing DG is described in the next two sections.

4.4.2 NON-SEISMIC SEQUENCES

The dominant non-seismic initiating event sequences listed in Appendix B are reviewed to identify those which involve failure of the swing DG (i.e., Top event GF fails). For the period of time while in the scheduled outage, the failure fraction for Top Event GF is set to 1.0, since the swing DG is not available to either Unit during this time.

The failure fractions for the other two Unit 1 dedicated diesels in these same sequences are then reset (see Section 4.3.1) to account for the different boundary conditions imposed on them by the swing DG being unavailable. For example, instead of the failure fraction for top event GG with the boundary condition of top event GF failing independently, the failure fraction for top event GG with the



boundary condition of top event GF being guaranteed failed due to the overhaul is used.

The resulting non-seismic initiated sequences that are affected by the swing DG being out for the overhaul are indicated in Appendix B.

4.4.3 SEISMIC SEQUENCES

The seismic initiated sequences which contribute significantly to the total core damage frequency are not included in the list of important sequences found in the reduced sequence model in Appendix B. Seismic initiated sequences are treated separately because the frequency of individual sequences can not be represented without a complete specification of which systems succeed as well as which fail; i.e., the degree of conservatism introduced by assuming the systems which succeed have a success frequency of unity becomes excessive. However, the list of important seismic initiated sequences, even without the representation of which systems succeed, is an important tool for determining which sequences should be considered further in an integrated model of seismic and non-seismic caused system failures.

The top 200 point estimate core damage sequences initiated by seismic events are listed in Appendix C. The top 150 of these sequences were examined individually to determine which sequences should be modeled separately for this study. The remaining 50 were checked to insure that they were represented by the first 150 sequences. As part of the original DCPRA, a similar process was undertaken to determine which sequences needed to be modeled in the seismic uncertainty analysis.

For this study, the sequences are again reviewed to determine which sequence frequencies would change for the cases being considered. The sequences involving failure of one or more DGs are the only ones whose frequency may change appreciably; i.e., those involving failure of top events GF, GG, GH, 2G and 2H. The sequences identified as possibly changing are numbered sequences 3, 29, 39, 78, and 99 in Appendix C. These sequences are of interest because, although they are initiated by seismic events, they involve only non-seismic failures of the DGs. The DCPRA models seismic failures of the DGs as failing all five DGs. Consequently, the



scheduled overhaul on the swing DG has no impact on sequences involving seismic failure of the diesels. The scheduled overhaul only affects those sequences involving non-seismic failures of the diesels.

For seismic initiated core damage sequences, in which the system success fractions differ significantly from unity, care must be taken to not over-estimate the true contribution of each sequence to the total seismic core damage frequency.

The SEIS4 program (Ref. 15) is used to compute the increase in seismic core damage frequency while in the 18 month scheduled overhaul configuration for the swing DG. The list of affected sequences can be further grouped into two categories. Category 1 includes sequences in which the seismic event causes a LOOP, and then core damage results due to non-seismic failure of at least two Unit 1 diesels combined with other non-seismic failures. Category 2 involves sequences in which the seismic event results in a LOOP, and a failure of either the component cooling water or the auxiliary saltwater system. Loss of component cooling water or auxiliary saltwater may lead to a reactor coolant pump seal LOCA with failure of all high head injection pumps. The sequences in this category also involve non-seismic failures of the swing DG and the dedicated DG-12. The 4.16 kV buses supplied by these two diesels supply power to all three charging pumps. Therefore, these sequences involve an RCP seal LOCA with no power available to the charging pumps for their continued operation even if the operators supplied alternative cooling to the charging pumps via the fire service water system.

The SEIS4 model is used to compute the seismic failure frequency portion of each of these two sequence categories. SEIS4 combines the DCPRA hazard curves and fragilities for all seismic levels to compute the seismic frequency portion of each of these sequence categories; i.e., two quantities are computed. These terms (hereafter known as TERM1 for sequences 3, 29, 39, 78 and 99; and TERM2 for sequence 86) are then explicitly combined with the non-seismic system split fractions to arrive at the increase in core damage frequency caused by the scheduled 18 month overhaul. Appendix C lists these sequences.

The original SEIS4 input file is modified to compute the two terms described above for the time when the swing DG is in maintenance. To recompute the total seismic core damage frequency for the case which evaluates the 7-day AOT and the case




with no DG maintenance allowed, minor changes are made to reflect the particulars of each case. First, the computation of the total seismic core damage frequency is discussed.

To recompute the total seismic core damage frequency for each case, the frequencies of the systems which fail independently due to non-seismic or random failure causes following the seismic initiating event, must first be adjusted for the particular case in question. The failure causes are input as constants to the SEIS4 model since they are not dependent on the seismic level. These constants were computed for the original DCPRA assuming that the DGs are subject to an AOT of 72-hours. For the cases of interest here, these constants are recomputed using the DG system split fractions quantified for seismic events presented in Table 4-3. To represent the planned six diesel configuration, the swing DG is conservatively modeled as always being aligned to Unit 1. This is accomplished by setting the swing DG alignment event, SW, always to 0. This is conservative because no credit for emergency power on Unit 2's F bus is taken. Thus, with the system split fractions redefined to reflect each case, the constants representing the non-seismic failures are then computed for input to the SEIS4 program. SEIS4 then computes the total seismic core damage frequency for the cases when the swing DG is not in scheduled maintenance.

For the time when the swing DG is in maintenance, the same SEIS4 constants which account for non-seismic system failures must be adjusted for the particular case in order to compute TERM1 and TERM2. Since during the period of time in which the swing DG is in maintenance, no other DG outages are permitted, the system split fraction values from the scheduled maintenance seismic quantification are used, in combination with TERM1 and TERM2, to calculate the increase in the seismic core damage frequency.

In addition to modifying the input constants for SEIS4, the SEIS4 input is further modified to compute TERM1 and TERM2, (i.e., to compute the increase in seismic core damage frequency rather than the total seismic core damage frequency). These modifications simply assure that TERM1 and TERM2 represent only the increase in the seismic core damage frequency caused by being in the swing DG overhaul alignment. This is accomplished by computing the intersection of each of the two terms with the complement of all the other seismic initiated sequences



included in the original SEIS4 core damage frequency model. Use of the computed values for TERM1 and TERM2 then assures that there is no double counting of the seismic sequences.

4.5 QUANTIFICATION OF CORE DAMAGE FREQUENCY

The quantification of the impact on core damage frequency due to changes of the DG AOT is presented in this section. The results are presented first for the absolute risk which is based on the average annual core damage frequency and then for the relative risk ratio. For a definition of the calculations, refer to Table 4-1.

4.5.1 ABSOLUTE RISK RESULTS

The core damage frequency for each of the cases was evaluated using the results of the system split fraction quantification for both seismic and non-seismic events. For calculations in which there is no scheduled maintenance performed on the swing DG while the plant is at power (i.e., Calculations 1A and 1B), the DCPRA seismic model and non-seismic dominant sequence model were used. For the calculations where maintenance on the swing DG is considered (Calculations 2 and 3) the quantification process is slightly different; the revised split fractions for seismic and non-seismic events were used to calculate the increase in core damage frequency which was then added to the total core damage frequency evaluated with no scheduled maintenance allowed.

For Calculation 4, which represents a six DG configuration, the full DCPRA model was requantified with the change that the swing DG is always aligned to Unit 1 (this is representative of the addition of a sixth DG). This is a conservative modeling approach since no credit is given for Unit 2 having three DGs instead of two; this mostly affects the system analysis of the auxiliary salt water system. The revised non-seismic and seismic DG system quantifications were used.

Calculation 5 was also evaluated for use in the relative risk calculations. Calculation 5 represents the core damage frequency if no maintenance were performed on any of the DGs. This calculation is not an achievable level of plant risk as it is not possible to eliminate all DG outages. Again, the revised system quantifications for this case were used in the DCPRA core damage models.



Calculation 6 is also needed for the relative risk calculation. Calculation 6 represents the risk during the period the swing DG (or any other DG) is unavailable. The value is calculated in a similar manner as was done for Calculations 2 and 3 except that the value of F, the fraction of time in the maintenance alignment, is set equal to 1.0. Setting F to 1.0 is equivalent to a DG being unavailable for an entire year.

The results for each calculation are summarized in Table 4-4.

4.5.2 RELATIVE RISK RESULTS

The impact of changes to the DG AOT may also be presented in terms of a relative risk ratio. The relative risk ratio is defined differently for unscheduled and scheduled maintenance activities.

The relative risk ratio for unscheduled maintenance is computed by comparing the core damage frequency during the period when a DG is unavailable due to unscheduled maintenance, to the core damage frequency during the period when no DG is in maintenance. The period when no DG is in maintenance is termed the baseline period. This baseline period is determined from the DG maintenance frequency. On a per unit basis, the frequency of one of three DGs being out for maintenance is three times the individual DG maintenance frequency. The interval between DG maintenance outages is then the inverse of this value or, approximately 19 days.

The relative risk ratio for scheduled maintenance, which only applies to DG 1-3, is computed by comparing the core damage frequency during the period when DG 1-3 is in maintenance, to the core damage frequency during the interval (baseline period) between maintenance activities. For scheduled maintenance this interval is 18 months.

The relative risk for the cases of 72-hour and 7-day AOTs with five DG and 7-day AOTs with six DG configurations were each evaluated. The risk during a DG outage is the same for all four of these cases; it is calculated assuming that DG 1-3 is the DG which is unavailable (see discussion in Section 4.5.3). The core damage frequency under this criterion (Calculation 6) is $4.650E-4$ per year. The core damage frequency



with no maintenance on any DG was evaluated as Calculation 5 and has the value of 2.042E-4 per year. This is based on a five DG configuration. A six DG configuration would actually yield a slightly lower value; however, the difference is very small and for simplicity, the six DG configuration is treated the same as the five DG case. For the 72-hour AOT the mean outage duration was found to be approximately 10 hours. For a 7-day AOT a mean outage duration of 16 hours is used. The relative risk for unscheduled maintenance is calculated as follows:

The risk during unscheduled DG maintenance is:

$$\text{MOD} * \text{CDF13}/8760$$

where :

MOD - Mean outage duration (10 hours for the 3-day AOT and 16 hours for the 7-day AOT),

CDF13 - Core damage frequency when DG 1-3 is in maintenance (4.650E-4 per year), and

8760 - The number of hours in a year.

The risk during the baseline period (i.e., period of 19 days with no DG maintenance) is:

$$\text{BLN} * \text{CDFOM}/8760$$

where :

BLN - Baseline period (average interval between DG outages) 19 days = 456 hours, and

CDFOM - Core damage frequency when there is no maintenance on any of the DGs (2.042E-4 per year).



The risk ratio is the ratio of the risk during unscheduled DG maintenance to the risk during the baseline period. The results of these calculations are presented in the first half of Table 4-5.

The risk ratio for scheduled maintenance is calculated in a similar manner; however, some of the parameters are changed. The numerator of the ratio (the risk during the scheduled maintenance) is calculated as follows:

$$\text{SCHD} * \text{CDF13}/8760$$

where :

SCHD - is the scheduled maintenance duration (10 days for 72-hour AOT, and 7 days for 7-day AOT), and

CDF13 - is the core damage frequency while the swing DG is in maintenance (4.650E-4 per year).

The denominator is the risk associated with the period between scheduled maintenance events, which is every 18 months:

$$\text{BNL} * \text{CDF}/8760$$

where :

BNL - is the period between scheduled maintenance events (18 months), and

CDF - is the core damage frequency; for cases with a 3-day AOT the value of 2.078E-4 is used (Calculation 1A) and for a 7-day AOT the value of 2.120E-4 is used (Calculation 1B).

The results of these calculations are presented in the second half of Table 4-5. The relative risk for scheduled maintenance for a six DG configuration is zero. This is because the addition of a sixth DG eliminates scheduled maintenance during operation; by definition then, the relative risk is zero.



4.5.3 SENSITIVITY TO SWING DIESEL IN MAINTENANCE

One assumption which was utilized in evaluating the relative risk was that the risk associated with maintenance of the swing DG is approximately the same as the risk associated with maintenance of the other two Unit 1 DGs. A study was performed to identify the contribution of each of the DGs to core damage frequency. The results indicated a 9 percent contribution for DG 1-3, 11% contribution for DG 1-2, and 12 percent contribution for DG 1-1.

From these results, it can be seen that within a few percentage points, each DG contributes approximately the same amount to plant risk. In relative risk calculations, it was assumed that DG 1-3 was the DG in maintenance. In actuality, there is a 33 percent chance that it is any one of the three diesels. By approximating the risk during the maintenance period as the risk associated with maintenance on DG 1-3, a minor non-conservatism was introduced. This non-conservatism, however, is not significant in light of the low values of the risk ratios.

4.6 INTERPRETATION OF RESULTS

Three of these calculations are representative of how DCPD is currently operated or planned to operate in the future. These are Calculations 2, 3, and 4, corresponding to Cases 1, 2, and 3, respectively. The other calculations were performed to support the relative risk measure analysis.

Case 1 addresses the current design and operational practices at DCPD, and is the base case against which comparisons are made. Case 1 represents a five DG configuration with a 72-hour AOT, and scheduled maintenance performed once every 18 months on the swing DG for a total duration of 10 days. The base case plant risk is $2.12E-4$ per year.

Case 2 is representative of the current plant configuration as it would exist under a 7-day AOT. Under the 7-day AOT, greater maintenance efficiency is realized in performing the 18 month swing DG scheduled maintenance. Instead of a total maintenance duration of 10 days (as is necessary under the 72-hour AOT), the maintenance can be completed in one 7-day period. As a partial tradeoff, an




extension of the mean maintenance duration for unscheduled maintenance is expected. The plant risk under this configuration is $2.15E-4$ per year.

The final case is Case 3, which is the six DG plant configuration under a 7-day DG AOT. Scheduled maintenance is no longer necessary while at power since each unit has three dedicated DG. The plant risk for this case is $2.02E-4$ per year.

The absolute risk results presented above indicate that for the five DG configuration, changing from a 72-hour AOT to a 7-day AOT results in an insignificant change of approximately 1.4 percent increase in plant risk. In contrast, the addition of a sixth DG with a 7-day AOT shows a net reduction in plant risk of approximately 4.7 percent.

It is further emphasized that these results are conservative estimates since it is believed that in changing from a 72-hour AOT to a 7-day AOT, the mean DG maintenance duration will not change significantly due to PG&E's commitments to minimize DG unavailability. Had a less conservative value of the mean maintenance duration been used, the increase in risk for Case 2 would be less than 1.4 percent as calculated and the reduction in risk for Case 3 would be greater than the 4.7 percent calculated.



**TABLE 4-1
DEFINITION OF CALCULATIONS**

<u>Calculation</u>	<u>No. of DGs</u>	<u>Allowed Outage Time</u>	<u>Period of Scheduled Overhaul on Swing DG (with Unit 1 at power)</u>
1A	5	3 Days	0 Days
1B	5	7 Days	0 Days
2	5	3 Days	10 Days
3	5	7 Days	7 Days
4	6	7 Days	0 Days
5	5	No Maintenance	0 Days
6*	5	7 Days	1 year

* This calculation evaluates the risk if the swing DG were unavailable for the entire year under a 7-day AOT.





TABLE 4-2
DIESEL GENERATOR SPLIT FRACTION TRANSLATION TABLE FOR
THE SCHEDULED MAINTENANCE QUANTIFICATION

<u>Split Fraction to be Replaced in the Core Damage Scenarios</u>	<u>New Split Fraction Name</u>		<u>Split Fraction Used as a Base for the New Split Fraction</u>
	<u>Nonseismic</u>	<u>Seismic</u>	
GF1	GFF	GFF	GFF
GG2	GG4	GG5	GG3
GH2	GH7	GHA	GH4
GH3	GH8	GHB	GH5
GH5	GH9	(NN)	GH6
2G3	2GC	2GI	2G6
2G6	2GE	(NN)	2G8
2H3	2HI	(NN)	2H7
2H4	2HJ	(NN)	2H8

Note: NN = Not Needed





**TABLE 4-3
DIESEL GENERATOR SPLIT FRACTION VALUES**

Split Fraction	Calc. 1A & 2 (DCPRA) 3 Day AOT for all Diesels		Calcs. 1B & 3 & 4 7 Day AOT for all Diesels		Calcs. 2, 3 & 6 Scheduled Maintenance on Diesel 13		Calc. 5 Zero Diesel Maintenance	
	<u>Nonseismic</u>	<u>Seismic</u>	<u>Nonseismic</u>	<u>Seismic</u>	<u>S.F. Nonseismic</u>	<u>S.F. Seismic</u>	<u>Nonseismic</u>	<u>Seismic</u>
GF1	4.523E-02	8.510E-02	4.946E-02	8.721E-02	(1)		3.711E-02	7.561E-02
GG1	4.477E-02	8.417E-02	4.909E-02	8.654E-02			3.687E-02	7.507E-02
GG2	5.561E-02	9.502E-02	5.682E-02	9.428E-02	GG4 4.344E-02	GG5 8.114E-02	4.395E-02	8.226E-02
GG3	4.523E-02	8.510E-02	4.946E-02	8.721E-02			3.711E-02	7.561E-02
GH1	4.436E-02	8.334E-02	4.878E-02	8.595E-02			3.668E-02	7.462E-02
GH2	5.408E-02	9.329E-02	5.545E-02	9.275E-02	GH7 4.324E-02	GHA 8.064E-02	4.202E-02	8.060E-02
GH3	8.265E-02	1.115E-01	8.063E-02	1.090E-01	GH8 4.784E-02	GHB 8.685E-02	8.933E-02	1.008E-01
GH4	4.477E-02	8.417E-02	4.909E-02	8.654E-02			3.687E-02	7.507E-02
GH5	5.561E-02	9.502E-02	5.682E-02	9.428E-02	GH9 4.344E-02		4.395E-02	8.226E-02
GH6	4.523E-02	8.510E-02	4.946E-02	8.721E-02			3.711E-02	7.561E-02
2G1	4.396E-02	8.251E-02	4.847E-02	8.537E-02			3.651E-02	7.419E-02
2G2	5.364E-02	9.244E-02	5.507E-02	9.205E-02			4.145E-02	7.990E-02
2G3	6.250E-02	1.016E-01	6.254E-02	9.964E-02	2GC 4.631E-02	2GI 8.531E-02	5.629E-02	8.852E-02
2G4	2.898E-01	1.903E-01	2.726E-01	1.851E-01			3.834E-01	2.100E-01
2G5	4.436E-02	8.334E-02	4.878E-02	8.595E-02			3.668E-02	7.462E-02
2G6	5.408E-02	9.329E-02	5.545E-02	9.275E-02	2GE 4.324E-02		4.202E-02	8.060E-02
2G7	8.265E-02	1.115E-01	8.063E-02	1.090E-01			8.933E-02	1.008E-01
2G8	4.477E-02	8.417E-02	4.909E-02	8.654E-02			3.687E-02	7.507E-02
2G9	5.561E-02	9.502E-02	5.682E-02	9.428E-02			4.395E-02	8.226E-02
2GA	4.523E-02	8.510E-02	4.946E-02	8.721E-02			3.711E-02	7.561E-02
2H1	4.356E-02	8.169E-02	4.817E-02	8.481E-02			3.636E-02	7.379E-02
2H2	5.320E-02	9.162E-02	5.470E-02	9.138E-02			4.090E-02	7.925E-02
2H3	6.206E-02	1.005E-01	6.205E-02	9.863E-02	2HI 4.585E-02		5.589E-02	8.739E-02
2H4	6.922E-02	1.112E-01	6.996E-02	1.087E-01	2HJ 5.573E-02		6.415E-02	1.002E-01
2H5	7.729E-01	5.269E-01	7.521E-01	5.214E-01			8.494E-01	6.230E-01
2H6	4.396E-02	8.251E-02	4.847E-02	8.537E-02			3.651E-02	7.419E-02
2H7	5.364E-02	9.244E-02	5.507E-02	9.205E-02			4.145E-02	7.990E-02
2H8	6.250E-02	1.016E-01	6.254E-02	9.964E-02			5.629E-02	8.852E-02
2H9	2.898E-01	1.903E-01	2.726E-01	1.851E-01			3.834E-01	2.100E-01
2HA	4.436E-02	8.334E-02	4.878E-02	8.595E-02			3.668E-02	7.462E-02
2HB	5.408E-02	9.329E-02	5.545E-02	9.275E-02			4.202E-02	8.060E-02
2HC	8.265E-02	1.115E-01	8.063E-02	1.090E-01			8.933E-02	1.008E-01
2HD	4.477E-02	8.417E-02	4.909E-02	8.654E-02			3.687E-02	7.507E-02
2HE	5.561E-02	9.502E-02	5.682E-02	9.428E-02			4.395E-02	8.226E-02
2HG	4.523E-02	8.510E-02	4.946E-02	8.721E-02			3.711E-02	7.561E-02

Note: (1) This quantification was used to evaluate core damage sequences that involved failure of the swing DG. The DG split fractions not listed for this case were not needed to quantify these sequences.





**TABLE 4-4
ABSOLUTE FREQUENCY RESULTS**

<u>Calculation</u>	<u>No. of DGs</u>	<u>Allowed Outage Time</u>	<u>Period of Scheduled Overhaul on Swing DG (with Unit 1 at power)</u>	<u>Frequency (per year)</u>
1A	5	3 Day	0 Days*	2.078E-04
1B	5	7 Day	0 Days	2.120E-04
2	5	3 Day	10 Days	2.124E-04
3	5	7 Day	7 Days	2.152E-04
4	6	7 Day	0 Days	2.017E-04
5	5	No Maintenance	0 Days	2.042E-04
6	5	7 Day	1 Yr.	4.650E-04

* DCPRA Assumption; see Ref. 4 and 14






**TABLE 4-5
RELATIVE RISK RESULTS**

<u>Description</u>	<u>Risk Ratio</u>	<u>Comments</u>
Impact of Allowed Outage Time		
3 Day AOT:		
-5 DG configuration	0.05*	Risk during AOT/risk during base period with no maintenance
7-day AOT:		
-5 DG configuration	0.08*	Risk during AOT/risk during base period with no maintenance
-6 DG configuration	0.08*	Risk during AOT/risk during base period with no maintenance
<hr style="border-top: 1px dashed black;"/>		
Impact of Scheduled Outages		
-5 DG configuration (3 Day AOT) + 10 Days	0.04	Risk for scheduled outage/ risk for 18 months(72-hour AOT)
-5 DG configuration (7 Day AOT) + 7 Days	0.03	Risk for scheduled outage/ risk for 18 months(7-day AOT)
-6 DG configuration (7 Day AOT) + 7 Days	0.00	No scheduled outage/ risk for 18 months(7 Day AOT)

* Based on mean maintenance duration.





5.0 RELIABILITY ANALYSIS

This section describes the reliability analysis, associated data, methodology, and results. The approach of this analysis follows that used by the NRC approved Brunswick AOT analysis, which is based on NUREG/CR-3082 (Ref. 3). For this reliability analysis, DCPD DG outage time data was collected and evaluated for the 72-hour AOT risk calculations. Palisades data was evaluated and utilized for the 7-day AOT risk calculations. The Palisades' plant data was chosen because the Palisades Technical Specifications provide a 7-day AOT. Additionally, the Palisades DGs were provided by the same manufacturer (ALCO) of the DCPD DGs.

The reliability analysis consists of three segments. The first segment calculates a DG hardware unavailability. This is accomplished by modeling the DG and its support systems in a fault tree and then quantifying the models. Section 5.1 discusses the details of the DG fault tree model.

The second segment of the reliability analysis generates fault trees to model DG system unavailability for the licensing design basis cases which are being evaluated, namely, the LOOP event and the LOCA in one unit with a LOOP event. These case models are quantified to generate cutsets which are then loaded into the FRANTIC-ABC computer code (Ref. 9), a PC version of FRANTIC-III. This code calculates an average and a maximum unavailability for each case model by employing time-dependent unavailability analysis. Section 5.2 discusses the case models in more detail. Section 5.3 discusses the FRANTIC-ABC analysis.

In the third segment, the relationship of risk associated with the AOT for both units is evaluated. The risk levels for the current 72-hour AOT and the proposed 7-day AOT are calculated using the relative risk and the average annual risk methods as described in NUREG/CR-3082. The risk methods are described in detail in Section 5.4.

5.1 DIESEL GENERATOR FAULT TREE

This section discusses the success criteria, mission time, and boundary conditions used to generate a "stand alone" fault tree model representative of a DG, its subsystems, and support systems. The fault tree models are presented as well as the quantification results.



5.1.1 SUCCESS CRITERIA

DG availability is challenged when a LOOP event occurs. During this event, the DGs must start and run to supply power to the vital 4.16 kV AC buses for a period of four hours. The mission time of four hours is based on the DCPD station blackout (SBO) evaluation (Ref. 13). In the case of the planned six DG configuration at the DCPD, preliminary analyses show the SBO mission time is reduced to two hours.

5.1.2 ASSUMPTIONS AND BOUNDARY CONDITIONS

The equipment boundaries for each DG includes the following:

- Diesel generator,
- DG output feeder breaker,
- Fuel oil day tank,
- Day tank LCVs,
- Undervoltage and transfer control relays,
- Initiation signal,
- Subsystems which support the diesel operation, and
- Support systems.

The subsystems which support DG operation include the lube oil system, the starting air system, the jacket water cooling system, the engine fuel oil system, the turbo-assist air system, and the crankcase exhausters fans. The DCPD DG fault tree models have been expanded to include each of these subsystems. These systems are modeled in detail in order to fully understand the workings and possible ways to fail a DG.

There are two major support systems for the DGs: DC power and the diesel fuel oil transfer system. Support power for the controls of the DG is provided by vital 125 V DC trains. Each diesel is provided with a normal supply of DC power and a manually available standby source of DC power. The loss of both sources of DC power will result in the loss of the associated diesel.



The fuel oil transfer system maintains a supply of diesel fuel oil to each DG day tank. If the fuel transfer system is unavailable, it results in failure of all the DGs since the fuel transfer system is common to all DGs.

As previously stated, the DG fault tree presented in this reliability analysis is an expansion of the DCPRA fault tree model. As such, only the modeling criteria of the additional subsystems included in the fault tree model are discussed. The criteria, which are based on the system description in Chapter 3, are presented below together with any points which contrast with the DCPRA models.

1. **Starting Air System:** There are two independent and redundant starting air systems per diesel. These systems are referred to as Train A and Train B. The starting air system supplies air to the diesel engine as well as to the diesel day tank LCVs. The success criteria of the air supplies is as follows:
 - a. **Air Supply to the Diesel Engine:** There are two air start motors per train. For DG operability, any one of the four motors must be operable.
 - b. **Air Supply to the Day Tank LCVs:** There is one air supply line per LCV. For day tank operability, one of the supply lines must be operable, including the supply to the air-operated LCV located along the line.
2. **Lube Oil System:** If the lube oil filter plugs and its internal bypass mechanism fails, the lube oil system becomes inoperable. Excessive leakage of the lube oil heat exchanger will fail the DG. Additionally, due to the pressure differential between the lube oil and jacket water systems, if a leak occurs, the oil will leak into the jacket water system and fail that subsystem.
3. **Jacket Water Cooling System:**
 - a. As there are no isolation valves in the heat exchanger lines, excessive leakage of either the lube oil heat exchanger or the aftercooler heat exchanger will fail the system.
 - b. Excessive leakage of either radiator will fail the diesel due to high jacket water temperature. It is assumed that with excessive leakage of a



radiator, the expansion tank supply water would not be sufficient to replace the water lost through leakage.

- c. Failures of the expansion tank were not modeled nor was orifice plugging.
4. Engine Fuel Oil System: If the oil filters plug, this system becomes inoperable, resulting in the loss of fuel oil to the diesel engine injectors. Additionally, there is a solenoid valve on the line from the priming tank. DG failure may result if this valve is not aligned properly, i.e., open for DG start, closed for DG run. These failure modes are considered in the modeling and are conservative because no credit is taken for a recirculation line back to the head tank.
5. There are two crankcase exhausters fans per diesel. If both fans are inoperable, the DG is considered to be inoperable. There are relief ports on the crank case that may relieve pressure buildup; however, these ports are not modeled.
6. Failure of the turbo-charger air assist system will result in the DG failing to meet the required 10 second start time, and is modeled as DG failure. While the turbo-charger is specified by Technical Specifications for DG operability, this failure is conservatively modeled since operational testing shows that the DGs will start without the turbo-charger.
7. Both the normal and the standby 125 V DC power supplies to the DG must fail in order for the respective DG to fail due to loss of starting power. This contrasts with the DCPRA which only takes credit for the normal power supply.
8. Test and maintenance activities for the diesels subsystems are not modeled in the fault trees; they are tested separately as part of the diesel test and maintenance activities, and are included as part of the FRANTIC-ABC analysis.

The assumptions used in this fault tree analysis include the following:

1. Swing DG 1-3 may be aligned to either Unit 1 or to Unit 2 in a LOOP situation, but not simultaneously. For ease in modeling it has been assumed that the swing DG will automatically align to Unit 2. If the swing DG is needed on Unit



1 and the dedicated Unit 2 DG(s) are capable of supplying the necessary power for Unit 2, the operator must take action to realign the swing DG to Unit 1. This modeling assumption is made in order to model automatic alignment to one unit while making sure it is not aligned to both units. This assumption is conservative as it introduces human errors.

2. The mission time for the DGs to run is four hours (two hours when the six DG configuration is considered). This time is based on the DCPD SBO evaluation and is consistent with performing a design basis analysis. Note that only non-seismic initiating events are being considered in the reliability analysis.

5.1.3 FAULT TREE DEVELOPMENT

The unavailability of a DG was calculated using fault tree techniques. A detailed "stand alone" model was developed to represent the DG configuration by including diesel subsystems and support systems. The DG fault trees were quantified twice, once for the mission time of four hours (current five diesel configuration), and once for the two hour mission time (planned six diesel configuration).

The three major contributors to DG hardware unavailability are listed below:

1. Unavailability of components due to random failures,
2. Unavailability of components due to human error, and
3. Common cause failures.

Component unavailability due to test or maintenance is not considered in the fault trees. Rather, it is accounted for in the time-dependent FRANTIC-ABC analysis. The major contributors are further discussed below.

1. Unavailability of Components due to Random Failures

Hourly failure rates for the components modeled in the fault tree were obtained using plant specific data. These failure rates were then converted to failure probabilities using the following formula:

$$P_r = \text{Failure Rate (hourly)} * T_M,$$



where: P_r = Random failure probability, and
 T_M = Total defined mission time (hours).

The demand failure probability is given directly by the data base such that:

$$P_r = \text{Failure Rate (demand)} \times 1 \text{ demand.}$$

2. Unavailability of Components due to Human Error

There are four possible human errors considered in the DG fault trees. Each is described below.

- a. It is assumed that if the swing DG is aligned to Unit 2 but is required for Unit 1 operation, an operator will switch the DG to supply power to Unit 1. If the operator fails to switch the DG, it is modeled as a procedural error and the action is assigned a nominal failure probability of 1.0E-03.
- b. Following a DG test in which the operator changes the control switch from AUTO to MANUAL, there is a possibility the operators fail to reposition the switch back to AUTO. However, this event is considered to be highly unlikely because there are checklists in which the personnel must signoff that the switch was returned to AUTO. In addition, before the DG can be declared "operable" following the test, a tag which was placed on the switch at the beginning of the test, must be removed. Thus the personnel removing the tag must also acknowledge the switch is in AUTO. Note that of the 905 diesel tests considered in this reliability analysis, there were no occurrences of this error. Therefore, a low probability of 1.0E-04 is assigned for these human errors.
- c. If an initiation signal should fail, the operator may manually try to start the diesel. The probability that the operator fails to manually actuate is considered to be small, thus a value of 1.0E-03 is assigned for this error.
- d. There is a probability that during the monthly stroke test of the LCVs on the lines to the day tank, the operator fails to return the LCVs control



switch to AUTO. This is modeled as a procedural error and the probability of this event occurring is estimated to be 1.0E-03.

3. Common Cause Failures

Common cause failures are simultaneous failures of like components with identical functional requirements. Possible independent and dependent component failures were identified and accounted for in the common cause failure calculations. The Beta factor method was employed, which assumes that the total failure rate for each component can be expanded into independent and dependent failure contributions. The Beta factors were defined pursuant to EPRI NP-3967, "Classification and Analysis of Reactor Operating Experience Involving Dependent Failures" (Ref. 16), and were used in calculating the conditional probability of a common cause initiated failure of a component given that a similar component has failed. The total common cause failure contributions were calculated and accounted for in each fault tree.

The failure rate estimates used in calculating the component unavailabilities are based on DCPD plant specific data. The DG "Fail to Start" and "Fail to Run" failure rates are based on plant specific data from August 1985 through March 1989. Palisades PRA diesel failure data (Ref. 17) from January 1977 to December 1982 is considered for the 7-day AOT cases. The failure rate of the DG turbo-charger was calculated using data from NSAC-108, "The Reliability of Emergency Diesel Generators at U.S. Nuclear Power Plants" (Ref. 18). For component data not included in the DCPRA, the failure rates are taken from the IEEE Standard Reliability Data (Ref. 19). The data base developed for the reliability analysis is presented in Table 5-1.

Two fault trees were developed to model DG unavailability. The first tree models the ways a dedicated unit diesel may become unavailable during the mission time. DG 1-1 was chosen to represent the dedicated diesels. The second fault tree models the swing DG failures except those components which are unit specific (i.e., feeder breakers to AC buses and actuation signals).



The unit specific components mentioned above are modeled in two additional fault trees. The first one represents the unavailability of the swing DG to supply power to its Unit 2 bus. This encompasses the output feeder breaker to the Unit 2 4.16 kV AC bus, the Unit 2 relays (transfer control and undervoltage), and the DG initiation signal.

The other fault tree considers the case when the swing DG is aligned to Unit 2 but is needed to supply power for Unit 1. If the appropriate number of dedicated diesels are available for Unit 2 operation, then the operator must switch the swing DG to Unit 1.

The fault trees discussed above are presented in Appendix D as follows:

Figure	Tree Name	Fault Tree Representation
D-1	DG11	DG 1-1 unavailable
D-2	DG13	Swing DG 1-3 unavailable
D-3	DG13POW2	Power from swing DG for a given unit unavailable or no initiation signal received
D-4	SWITCH1	Swing DG aligned to Unit 2, one DG in Unit 2 available, operator error to realign swing DG to Unit 1

5.1.4 QUANTIFICATION

Following initial quantification of the DG11 and DG13 trees, the resultant cutsets are screened to identify dependent failures (common cause). The fault trees are then requantified to include the common cause failure probability, resulting in DG hardware unavailability. The common cause contribution from DG13POW2 is included with the swing DG common cause contribution which is modeled in the DG13 fault tree model. There are no common cause failures associated with the SWITCH1 fault tree.

Table 5-2 lists the hardware unavailability for each of the fault tree models discussed. The dominant contributors to the dedicated DG unavailability are listed in Table 5-3.



Once these fault trees have been quantified, the calculations regarding the initiating events may be performed. The calculations are discussed in the next section.

5.2 CALCULATION MODELS

Once the DG unavailabilities have been calculated, the unavailability of the DG system may be evaluated. Of interest in this analysis is the availability of the system, with one of two conditions:

1. LOOP, and
2. LOOP coincident with a LOCA in one Unit.

Several fault tree models are developed to represent the above conditions during the AOT (when one DG is out of service) as well as for the condition in which all DGs are in standby (none out for maintenance or repair). The fault trees are quantified to generate cutsets and are then used as input into the FRANTIC-ABC computer code.


5.2.1 SUCCESS CRITERIA

Each DG supplies power to one 4.16 kV bus, which in turn supplies power to ESF equipment. In the event of a LOOP, one DG per unit must successfully start, load, and run.

In the second condition to be evaluated, a LOOP occurs along with a LOCA in one unit, which is assumed to be in Unit 1. This is the FSAR design basis for DCP. Any two of the three DG buses are adequate to serve at least the minimum required ESF loads of the unit in which the LOCA occurred. Therefore, two of three DGs must successfully start, load, and run for the unit in which the LOCA has occurred.

5.2.2 CALCULATION MODEL CRITERIA

The top-level fault trees were developed with the following conditions:



1. For a LOOP event, one DG per unit is needed. For the unit in which a LOCA occurs, two DGs are required.
2. The fuel oil transfer system is required for DG operability.
3. The top-level fault tree models must consider in which unit the LOCA occurs. If the LOCA occurs in Unit 1, two of the three DGs which supply power to Unit 1 must be operable. These three diesels include the two dedicated Unit 1 DGs as well as the swing DG. This analysis assumes that the required number of dedicated diesels needed for Unit 2 are operable.

5.2.3 CALCULATIONS

A total of 8 top-level fault trees were developed to model the DG system unavailability given any of three situations. The current DCPD five DG configuration and the planned six DG configuration were analyzed. The calculations and the associated fault trees are listed in Table 5-4. The fault trees are presented in Appendix D.

There is a symmetry between the units with the addition of a sixth DG such that each unit now has three dedicated DGs. At this point there is no swing DG considered in the models.

The fault tree models are presented in Appendix D as follows.

Current five DG configuration:

Figure	Tree Name	Fault Tree Representation
D-5	CASE1-LP	LOOP in both units, all DGs in standby
D-6	CASE1-1	LOCA in Unit 1 with LOOP, all DGs in standby
D-7	CASE2	LOOP, swing DG out of service (limiting case)
D-8	CASE3	LOCA in Unit 1 with LOOP, one DG out of service





Planned six DG configuration:

Figure	Tree Name	Fault Tree Representation
D-9	CASE4-LP	LOOP in both units, all DGs in standby
D-10	CASE4-1	LOCA in Unit 1 with LOOP, all DGs in standby
D-11	CASE5	LOOP, Unit 1 dedicated DG out of service
D-12	CASE6	LOCA in Unit 1 with LOOP, Unit 1 dedicated DG out of service

5.3 ALLOWED OUTAGE TIME ANALYSIS

A time dependent unavailability analysis was performed on the fault tree models using the FRANTIC-ABC computer code (Ref. 9). FRANTIC-ABC (FRANTIC) is the PC version of the FRANTIC-III code which is discussed in References 20, 21, and 22. This code calculates the maximum and average time dependent unavailability of a system.

FRANTIC assumes the unavailability of a system is based on a Weibull probability density function. A brief discussion of the most relevant code inputs for this reliability analysis is provided in Table 5-5.

The LAMBDA (Weibull scale) parameter input to the FRANTIC code can be derived in several ways. NUREG-2989, "Reliability of Emergency AC Power Systems at Nuclear Power Plants," (Ref. 23) and "FRANTIC-III - A Computer Code for Time-Dependent Reliability Analysis (User's Manual)," (Ref. 21) discuss the method of estimating this parameter. For the reliability analysis, the failures of the DGs were assumed to be dominated by a time dependency. An estimate of LAMBDA was calculated to be equal to the number of DG failures ("Fail to Start" and "Fail to Run") divided by the time of observation over which the failures occurred.

The cutsets from the top level fault tree case models discussed in Section 5.2.3 were used as input to FRANTIC. Each element of the cutsets is defined as a component in the FRANTIC code. The DGs are represented individually in these cutsets as periodically tested components. Other "components" in the model represent the fuel oil transfer system (a support system) and common cause failures of the DGs. These have a constant unavailability.



Table 5-4 describes the various case models used with the FRANTIC code. Cases 1 and 4 assume all the DGs are in a standby mode and are capable of performing their intended function. These standby cases used a test interval (TEST2 parameter) of 31 days as required by Surveillance Requirement 4.8.1.1.2. The testing occurs on a staggered test basis (TEST1 parameter) pursuant to Reference 1. The start test requires one-half hour to complete (TAU parameter) representing the current situation at DCP. This test duration is used for the 72-hour AOT as well as the 7-day AOT.

The other cases represent situations where one DG is out of service, placing the unit in the subject Action Statement. The unit(s) affected by the Action Statement are required to test the remaining DGs within 24 hours. It was assumed the first remaining DG is tested six hours after entry into the Action Statement. The other DGs are then tested in a sequential manner.

The 7-day AOT cases for the loss of one DG situation also assume the remaining DGs are tested sequentially starting six hours after entry into the Action Statement condition. Consistent with the current practice at DCP, the operable DGs will be tested once within the first 24 hours during the 7-day AOT cases.

The unavailability values calculated with the FRANTIC code are presented in Table 5-6.

5.4 RELIABILITY ANALYSIS RESULTS

Generally, when a component is removed from service for repair or test for a period of time, there is a period of increased vulnerability concerning the fact that the affected system will not be available to mitigate an accident. This period of increased vulnerability exists until the component is restored to service (operable status). Of interest in this study is the relationship of risk to the AOT. Only by explicitly relating risk to AOT can outage times be constrained by placing limits on risk. The relative risk method and the average annual risk comparison method both relate the AOT to the risk, as discussed in NUREG/CR-3082 and presented in this section.



5.4.1 RELATIVE RISK METHOD

The relative risk method limits component (DG) outage time by constraining the risk during the DG outage to be no larger than the risk during a period in which no DG outage occurs. This method is consistent with that used in Chapter 4. The exposure time during the AOT outage is determined by the fraction of time a DG is inoperable while the plant is in Modes 1 through 4. This fraction is assigned a parameter value, f_o , in the analysis. Two sets of values were derived for this f_o parameter: one for the 72-hour AOT, based on DCPD DG outage time records, and one for the 7-day AOT, based on Palisades data.

The DCPD DG outage time records were reviewed to determine when the DGs were declared inoperable due to testing, maintenance/repairs, and failures with either unit in Modes 1 through 4. The outage records were screened to remove biases for 1) any unusual situations which may considerably skew the data, such as the swing DG preplanned maintenance which was performed under a 10-day AOT exemption from Technical Specification 3.8.1.1 (Ref. 8); and 2) the additional time that had been required for maintenance work on the swing DG due to its more complex tag-out and maintenance processes compared to that of dedicated DGs.

A list of the outage times and dates was collected from the Palisades PRA (Ref. 17) and updated with additional Palisades data from EPRI report NSAC-108 (Ref. 18).

Based on the data, f_o was determined for DCPD to be 0.0303 for the 72-hour AOT. The value of f_o for the Palisades 7-day AOT was determined to be 0.0308. Table 5-7 summarizes the DG outage time data for both DCPD and Palisades.

The relative risk criterion, as defined in NUREG/CR-3082, is:

$$R_o \leq R_t$$

where:

R_o = risk during DG outage duration, and

R_t = risk during standby period, assuming no DG outage.



NUREG/CR-3082 states:

If the risk due to a DG AOT during an LCO is less than the risk during a baseline (non-LCO) period, then the risk due to the AOT is considered acceptable."

Consistent with NUREG/CR-3082, the standby period of the relative risk criterion is defined to be that period during which all DGs are available in the normal standby condition; i.e., the standby period is defined by the fraction of time that the DGs are not inoperable and, therefore, is determined as $f_t = 1 - f_o$.

These risks are calculated for each condition analyzed but are distinguished from each other by initiating event. The analyses for two initiating event conditions (LOOP event, LOCA in one unit with a LOOP event) are described below.

LOOP Event:

The risk during the DG outage is the probability of the LOOP event occurring during the DG outage, multiplied by the probability the remaining DG systems fail during that time. The equation used to calculate risk during the DG outage is:

$$R_o = \lambda_1 f_o Q_o$$

where:

λ_1 = initiating event frequency for a LOOP event,

f_o = fraction of time the DG was inoperable as defined above, and

Q_o = system average unavailability with one DG out of service.

The risk during the standby period, or the time the DG is not in an outage, is calculated using the following formula:

$$R_t = \lambda_1 f_t Q_t$$

where:

f_t = fraction of time the DG was operable ($1 - f_o$), i.e., the DG standby time fraction as defined above, and



Q_t = system average unavailability over the period when all five DGs are in normal standby configuration.

The system average and maximum unavailabilities (Q) calculated using FRANTIC are provided in Table 5-6.

LOCA in One Unit with a LOOP Event:

For this event, the risk during the DG outage is the probability that the LOOP event occurs within 24 hours following a large break LOCA in one unit multiplied by the probability the DG system failed during the outage. The equation used to calculate this risk is:

$$R_o = \lambda_2 f_o Q_o$$

where:

λ_2 = frequency of a large break LOCA and LOOP event.


The risk during the standby period with a LOOP event and a large break LOCA is calculated as follows:

$$R_t = \lambda_2 f_t Q_t.$$

The initiating event frequencies (λ) used in the reliability analysis risk calculations are based on the DCPRA initiating event frequencies. The LOOP initiating event frequency is taken directly from the DCPRA, which is $9.10E-02$ /year. The LOCA with a LOOP event is calculated to be the frequency of a large break LOCA occurring ($2.02E-04$ /year) multiplied by the frequency of a LOOP event and is calculated to be $5.04E-08$ /year.

5.4.2 AVERAGE ANNUAL RISK METHOD

The average annual risk considers the status of the DG system. Over a period of time, the status alternates between the periods of an AOT and the normal standby condition of the DG. Thus the average system unavailability is determined over a



cycle. The equations used to calculate the average annual risk for the two conditions analyzed are presented below.

For a LOOP event, the annual risk is calculated by

$$R_a = \lambda_1 (f_o Q_o + f_t Q_t).$$

For a large break LOCA in one unit with a LOOP event, the risk is calculated using

$$R_a = \lambda_2 (f_o Q_o + f_t Q_t).$$

The results of the relative and annual risk quantifications are presented below.


5.4.3 RISK RESULTS

As previously discussed, the reliability analysis considered two methods of calculating risk, the relative risk method and the annual risk method, for the impact of unplanned maintenance activities upon plant risk. These methods will now assist in the comparison of results for the AOT study. Table 5-8 presents the results of the relative risk analysis for three cases:

1. 72-hour AOT with the current five DG configuration,
2. 7-day AOT with the current five DG configuration, and
3. 7-day AOT with the planned six DG configuration.

The average and maximum risks for these cases are listed with the relative risk ratios in Table 5-8. The average annual risk results for the three cases are listed in Table 5-9.

The acceptance criterion, as defined in NUREG/CR-3082, for the relative risk ratio is required to be less than unity. In all cases of the reliability analysis, the results show the relative risk ratios more than satisfy the acceptance criteria, thus indicating the risk while in an LCO Action Statement (DG inoperable) is always much less than the risk while the DGs are all in the standby mode.



Comparing the relative risk values between the 72-hour AOT and the 7-day AOT cases, it can be seen that the risk during the 72-hour LCO Action Statement is much smaller than the risk during the standby period. As shown in Table 5-8, when the AOT is increased to seven days, the resulting ratio of risk during the AOT to the risk during the standby period remains much less than one. In fact, the relative risk ratios for the five DG configuration indicates the risk during the AOT is never more than 10 percent of the risk during the standby period. With the planned six DG configuration, the risk during a 7-day AOT is only 13 percent of the risk during the standby period. These values clearly show the risk associated with a 7-day AOT is acceptable.

Similar results are shown in Table 5-9 for the average annual risk values. Furthermore, with the addition of the sixth DG, the annual risk decreases by approximately 15 percent from the current risk levels. Such a decrease indicates that when the sixth DG is installed with a 7-day AOT, the risk levels during an AOT will be less than that for the five DG configuration with either a 72-hour AOT or a 7-day AOT

5.5 SENSITIVITY STUDY

A sensitivity study was performed to determine the effects of testing the remaining operable DGs every 72 hours during a 7-day AOT rather than just once within the first 24 hours while in the LCO Action Statement. A discussion of the effects of this additional testing is provided below.

The testing procedures at DCPD currently require each remaining operable DG to be start tested within 24 hours of the initiation of the AOT (when the inoperable DG is out for other than preventive maintenance or testing). As a sensitivity study, consideration was given to additional testing of the operable DGs during the 7-day AOT. Specifically, this sensitivity study modeled the operable DGs such that they were tested every 72 hours during the AOT. This additional testing was shown to slightly reduce the risk. However, the need to perform a fast start test on the remaining operable DGs every 72 hours during the 7-day AOT not only imposes additional work on the operating staff, but also contributes to further wear and stress of the DGs. Therefore, the additional testing is not considered beneficial.



TABLE 5-1
DIABLO CANYON DIESEL GENERATOR RELIABILITY DATA BASE

<u>#</u>	<u>COMP</u>	<u>FAILURE MODE</u>	<u>FAILRATE</u>	<u>UNIT</u>	<u>SOURCE</u>
1	BU	BUS FAILS DURING OPERATION	4.48E-07	HR	PG&E
2	GN	GENERATOR FAILURE	1.28E-08	HR	IEEE
3	CB	DC CIRCUIT BREAKER TRANSFERS OPEN	2.68E-07	HR	PG&E
4	DG	DIESEL GENERATOR FAILS TO START (72-HOUR AOT)	3.32E-03	D	DCPP
5	DG	DIESEL GENERATOR FAILS TO RUN (72-HOUR AOT)	2.29E-03	HR	DCPP
6	HE	OPERATOR FAILS TO SWITCH DG TO AUTO AFTER TEST	1.00E-04	D	CALC
7	RE	RELAY FAILS TO OPERATE	2.41E-04	D	PG&E
8	SW	LEVEL SWITCH FAILS TO OPERATE	2.69E-04	D	PG&E
9	TK	TANK RUPTURES DURING OPERATION	2.66E-08	HR	PG&E
10	AV	AIR OPERATED VALVE FAILS TO OPERATE	6.22E-04	D	PG&E
11	AV	AIR OPERATED VALVE TRANSFERS OPEN/CLOSED	2.29E-07	HR	PG&E
12	CV	CHECK VALVE FAILS TO OPERATE	1.70E-04	D	PG&E
13	PV	PRESSURE CONTROL VALVE FAILS DURING OPERATION	3.90E-06	HR	PG&E
14	SV	SOLENOID VALVE FAILURE TO OPERATE	2.43E-03	D	PG&E
15	SV	SOLENOID VALVE TRANSFERS OPEN/CLOSED	1.27E-06	HR	PG&E
16	CB	CIRCUIT BREAKER (>480 V AC) FAILS TO CLOSE	1.61E-03	D	PG&E
17	CB	CIRCUIT BREAKER (>480 V AC) TRANSFERS OPEN	8.28E-07	HR	PG&E
19	CC	COMMON CAUSE FAILURE OF DIESEL GENERATOR	7.40E-04	D	CALC
20	DG	DIESEL GENERATOR AVAILABILITY (5 DGs)	9.84E-01	D	CALC
21	HE	OPERATOR ERROR	1.00E-03	D	CALC
23	HX	HEAT EXCHANGER PLUGGING/EXCESSIVE LEAKAGE	1.54E-06	HR	PG&E
24	SR	STRAINER PLUGS DURING OPERATION	6.22E-06	HR	PG&E
25	FL	FUEL OIL FILTER PLUGGED	1.06E-06	HR	PG&E
26	SW	PRESSURE SWITCH FAILS TO OPERATE	2.69E-04	D	PG&E





TABLE 5-1 (Continued)
DIABLO CANYON DIESEL GENERATOR RELIABILITY DATA BASE

<u>#</u>	<u>COMP</u>	<u>FAILURE MODE</u>	<u>FAILRATE</u>	<u>UNIT</u>	<u>SOURCE</u>
27	TB	TURBO-CHARGER FAILS TO OPERATE	2.73E-04	D	CALC
29	PM	JACKET WATER/LUBE OIL PUMPS FAIL	1.81E-06	HR	IEEE
30	MR	AIR START MOTORS FAIL	3.20E-06	HR	IEEE
31	FN	EXHAUST FANS FAIL TO OPERATE	2.50E-06	HR	IEEE
32	SI	INITIATION SIGNAL FAILS	1.10E-03	D	CALC
33	DG	DIESEL GENERATOR FAILS TO START (7 DAY AOT)	6.37E-03	D	PALS
34	DG	DIESEL GENERATOR FAILS TO RUN (7 DAY AOT)	1.63E-03	HR	PALS
35	DG	COMMON CAUSE FAILURE OF DG (6 DGs)	7.37E-04	D	CALC

NOTES:

- CALC: CALCULATED VALUE
- DCPP: DIABLO CANYON PLANT SPECIFIC DATA
- IEEE: IEEE-500 EQUIPMENT RELIABILITY DATA
- PALS: PALISADES DATA
- PG&E: DIABLO CANYON PRA DATA





**TABLE 5-2
FAULT TREE QUANTIFICATION RESULTS**

Unavailability for Current Diesel Configuration

<u>Tree Name</u>	<u>72-Hour AOT</u>	<u>7 Day AOT</u>
DG11	1.98E-02	2.02E-02
DG13	1.77E-02	1.81E-02
DG13POW2	2.09E-03	2.09E-03
SWITCH1	1.95E-03	1.95E-03

Unavailability for Planned Six Diesel Configuration

<u>Tree Name</u>	<u>7 Day AOT</u>
DG11	1.62E-02
DG13	1.62E-02*
DG13POW2	N/A
SWITCH1	N/A

* The unavailability of DG 1-3 for the six DG configuration is the same as the unavailability of dedicated DG 1-1.





TABLE 5-3
DOMINANT CONTRIBUTORS TO DG 1-1 UNAVAILABILITY

1.	9.16E-03	DG 11 FAILS TO RUN FOR 4 HOURS
2.	3.32E-03	DG 11 FAILS TO START
3.	2.43E-03	FUEL OIL SDV SV-713 FAILS TO CLOSE WHEN DG STARTS
4.	1.61E-03	BREAKER CB 52-HH-7 FAILS TO CLOSE
5.	1.49E-03	DG 11 COMMON CAUSE FAILURES
6.	4.72E-04	FUEL OIL SDV SV-713 TRANSFERS CLOSED PRIOR TO DG START/TRANSFERS OPEN AFTER START
7.	2.73E-04	TURBO-CHARGER FAILS
8.	2.41E-04	UV RELAY 27-HH-B2 FAILS TO ACTUATE
9.	2.41E-04	TRANSFER CONTROL RELAY 4HH FAILS TO ACTUATE
10.	1.70E-04	FUEL OIL CHECK VALVE 1-999 FAILS TO OPERATE
11.	1.70E-04	FUEL OIL CHECK VALVE 1-134 FAILS TO OPERATE
12.	1.00E-04	OPERATOR FAILS TO RETURN DG SWITCH TO AUTO AFTER TEST

DG1-1 UNAVAILABILITY = 1.98E-02



TABLE 5-4
RELIABILITY CASES ANALYZED

CURRENT FIVE DIESEL CONFIGURATION

Calculation 1:	All DGs in Standby
Calculation 1-LP	LOOP event in both units
Calculation 1-1	LOCA in Unit 1 with a LOOP event
Calculation 2:	LOOP Event, AOT Condition (One DG Out of Service)
Calculation 3:	LOCA in Unit 1 with a LOOP event AOT Condition (One DG Out of Service)

PLANNED SIX DIESEL CONFIGURATION

Calculation 4:	All DGs in Standby
Calculation 4-LP	LOOP event in both units
Calculation 4-1	LOCA in Unit 1 with a LOOP event
Calculation 5:	LOOP Event, AOT Condition (One DG Out of Service)
Calculation 6:	LOCA in Unit 1 with a LOOP event AOT Condition (One DG Out of Service)



**TABLE 5-5
FRANTIC COMPONENT INPUTS**

The inputs discussed here are all relevant for periodically tested components in the DG system model. The components other than the DGs are modeled such that only one input, QRESID, is required by FRANTIC.

<u>Input Name</u>	<u>Discussion</u>
LAMBDA	The Weibull distribution scale parameter, estimated to be the number of DG failures per hours of observation (1.60E-04).
TEST2	The periodic testing interval for each component (31 days).
TEST1	The time when the first periodic test occurs. This parameter allows the model to include Staggered Test Basis testing of components as well as sequential and simultaneous testing sequences (Day 1, 2, 11, 12, 21, 22).
TAU	The average duration of the test period (0.5 hours for a DG start test).
QOVRD	The probability that the component cannot transfer from the testing state to the operating state (4.2E-05).
QRESID	A constant unavailability of the component equal to the fault tree calculated unavailabilities.
ITYPE	This parameter is used to model the state of the component after the test. For this study, all periodically tested components, i.e., the DGs, were assumed to be "as good as new" after a test. From the perspective of the FRANTIC code, the components were modeled such that their age is set to zero after the test.





TABLE 5-6
FRANTIC DG SYSTEM UNAVAILABILITY RESULTS

72-HOUR CALCULATIONS:

<u>Calculation</u>	<u>Average Unavailability</u>	<u>Max Unavailability</u>
1-1	2.10E-02	3.80E-02
1-LP	2.45E-03	3.27E-03
2	4.83E-03	5.37E-03
3	5.07E-02	6.17E-02

7 DAY CALCULATIONS:

<u>Calculation</u>	<u>Average Unavailability</u>	<u>Max Unavailability</u>
1-1	2.03E-02	3.83E-02
1-LP	2.48E-03	3.31E-03
2	5.99E-03	7.68E-03
3	6.61E-02	9.18E-02
4-1	1.34E-02	2.49E-02
4-LP	2.16E-03	2.87E-03
5	3.24E-03	4.06E-03
6	5.66E-02	8.18E-02





**TABLE 5-7
DIESEL GENERATOR OUTAGE TIMES**

DCPP

	<u>DG 1-1</u>	<u>DG 1-2</u>	<u>DG 1-3</u>	<u>DG 2-1</u>	<u>DG 2-2</u>	<u>For Both Units</u>
Total outage hours	259	157	388	358	269	1431
Outage hours/ hours plant at power	0.0108	0.0066	0.0164	0.0154	0.0116	0.0303

Total number of DG outages 123

	<u>Unit 1</u>	<u>Unit 2</u>	<u>Total</u>
Total hours plant at power	23978	23309	47287

PALISADES

	<u>DG 1-1</u>	<u>DG 1-2</u>	<u>For both DGs</u>
Total outage hours	557	460	1017
Outage hours/ hours plant at power	0.0169	0.0139	0.0308

Total number of DG outages: 88

Total hours plant at power: 32991





TABLE 5-8
RELATIVE RISK ANALYSIS RESULTS

	<u>Average/ Maximum Risk</u>	<u>Ratio</u>	<u>Standby Risk</u>
<u>72-Hour AOT - 5 DGs</u>			
LOOP	1.33E-05/ 1.48E-05	0.06	2.16E-04
LOOP/LOCA	7.74E-11/ 9.41E-11	0.08	1.03E-09
<u>7-Day AOT - 5 DGs</u>			
LOOP	1.68E-05/ 2.15E-05	0.08	2.19E-04
LOOP/LOCA	1.03E-10/ 1.42E-10	0.10	9.93E-10
<u>7-Day AOT - 6 DGs</u>			
LOOP	9.09E-06/ 1.14E-05	0.05	1.91E-04
LOOP/LOCA	8.78E-11/ 1.27E-10	0.13	6.55E-10





TABLE 5-9
AVERAGE ANNUAL RISK RESULTS

	<u>Annual Risk</u>
<u>72-Hour AOT - 5 DGs</u>	
LOOP	2.29E-04
LOOP/LOCA	1.10E-09
<u>7-Day AOT - 5 DGs</u>	
LOOP	2.35E-04
LOOP/LOCA	1.10E-09
<u>7-Day AOT - 6 DGs</u>	
LOOP	2.00E-04
LOOP/LOCA	7.43E-10





6.0 SUMMARY OF RESULTS

This section discusses the overall results of the AOT determination studies, based on the two approaches of probabilistic risk analysis and the reliability analysis.

Table 6-1 presents the numerical values of the results for the cases analyzed, for both the PRA approach and the reliability analysis approach. The table presents the results for each of the three cases. The PRA analysis provides the risk frequencies for the combined effect of unplanned and planned maintenance activities. The duration to perform technical specification required preventive maintenance is shown for the five DG configuration. These results combine the benefits and impacts of the change from a 3-day to a 7-day AOT period and the elimination of planned maintenance when a unit is at power. The reliability analysis provides results expressed as frequencies of DG unavailability in combination with LOOP or LOOP/LOCA initiators. For both the PRA and reliability analysis, the risk frequencies and relative ratios are shown for the unplanned maintenance activities; the unplanned maintenance results do not account for the benefits of eliminating DG maintenance while at power.

Several observations can be made from these results.

1. The frequencies for all cases are acceptably low (in the E-4 range).
2. The relative risk ratio criterion is satisfied for all cases by both methods of analysis.
3. The effect of changing from a 72-hour to a 7-day AOT is insignificant, on the order of 1 percent to 3 percent.
4. The effect of adding the sixth DG is greater than the effect of changing to a 7-day AOT, with a decrease on the order of 5 percent to 15 percent.
5. The two analyses provide results which are consistent. The trends of the results for the three cases are comparable between the PRA and reliability analyses. Further, the magnitude of the frequency results are comparable between the two different quantitative approaches.



Overall, the risk and reliability analyses show low levels of risk with the multiple 72-hour AOTs for the five DG configuration, and the risk levels do not change significantly when the AOT is changed to seven days. The slight increase in risk in changing to a 7-day AOT may be generally attributed to the longer period of time the DGs are unavailable in the AOT condition due to an assumed longer maintenance duration (see Section 4.2). However, the increase is insignificant when compared to the overall uncertainty in plant risk, as determined in the DCPRA. Furthermore, it is no longer necessary to use multiple DG outages as in the 72-hour AOT situation, and the risk levels remained low with the 7-day AOT because effective maintenance practices will continue to minimize the time needed to perform DG maintenance regardless of the AOT period.

More specifically, without a 7-day AOT, Technical Specification Surveillance Requirement 4.8.1.1.2b for the Unit 1 third and fourth refueling outages would have to be scheduled to be performed in several 72-hour periods in accordance with the present Technical Specification 3.8.1.1 AOT. However, it would be more efficient to perform the surveillances in one 7-day period. Performing the surveillances in one 7-day period would result in DG 1-3 total out-of-service time being less than if they were performed in several 72-hour periods. Likewise, performing the maintenance in several 72-hour periods requires more DG testing than if the maintenance were performed in one 7-day period. This additional testing is necessary because the DG must be tested and subsequently declared operable at the end of each 72-hour period. In addition, performing all maintenance activities in a single 7-day AOT should minimize the possibility for turnover and other related operator errors. Further, with an increase in the AOT, maintenance personnel would be given more flexibility to perform their repairs and would in turn increase the thoroughness and quality of the maintenance process.

Moreover, the risk and reliability analyses show that the risk levels during the AOTs are significantly less than the plant risk during the time the plant is normally operating with the DGs in a standby condition for the five DG configuration. Risks in the AOT are small because effective maintenance practices minimize the time the DG is actually unavailable, thus making the period of DG unavailability short compared to the DG standby period.



Finally, the analyses show that the risk levels decrease when the sixth DG is installed. This decrease in risk is attributable to the elimination of the swing DG configuration, along with the inclusion of a third dedicated DG to each unit; thus assuring that each unit has a full complement of emergency onsite supply. Further, scheduled maintenance activities do not have to be performed with a unit at power.

In summary, the reliability analysis approach focuses on the situation where a DG is out of service due to reasons other than scheduled or preventive maintenance. The analysis demonstrated that the risk levels are essentially unchanged when the AOT is changed from 72 hours to seven days, and remain much less than the risk levels from normal plant operation when the DGs are in the standby condition. This result is due to increased availability of the remaining DGs, which are demonstrated by the testing of these remaining DGs in the first 24 hours after a DG is declared inoperable.

These risk variations are confirmed by the PRA analysis; the risk values resulting from the PRA for the 7-day AOT show a small change from that of the 72-hour AOT. The PRA approach, however, includes consideration of both scheduled/preventive maintenance as well as unplanned maintenance. In particular, the PRA demonstrated that a planned DG outage, utilizing several 72-hour AOT periods for a maintenance activity, and a planned or unplanned DG outage with a 7-day AOT result in a decrease in the risk level for the 7-day AOT. Furthermore, the risk levels following installation of the sixth DG are less than those for the five DG configuration, as shown by both the reliability analyses and the PRA, for both the unplanned maintenance situation and for scheduled/preventive maintenance.



TABLE 6-1
ANALYTICAL RESULTS⁽¹⁾
FOR UNPLANNED AND PLANNED MAINTENANCE ACTIVITIES

	<u>PRA Analysis</u>			<u>Reliability Analysis (Unplanned)</u>	
	<u>Unplanned & Planned⁽²⁾</u>	<u>Unplanned</u>		<u>Frequency</u>	<u>Relative Ratio⁽³⁾</u>
	<u>Frequency</u>	<u>Frequency</u>	<u>Relative Ratio⁽³⁾</u>		
<u>BASE CASE</u>					
3-Day AOT/5 DGs (10 day Outage) ⁽²⁾	2.12E-04	2.08E-04	0.05	LOOP 2.29E-04 LOCA/ LOOP 1.10E-09	0.06 0.08
<u>CASE 2</u>					
7-Day AOT/5 DGs (7 day Outage) ⁽²⁾	2.15E-04	2.12E-04	0.08	LOOP 2.35E-04 LOCA/ LOOP 1.10E-09	0.08 0.10
<u>CASE 3</u>					
7-Day AOT/6 DGs (0 day) ⁽²⁾	2.02E-04	2.02E-04	0.08	LOOP 2.00E-04 LOCA/ LOOP 7.43E-10	0.05 0.13

- (1) PRA reflects frequency for Unit 1 only, whereas reliability considers frequency for both units
(2) Duration of outage for planned maintenance.
(3) AOT Risk Level/Non-AOT Risk Level



7.0 CONCLUSIONS

PG&E has previously implemented activities to improve DG reliability at DCPD. As part of these activities, PG&E is planning to install a sixth DG and has committed significant resources to this effort. Further, PG&E has performed this study to determine an appropriate AOT for DCPD. This study focused on the assessment of two issues: (1) the appropriateness of a 7-day AOT for the purposes of unplanned maintenance for the current five DG and future six DG configurations and (2) the impact of a 7-day AOT for preplanned Technical Specification required maintenance activities.

Two different probabilistic calculation methods were used, both of which have been previously reviewed and accepted by the NRC. PG&E's plant specific DCPRA, which is currently under review by the NRC Staff, was used to find time-averaged risks involved with both planned and unplanned maintenance. A DCPD specific reliability analysis was also performed to assess the time-dependent risk involved in an AOT for unplanned maintenance, which require testing of the remaining DGs. PG&E believes that conservatism is present in both these analyses which provide margins to further support the validity of the qualitative conclusions.

Both methodologies were used to analyze three different cases: the base case addresses the current situation of five DGs with a 72-hour AOT; the second case addresses a similar situation but with a 7-day AOT; and the third case addresses six DGs with a 7-day AOT.

Using a relative risk criterion developed by Brookhaven National Laboratory (Ref. 3) that was previously reviewed and accepted by the NRC (Ref. 2), both of these methods confirm the acceptability of a 7-day AOT for the purposes of performing unplanned maintenance for both the five and six DG configurations. In particular, the relative risk ratios for all cases were determined to be significantly less than one; that is, the risk level during the DG AOT was found to be significantly less than the risk level during the non-AOT period when all DGs are in a normal standby condition while the plant is in Modes 1 through 4.



Furthermore, the risk-based PRA evaluation also demonstrated that there is an insignificant change in risk associated with a 7-day AOT over a 72-hour AOT and that there are slight qualitative and quantitative benefits in performing Technical Specification required maintenance with a 7-day AOT. The risk-based PRA and the reliability analyses also determined that addition of the sixth diesel will have a positive benefit by reducing risk over the life of the plant. In summary, quantitative and qualitative analyses confirm that the 7-day AOT, along with addition of the sixth diesel in the fourth refueling outage of Unit 2, will improve overall DG system reliability and will provide both short term and long term benefits to the safe operation of the plant.



8.0 REFERENCES

1. Diablo Canyon Power Plant Technical Specifications, Appendix A to Facility Operating Licenses Numbers DPR-80 and DPR-02.
2. Sylvester, E.D., Issuance of Amendments Nos. 104 and 134 to Facility Operating Nos. DPR-71 and DPR-62 for the Brunswick Steam Electric Plants, Units 1 and 2, March 27, 1989.
3. Lofgren, E.V. and F. Varcolik, "Probabilistic Approaches to LCO's and Surveillance Requirements For Standby Safety Systems", November, 1982, NUREG/CR-3082, (BNL-NUREG-51628).
4. Pacific Gas and Electric Company, "Documentation of Long-term Seismic Program Probabilistic Risk Assessment," DCL-88-260, October 28, 1988.
5. Carolina Power and Light Company, "Brunswick Steam Electric Plant, Unit Nos. 1 and 2, Docket Nos. 50-325 & 50-324/License Nos. DPR-71 and DPR-62, Request for License Amendment, Diesel Generator Operability, Enclosure to NLS-85-516, Proposed Technical Specification Pages," 85TSB01, June 28, 1985.
6. "Proposed Staff Actions to Improve and Maintain Diesel Generator Reliability," Generic Letter 84-15, and Regulatory Guide 1.108, Rev. 1, August, 1977.
7. PG&E License Amendment Request 85-12, DCL-85-329, October 25, 1985.
8. PG&E License Amendment Request 85-15, DCL-85-375, December 26, 1985.
9. Ginzburg, T., Jacquez, G. M. and Vesely, W. E., "FRANTIC ABC User's Manual - Time Dependent Reliability Analysis," Applied Biomathematics, Inc., 100 North Country Road, Setauket, N.Y., 11733, December 1988.
10. DCPP System Description - Electrical Systems, Revision 1, 1987.





11. PG&E, "Units 1 and 2 Diablo Canyon Power Plant Final Safety Analysis Report Update," Docket No. 50-275 and 50-323.
12. PG&E, Diablo Canyon Units 1 and 2, "Station Blackout," April 17, 1989.
13. Memorandum from Nuclear Engineering and Construction Services to Nuclear Regulatory Affairs, Dated March 27, 1989, re: 10 CFR 50.63, Station Blackout Engineering Evaluation.
14. PG&E, "Final Report of the Diablo Canyon Longterm Seismic Program", July, 1988; Docket Nos 50-275 And 50-323.
15. Lin, J.C. and Stan Kaplan, "SEIS4 (Seismic Risk Assessment) Computer Code User's Manual", December, 1985, PLG-0287.
16. EPRI NP-3967, "Classification and Analysis of Reactor Operating Experience Involving Dependent Failures," Pickard, Lowe and Garrick, Fleming, K.N, et al., Sponsored by Electric Power Research Institute, June 1985.
17. Consumers Power Company, "Palisades Plant - Evaluation of Palisades - MSLB Single-Failure Backfits," Appendix 4, Docket No. 50-255, August 21, 1984.
18. "The Reliability of Emergency Diesel Generators at U.S. Nuclear Power Plants," EPRI Report NSAC 108, September, 1986.
19. "I.E.E.E. Guide to the Collection and Presentation of Electrical, Electronic, Sensing Component, and Mechanical Equipment Reliability Data for Nuclear-Power Generating Stations," IEEE Std 500-1984, Institute of Electrical and Electronics Engineers, Inc., 1983.
20. Ginzburg, T. and Powers, J. T., "FRANTIC III - A Computer Code for Time-Dependent Reliability Analysis (Methodology Manual)," Brookhaven National Laboratory, Upton, Long Island, New York, 11973, April 1, 1984.



21. Ginzburg, T. and Powers, J. T., "FRANTIC III - A computer code for Time-Dependent Reliability Analysis (User's Manual)," Brookhaven National Laboratory, Upton, Long Island, New York, 11973, August 20, 1986.
22. FRANTIC, "A Computer Code for Time Dependent Unavailability Analysis," NUREG-0193, March, 1977.
23. NUREG-2989, "Reliability of Emergency AC Power Systems at Nuclear Power Plants".





APPENDIX A: DIESEL GENERATOR EQUATIONS
 Figure A-1: Base System Equations From the DCPRA
 Reference: PGE.1123.2 RISKMAN3.PHASE3 SEISPH3B EPDGS.EQS

GF1	1 GF1	= P[1]
GF1	2 TOTAL	= HW + TS + MN
GF1	3 HW	= HWI + HWD
GF1	4 HWI	= HWI1
GF1	5 HWD	= HWD1
GF1	6 TS	= TS1 + TS5
GF1	7 MN	= MN1
GF1	8 SEIS	= SEIST
GG1	1 GG1	= (P[1]-P[2])/(1-P[1])
GG1	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
GG2	1 GG2	= P[2]/P[1]
GG2	2 TOTAL	= HW + TS + MN
GG2	3 HW	= HWI + HWD
GG2	4 HWI	= HWI2
GG2	5 HWD	= HWD2
GG2	6 TS	= 2*TS1*HW1 + TS5
GG2	7 MN	= 2*MN1*HW1 + 2*T1M
GG2	8 SEIS	= SEIST
GG3	1 GG3	= P[1]
GG3	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
GH1	1 GH1	= (P[1]-2*P[2]+P[3])/(1-2*P[1]+P[2])
GH1	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
GH2	1 GH2	= (P[2]-P[3])/(P[1]-P[2])
GH2	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
GH3	1 GH3	= P[3]/P[2]
GH3	2 TOTAL	= HW + TS + MN
GH3	3 HW	= HWI + HWD
GH3	4 HWI	= HWI3
GH3	5 HWD	= HWD3
GH3	6 TS	= 3*TS1*HW2 + TS5
GH3	7 MN	= 3*MN1*HW2 + 6*T1M*HW1
GH3	8 SEIS	= SEIST
GH4	1 GH4	= (P[1]-P[2])/(1-P[1])
GH4	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
GH5	1 GH5	= P[2]/P[1]

CSF for GF given: All support available.
 Total for P[1].

CSF for GG given: GF-S
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GG given: GF-F
 Total for P[2].

CSF for GG given: GF-B
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-S, GG-S
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-S/F, GG-F/S
 Total for P[2]. See GG2 for breakdown of P[2].
 CSF for GH given: GF-F, GG-F
 Total for P[3].

CSF for GH given: GF-S/B, GG-B/S
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-F/B, GG-B/F



GH5 2 TOTAL = HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
 GH6 1 GH6 = P[1]
 GH6 2 TOTAL = HWI1 + HWD1 + TS1 + MN1 + TS5
 2G1 1 2G1 = (P[1]-3*P[2] + 3*P[3]-P[4])/(1-3*P[1] + 3*P[2]-P[3])
 2G1 2 TOTAL = HWI1 + HWD1 + TS1 + MN1 + TS5
 2G2 1 2G2 = (P[2]-2*P[3] + P[4])/(P[1]-2*P[2] + P[3])
 2G2 2 TOTAL = HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
 2G3 1 2G3 = (P[3]-P[4])/(P[2]-P[3])
 2G3 2 TOTAL = HWI3 + X2G32
 2G3 2X2G32 = HWD3 + 3*TS1*HW2 + 3*MN1*HW2 + 6*T1M*HW1 + TS5
 2G4 1 2G4 = P[4]/P[3]
 2G4 2 TOTAL = HW + TS + MN

 2G4 3 HW = HWI + HWD
 2G4 4 HWI = HWI4
 2G4 5 HWD = HWD4
 2G4 6 TS = 4*TS1*HW3 + TS5
 2G4 7 MN = 4*MN1*HW3 + 12*T1M*HW2
 2G4 8 SEIS = SEIST
 2G5 1 2G5 = (P[1]-2*P[2] + P[3])/(1-2*P[1] + P[2])
 2G5 2 TOTAL = HWI1 + HWD1 + TS1 + MN1 + TS5
 2G6 1 2G6 = (P[2]-P[3])/(P[1]-P[2])
 2G6 2 TOTAL = HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
 2G7 1 2G7 = P[3]/P[2]
 2G7 2 TOTAL = HWI3 + X2G72
 2G7 2X2G72 = HWD3 + 3*TS1*HW2 + 3*MN1*HW2 + 6*T1M*HW1 + TS5
 2G8 1 2G8 = (P[1]-P[2])/(1-P[1])
 2G8 2 TOTAL = HWI1 + HWD1 + TS1 + MN1 + TS5
 2G9 1 2G9 = P[2]/P[1]
 2G9 2 TOTAL = HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
 2GA 1 2GA = P[1]
 2GA 2 TOTAL = HWI1 + HWD1 + TS1 + MN1 + TS5
 2H1 1 2H1 = (P[1]-4*P[2] + 6*P[3]-4*P[4] + P[5])/X2H11
 2H1 1X2H11 = (1-4*P[1] + 6*P[2]-4*P[3] + P[4])
 2H1 2 TOTAL = HWI1 + HWD1 + TS1 + MN1 + TS5
 2H2 1 2H2 = (P[2]-3*P[3] + 3*P[4]-P[5])/(P[1]-3*P[2] + 3*P[3]-P[4])
 2H2 2 TOTAL = HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
 2H3 1 2H3 = (P[3]-2*P[4] + P[5])/(P[2]-2*P[3] + P[4])
 2H3 2 TOTAL = HWI3 + X2H32

Total for P[2]. See GG2 for breakdown of P[2].

CSF for GH given: GF-B, GG-B

Total for P[1]. See GF1 for breakdown of P[1].

CSF for 2G given: GF-S; GG-S, GH-S

Total for P[1]. See GF1 for breakdown of P[1].

CSF for 2G given: GF-S/S/F, GG-S/F/S, GH-F/S/S

Total for P[2]. See GG2 for breakdown of P[2].

CSF for 2G given: GF-S/F/F, GG-F/F/S, GH-F/S/F

Total for P[3]. See GH3 for breakdown of P[3].

CSF for 2G given: GF-F, GG-F, GH-F

Total for P[4].

CSF for 2G given: GF-S/S/B, GG-S/B/S, GH-B/S/S

Total for P[1]. See GF1 for breakdown of P[1].

CSF for 2G given: GF&GG-GH:S&FB/BF, F&BS/SB, B&FS/SF

Total for P[2]. See GG2 for breakdown of P[2].

CSF for 2G given: GF-F/F/B, GG-F/B/F, GH-B/F/F

Total for P[3]. See GH3 for breakdown of P[3].

CSF for 2G given: GF-S/B/B, GG-B/S/B, GH-B/B/S

Total for P[1]. See GF1 for breakdown of P[1].

CSF for 2G given: GF-F/B/B, GG-B/F/B, GH-B/B/F

Total for P[2]. See GG2 for breakdown of P[2].

CSF for 2G given: GF-B, GG-B, GH-B

Total for P[1]. See GF1 for breakdown of P[1].

CSF for 2H given: GF-GG&GH-2G: SS&SS

Total for P[1]. See GF1 for breakdown of P[1].

CSF for 2H given: GF-GG&GH-2G: SS&SF/FS, SF/FS&SS

Total for P[2]. See GG2 for breakdown of P[2].

CSF-2H: GF-GG&GH-2G: FS/SF&SF/FS, SS&FF, FF&SS

Total for P[3]. See GH3 for breakdown of P[3].





2H3	2 X2H32	= HWD3 + 3*TS1*HW2 + 3*MN1*HW2 + 6*T1M*HW1 + TS5
2H4	1 2H4	= (P[4]-P[5])/(P[3]-P[4])
2H4	2 TOTAL	= HWI4 + X2H42
2H4	2 X2H42	= HWD4 + 4*TS1*HW3 + 4*MN1*HW3 + 12*T1M*HW2 + TS5
2H5	1 2H5	= P[5]/P[4]
2H5	2 TOTAL	= HW + TS + MN
2H5	3 HW	= HWI + HWD
2H5	4 HWI	= HWI5
2H5	5 HWD	= HWD5
2H5	6 TS	= 5*TS1*HW4 + TS5
2H5	7 MN	= 5*MN1*HW4 + 20*T1M*HW3
2H5	8 SEIS	= SEIST
2H6	1 2H6	= (P[1]-3*P[2] + 3*P[3]-P[4])/(1-3*P[1] + 3*P[2]-P[3])
2H6	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
2H7	1 2H7	= (P[2]-2*P[3] + P[4])/(P[1]-2*P[2] + P[3])
2H7	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
2H8	1 2H8	= (P[3]-P[4])/(P[2]-P[3])
2H8	2 TOTAL	= HWI3 + X2H82
2H8	2 X2H82	= HWD3 + 3*TS1*HW2 + 3*MN1*HW2 + 6*T1M*HW1 + TS5
2H9	1 2H9	= P[4]/P[3]
2H9	2 TOTAL	= HWI4 + X2H92
2H9	2 X2H92	= HWD4 + 4*TS1*HW3 + 4*MN1*HW3 + 12*T1M*HW2 + TS5
2HA	1 2HA	= (P[1]-2*P[2] + P[3])/(1-2*P[1] + P[2])
2HA	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
2HB	1 2HB	= (P[2]-P[3])/(P[1]-P[2])
2HB	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
2HC	1 2HC	= P[3]/P[2]
2HC	2 TOTAL	= HWI3 + X2HC2
2HC	2 X2HC2	= HWD3 + 3*TS1*HW2 + 3*MN1*HW2 + 6*T1M*HW1 + TS5
2HD	1 2HD	= (P[1]-P[2])/(1-P[1])
2HD	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
2HE	1 2HE	= P[2]/P[1]
2HE	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + 2*T1M + TS5
2HG	1 2HG	= P[1]
2HG	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5
SW0	1 SW0	= 0.0
SW1	1 SW1	= 0.5
SW2	1 SW2	= 0.5*ZHESW1
SW3	1 SW3	= 0.5 + 0.5*(1-ZHESW1)

CSF for 2H given: GF-GG&GH-2G: SF/FS&FF, FF&SF/FS
Total for P[4]. See 2G4 for breakdown of P[4].

CSF for 2H given: GF-GG&GH-2G: FF&FF
Total for P[5].

CSF for 2H given: GF-GG&GH-2G: SS&SB/BS, SB/BS&SS
Total for P[1]. See GF1 for breakdown of P[1].
CSF-2H: Two DGs succeed, one fails, one bypassed.
Total for P[2]. See GG2 for breakdown of P[2].
CSF-2H: Two DGs fail, one succeeds, one bypassed.
Total for P[3]. See GH3 for breakdown of P[3].

CSF for 2H given: GF-GG&GH-2G: FF&FB/BF, FB/BF&FF
Total for P[4]. See 2G4 for breakdown of P[4].

CSF-2H: GF-GG&GH-2G: SB/BS&BS/SB, SS&BB, BB&SS
Total for P[1]. See GF1 for breakdown of P[1].
CSF-2H: Two DGs bypassed, one fails, one succeeded.
Total for P[2]. See GG2 for breakdown of P[2].
CSF-2H: GF-GG&GH-2G: FB/BF&BF/FB, FF&BB, BB&FF
Total for P[3]. See GH3 for breakdown of P[3].

CSF for 2H given: GF-GG&GH-2G: SB/BS&BB, BB&SB/BS
Total for P[1]. See GF1 for breakdown of P[1].
CSF for 2H given: GF-GG&GH-2G: FB/BF&BB, BB&FB/BF
Total for P[2]. See GG2 for breakdown of P[2].
CSF for 2H given: GF-GG&GH-2H: BB&BB
Total for P[1]. See GF1 for breakdown of P[1].
All branch points for LOCA initiating event.
LOSP with equal number of DG operating on each unit.
LOSP with more DGs aligned to unit 2 than unit 1.
LOSP with more DGs aligned to unit 1 than unit 2.



$P[1] = TOT1 + SEIST - SEIST * TOT1$
 $TOT1 = HW1 * F1 + MN1 + TS1 + TS5$
 $P[2] = TOT2 + SEIST - SEIST * TOT2$
 $TOT2 = HW2 * F2 + (2 * MN1 - 2 * TIM) * HW1 + 2 * TS1 * HW1 + 2 * TIM + TS5$
 $P[3] = TOT3 + SEIST - SEIST * TOT3$
 $TOT3 = HW3 * F3 + (3 * MN1 - 6 * TIM) * HW2 + 3 * TS1 * HW2 + 6 * TIM * HW1 + TS5$
 $P[4] = TOT4 + SEIST - SEIST * TOT4$
 $TOT4 = HW4 * F4 + (4 * MN1 - 12 * TIM) * HW3 + 4 * TS1 * HW3 + 12 * TIM * HW2 + TS5$
 $P[5] = TOT5 + SEIST - SEIST * TOT5$
 $TOT5 = HW5 * F5 + (5 * MN1 - 20 * TIM) * HW4 + 5 * TS1 * HW4 + 20 * TIM * HW3 + TS5$
 $F1 = (1 - MN1 - TS1 - TS5)$
 $F2 = (1 - 2 * MN1 - 2 * TS1 - TS5)$
 $F3 = (1 - 3 * MN1 - 3 * TS1 - TS5)$
 $F4 = (1 - 4 * MN1 - 4 * TS1 - TS5)$
 $F5 = (1 - 5 * MN1 - 5 * TS1 - TS5)$
 $HW1 = HWI1 + HWD1$
 $HW2 = HWI2 + HWD2$
 $HW3 = HWI3 + HWD3$
 $HW4 = HWI4 + HWD4$
 $HW5 = HWI5 + HWD5$
 $HWI1 = 1 * HEV * IV + 1 * ID$
 $HWI2 = 2 * HEV * ID * IV + 1 * HEV * IV * IV + 1 * ID * ID$
 $HWI3 = 3 * HEV * ID * ID * IV + 3 * HEV * ID * IV * IV + 1 * HEV * IV * IV * IV + 1 * ID * ID * ID$
 $HWI4 = 4 * HEV * ID * ID * ID * IV + 6 * HEV * ID * ID * IV * IV + ZI401$
 $ZI401 = 4 * HEV * ID * IV * IV * IV + 1 * HEV * IV * IV * IV * IV + 1 * ID * ID * ID * ID$
 $HWI5 = 5 * HEV * ID * ID * ID * ID * IV + 10 * HEV * ID * ID * ID * IV * IV + ZI501$
 $ZI501 = 10 * HEV * ID * ID * IV * IV * IV + 5 * HEV * ID * IV * IV * IV * IV + ZI502$
 $ZI502 = 1 * HEV * IV * IV * IV * IV * IV + 1 * ID * ID * ID * ID * ID$
 $HWD1 = 4 * DV * HEV + 1 * GD + 1 * GV * HEV + 6 * HEV * TV + 6 * TD$
 $HWD2 = 1 * DD + 9 * DD * DD + 18 * DD * DV * HEV + 6 * DD * HEV * IV + ZD201$
 $ZD201 = 18 * DD * HEV * TV + 6 * DD * ID + 18 * DD * TD + 9 * DV * DV * HEV + ZD202$
 $ZD202 = 1 * DV * HEV + 6 * DV * HEV * ID + 6 * DV * HEV * IV + 18 * DV * HEV * TD + ZD203$
 $ZD203 = 18 * DV * HEV * TV + 1 * GD + 1 * GV * HEV + 6 * HEV * ID * TV + ZD204$
 $ZD204 = 6 * HEV * IV * TD + 6 * HEV * IV * TV + 18 * HEV * TD * TV + 3 * HEV * TV + ZD205$
 $ZD205 = 9 * HEV * TV * TV + 6 * ID * TD + 3 * TD + 9 * TD * TD$
 $HWD3 = 8 * DD * DD * DD + 24 * DD * DD * DV * HEV + 12 * DD * DD * HEV * IV + ZD301$
 $ZD301 = 12 * DD * DD * HEV * TV + 12 * DD * DD * ID + 12 * DD * DD * TD + ZD302$
 $ZD302 = 24 * DD * DV * DV * HEV + 18 * DD * DV * HEV + 24 * DD * DV * HEV * ID + ZD303$
 $ZD303 = 24 * DD * DV * HEV * IV + 24 * DD * DV * HEV * TD + ZD304$

Total single train unavailability.

Total two train unavailability.

Total three train unavailability.

Total four train unavailability.

Total five train unavailability.

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Single train total hardware failures.

Two train total hardware failures.

Three train total hardware failures.

Four train total hardware failures.

Five train total hardware failures.

Single train independent hardware failure.

Two train independent hardware failure.

Three train independent hardware failure.

Four train independent hardware failure.

Five train independent hardware failure.

Single train dependent hardware failures.

Two train dependent hardware failures.

Three train dependent hardware failures.



ZD304 = 24*DD*DV*HEV*TV + 12*DD*HEV*ID*IV + ZD305
 ZD305 = 12*DD*HEV*ID*TV + 3*DD*HEV*IV + 6*DD*HEV*IV*IV + ZD306
 ZD306 = 12*DD*HEV*IV*TD + 12*DD*HEV*IV*TV + ZD307
 ZD307 = 12*DD*HEV*TD*TV + 27*DD*HEV*TV + 6*DD*HEV*TV*TV + ZD308
 ZD308 = 3*DD*ID + 6*DD*ID*ID + 12*DD*ID*TD + 27*DD*TD + ZD309
 ZD309 = 6*DD*TD*TD + 8*DV*DV*DV*HEV + 9*DV*DV*HEV + ZD310
 ZD310 = 12*DV*DV*HEV*ID + 12*DV*DV*HEV*IV + ZD311
 ZD311 = 12*DV*DV*HEV*TD + 12*DV*DV*HEV*TV + 3*DV*HEV*ID + ZD312
 ZD312 = 6*DV*HEV*ID*ID + 12*DV*HEV*ID*IV + 12*DV*HEV*ID*TD + ZD313
 ZD313 = 12*DV*HEV*ID*TV + 3*DV*HEV*IV + 6*DV*HEV*IV*IV + ZD314
 ZD314 = 12*DV*HEV*IV*TD + 12*DV*HEV*IV*TV + 27*DV*HEV*TD + ZD315
 ZD315 = 6*DV*HEV*TD*TD + 12*DV*HEV*TD*TV + 27*DV*HEV*TV + ZD316
 ZD316 = 6*DV*HEV*TV*TV + 1*GD + 1*GV*HEV + 3*HEV*ID*ID*TV + ZD317
 ZD317 = 6*HEV*ID*IV*TD + 12*HEV*ID*IV*TV + 6*HEV*ID*TV + ZD318
 ZD318 = 3*HEV*ID*TV*TV + 3*HEV*IV*IV*TD + 3*HEV*IV*IV*TV + ZD319
 ZD319 = 6*HEV*IV*TD + 3*HEV*IV*TD*TD + 6*HEV*IV*TD*TV + ZD320
 ZD320 = 6*HEV*IV*TV + 6*HEV*IV*TV*TV + 36*HEV*TD*TV + ZD321
 ZD321 = 3*HEV*TD*TV*TV + 1*HEV*TV + 18*HEV*TV*TV + ZD322
 ZD322 = 1*HEV*TV*TV*TV + 3*ID*ID*TD + 6*ID*TD + 3*ID*TD*TD + ZD323
 ZD323 = 1*TD + 18*TD*TD + 1*TD*TD*TD
 HWD4 = 3*DD*DD + 22*DD*DD*DD + 1*DD*DD*DD*DD + ZD401
 ZD401 = 4*DD*DD*DD*DV*HEV + 4*DD*DD*DD*HEV*IV + ZD402
 ZD402 = 4*DD*DD*DD*ID + 6*DD*DD*DV*DV*HEV + ZD403
 ZD403 = 66*DD*DD*DV*HEV + 12*DD*DD*DV*HEV*ID + ZD404
 ZD404 = 12*DD*DD*DV*HEV*IV + 12*DD*DD*HEV*ID*IV + ZD405
 ZD405 = 24*DD*DD*HEV*IV + 6*DD*DD*HEV*IV*IV + ZD406
 ZD406 = 42*DD*DD*HEV*TV + 24*DD*DD*ID + 6*DD*DD*ID*ID + ZD407
 ZD407 = 42*DD*DD*TD + 4*DD*DV*DV*DV*HEV + 66*DD*DV*DV*HEV + ZD408
 ZD408 = 24*DD*DV*DV*HEV*ID + 6*DD*DV*HEV + 48*DD*DV*HEV*ID + ZD409
 ZD409 = 12*DD*DV*HEV*ID*ID + 24*DD*DV*HEV*ID*IV + ZD410
 ZD410 = 48*DD*DV*HEV*IV + 12*DD*DV*HEV*IV*IV + ZD411
 ZD411 = 84*DD*DV*HEV*TD + 84*DD*DV*HEV*TV + ZD412
 ZD412 = 12*DD*HEV*ID*ID*IV + 12*DD*HEV*ID*IV + ZD413
 ZD413 = 12*DD*HEV*ID*IV*IV + 36*DD*HEV*ID*TV + ZD414
 ZD414 = 6*DD*HEV*IV*IV + 4*DD*HEV*IV*IV*IV + ZD415
 ZD415 = 36*DD*HEV*IV*TD + 84*DD*HEV*IV*TV + 22*DD*HEV*TV + ZD416
 ZD416 = 24*DD*HEV*TV*TV + 6*DD*ID*ID + 4*DD*ID*ID*ID + ZD417
 ZD417 = 36*DD*ID*TD + 22*DD*TD + 24*DD*TD*TD + ZD418
 ZD418 = 1*DV*DV*DV*DV*HEV + 22*DV*DV*DV*HEV + ZD419

Four train dependent hardware failures.





ZD419 = 4*DV*DV*DV*HEV*ID + 4*DV*DV*DV*HEV*IV + ZD420
 ZD420 = 3*DV*DV*HEV + 24*DV*DV*HEV*ID + 6*DV*DV*HEV*ID*ID + ZD421
 ZD421 = 12*DV*DV*HEV*ID*IV + 24*DV*DV*HEV*IV + ZD422
 ZD422 = 6*DV*DV*HEV*IV*IV + 42*DV*DV*HEV*TD + ZD423
 ZD423 = 42*DV*DV*HEV*TV + 6*DV*HEV*ID*ID + ZD424
 ZD424 = 4*DV*HEV*ID*ID*ID + 12*DV*HEV*ID*ID*IV + ZD425
 ZD425 = 12*DV*HEV*ID*IV + 12*DV*HEV*ID*IV*IV + ZD426
 ZD426 = 12*DV*HEV*ID*TD + 36*DV*HEV*ID*TV + 6*DV*HEV*IV*IV + ZD427
 ZD427 = 4*DV*HEV*IV*IV*IV + 36*DV*HEV*IV*TD + ZD428
 ZD428 = 36*DV*HEV*IV*TV + 22*DV*HEV*TD + 24*DV*HEV*TD*TD + ZD429
 ZD429 = 48*DV*HEV*TD*TV + 22*DV*HEV*TV + 24*DV*HEV*TV*TV + ZD430
 ZD430 = 1*GD + 1*GV*HEV + 6*HEV*ID*ID*TV + ZD431
 ZD431 = 48*HEV*ID*IV*TD + 4*HEV*ID*TV + 12*HEV*ID*TV*TV + ZD432
 ZD432 = 6*HEV*IV*IV*TD + 6*HEV*IV*IV*TV + 4*HEV*IV*TD + ZD433
 ZD433 = 36*HEV*IV*TD*TD + 4*HEV*IV*TV + 24*HEV*IV*TV*TV + ZD434
 ZD434 = 42*HEV*TD*TV + 12*HEV*TD*TV*TV + 21*HEV*TV*TV + ZD435
 ZD435 = 4*HEV*TV*TV*TV + 6*ID*ID*TD + 4*ID*TD + 12*ID*TD*TD + ZD436
 ZD436 = 21*TD*TD + 4*TD*TD*TD
 HWDS = 30*DD*DD*DD + 5*DD*DD*DD*DD + 20*DD*DD*DD*DV*HEV + ZD501
 ZD501 = 20*DD*DD*DD*HEV*IV + 20*DD*DD*DD*ID + ZD502
 ZD502 = 30*DD*DD*DV*DV*HEV + 90*DD*DD*DV*HEV + ZD503
 ZD503 = 60*DD*DD*DV*HEV*ID + 60*DD*DD*DV*HEV*IV + ZD504
 ZD504 = 60*DD*DD*HEV*ID*IV + 15*DD*DD*HEV*IV + ZD505
 ZD505 = 30*DD*DD*HEV*IV*IV + 90*DD*DD*HEV*TV + 15*DD*DD*ID + ZD506
 ZD506 = 30*DD*DD*ID*ID + 90*DD*DD*TD + 20*DD*DV*DV*DV*HEV + ZD507
 ZD507 = 90*DD*DV*DV*HEV + 60*DD*DV*DV*HEV*ID + ZD508
 ZD508 = 60*DD*DV*DV*HEV*IV + 30*DD*DV*HEV*ID + ZD509
 ZD509 = 60*DD*DV*HEV*ID*ID + 120*DD*DV*HEV*ID*IV + ZD510
 ZD510 = 30*DD*DV*HEV*IV + 60*DD*DV*HEV*IV*IV + ZD511
 ZD511 = 180*DD*DV*HEV*TD + 180*DD*DV*HEV*TV + ZD512
 ZD512 = 30*DD*HEV*ID*ID*IV + 30*DD*HEV*ID*IV*IV + ZD513
 ZD513 = 60*DD*HEV*ID*TV + 10*DD*HEV*IV*IV*IV + ZD514
 ZD514 = 120*DD*HEV*IV*TD + 120*DD*HEV*TD*TV + 10*DD*HEV*TV + ZD515
 ZD515 = 60*DD*HEV*TV*TV + 10*DD*ID*ID*ID + 60*DD*ID*TD + ZD516
 ZD516 = 10*DD*TD + 60*DD*TD*TD + 5*DV*DV*DV*DV*HEV + ZD517
 ZD517 = 30*DV*DV*DV*HEV + 20*DV*DV*DV*HEV*ID + ZD518
 ZD518 = 20*DV*DV*DV*HEV*IV + 15*DV*DV*HEV*ID + ZD519
 ZD519 = 30*DV*DV*HEV*ID*ID + 60*DV*DV*HEV*ID*IV + ZD520
 ZD520 = 15*DV*DV*HEV*IV + 30*DV*DV*HEV*IV*IV + ZD521

Five train dependent hardware failures.





ZD521 = 90*DV*DV*HEV*TD + 90*DV*DV*HEV*TV + ZD522
 ZD522 = 10*DV*HEV*ID*ID*ID + 30*DV*HEV*ID*ID*IV + ZD523
 ZD523 = 30*DV*HEV*ID*IV*IV + 60*DV*HEV*ID*TD + ZD524
 ZD524 = 60*DV*HEV*ID*TV + 10*DV*HEV*IV*IV*IV + ZD525
 ZD525 = 60*DV*HEV*IV*TD + 60*DV*HEV*IV*TV + 10*DV*HEV*TD + ZD526
 ZD526 = 60*DV*HEV*TD*TD + 120*DV*HEV*TD*TV + 10*DV*HEV*TV + ZD527
 ZD527 = 60*DV*HEV*TV*TV + 1*GD + 1*GV*HEV + ZD528
 ZD528 = 10*HEV*ID*ID*TV + 20*HEV*ID*IV*TD + ZD529
 ZD529 = 20*HEV*ID*IV*TV + 60*HEV*ID*TD*TV + ZD530
 ZD530 = 30*HEV*ID*TV*TV + 10*HEV*IV*IV*TD + ZD531
 ZD531 = 10*HEV*IV*IV*TV + 30*HEV*IV*TD*TD + ZD532
 ZD532 = 60*HEV*IV*TD*TV + 30*HEV*IV*TV*TV + ZD533
 ZD533 = 30*HEV*TD*TD*TV + 30*HEV*TD*TV + 30*HEV*TD*TV*TV + ZD534
 ZD534 = 15*HEV*TV*TV + 10*HEV*TV*TV*TV + 10*ID*ID*TD + ZD535
 ZD535 = 30*ID*TD*TD + 15*TD*TD + 10*TD*TD*TD
 DD = D5DGS + D5DGS1 + D5DGS2*(TM-1) + D5CB1C + D5RL1D + D5RL1D
 TD = T5DGS + T5DGS1 + T5DGS2*(TM-1) + T5CB1C + T5RL1D + T5RL1D
 GD = G5DGS + G5DGS1 + G5DGS2*(TM-1) + G5CB1C + G5RL1D + G5RL1D
 ID = S5DGS + S5DGS1 + S5DGS2*(TM-1) + S5CB1C + S5RL1D + S5RL1D + IDA
 IDA = DAYTNK + ZTCB1*TM
 DAYTNK = ZTTK1B*TM
 IV = ND*(ZTVAOD + ZTSWLD + ZTVCOD) + (VCHK + VLCV)*TR + IVA
 IVA = (AIRRCV + VMAN + VPCV + FLINK)*TM
 DV = ND*(DDVAOD + DDSWLD + DDVCOD) + 5.0*TV
 TV = ND*(TDVAOD + TDSWLD + TDVCOD)
 GV = ND*(GDVAOD + GDSWLD + GDVCOD)
 VCHK = ZTVCOP
 VLCV = ZTVAOT
 AIRRCV = ZTTK1B
 VMAN = ZTVHOT
 VPCV = ZTVPCT
 FLINK = ZTSPRI
 TR = ND*(PSTOP - PSTART)/(FDR - FCR)
 PSTOP = 509
 PSTART = 252
 FDR = 55*60
 FCR = 3.2*60
 ND = (5/6)*TM
 MN1 = MD + MV - MV*MD

All DG double event failures.
 All DG triple event failures.
 All DG global event failures.
 Total DG independent failures.

DG day tank ruptures during operation.
 Total LCV train independent failures.

LCV train double event failures.
 LCV train triple event failures.
 LCV train global event failures.

Run time for LCVs.
 Valve close level.
 Valve open level.
 Pump fuel delivery rate.
 DG fuel consumption rate.
 No. of valve demands in time TM.
 Total maintenance unavailability.



MD = ZMDGSF*ZMDGSD
 MV = ZMGNDF*ZMGN3D
 TS1 = TS1HE + TS2HE
 TS5 = TS3HE
 TS1HE = TSD*TSF*HE1A + DT1*TSF*HE1B
 TS2HE = DT2*TSF*HE2
 TS3HE = ZHDFO2*TS3F*ZHEFO2
 ZHEFO2 = ZHEO1B
 TS3F = 1/2160
 TIM = ZMDGSF*N*TSD*HE1A + ZMDGSF*N*(HE1B*DT1 + HE2*DT2)
 N = 1.0
 TM = 6*ZDGSM T + 24*(1-ZDGSM T)
 TSD = 70/60
 TSF = 1/720.0
 DT1 = ZHDDG1
 DT2 = ZHDDG3
 HE1A = ZHEDG1
 HE1B = ZHEDG2
 HE2 = ZHEDG3
 ZHEDG1 = ZHED01
 ZHEDG2 = ZHEO1B
 ZHEDG3 = ZHEO1B
 SEIST = ZDGC PN + SEIS1 - ZDGC PN*SEIS1
 SEIS1 = ZDGEXC + SEIS2 - ZDGEXC*SEIS2
 SEIS2 = ZDGRWP + SEIS3 - ZDGRWP*SEIS3
 SEIS3 = ZDSLGN
 HEV = ZHEFO6

DG maintenance unavailability.
 LCV maintenance unavailability.
 Total DG unavailability due to surveillance test.
 Unavailability of 5 DGs due to test error.
 Diesel unavailability due to auto control missalignment.
 Diesel unavailability due to LCV missalignment.
 STP-V303: Misalignment of all LCV in stop position.
 Human error of omission.
 STP-V303 testing frequency.
 DG test unavailability resulting from DG maintenance.
 Number of tests for DGs while one is in maintenance.
 Mission time.
 DG test duration.
 DG test frequency.
 Discovery time for failure to restore auto control.
 D.T. for LCVs not in auto control.
 Human error to restore DG to auto control during test.
 Human error to restore DG to auto control after test.
 Human error to restore LCVs to auto control.
 Dynamic human error.
 Human error of omission.

 DG control panel.
 DG excitation cubicle.
 DG radiator/water pump.
 Diesel Generator.
 Operator action to manually operate LCVs.



Figure A-2: Basic Component Failure Rates Used in the Diesel Generator
Split Fraction Quantification

Reference: PGE.1123 EVENT.TREES BNL DATA.TITLES

DCPP PLANT SPECIFIC DATA BASE AS OF 7/9/88

SEQUENCE NO.	NAME OF DISTRIBUTION	MEAN	VARIANCE	5TH %ILE	MEDIAN	95TH %ILE
6.S5CB1C	CCA 1 OF 5 CIRCUIT BREAKER (480VAC AND ABOVE) FAIL TO CLOSE	1.50E-03	3.53E-06	2.60E-04	1.09E-03	2.99E-03
7.D5CB1C	CCA 2 OF 5 CIRCUIT BREAKER (480VAC AND ABOVE) FAIL TO CLOSE	3.19E-05	3.01E-09	3.30E-07	1.52E-05	8.02E-05
8.T5CB1C	CCA 3 OF 5 CIRCUIT BREAKER (480VAC AND ABOVE) FAIL TO CLOSE	4.33E-06	5.99E-11	4.89E-08	1.82E-06	1.20E-05
9.G5CB1C	CCA 4/5 OR 5/5 C.B.BREAKER (480VAC AND ABOVE) FAIL TO CLOSE	2.86E-06	4.46E-11	2.00E-08	9.00E-07	8.22E-06
29.S5DGSS	CCA 1 OF 5 DIESEL GENERATORS FAIL TO START	1.58E-02	3.81E-05	7.48E-03	1.45E-02	2.70E-02
30.D5DGSS	CCA 2 OF 5 DIESEL GENERATORS FAIL TO START	8.27E-06	4.64E-11	9.46E-07	5.59E-06	1.95E-05
31.T5DGSS	CCA 3 OF 5 DIESEL GENERATORS FAIL TO START	5.23E-07	5.16E-13	8.71E-09	2.22E-07	1.59E-06
32.G5DGSS	CCA 4 OR MORE OF 5 DIESEL GENERATORS FAIL TO START	6.17E-07	1.01E-12	7.57E-09	2.30E-07	1.85E-06
33.S5DGS1	CCA 1 OF 5 DIESEL GENERATORS FAIL TO RUN DURING 1ST HR.	8.63E-03	1.34E-05	3.66E-03	7.62E-03	1.41E-02
34.D5DGS1	CCA 2 OF 5 DIESEL GENERATORS FAIL TO RUN DURING 1ST HR.	3.48E-05	5.62E-10	7.78E-06	2.66E-05	7.28E-05
35.T5DGS1	CCA 3 OF 5 DIESEL GENERATORS FAIL TO RUN DURING 1ST HR.	4.65E-06	2.67E-11	3.75E-07	2.61E-06	1.22E-05
36.G5DGS1	CCA 4 OR 5 OF 5 DIESEL GENERATORS FAIL TO RUN DURING 1ST HR.	6.15E-06	6.16E-11	3.65E-07	3.08E-06	1.68E-05
37.S5DGS2	CCA 1 OF 5 DIESEL GENERATORS FAIL TO RUN AFTER 1ST HR.	2.07E-03	4.05E-06	2.11E-04	1.41E-03	4.37E-03
38.D5DGS2	CCA 2 OF 5 DIESEL GENERATORS FAIL TO RUN AFTER 1ST HR.	5.06E-06	5.44E-11	2.38E-07	2.37E-06	1.44E-05
39.T5DGS2	CCA 3 OF 5 DIESEL GENERATORS FAIL TO RUN AFTER 1ST HR.	1.27E-06	4.11E-12	4.63E-08	5.27E-07	3.74E-06
40.G5DGS2	CCA 4 OR 5 OF 5 DIESEL GENERATORS FAIL TO RUN AFTER 1ST HR.	1.48E-06	6.47E-12	4.79E-08	5.99E-07	4.31E-06
112.S5RL1D	CCC 1 OF 5 RELAYS FAIL ON DEMAND	2.28E-04	1.29E-07	1.54E-05	1.23E-04	6.19E-04
113.D5RL1D	CCC 2 OF 5 RELAYS FAIL ON DEMAND	5.23E-06	1.15E-10	4.35E-08	1.74E-06	1.52E-05
114.T5RL1D	CCC 3 OF 5 RELAYS FAIL ON DEMAND	2.82E-07	6.10E-13	7.50E-10	6.35E-08	7.83E-07
115.G5RL1D	CCC 4 OR 5 OF 5 RELAYS FAIL ON DEMAND	3.38E-07	9.22E-13	8.20E-10	7.08E-08	9.70E-07
142.DDSWLD	CCC 2 OF 10 LEVEL SWITCHES FAIL TO OPERATE ON DEMAND	5.81E-06	1.47E-10	6.98E-08	1.61E-06	1.78E-05
143.TDSWLD	CCC 3 OF 10 LEVEL SWITCHES FAIL TO OPERATE ON DEMAND	3.08E-07	6.28E-13	6.57E-10	5.99E-08	9.60E-07
144.GDSWLD	CCC 4 OR MORE OF 10 LEVEL SWITCHES FAIL TO OPERATE ON DEMAND	3.72E-07	9.41E-13	7.59E-10	6.95E-08	1.13E-06
161.DDVAOD	CCC 2 OF 10 AIR OPERATED VALVES FAIL ON DEMAND	1.25E-05	1.64E-10	2.54E-07	7.43E-06	3.23E-05
162.TDVAOD	CCC 3 OF 10 AIR OPERATED VALVES FAIL ON DEMAND	1.70E-06	4.57E-12	2.38E-08	8.49E-07	4.68E-06
163.GDVAOD	CCC 4 OR MORE OF 10 AIR OPERATED VALVES FAIL ON DEMAND	1.16E-06	3.97E-12	1.45E-08	4.35E-07	3.36E-06
178.DDVCOD	CCD 2 OF 10 CHECK VALVES FAIL ON DEMAND	4.61E-07	2.08E-13	3.99E-08	2.79E-07	1.19E-06
179.TDVCOD	CCD 3 OF 10 CHECK VALVES FAIL ON DEMAND	5.54E-08	4.49E-15	3.51E-09	2.79E-08	1.52E-07
180.GDVCOD	CCD 4 OR MORE OF 10 CHECK VALVES FAIL ON DEMAND	6.78E-08	7.90E-15	3.30E-09	3.21E-08	1.87E-07
226.ZTCB1T	CIRCUIT BREAKER (480VAC AND ABOVE)-TRANSFER OPEN DURING OPER.	8.28E-07	1.57E-12	5.08E-08	3.99E-07	2.36E-06
295.ZTSPRI	FIRE SPRINKLER HEAD INADVERTANT ACTUATION	9.99E-07	1.47E-12	1.18E-07	6.06E-07	3.01E-06





299. ZTSWLD	LEVEL SWITCH - FAIL TO OPERATE ON DEMAND	2.69E-04	2.09E-07	1.41E-05	1.25E-04	7.69E-04
301. ZTTK1B	STORAGE TANK -- RUPTURE DURING OPERATION	2.66E-08	3.17E-15	7.59E-10	1.04E-08	7.63E-08
307. ZTVAOD	AIR OPERATED VALVE - FAIL TO OPERATE ON DEMAND	6.22E-04	1.41E-07	1.58E-04	5.09E-04	1.23E-03
309. ZTVAOT	AIR OPERATED VALVES TRANSFER OPEN/CLOSED	2.29E-07	1.53E-13	1.74E-08	1.14E-07	5.91E-07
310. ZTVCOD	OTHER CHECK VALVE - FAIL TO OPERATE ON DEMAND	1.70E-04	8.55E-09	4.05E-05	1.41E-04	2.84E-04
313. ZTVCOP	CHECK VALVES (OTHER STOP) TRANSFER CLOSED/PLUGGED	1.04E-08	5.60E-17	2.43E-09	7.80E-09	2.18E-08
322. ZTVHOT	MANUAL VALVE TRANSFERS CLOSED/OPEN	3.32E-08	3.45E-15	1.65E-09	1.39E-08	1.04E-07
327. ZTVPCT	PRESSURE CONTROL VALVE, SELF CONTAINED FAILURE DURING OPERATION	3.90E-06	2.35E-10	2.49E-08	6.05E-07	1.41E-05
347. ZHDDG1	DISCOVERY TIME FOR FAIL TO RETURN DG TO AUTO AFTER SURV TEST	1.72E + 00	1.66E + 00	8.33E-02	1.00E + 00	3.50E + 00
349. ZHDDG3	DISCOV TIME FOR FAIL TO RTN FTP AND LCV CTRLS TO AUTO AFTER TEST	1.38E + 01	4.60E + 01	2.30E + 00	1.33E + 01	2.25E + 01
351. ZHDFO2	DISCOV TIME FOR FAIL TO RTN FTP AND LCV CTRLS TO AUTO AFTER TEST	1.38E + 01	4.60E + 01	2.30E + 00	1.33E + 01	2.25E + 01
354. ZDGSMT	SWITCH TO DETERMINE WHICH MISSION TIME TO USE	1.00E + 00	0.00E-01	1.00E + 00	1.00E + 00	1.00E + 00
364. ZMDGSF	DIESEL GENERATOR - MAINTENANCE FREQUENCY	7.74E-04	2.33E-08	5.25E-04	7.52E-04	9.66E-04
371. ZMGNDF	MAINTENANCE FREQUENCY FOR VALVES	2.03E-05	3.52E-11	1.14E-05	1.91E-05	2.97E-05
393. ZMDGSD	DIESEL GENERATOR - MAINT. DURATION	1.01E + 01	3.99E + 00	6.65E + 00	9.74E + 00	1.33E + 01
398. ZMGN3D	MAINT. DURATION FOR VALVES WITH TECH SPEC LIMITS OF 72 HRS.	1.89E + 01	5.97E + 02	1.54E + 00	1.01E + 01	5.13E + 01
469. ZHESW1	H.E. FAIL TO REALIGN SWING DG TO OPPOSITE UNIT	3.54E-03	3.68E-05	2.09E-04	1.63E-03	1.21E-02
477. ZHEO1B	HUMAN ERROR RATE OF OMISSION - TYPE 1B	4.70E-03	2.76E-05	5.40E-04	2.85E-03	1.18E-02
478. ZHED01	H.E. DYNAMIC HUMAN ERROR RATE (KNOWLEDGE BASED)	1.00E-01	1.10E-02	1.02E-02	6.98E-02	2.49E-01
488. ZHEFO6	H.E. FAIL TO ALIGN A DEDICATED, PORTABLE FUEL OIL TRANSFER PUMP	4.00E-02	2.36E-03	4.72E-03	2.43E-02	1.21E-01
519. ZDSLGN	DIESEL GENERATORS	0.00E-01	0.00E-01	0.00E-01	0.00E-01	0.00E-01
520. ZDGRWP	DG RADIATOR/WATER PUMP	0.00E-01	0.00E-01	0.00E-01	0.00E-01	0.00E-01
521. ZDGEXC	DG EXCITATION CUBICAL	0.00E-01	0.00E-01	0.00E-01	0.00E-01	0.00E-01
522. ZDGCNP	DG CONTROL PANEL	0.00E-01	0.00E-01	0.00E-01	0.00E-01	0.00E-01



Figure A-3: Equations Modified for One DG in Scheduled Maintenance (Non-Seismic)

Reference: PGE.1123.2 RISKMAN3.PHASE3 SEISPH3B DGAOT.SYS SCHD.EQS

GG4	1 GG3	= P[1]
GG4	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TSS + TIM
GH7	1 GH4	= (P[1]-P[2])/(1-P[1])
GH7	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TSS + TIM
GH8	1 GH5	= P[2]/P[1]
GH8	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + TSS + 2*TIM*HW1
GH9	1 GH6	= P[1]
GH9	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TSS
2GC	1 2G6	= (P[2]-P[3])/(P[1]-P[2])
2GC	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + TSS + 2*TIM*HW1
2GE	1 2G8	= (P[1]-P[2])/(1-P[1])
2GE	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TSS + TIM
2HI	1 2H7	= (P[2]-2*P[3] + P[4])/(P[1]-2*P[2] + P[3])
2HI	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + TSS + 2*TIM*HW1
2HJ	1 2H8	= (P[3]-P[4])/(P[2]-P[3])
2HJ	2 TOTAL	= HWI3 + X2H82 - HWI3 * X2H82
2HJ	X2H82	= HWD3 + 3*TS1*HW2 + 3*MN1*HW2 + TSS + 3*T>M*HW2
	P[1]	= TOT1 + SEIST - SEIST*TOT1
	TOT1	= HW1*F1 + MN1 + TS1 + TSS + TIM
	P[2]	= TOT2 + SEIST - SEIST*TOT2
	TOT2	= HW2*F2 + 2*MN1*HW1 + 2*TS1*HW1 + TSS + 2*T>M*HW1
	P[3]	= TOT3 + SEIST - SEIST*TOT3
	TOT3	= HW3*F3 + 3*MN1*HW2 + 3*TS1*HW2 + TSS + 3*TIM*HW2
	P[4]	= TOT4 + SEIST - SEIST*TOT4
	TOT4	= HW4*F4 + 4*MN1*HW3 + 4*TS1*HW3 + TSS + 4*TIM*HW3
	P[5]	= TOT5 + SEIST - SEIST*TOT5
	TOT5	= HW5*F5 + (5*MN1-20*TIM)*HW4 + 5*TS1*HW4 + TSS + 20*TIM*HW3
F1		= (1 - MN1 - TS1 - TSS + TIM)
F2		= (1 - 2*MN1 - 2*TS1 - TSS + 2*TIM*HW1)
F3		= (1 - 3*MN1 - 3*TS1 - TSS + 3*TIM*HW2)
F4		= (1 - 4*MN1 - 4*TS1 - TSS + 4*TIM*HW3)
F5		= (1 - 5*MN1 - 5*TS1 - TSS)
HW1		= HWI1 + HWD1
HW2		= HWI2 + HWD2
HW3		= HWI3 + HWD3
HW4		= HWI4 + HWD4

CSF for GG given: GF-B
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-S/B, GG-B/S
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-F/B, GG-B/F
 Total for P[2].
 \$ CSF for GH given: GF-B, GG-B
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for 2G given: GF&GG-GH:S&FB/BF,F&BS/SB,B&FS/SF
 Total for P[2]. See GG2 for breakdown of P[2].
 CSF for 2G given: GF-S/B/B,GG-B/S/B,GH-B/B/S
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF-2H: Two DGs succeed, one fails, one bypassed.
 Total for P[2]. See GG2 for breakdown of P[2].
 CSF-2H: Two DGs fail, one succeeds, one bypassed.
 Total for P[3]. See GH3 for breakdown of P[3].

Total single train unavailability.

Total two train unavailability.

Total three train unavailability.

Total four train unavailability.

Total five train unavailability.

(Not used for these split fractions)

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Fraction of the time the system is in normal alignment.

Single train total hardware failures.

Two train total hardware failures.

Three train total hardware failures.

Four train total hardware failures.





HW5 = HWI5 + HWDS
 HWI1 = 1*HEV*IV + 1*ID
 HWI2 = 2*HEV*ID*IV + 1*HEV*IV*IV + 1*ID*ID
 HWI3 = 3*HEV*ID*ID*IV + 3*HEV*ID*IV*IV + 1*HEV*IV*IV*IV + 1*ID*ID*ID
 HWI4 = 4*HEV*ID*ID*ID*IV + 6*HEV*ID*ID*IV*IV + ZI401
 ZI401 = 4*HEV*ID*IV*IV*IV + 1*HEV*IV*IV*IV*IV + 1*ID*ID*ID*ID
 HWI5 = 5*HEV*ID*ID*ID*ID*IV + 10*HEV*ID*ID*ID*IV*IV + ZI501
 ZI501 = 10*HEV*ID*ID*IV*IV*IV + 5*HEV*ID*IV*IV*IV*IV + ZI502
 ZI502 = 1*HEV*IV*IV*IV*IV*IV + 1*ID*ID*ID*ID*ID
 HWD1 = 4*DV*HEV + 1*GD + 1*GV*HEV + 6*HEV*TV + 6*TD
 HWD2 = 1*DD + 9*DD*DD + 18*DD*DV*HEV + 6*DD*HEV*IV + ZD201
 ZD201 = 18*DD*HEV*TV + 6*DD*ID + 18*DD*TD + 9*DV*DV*HEV + ZD202
 ZD202 = 1*DV*HEV + 6*DV*HEV*ID + 6*DV*HEV*IV + 18*DV*HEV*TD + ZD203
 ZD203 = 18*DV*HEV*TV + 1*GD + 1*GV*HEV + 6*HEV*ID*TV + ZD204
 ZD204 = 6*HEV*IV*TD + 6*HEV*IV*TV + 18*HEV*TD*TV + 3*HEV*TV + ZD205
 ZD205 = 9*HEV*TV*TV + 6*ID*TD + 3*TD + 9*TD*TD
 HWD3 = 8*DD*DD*DD + 24*DD*DD*DV*HEV + 12*DD*DD*HEV*IV + ZD301
 ZD301 = 12*DD*DD*HEV*TV + 12*DD*DD*ID + 12*DD*DD*TD + ZD302
 ZD302 = 24*DD*DV*DV*HEV + 18*DD*DV*HEV + 24*DD*DV*HEV*ID + ZD303
 ZD303 = 24*DD*DV*HEV*IV + 24*DD*DV*HEV*TD + ZD304
 ZD304 = 24*DD*DV*HEV*TV + 12*DD*HEV*ID*IV + ZD305
 ZD305 = 12*DD*HEV*ID*TV + 3*DD*HEV*IV + 6*DD*HEV*IV*IV + ZD306
 ZD306 = 12*DD*HEV*IV*TD + 12*DD*HEV*IV*TV + ZD307
 ZD307 = 12*DD*HEV*TD*TV + 27*DD*HEV*TV + 6*DD*HEV*TV*TV + ZD308
 ZD308 = 3*DD*ID + 6*DD*ID*ID + 12*DD*ID*TD + 27*DD*TD + ZD309
 ZD309 = 6*DD*TD*TD + 8*DV*DV*DV*HEV + 9*DV*DV*HEV + ZD310
 ZD310 = 12*DV*DV*HEV*ID + 12*DV*DV*HEV*IV + ZD311
 ZD311 = 12*DV*DV*HEV*TD + 12*DV*DV*HEV*TV + 3*DV*HEV*ID + ZD312
 ZD312 = 6*DV*HEV*ID*ID + 12*DV*HEV*ID*IV + 12*DV*HEV*ID*TD + ZD313
 ZD313 = 12*DV*HEV*ID*TV + 3*DV*HEV*IV + 6*DV*HEV*IV*IV + ZD314
 ZD314 = 12*DV*HEV*IV*TD + 12*DV*HEV*IV*TV + 27*DV*HEV*TD + ZD315
 ZD315 = 6*DV*HEV*TD*TD + 12*DV*HEV*TD*TV + 27*DV*HEV*TV + ZD316
 ZD316 = 6*DV*HEV*TV*TV + 1*GD + 1*GV*HEV + 3*HEV*ID*ID*TV + ZD317
 ZD317 = 6*HEV*ID*IV*TD + 12*HEV*ID*IV*TV + 6*HEV*ID*TV + ZD318
 ZD318 = 3*HEV*ID*TV*TV + 3*HEV*IV*IV*TD + 3*HEV*IV*IV*TV + ZD319
 ZD319 = 6*HEV*IV*TD + 3*HEV*IV*TD*TD + 6*HEV*IV*TD*TV + ZD320
 ZD320 = 6*HEV*IV*TV + 6*HEV*IV*TV*TV + 36*HEV*TD*TV + ZD321
 ZD321 = 3*HEV*TD*TV*TV + 1*HEV*TV + 18*HEV*TV*TV + ZD322
 ZD322 = 1*HEV*TV*TV*TV + 3*ID*ID*TD + 6*ID*TD + 3*ID*TD*TD + ZD323

Five train total hardware failures.
 Single train independent hardware failure.
 Two train independent hardware failure.
 Three train independent hardware failure.
 Four train independent hardware failure.

Five train independent hardware failure.

Single train dependent hardware failures.
 Two train dependent hardware failures.

Three train dependent hardware failures.



ZD323 = 1*TD + 18*TD*TD + 1*TD*TD*TD
 HWD4 = 3*DD*DD + 22*DD*DD*DD + 1*DD*DD*DD*DD + ZD401
 ZD401 = 4*DD*DD*DD*DV*HEV + 4*DD*DD*DD*HEV*IV + ZD402
 ZD402 = 4*DD*DD*DD*ID + 6*DD*DD*DV*DV*HEV + ZD403
 ZD403 = 66*DD*DD*DV*HEV + 12*DD*DD*DV*HEV*ID + ZD404
 ZD404 = 12*DD*DD*DV*HEV*IV + 12*DD*DD*HEV*ID*IV + ZD405
 ZD405 = 24*DD*DD*HEV*IV + 6*DD*DD*HEV*IV*IV + ZD406
 ZD406 = 42*DD*DD*HEV*TV + 24*DD*DD*ID + 6*DD*DD*ID*ID + ZD407
 ZD407 = 42*DD*DD*TD + 4*DD*DV*DV*DV*HEV + 66*DD*DV*DV*HEV + ZD408
 ZD408 = 24*DD*DV*DV*HEV*ID + 6*DD*DV*HEV + 48*DD*DV*HEV*ID + ZD409
 ZD409 = 12*DD*DV*HEV*ID*ID + 24*DD*DV*HEV*ID*IV + ZD410
 ZD410 = 48*DD*DV*HEV*IV + 12*DD*DV*HEV*IV*IV + ZD411
 ZD411 = 84*DD*DV*HEV*TD + 84*DD*DV*HEV*TV + ZD412
 ZD412 = 12*DD*HEV*ID*ID*IV + 12*DD*HEV*ID*IV + ZD413
 ZD413 = 12*DD*HEV*ID*IV*IV + 36*DD*HEV*ID*TV + ZD414
 ZD414 = 6*DD*HEV*IV*IV + 4*DD*HEV*IV*IV*IV + ZD415
 ZD415 = 36*DD*HEV*IV*TD + 84*DD*HEV*IV*TV + 22*DD*HEV*TV + ZD416
 ZD416 = 24*DD*HEV*TV*TV + 6*DD*ID*ID + 4*DD*ID*ID*ID + ZD417
 ZD417 = 36*DD*ID*TD + 22*DD*TD + 24*DD*TD*TD + ZD418
 ZD418 = 1*DV*DV*DV*DV*HEV + 22*DV*DV*DV*HEV + ZD419
 ZD419 = 4*DV*DV*DV*HEV*ID + 4*DV*DV*DV*HEV*IV + ZD420
 ZD420 = 3*DV*DV*HEV + 24*DV*DV*HEV*ID + 6*DV*DV*HEV*ID*ID + ZD421
 ZD421 = 12*DV*DV*HEV*ID*IV + 24*DV*DV*HEV*IV + ZD422
 ZD422 = 6*DV*DV*HEV*IV*IV + 42*DV*DV*HEV*TD + ZD423
 ZD423 = 42*DV*DV*HEV*TV + 6*DV*HEV*ID*ID + ZD424
 ZD424 = 4*DV*HEV*ID*ID*ID + 12*DV*HEV*ID*ID*IV + ZD425
 ZD425 = 12*DV*HEV*ID*IV + 12*DV*HEV*ID*IV*IV + ZD426
 ZD426 = 12*DV*HEV*ID*TD + 36*DV*HEV*ID*TV + 6*DV*HEV*IV*IV + ZD427
 ZD427 = 4*DV*HEV*IV*IV*IV + 36*DV*HEV*IV*TD + ZD428
 ZD428 = 36*DV*HEV*IV*TV + 22*DV*HEV*TD + 24*DV*HEV*TD*TD + ZD429
 ZD429 = 48*DV*HEV*TD*TV + 22*DV*HEV*TV + 24*DV*HEV*TV*TV + ZD430
 ZD430 = 1*GD + 1*GV*HEV + 6*HEV*ID*ID*TV + ZD431
 ZD431 = 48*HEV*ID*IV*TD + 4*HEV*ID*TV + 12*HEV*ID*TV*TV + ZD432
 ZD432 = 6*HEV*IV*IV*TD + 6*HEV*IV*IV*TV + 4*HEV*IV*TD + ZD433
 ZD433 = 36*HEV*IV*TD*TD + 4*HEV*IV*TV + 24*HEV*IV*TV*TV + ZD434
 ZD434 = 42*HEV*TD*TV + 12*HEV*TD*TV*TV + 21*HEV*TV*TV + ZD435
 ZD435 = 4*HEV*TV*TV*TV + 6*ID*ID*TD + 4*ID*TD + 12*ID*TD*TD + ZD436
 ZD436 = 21*TD*TD + 4*TD*TD*TD
 HWD5 = 30*DD*DD*DD + 5*DD*DD*DD*DD + 20*DD*DD*DD*DV*HEV + ZD501

Four train dependent hardware failures.

Five train dependent hardware failures.





ZD501 = 20*DD*DD*DD*HEV*IV + 20*DD*DD*DD*ID + ZD502
 ZD502 = 30*DD*DD*DV*DV*HEV + 90*DD*DD*DV*HEV + ZD503
 ZD503 = 60*DD*DD*DV*HEV*ID + 60*DD*DD*DV*HEV*IV + ZD504
 ZD504 = 60*DD*DD*HEV*ID*IV + 15*DD*DD*HEV*IV + ZD505
 ZD505 = 30*DD*DD*HEV*IV*IV + 90*DD*DD*HEV*TV + 15*DD*DD*ID + ZD506
 ZD506 = 30*DD*DD*ID*ID + 90*DD*DD*TD + 20*DD*DV*DV*DV*HEV + ZD507
 ZD507 = 90*DD*DV*DV*HEV + 60*DD*DV*DV*HEV*ID + ZD508
 ZD508 = 60*DD*DV*DV*HEV*IV + 30*DD*DV*HEV*ID + ZD509
 ZD509 = 60*DD*DV*HEV*ID*ID + 120*DD*DV*HEV*ID*IV + ZD510
 ZD510 = 30*DD*DV*HEV*IV + 60*DD*DV*HEV*IV*IV + ZD511
 ZD511 = 180*DD*DV*HEV*TD + 180*DD*DV*HEV*TV + ZD512
 ZD512 = 30*DD*HEV*ID*ID*IV + 30*DD*HEV*ID*IV*IV + ZD513
 ZD513 = 60*DD*HEV*ID*TV + 10*DD*HEV*IV*IV*IV + ZD514
 ZD514 = 120*DD*HEV*IV*TD + 120*DD*HEV*TD*TV + 10*DD*HEV*TV + ZD515
 ZD515 = 60*DD*HEV*TV*TV + 10*DD*ID*ID*ID + 60*DD*ID*TD + ZD516
 ZD516 = 10*DD*TD + 60*DD*TD*TD + 5*DV*DV*DV*DV*HEV + ZD517
 ZD517 = 30*DV*DV*DV*HEV + 20*DV*DV*DV*HEV*ID + ZD518
 ZD518 = 20*DV*DV*DV*HEV*IV + 15*DV*DV*HEV*ID + ZD519
 ZD519 = 30*DV*DV*HEV*ID*ID + 60*DV*DV*HEV*ID*IV + ZD520
 ZD520 = 15*DV*DV*HEV*IV + 30*DV*DV*HEV*IV*IV + ZD521
 ZD521 = 90*DV*DV*HEV*TD + 90*DV*DV*HEV*TV + ZD522
 ZD522 = 10*DV*HEV*ID*ID*ID + 30*DV*HEV*ID*ID*IV + ZD523
 ZD523 = 30*DV*HEV*ID*IV*IV + 60*DV*HEV*ID*TD + ZD524
 ZD524 = 60*DV*HEV*ID*TV + 10*DV*HEV*IV*IV*IV + ZD525
 ZD525 = 60*DV*HEV*IV*TD + 60*DV*HEV*IV*TV + 10*DV*HEV*TD + ZD526
 ZD526 = 60*DV*HEV*TD*TD + 120*DV*HEV*TD*TV + 10*DV*HEV*TV + ZD527
 ZD527 = 60*DV*HEV*TV*TV + 1*GD + 1*GV*HEV + ZD528
 ZD528 = 10*HEV*ID*ID*TV + 20*HEV*ID*IV*TD + ZD529
 ZD529 = 20*HEV*ID*IV*TV + 60*HEV*ID*TD*TV + ZD530
 ZD530 = 30*HEV*ID*TV*TV + 10*HEV*IV*IV*TD + ZD531
 ZD531 = 10*HEV*IV*IV*TV + 30*HEV*IV*TD*TD + ZD532
 ZD532 = 60*HEV*IV*TD*TV + 30*HEV*IV*TV*TV + ZD533
 ZD533 = 30*HEV*TD*TD*TV + 30*HEV*TD*TV + 30*HEV*TD*TV*TV + ZD534
 ZD534 = 15*HEV*TV*TV + 10*HEV*TV*TV*TV + 10*ID*ID*TD + ZD535
 ZD535 = 30*ID*TD*TD + 15*TD*TD + 10*TD*TD*TD
 DD = D5DGSS + D5DGS1 + D5DGS2*(TM-1) + D5C81C + D5RL1D + D5RL1D
 TD = T5DGSS + T5DGS1 + T5DGS2*(TM-1) + T5C81C + T5RL1D + T5RL1D
 GD = G5DGSS + G5DGS1 + G5DGS2*(TM-1) + G5C81C + G5RL1D + G5RL1D
 ID = S5DGSS + S5DGS1 + S5DGS2*(TM-1) + S5C81C + S5RL1D + S5RL1D + IDA

All DG double event failures.
 All DG triple event failures.
 All DG global event failures.
 Total DG independent failures.



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail. The text also mentions that proper record-keeping is essential for identifying and correcting errors in a timely manner.



2. The second part of the document focuses on the role of internal controls in preventing fraud and misstatements. It highlights that a strong internal control system is necessary to ensure that all transactions are properly authorized, recorded, and classified. The text also notes that internal controls should be designed to provide reasonable assurance of the reliability of the financial reporting process.




3. The third part of the document discusses the importance of segregation of duties in reducing the risk of error and fraud. It explains that no single individual should be responsible for all aspects of a transaction, as this could lead to conflicts of interest and a lack of oversight. The text also mentions that segregation of duties is a key component of an effective internal control system and should be implemented in all areas of the organization.

IDA = DAYTNK + ZTCB1T*TM
 DAYTNK = ZTTK1B*TM
 IV = ND*(ZTVAOD + ZTSWLD + ZTVCOD) + (VCHK + VLCV)*TR + IVA
 IVA = (AIRRCV + VMAN + VPCV + FLINK)*TM
 DV = ND*(DDVAOD + DDSWLD + DDVCOD) + 5.0*TV
 TV = ND*(TDVAOD + TDSWLD + TDVCOD)
 GV = ND*(GDVAOD + GDSWLD + GDVCOD)
 VCHK = ZTVCOP
 VLCV = ZTVAOT
 AIRRCV = ZTTK1B
 VMAN = ZTVHOT
 VPCV = ZTVPCT
 FLINK = ZTSPRI
 TR = ND*(PSTOP - PSTART)/(FDR - FCR)
 PSTOP = 509
 PSTART = 252
 FDR = 55*60
 FCR = 3.2*60
 ND = (5/6)*TM
 MN1 = MD + MV - MV*MD
 MD = ZMDGSF*ZM2DGD
 MV = ZMGNDF*ZM2DGD
 ZM2DGD = 8.0
 TS1 = TS1HE + TS2HE
 TS5 = TS3HE
 TS1HE = TSD*TSF*HE1A + DT1*TSF*HE1B
 TS2HE = DT2*TSF*HE2
 TS3HE = ZHDFO2*TS3F*ZHEFO2
 ZHEFO2 = ZHEO1B
 TS3F = 1/2160
 TIM = 0.0
 TM = 6*ZDGSMT + 24*(1-ZDGSMT)
 TSD = 70/60
 TSF = 1/720.0
 DT1 = ZHDDG1
 DT2 = ZHDDG3
 HE1A = ZHEDG1
 HE1B = ZHEDG2
 HE2 = ZHEDG3

DG day tank ruptures during operation.
 Total LCV train independent failures.

LCV train double event failures.
 LCV train triple event failures.
 LCV train global event failures.

Run time for LCVs.
 Valve close level.
 Valve open level.
 Pump fuel delivery rate.
 DG fuel consumption rate.
 No. of valve demands in time TM.
 Total maintenance unavailability.
 DG maintenance unavailability.
 LCV maintenance unavailability.
 8 hour tech. spec. given 2 DGs in maint.
 Total DG unavailability due to surveillance test.
 Unavailability of 5 DGs due to test error.
 Diesel unavailability due to auto control misalignment.
 Diesel unavailability due to LCV misalignment.
 STP-V303: Misalignment of all LCV in stop position.
 Human error of omission.
 STP-V303 testing frequency.
 DG test unavailability resulting from DG maintenance.
 Mission time.
 DG test duration.
 DG test frequency.
 Discovery time for failure to restore auto control.
 D.T. for LCVs not in auto control.
 Human error to restore DG to auto control during test.
 Human error to restore DG to auto control after test.
 Human error to restore LCVs to auto control.



ZHEDG1 = ZHED01
ZHEDG2 = ZHEO1B
ZHEDG3 = ZHEO1B
SEIST = ZDGCNP + SEIS1 - ZDGCNP*SEIS1
SEIS1 = ZDGEXC + SEIS2 - ZDGEXC*SEIS2
SEIS2 = ZDGRWP + SEIS3 - ZDGRWP*SEIS3
SEIS3 = ZDSLGN
HEV = ZHEFO6
ZDGFPM = 0.0
ZDGRWP = 0.0
ZDGEXC = 0.0
ZDGCNP = 0.0
ZDSLGN = 0.0

Dynamic human error.
Human error of omission.

DG control panel.
DG excitation cubicle.
DG radiator/water pump.
Diesel Generator.
Operator action to manually operate LCVs.



Figure A-4: Equations Modified for One DG in Scheduled Maintenance (Seismic)
 Reference: PGE.1123.2 RISKMAN3.PHASE3 SEISPH3B DGAOT.SYS SCHD/S.EQS

GG5	1 GG3	= P[1]
GG5	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5 + TIM
GHA	1 GH4	= (P[1]-P[2])/(1-P[1])
GHA	2 TOTAL	= HWI1 + HWD1 + TS1 + MN1 + TS5 + TIM
GHB	1 GH5	= P[2]/P[1]
GHB	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + TS5 + 2*TIM*HW1
2GI	1 2G6	= (P[2]-P[3])/(P[1]-P[2])
2GI	2 TOTAL	= HWI2 + HWD2 + 2*TS1*HW1 + 2*MN1*HW1 + TS5 + 2*TIM*HW1
	P[1]	= TOT1 + SEIST - SEIST*TOT1
	TOT1	= HW1*F1 + MN1 + TS1 + TS5 + TIM
	P[2]	= TOT2 + SEIST - SEIST*TOT2
	TOT2	= HW2*F2 + 2*MN1*HW1 + 2*TS1*HW1 + TS5 + 2*TIM*HW1
	P[3]	= TOT3 + SEIST - SEIST*TOT3
	TOT3	= HW3*F3 + 3*MN1*HW2 + 3*TS1*HW2 + TS5 + 3*TIM*HW2
	P[4]	= TOT4 + SEIST - SEIST*TOT4
	TOT4	= HW4*F4 + 4*MN1*HW3 + 4*TS1*HW3 + TS5 + 4*TIM*HW3
	P[5]	= TOT5 + SEIST - SEIST*TOT5
	TOT5	= HW5*F5 + (5*MN1-20*TIM)*HW4 + 5*TS1*HW4 + TS5 + 20*TIM*HW3
	F1	= (1 - MN1 - TS1 - TS5 + TIM)
	F2	= (1 - 2*MN1 - 2*TS1 - TS5 + 2*TIM*HW1)
	F3	= (1 - 3*MN1 - 3*TS1 - TS5 + 3*TIM*HW2)
	F4	= (1 - 4*MN1 - 4*TS1 - TS5 + 4*TIM*HW3)
	F5	= (1 - 5*MN1 - 5*TS1 - TS5)
	HW1	= HWI1 + HWD1
	HW2	= HWI2 + HWD2
	HW3	= HWI3 + HWD3
	HW4	= HWI4 + HWD4
	HW5	= HWI5 + HWD5
	HWI1	= 1*HEV*IV + 1*ID
	HWI2	= 2*HEV*ID*IV + 1*HEV*IV*IV + 1*ID*ID
	HWI3	= 3*HEV*ID*ID*IV + 3*HEV*ID*IV*IV + 1*HEV*IV*IV*IV + 1*ID*ID*ID
	HWI4	= 4*HEV*ID*ID*ID*IV + 6*HEV*ID*ID*IV*IV + ZI401
	ZI401	= 4*HEV*ID*IV*IV*IV + 1*HEV*IV*IV*IV*IV + 1*ID*ID*ID*ID
	HWI5	= 5*HEV*ID*ID*ID*ID*IV + 10*HEV*ID*ID*ID*IV*IV + ZI501
	ZI501	= 10*HEV*ID*ID*IV*IV*IV + 5*HEV*ID*IV*IV*IV*IV + ZI502
	ZI502	= 1*HEV*IV*IV*IV*IV*IV + 1*ID*ID*ID*ID*ID

CSF for GG given: GF-B
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-S/B, GG-B/S
 Total for P[1]. See GF1 for breakdown of P[1].
 CSF for GH given: GF-F/B, GG-B/F
 Total for P[2].
 CSF for 2G given: GF&GG-GH:S&FB/BF,F&BS/SB,B&FS/SF
 Total for P[2]. See GG2 for breakdown of P[2].
 Total single train unavailability.

Total two train unavailability.

Total three train unavailability.

Total four train unavailability.

Total five train unavailability.
 (Not used for these split fractions)
 Fraction of the time the system is in normal alignment.
 Fraction of the time the system is in normal alignment.
 Fraction of the time the system is in normal alignment.
 Fraction of the time the system is in normal alignment.
 Fraction of the time the system is in normal alignment.
 Single train total hardware failures.
 Two train total hardware failures.
 Three train total hardware failures.
 Four train total hardware failures.
 Five train total hardware failures.
 Single train independent hardware failure.
 Two train independent hardware failure.
 Three train independent hardware failure.
 Four train independent hardware failure.

Five train independent hardware failure.



HWD1 = 4*DV*HEV + 1*GD + 1*GV*HEV + 6*HEV*TV + 6*TD
 HWD2 = 1*DD + 9*DD*DD + 18*DD*DV*HEV + 6*DD*HEV*IV + ZD201
 ZD201 = 18*DD*HEV*TV + 6*DD*ID + 18*DD*TD + 9*DV*DV*HEV + ZD202
 ZD202 = 1*DV*HEV + 6*DV*HEV*ID + 6*DV*HEV*IV + 18*DV*HEV*TD + ZD203
 ZD203 = 18*DV*HEV*TV + 1*GD + 1*GV*HEV + 6*HEV*ID*TV + ZD204
 ZD204 = 6*HEV*IV*TD + 6*HEV*IV*TV + 18*HEV*TD*TV + 3*HEV*TV + ZD205
 ZD205 = 9*HEV*TV*TV + 6*ID*TD + 3*TD + 9*TD*TD
 HWD3 = 8*DD*DD*DD + 24*DD*DD*DV*HEV + 12*DD*DD*HEV*IV + ZD301
 ZD301 = 12*DD*DD*HEV*TV + 12*DD*DD*ID + 12*DD*DD*TD + ZD302
 ZD302 = 24*DD*DV*DV*HEV + 18*DD*DV*HEV + 24*DD*DV*HEV*ID + ZD303
 ZD303 = 24*DD*DV*HEV*IV + 24*DD*DV*HEV*TD + ZD304
 ZD304 = 24*DD*DV*HEV*TV + 12*DD*HEV*ID*IV + ZD305
 ZD305 = 12*DD*HEV*ID*TV + 3*DD*HEV*IV + 6*DD*HEV*IV*IV + ZD306
 ZD306 = 12*DD*HEV*IV*TD + 12*DD*HEV*IV*TV + ZD307
 ZD307 = 12*DD*HEV*TD*TV + 27*DD*HEV*TV + 6*DD*HEV*TV*TV + ZD308
 ZD308 = 3*DD*ID + 6*DD*ID*ID + 12*DD*ID*TD + 27*DD*TD + ZD309
 ZD309 = 6*DD*TD*TD + 8*DV*DV*DV*HEV + 9*DV*DV*HEV + ZD310
 ZD310 = 12*DV*DV*HEV*ID + 12*DV*DV*HEV*IV + ZD311
 ZD311 = 12*DV*DV*HEV*TD + 12*DV*DV*HEV*TV + 3*DV*HEV*ID + ZD312
 ZD312 = 6*DV*HEV*ID*ID + 12*DV*HEV*ID*IV + 12*DV*HEV*ID*TD + ZD313
 ZD313 = 12*DV*HEV*ID*TV + 3*DV*HEV*IV + 6*DV*HEV*IV*IV + ZD314
 ZD314 = 12*DV*HEV*IV*TD + 12*DV*HEV*IV*TV + 27*DV*HEV*TD + ZD315
 ZD315 = 6*DV*HEV*TD*TD + 12*DV*HEV*TD*TV + 27*DV*HEV*TV + ZD316
 ZD316 = 6*DV*HEV*TV*TV + 1*GD + 1*GV*HEV + 3*HEV*ID*ID*TV + ZD317
 ZD317 = 6*HEV*ID*IV*TD + 12*HEV*ID*IV*TV + 6*HEV*ID*TV + ZD318
 ZD318 = 3*HEV*ID*TV*TV + 3*HEV*IV*IV*TD + 3*HEV*IV*IV*TV + ZD319
 ZD319 = 6*HEV*IV*TD + 3*HEV*IV*TD*TD + 6*HEV*IV*TD*TV + ZD320
 ZD320 = 6*HEV*IV*TV + 6*HEV*IV*TV*TV + 36*HEV*TD*TV + ZD321
 ZD321 = 3*HEV*TD*TV*TV + 1*HEV*TV + 18*HEV*TV*TV + ZD322
 ZD322 = 1*HEV*TV*TV*TV + 3*ID*ID*TD + 6*ID*TD + 3*ID*TD*TD + ZD323
 ZD323 = 1*TD + 18*TD*TD + 1*TD*TD*TD
 HWD4 = 3*DD*DD + 22*DD*DD*DD + 1*DD*DD*DD*DD + ZD401
 ZD401 = 4*DD*DD*DD*DV*HEV + 4*DD*DD*DD*HEV*IV + ZD402
 ZD402 = 4*DD*DD*DD*ID + 6*DD*DD*DV*DV*HEV + ZD403
 ZD403 = 66*DD*DD*DV*HEV + 12*DD*DD*DV*HEV*ID + ZD404
 ZD404 = 12*DD*DD*DV*HEV*IV + 12*DD*DD*HEV*ID*IV + ZD405
 ZD405 = 24*DD*DD*HEV*IV + 6*DD*DD*HEV*IV*IV + ZD406
 ZD406 = 42*DD*DD*HEV*TV + 24*DD*DD*ID + 6*DD*DD*ID*ID + ZD407
 ZD407 = 42*DD*DD*TD + 4*DD*DV*DV*DV*HEV + 66*DD*DV*DV*HEV + ZD408

Single train dependent hardware failures.

Two train dependent hardware failures.

Three train dependent hardware failures.

Four train dependent hardware failures.



ZD408 = 24*DD*DV*DV*HEV*ID + 6*DD*DV*HEV + 48*DD*DV*HEV*ID + ZD409
 ZD409 = 12*DD*DV*HEV*ID*ID + 24*DD*DV*HEV*ID*IV + ZD410
 ZD410 = 48*DD*DV*HEV*IV + 12*DD*DV*HEV*IV*IV + ZD411
 ZD411 = 84*DD*DV*HEV*TD + 84*DD*DV*HEV*TV + ZD412
 ZD412 = 12*DD*HEV*ID*ID*IV + 12*DD*HEV*ID*IV + ZD413
 ZD413 = 12*DD*HEV*ID*IV*IV + 36*DD*HEV*ID*TV + ZD414
 ZD414 = 6*DD*HEV*IV*IV + 4*DD*HEV*IV*IV*IV + ZD415
 ZD415 = 36*DD*HEV*IV*TD + 84*DD*HEV*IV*TV + 22*DD*HEV*TV + ZD416
 ZD416 = 24*DD*HEV*TV*TV + 6*DD*ID*ID + 4*DD*ID*ID*ID + ZD417
 ZD417 = 36*DD*ID*TD + 22*DD*TD + 24*DD*TD*TD + ZD418
 ZD418 = 1*DV*DV*DV*DV*HEV + 22*DV*DV*DV*HEV + ZD419
 ZD419 = 4*DV*DV*DV*HEV*ID + 4*DV*DV*DV*HEV*IV + ZD420
 ZD420 = 3*DV*DV*HEV + 24*DV*DV*HEV*ID + 6*DV*DV*HEV*ID*ID + ZD421
 ZD421 = 12*DV*DV*HEV*ID*IV + 24*DV*DV*HEV*IV + ZD422
 ZD422 = 6*DV*DV*HEV*IV*IV + 42*DV*DV*HEV*TD + ZD423
 ZD423 = 42*DV*DV*HEV*TV + 6*DV*HEV*ID*ID + ZD424
 ZD424 = 4*DV*HEV*ID*ID*ID + 12*DV*HEV*ID*ID*IV + ZD425
 ZD425 = 12*DV*HEV*ID*IV + 12*DV*HEV*ID*IV*IV + ZD426
 ZD426 = 12*DV*HEV*ID*TD + 36*DV*HEV*ID*TV + 6*DV*HEV*IV*IV + ZD427
 ZD427 = 4*DV*HEV*IV*IV*IV + 36*DV*HEV*IV*TD + ZD428
 ZD428 = 36*DV*HEV*IV*TV + 22*DV*HEV*TD + 24*DV*HEV*TD*TD + ZD429
 ZD429 = 48*DV*HEV*TD*TV + 22*DV*HEV*TV + 24*DV*HEV*TV*TV + ZD430
 ZD430 = 1*GD + 1*GV*HEV + 6*HEV*ID*ID*TV + ZD431
 ZD431 = 48*HEV*ID*IV*TD + 4*HEV*ID*TV + 12*HEV*ID*TV*TV + ZD432
 ZD432 = 6*HEV*IV*IV*TD + 6*HEV*IV*IV*TV + 4*HEV*IV*TD + ZD433
 ZD433 = 36*HEV*IV*TD*TD + 4*HEV*IV*TV + 24*HEV*IV*TV*TV + ZD434
 ZD434 = 42*HEV*TD*TV + 12*HEV*TD*TV*TV + 21*HEV*TV*TV + ZD435
 ZD435 = 4*HEV*TV*TV*TV + 6*ID*ID*TD + 4*ID*TD + 12*ID*TD*TD + ZD436
 ZD436 = 21*TD*TD + 4*TD*TD*TD
 HWD5 = 30*DD*DD*DD + 5*DD*DD*DD*DD + 20*DD*DD*DD*DV*HEV + ZD501
 ZD501 = 20*DD*DD*DD*HEV*IV + 20*DD*DD*DD*ID + ZD502
 ZD502 = 30*DD*DD*DV*DV*HEV + 90*DD*DD*DV*HEV + ZD503
 ZD503 = 60*DD*DD*DV*HEV*ID + 60*DD*DD*DV*HEV*IV + ZD504
 ZD504 = 60*DD*DD*HEV*ID*IV + 15*DD*DD*HEV*IV + ZD505
 ZD505 = 30*DD*DD*HEV*IV*IV + 90*DD*DD*HEV*TV + 15*DD*DD*ID + ZD506
 ZD506 = 30*DD*DD*ID*ID + 90*DD*DD*TD + 20*DD*DV*DV*DV*HEV + ZD507
 ZD507 = 90*DD*DV*DV*HEV + 60*DD*DV*DV*HEV*ID + ZD508
 ZD508 = 60*DD*DV*DV*HEV*IV + 30*DD*DV*HEV*ID + ZD509
 ZD509 = 60*DD*DV*HEV*ID*ID + 120*DD*DV*HEV*ID*IV + ZD510

Five train dependent hardware failures.





ZD510 = 30*DD*DV*HEV*IV + 60*DD*DV*HEV*IV*IV + ZD511
 ZD511 = 180*DD*DV*HEV*TD + 180*DD*DV*HEV*TV + ZD512
 ZD512 = 30*DD*HEV*ID*ID*IV + 30*DD*HEV*ID*IV*IV + ZD513
 ZD513 = 60*DD*HEV*ID*TV + 10*DD*HEV*IV*IV*IV + ZD514
 ZD514 = 120*DD*HEV*IV*TD + 120*DD*HEV*TD*TV + 10*DD*HEV*TV + ZD515
 ZD515 = 60*DD*HEV*TV*TV + 10*DD*ID*ID*ID + 60*DD*ID*TD + ZD516
 ZD516 = 10*DD*TD + 60*DD*TD*TD + 5*DV*DV*DV*DV*HEV + ZD517
 ZD517 = 30*DV*DV*DV*HEV + 20*DV*DV*DV*HEV*ID + ZD518
 ZD518 = 20*DV*DV*DV*HEV*IV + 15*DV*DV*HEV*ID + ZD519
 ZD519 = 30*DV*DV*HEV*ID*ID + 60*DV*DV*HEV*ID*IV + ZD520
 ZD520 = 15*DV*DV*HEV*IV + 30*DV*DV*HEV*IV*IV + ZD521
 ZD521 = 90*DV*DV*HEV*TD + 90*DV*DV*HEV*TV + ZD522
 ZD522 = 10*DV*HEV*ID*ID*ID + 30*DV*HEV*ID*ID*IV + ZD523
 ZD523 = 30*DV*HEV*ID*IV*IV + 60*DV*HEV*ID*TD + ZD524
 ZD524 = 60*DV*HEV*ID*TV + 10*DV*HEV*IV*IV*IV + ZD525
 ZD525 = 60*DV*HEV*IV*TD + 60*DV*HEV*IV*TV + 10*DV*HEV*TD + ZD526
 ZD526 = 60*DV*HEV*TD*TD + 120*DV*HEV*TD*TV + 10*DV*HEV*TV + ZD527
 ZD527 = 60*DV*HEV*TV*TV + 1*GD + 1*GV*HEV + ZD528
 ZD528 = 10*HEV*ID*ID*TV + 20*HEV*ID*IV*TD + ZD529
 ZD529 = 20*HEV*ID*IV*TV + 60*HEV*ID*TD*TV + ZD530
 ZD530 = 30*HEV*ID*TV*TV + 10*HEV*IV*IV*TD + ZD531
 ZD531 = 10*HEV*IV*IV*TV + 30*HEV*IV*TD*TD + ZD532
 ZD532 = 60*HEV*IV*TD*TV + 30*HEV*IV*TV*TV + ZD533
 ZD533 = 30*HEV*TD*TD*TV + 30*HEV*TD*TV + 30*HEV*TD*TV*TV + ZD534
 ZD534 = 15*HEV*TV*TV + 10*HEV*TV*TV*TV + 10*ID*ID*TD + ZD535
 ZD535 = 30*ID*TD*TD + 15*TD*TD + 10*TD*TD*TD
 DD = D5DGS5 + D5DGS1 + D5DGS2*(TM-1) + D5CB1C + D5RL1D + D5RL1D
 TD = T5DGS5 + T5DGS1 + T5DGS2*(TM-1) + T5CB1C + T5RL1D + T5RL1D
 GD = G5DGS5 + G5DGS1 + G5DGS2*(TM-1) + G5CB1C + G5RL1D + G5RL1D
 ID = S5DGS5 + S5DGS1 + S5DGS2*(TM-1) + S5CB1C + S5RL1D + S5RL1D + IDA
 IDA = DAYTNK + ZTCB1T*TM
 DAYTNK = ZTTK1B*TM
 IV = ND*(ZTVAOD + ZTSWLD + ZTVCOD) + (VCHK + VLCV)*TR + IVA
 IVA = (AIRRCV + VMAN + VPCV + FLINK)*TM
 DV = ND*(DDVAOD + DDSWLD + DDVCOD) + 5.0*TV
 TV = ND*(TDVAOD + TDSWLD + TDVCOD)
 GV = ND*(GDVAOD + GDSWLD + GDVCOD)
 VCHK = ZTVCOF
 VLCV = ZTVAOT

All DG double event failures.
 All DG triple event failures.
 All DG global event failures.
 Total DG independent failures.

DG day tank ruptures during operation.
 Total LCV train independent failures.

LCV train double event failures.
 LCV train triple event failures.
 LCV train global event failures.



AIRRCV = ZTTK1B
 VMAN = ZTVHOT
 VPCV = ZTVPCT
 FLINK = ZTSPRI
 TR = $ND * (PSTOP - PSTART) / (FDR - FCR)$
 PSTOP = 509
 PSTART = 252
 FDR = $55 * 60$
 FCR = $3.2 * 60$
 ND = $(5/6) * TM$
 MN1 = $MD + MV - MV * MD$
 MD = $ZMDGSF * ZM2DGD$
 MV = $ZMGNDF * ZM2DGD$
 ZM2DGD = 8.0
 TS1 = 0.0
 TS1 = $TS1HE + TS2HE$
 TSS = $TS3HE$
 TS1HE = $TSD * TSF * HE1A + DT1 * TSF * HE1B$
 TS2HE = $DT2 * TSF * HE2$
 TS3HE = $ZHDFO2 * TS3F * ZHEFO2$
 ZHEFO2 = ZHEO1B
 TS3F = $1/2160$
 TIM = 0.0
 TM = 24
 TSD = $70/60$
 TSF = $1/720.0$
 DT1 = ZHDDG1
 DT2 = ZHDDG3
 HE1A = ZHEDG1
 HE1B = ZHEDG2
 HE2 = ZHEDG3
 ZHEDG1 = ZHED01
 ZHEDG2 = ZHEO1B
 ZHEDG3 = ZHEO1B
 SEIST = $ZDGCN + SEIS1 - ZDGCN * SEIS1$

Run time for LCVs.
 Valve close level.
 Valve open level.
 Pump fuel delivery rate.
 DG fuel consumption rate.
 No. of valve demands in time TM.
 Total maintenance unavailability.
 DG maintenance unavailability.
 LCV maintenance unavailability.
 8 hour tech. spec. given 2 DGs in maint.
 Included in TIM term for the AOT split fractions.
 Total DG unavailability due to surveillance test.
 Unavailability of 5 DGs due to test error.
 Diesel unavailability due to auto control missalignment.
 Diesel unavailability due to LCV missalignment.
 STP-V303: Misalignment of all LCV in stop position.
 Human error of omission.
 STP-V303 testing frequency.
 DG test unavailability resulting from DG maintenance.
 Mission time (for ATWS events).
 DG test duration.
 DG test frequency.
 Discovery time for failure to restore auto control.
 D.T. for LCVs not in auto control.
 Human error to restore DG to auto control during test.
 Human error to restore DG to auto control after test.
 Human error to restore LCVs to auto control.
 Dynamic human error.
 Human error of omission.

 DG control panel.



SEIS1 = ZDGEXC + SEIS2 - ZDGEXC*SEIS2
SEIS2 = ZDGRWP + SEIS3 - ZDGRWP*SEIS3
SEIS3 = ZDSLGN
HEV = ZHEFO6
ZDGFPM = 0.0
ZDGRWP = 0.0
ZDGEXC = 0.0
ZDGCNP = 0.0
ZDSLGN = 0.0

DG excitation cubicle.
DG radiator/water pump.
Diesel Generator.
Operator action to manually operate LCVs.



APPENDIX B: REDUCED CORE DAMAGE SEQUENCE MODEL
 Figure B-1: Reduced Sequence Model (Internals and Externals, No Seismic)
 Reference: PGE.1123.EVENT.TREES.INTERNAL.SMODEL.DGAOT.BASE.MODEL.CDFREQ.EQS

CDF	1 TOTAL	= TOTAL1*(0.000607/0.0006229)
CDF	1 TOTAL1	= SEQ001 + SEQ002 + SEQ003 + SEQ004 + SEQ005 + SEQ006 + SEQ007 + X1
CDF	1 X1	= SEQ008 + SEQ009 + SEQ010 + SEQ011 + SEQ012 + SEQ013 + SEQ014 + X2
CDF	1 X2	= SEQ015 + SEQ016 + SEQ017 + SEQ018 + SEQ019 + SEQ020 + SEQ021 + X3
CDF	1 X3	= SEQ022 + SEQ023 + SEQ024 + SEQ025 + SEQ026 + SEQ027 + SEQ028 + X4
CDF	1 X4	= SEQ029 + SEQ030 + SEQ031 + SEQ032 + SEQ033 + SEQ034 + SEQ035 + X5
CDF	1 X5	= SEQ036 + SEQ037 + SEQ038 + SEQ039 + SEQ040 + SEQ041 + SEQ042 + X6
CDF	1 X6	= SEQ043 + SEQ044 + SEQ045 + SEQ046 + SEQ047 + SEQ048 + SEQ049 + X7
CDF	1 X7	= SEQ050 + SEQ051 + SEQ052 + SEQ053 + SEQ054 + SEQ055 + SEQ056 + X8
CDF	1 X8	= SEQ057 + SEQ058 + SEQ059 + SEQ060 + SEQ061 + SEQ062 + SEQ063 + X9
CDF	1 X9	= SEQ064 + SEQ065 + SEQ066 + SEQ067 + SEQ068 + SEQ069 + SEQ070 + X10
CDF	1 X10	= SEQ071 + SEQ072 + SEQ073 + SEQ074 + SEQ075 + SEQ076 + SEQ077 + X11
CDF	1 X11	= SEQ078 + SEQ079 + SEQ080 + SEQ081 + SEQ082 + SEQ083 + SEQ084 + X12
CDF	1 X12	= SEQ085 + SEQ086 + SEQ087 + SEQ088 + SEQ089 + SEQ090 + SEQ091 + X13
CDF	1 X13	= SEQ092 + SEQ093 + SEQ094 + SEQ095 + SEQ096 + SEQ097 + SEQ098 + X14
CDF	1 X14	= SEQ099 + SEQ100 + SEQ101 + SEQ102 + SEQ103 + SEQ104 + SEQ105 + X15
CDF	1 X15	= SEQ106 + SEQ107 + SEQ108 + SEQ109 + SEQ110 + SEQ111 + SEQ112 + X16
CDF	1 X16	= SEQ113 + SEQ114 + SEQ115 + SEQ116 + SEQ117 + SEQ118 + SEQ119 + X17
CDF	1 X17	= SEQ120 + SEQ121 + SEQ122 + SEQ123 + SEQ124 + SEQ125 + SEQ126 + X18
CDF	1 X18	= SEQ127 + SEQ128 + SEQ129 + SEQ130 + SEQ131 + SEQ132 + SEQ133 + X19
CDF	1 X19	= SEQ134 + SEQ135 + SEQ136 + SEQ137 + SEQ138 + SEQ139 + SEQ140 + X20
CDF	1 X20	= SEQ141 + SEQ142 + SEQ143 + SEQ144 + SEQ145 + SEQ146 + SEQ147 + X21
CDF	1 X21	= SEQ148 + SEQ149 + SEQ150 + SEQ151 + SEQ152 + SEQ153 + SEQ154 + X22
CDF	1 X22	= SEQ155 + SEQ156 + SEQ157 + SEQ158 + SEQ159 + SEQ160 + SEQ161 + X23
CDF	1 X23	= SEQ162 + SEQ163 + SEQ164 + SEQ165 + SEQ166 + SEQ167 + SEQ168 + X24
CDF	1 X24	= SEQ169 + SEQ170 + SEQ171 + SEQ172 + SEQ173 + SEQ174 + SEQ175 + X25
CDF	1 X25	= SEQ176 + SEQ177 + SEQ178 + SEQ179 + SEQ180 + SEQ181 + SEQ182 + X26
CDF	1 X26	= SEQ183 + SEQ184 + SEQ185 + SEQ186 + SEQ187 + SEQ188 + SEQ189 + X27
CDF	1 X27	= SEQ190 + SEQ191 + SEQ192 + SEQ193 + SEQ194 + SEQ195 + SEQ196 + X28
CDF	1 X28	= SEQ197 + SEQ198 + SEQ199 + SEQ200 + SEQ201 + SEQ202 + SEQ203 + X29
CDF	1 X29	= SEQ204 + SEQ205 + SEQ206 + SEQ207 + SEQ208 + SEQ209 + SEQ210 + X30
CDF	1 X30	= SEQ211 + SEQ212 + SEQ213 + SEQ214 + SEQ215 + SEQ216 + SEQ217 + X31
CDF	1 X31	= SEQ218 + SEQ219 + SEQ220 + SEQ221 + SEQ222 + SEQ223 + SEQ224 + X32





CDF 1 X32 =SEQ225 + SEQ226 + SEQ227 + SEQ228 + SEQ229 + SEQ230 + SEQ231 + X33
 CDF 1 X33 =SEQ232 + SEQ233 + SEQ234 + SEQ235 + SEQ236 + SEQ237 + SEQ238 + X34
 CDF 1 X34 =SEQ239 + SEQ240 + SEQ241 + SEQ242 + SEQ243 + SEQ244 + SEQ245 + X35
 CDF 1 X35 =SEQ246 + SEQ247 + SEQ248 + SEQ249 + SEQ250 + SEQ251 + SEQ252 + X36
 CDF 1 X36 =SEQ253 + SEQ254 + SEQ255 + SEQ256 + SEQ257 + SEQ258 + SEQ259 + X37
 CDF 1 X37 =SEQ260 + SEQ261 + SEQ262 + SEQ263 + SEQ264 + SEQ265 + SEQ266 + X38
 CDF 1 X38 =SEQ267 + SEQ268 + SEQ269 + SEQ270 + SEQ271 + SEQ272 + SEQ273 + X39
 CDF 1 X39 =SEQ274 + SEQ275 + SEQ276 + SEQ277 + SEQ278 + SEQ279 + SEQ280 + X40
 CDF 1 X40 =SEQ281 + SEQ282 + SEQ283 + SEQ284 + SEQ285 + SEQ286 + SEQ287 + X41
 CDF 1 X41 =SEQ288 + SEQ289 + SEQ290 + SEQ291 + SEQ292 + SEQ293 + SEQ294 + X42
 CDF 1 X42 =SEQ295 + SEQ296 + SEQ297 + SEQ298 + SEQ299 + SEQ300 + SEQ301 + X43
 CDF 1 X43 =SEQ302 + SEQ303 + SEQ304 + SEQ305 + SEQ306 + SEQ307 + SEQ308 + X44
 CDF 1 X44 =SEQ309 + SEQ310 + SEQ311 + SEQ312 + SEQ313 + SEQ314 + SEQ315 + X45
 CDF 1 X45 =SEQ316 + SEQ317 + SEQ318 + SEQ319 + SEQ320 + SEQ321 + SEQ322 + X46
 CDF 1 X46 =SEQ323 + SEQ324 + SEQ325 + SEQ326 + SEQ327 + SEQ328 + SEQ329 + X47
 CDF 1 X47 =SEQ330 + SEQ331 + SEQ332 + SEQ333 + SEQ334 + SEQ335 + SEQ336 + X48
 CDF 1 X48 =SEQ337 + SEQ338 + SEQ339 + SEQ340 + SEQ341 + SEQ342 + SEQ343 + X49
 CDF 1 X49 =SEQ344 + SEQ345 + SEQ346 + SEQ347 + SEQ348 + SEQ349 + SEQ350 + X50
 CDF 1 X50 =SEQ351 + SEQ352 + SEQ353 + SEQ354 + SEQ355 + SEQ356 + SEQ357 + X51
 CDF 1 X51 =SEQ358 + SEQ359 + SEQ360 + SEQ361 + SEQ362 + SEQ363 + SEQ364 + X52
 CDF 1 X52 =SEQ365 + SEQ366 + SEQ367 + SEQ368 + SEQ369 + SEQ370 + SEQ371 + X53
 CDF 1 X53 =SEQ372 + SEQ373 + SEQ374 + SEQ375 + SEQ376 + SEQ377 + SEQ378 + X54
 CDF 1 X54 =SEQ379 + SEQ380 + SEQ381 + SEQ382 + SEQ383 + SEQ384 + SEQ385 + X55
 CDF 1 X55 =SEQ386 + SEQ387 + SEQ388 + SEQ389 + SEQ390 + SEQ391 + SEQ392 + X56
 CDF 1 X56 =SEQ393 + SEQ394 + SEQ395 + SEQ396 + SEQ397 + SEQ398 + SEQ399 + X57
 CDF 1 X57 =SEQ400 + SEQ401 + SEQ402 + SEQ403 + SEQ404 + SEQ405 + SEQ406 + X58
 CDF 1 X58 =SEQ407 + SEQ408 + SEQ409 + SEQ410 + SEQ411 + SEQ412 + SEQ413 + X59
 CDF 1 X59 =SEQ414 + SEQ415 + SEQ416 + SEQ417 + SEQ418 + SEQ419 + SEQ420 + OTHER
 CDF 2 SEQ001 =LOS WV *IAF*SVF*(RF4S*CI1S*SI1S*OG1S*SA1S*SB1S)*ZHESV3
 CDF 3 SEQ002 =L1DC *DGF*I2F*AW7*OB3*(RF4S*CI1S)*ZHEAW3
 CDF 4 SEQ003 =LOOP *OGF*GF1*GG2*GH3*CVF*ASF*RESLC2
 CDF 5 SEQ004 =SLOCN *IAF*LA1*LB2*(CI1S)*MU2
 CDF 6 SEQ005 =LOOP *OGF*GF1*GH2*IAF*AW4*(GG2S*TG3S*TH3S)*RESLC1*REOB1
 CDF 7 SEQ006 =L1DC *DGF*I2F*CC3*(RF4S)*ZHERP2
 CDF 8 SEQ007 =LOOP *OGF*GF1*GG2*TG3*IAF*ASF*(GH3S*TH4S)*RESLC2
 CDF 9 SEQ008 =LOOP *OGF*FO1*CVF*ASF*(GF1S*GG1S*GH1S*TG1S*TH1S)*RSEQ8
 CDF 10 SEQ009 =LOOP *OGF*GG1*GH2*IAF*PRD*(GF1S)*ZHERE2*REAC06





CDF 11 SEQ010 = LOOP *OGF*GH1*TG2*SW1*IAF*AW4*(GF1S*GG1S*TH2S)*RSEQ10
 CDF 12 SEQ011 = LOOP *OGF*GH1*TH2*SW1*IAF*AW4*(GF1S*GG1S*TG2S)*RSEQ10
 CDF 13 SEQ012 = FS1 *IAF*AW4*OB1*(RF4S)
 CDF 14 SEQ013 = LOOP *OGF*SW1*IAF*SV2*(GF1S*GG1S*GH1S*TG1S*TH1S)*ZHESV3
 CDF 15 SEQ014 = SLBO *IAF*MS2*AW8*OB1*(RF4S)*(AW3 + ZHEAW4)
 CDF 16 SEQ015 = LOOP *OGF*GF1*GG2*IAF*CC5*(GH3S*TG3S*TH3S)*ZHERE2*RESLC3
 CDF 17 SEQ016 = RT *DH1*I3F*AW8*(RF4S*CI1S)
 CDF 18 SEQ017 = LOOP *OGF*GF1*GG2*IAF*AS8*(GH3S*TG3S*TH3S)*RESLC2
 CDF 19 SEQ018 = TT *DH1*I3F*AW8*(RF4S*CI1S)
 CDF 20 SEQ019 = FS8 *AFF*AGF*AHF*IAF*CCF
 CDF 21 SEQ020 = RT *DG1*I2F*AW7*(RF4S)*ZHEOB2
 CDF 22 SEQ021 = RT *IAF*HS1*(RF4S*CI1S)
 CDF 23 SEQ022 = TT *DG1*I2F*AW7*(RF4S)*ZHEOB2
 CDF 24 SEQ023 = TT *IAF*HS1*(RF4S*CI1S)
 CDF 25 SEQ024 = LOOP *OGF*GH1*IAF*AW3*(GF1S*GG1S*TG2S*TH2S)*RSEQ24
 CDF 26 SEQ025 = LOOP *OGF*GG1*TH2*FO4*CVF*ASF*(GF1S*GH2S*TG2S)*RSEQ25
 CDF 27 SEQ026 = LOSWV *IAF*SVF*RF4*(CI1S*SI1S)*ZHESV3
 CDF 28 SEQ027 = L1DC *DGF*I2F*AW7*OB3*RF4*(CI1S)*ZHEAW3
 CDF 29 SEQ028 = PLMFW *DH1*I3F*AW8*(RF4S*CI1S)
 CDF 30 SEQ029 = LOOP *OGF*GH1*IAF*PRD*LA1*REAC06
 CDF 31 SEQ030 = LOOP *OGF*GG1*IAF*PRD*LB3*(GF1S*GH2S*TG2S*TH2S)*REAC06
 CDF 32 SEQ031 = SLBO *DG1*I2F*MS2*(RF4S*CI1S)*(ZHEAW4 + AW7)
 CDF 33 SEQ032 = SLBO *DH1*I3F*MS2*(RF4S*CI1S)*(ZHEAW4 + AW8)
 CDF 34 SEQ033 = SLBO *AH1*IAF*MS2*(RF4S*CI1S)*(ZHEAW4 + AW3)
 CDF 35 SEQ034 = LOOP*OGF*GG1*TG2*SW1*IAF*CC5*GF1S*GH2S*TH3S*RSEQ34
 CDF 36 SEQ035 = RT *IAF*AW1*OB1*(RF4S*CI1S)
 CDF 37 SEQ036 = PLMFW *DG1*I2F*AW7*(RF4S)*ZHEOB2
 CDF 38 SEQ037 = PLMFW *IAF*HS1*(RF4S*CI1S)
 CDF 39 SEQ038 = FS11 *IAF*ASF*RP2*SE1
 CDF 40 SEQ039 = LOOP*OGF*GG1*TG2*SW1*IAF*AS8*GF1S*GH2S*TH3S*RSEQ34
 CDF 41 SEQ040 = TT *IAF*AW1*OB1
 CDF 42 SEQ041 = RT *IAF*SV1*(RF4S*CI1S*SI1S)*ZHESV3
 CDF 43 SEQ042 = L1DC *DGF*I2F*AS3*(RF4S)*ZHERP2
 CDF 44 SEQ043 = LOOP *OGF*SW1*IAF*AW3*OB1*AW1/AW3*(ZHESW1 + AW3)
 CDF 45 SEQ044 = FS1 *IAF*AW4*VI2
 CDF 46 SEQ045 = TT *IAF*SV1*(RF4S*CI1S*SI1S)*ZHESV3
 CDF 47 SEQ046 = LPCC *IAF*ASF*RP2*SE1





CDF 48 SEQ047 = LOOP *OGF*GF1*GG2*GH3*CVF*ASF*AW4*RESLC1
 CDF 49 SEQ048 = PLMFW *IAF*AW1*OB1
 CDF 50 SEQ049 = SLBO *IAF*MS2*AWB*VI2*(AW3 + ZHEAW4)
 CDF 51 SEQ050 = L1DC *DGF*I2F*AW7*VI2
 CDF 52 SEQ051 = L1DC *DGF*I2F*AW7*LB3*MU2
 CDF 53 SEQ052 = PLMFW *IAF*SV1*(RF4S*CI1S*SI1S)*ZHESV3
 CDF 54 SEQ053 = MLOCA *IAF*RF3
 CDF 55 SEQ054 = LOOP *OGF*GF1*GH2*IAF*SV5*ZHESV3
 CDF 56 SEQ055 = MLOCA *IAF*LA3*LB2
 CDF 57 SEQ056 = LOOP *OGF*GH1*TH2*FO2*CVF*ASF*RSEQ25
 CDF 58 SEQ057 = LOOP *OGF*GG1*TG2*FO2*CVF*ASF*RSEQ25
 CDF 59 SEQ058 = LOOP *OGF*GF1*GH2*TG3*IAF*AW4*REOB1*RESLC1
 CDF 60 SEQ059 = LOOP *OGF*GF1*GH2*TH3*IAF*AW4*REOB1*RESLC1
 CDF 61 SEQ060 = LOOP *OGF*GH1*TG2*TH3*SW3*IAF*AW4*REOB1*RESLC1
 CDF 62 SEQ061 = FS9 *IAF*OB1
 CDF 63 SEQ062 = LOOP *OGF*GG1*GH2*TG3*TH4*CVF*ASF*RESLC2
 CDF 64 SEQ063 = MLOCA *IAF*SI1*2*CH2
 CDF 65 SEQ064 = LOOP *OGF*GF1*GG2*TG3*TH4*IAF*ASF*RESLC2
 CDF 66 SEQ065 = EXFW *DH1*I3F*AW8
 CDF 67 SEQ066 = LOOP *OGF*FO1*CVF*ASF*AW4*ZHEFO6*RESLC1
 CDF 68 SEQ067 = LOOP *OGF*GF1*GG2*GH3*CVF*ASF*PRD
 CDF 69 SEQ068 = LOOP *OGF*IAF*SV4*(SW1S*RF4S*CI1S*SI1S)*ZHESV3
 CDF 70 SEQ069 = LOSW *IAF*ASF*RP2*SE1
 CDF 71 SEQ070 = LOOP *OGF*GG1*FO3*CVF*ASF*RSEQ25
 CDF 72 SEQ071 = LOOP *OGF*TH1*FO3*CVF*ASF*RSEQ25
 CDF 73 SEQ072 = LLOCA *IAF*AC1
 CDF 74 SEQ073 = EXFW *DG1*I2F*AW7*ZHEOB2
 CDF 75 SEQ074 = EXFW *IAF*HS1
 CDF 76 SEQ075 = SGTR *IAF*SL1*MU1
 CDF 77 SEQ076 = LOOP *OGF*GF1*GH2*IAF*AW4*PRD
 CDF 78 SEQ077 = FS1 *DG1*I2F
 CDF 79 SEQ078 = LOOP *OGF*GH1*IAF*SV2*ZHESV3*REAC12
 CDF 80 SEQ079 = LOOP *OGF*TG1*SW3*IAF*SV2*ZHESV3*REAC12
 CDF 81 SEQ080 = LOOP *OGF*TH1*SW3*IAF*SV2*ZHESV3*REAC12
 CDF 82 SEQ081 = LOOP *OGF*GF1*IAF*SV2*ZHESV3*REAC12
 CDF 83 SEQ082 = LOOP *OGF*GF1*GG2*TG3*CV3*ASF*RESLC2
 CDF 84 SEQ083 = L1DC *DGF*I2F*AW7*OB3*LB1*(RF4S)*ZHEAW3



CDF 85 SEQ084 = RT *AH1*IAF*AW3*REOB1
 CDF 86 SEQ085 = LOOP *OGF*GF1*GG2*TG3*IAF*ASF*PRD
 CDF 87 SEQ086 = RT *IAF*AW1*VI2
 CDF 88 SEQ087 = MLOCA *IAF*VI3
 CDF 89 SEQ088 = LOOP *OGF*GH1*TG2*SW1*IAF*SV5*ZHESV3
 CDF 90 SEQ089 = L1DC *DGF*I2F*AW7*OB3*CS2*(RF4S)*ZHEAW3
 CDF 91 SEQ090 = FS11 *IAF*ASF*(RP2S)
 CDF 92 SEQ091 = LOOP *OGF*GG1*GH2*TH3*CVF*PRD
 CDF 93 SEQ092 = L1DC *DGF*I2F*AW7*CH2*OB3*ZHEAW3
 CDF 94 SEQ093 = LOOP *OGF*GH1*IAF*PRD*HRD*REAC06
 CDF 95 SEQ094 = TT *AH1*IAF*AW3*REOB1
 CDF 96 SEQ095 = LOOP *OGF*GG1*GH2*TG3*IAF*PRD*REAC06
 CDF 97 SEQ096 = L1DC *DGF*DH2*I2F*I3F*I4F*AWA
 CDF 98 SEQ097 = LOOP *OGF*GH1*TH2*SW1*IAF*SV5*ZHESV3*REAC12
 CDF 99 SEQ098 = TT *IAF*AW1*VI2
 CDF SEQ099 = L1DC *DGF*AH4*I2F*I4F*AWA
 CDF SEQ100 = LOOP *OGF*GH1*IAF*PRD*VA1*REAC06
 CDF SEQ101 = SGTR *IAF*SL1*LA1*LB2
 CDF SEQ102 = LOOP *OGF*SW1*IAF*AW3*VI2
 CDF SEQ103 = LLOCA *IAF*RF3
 CDF SEQ104 = EXFW *IAF*AW1*OB1
 CDF SEQ105 = LOOP *OGF*GG1*IAF*PRD*VB1
 CDF SEQ106 = LOOP *OGF*GH1*FO1*CVF*ASF
 CDF SEQ107 = LOOP *OGF*TG1*FO1*CVF*ASF
 CDF SEQ108 = LOOP *OGF*GF1*FO1*CVF*ASF
 CDF SEQ109 = LPCC *IAF*ASF*(RP2S)
 CDF SEQ110 = LOOP *OGF*GG1*GH2*TH3*FO5*CVF*ASF
 CDF SEQ111 = LOOP *OGF*GG1*TG2*TH3*FO5*CVF*ASF
 CDF SEQ112 = LOOP *OGF*GG1*IAF*PRD*HRB
 CDF SEQ113 = EXFW *IAF*SV1
 CDF SEQ114 = LOOP *OGF*FO1*CVF*ASF*PRD
 CDF SEQ115 = LOPF *DH1*I3F*AW8
 CDF SEQ116 = LOOP *OGF*GG1*GH2*CV3*PRD
 CDF SEQ117 = PLMFW*AH1*IAF*AW3
 CDF SEQ118 = FS1 *IAF*AW4*OB1*RF4
 CDF SEQ119 = RT *DG1*I2F*CC3
 CDF SEQ120 = PLMFW*IAF*AW1*VI2



CDF SEQ121 = LOOP *OGF*GH1*SW2*IAF*AW4
 CDF SEQ122 = LOOP *OGF*GF1*GH2*IAF*CC5*AW4
 CDF SEQ123 = SLBI *IAF*AWB*RP2*OB1
 CDF SEQ124 = RT *DH1*I3F*CC2
 CDF SEQ125 = FS1 *IAF*AW4*LA1*LB2
 CDF SEQ126 = LOOP *OGF*GH1*TG2*SW1*IAF*AW4*PRD
 CDF SEQ127 = L1DC *DGF*DH2*I2F*I3F*I4F*AWA*OB3
 CDF SEQ128 = TT *DG1*I2F*CC3
 CDF SEQ129 = IMSIV *DH1*I3F*AW8
 CDF SEQ130 = L1DC *DGF*AH4*I2F*I4F*AWA*OB3
 CDF SEQ131 = LOOP *OGF*SW1*IAF*SV2*RF4
 CDF SEQ132 = LOOP *OGF*GH1*TH2*SW1*IAF*AW4*PRD
 CDF SEQ133 = L1DC *DF1*DGF*I1F*I2F*MS2*AWA*OB3
 CDF SEQ134 = TT *DH1*I3F*CC2
 CDF SEQ135 = L1DC *DGF*I2F*AW7*OB3*SR2
 CDF SEQ136 = L1DC *DGF*AF1*I2F*AWA*OB3
 CDF SEQ137 = TLMFW *DH1*I3F*AW8
 CDF SEQ138 = VSI *IAF*IT1*ME1
 CDF SEQ139 = LOPF *DG1*I2F*AW7
 CDF SEQ140 = LOPF *IAF*HS1
 CDF SEQ141 = LOSWV *SA1*SVF
 CDF SEQ142 = LOSWV *SB1*SVF
 CDF SEQ143 = L1DC *DF1*DGF*I1F*I2F*CC5*MS2
 CDF SEQ144 = SLBO *IAF*MS2*AWB*OB1*RF4
 CDF SEQ145 = SLOCI *IAF*PRN*LA1*LB2
 CDF SEQ146 = LOOP *OGF*GF1*GG2*TH3*IAF*CC5
 CDF SEQ147 = LCV *DH1*I3F*AW8
 CDF SEQ148 = L1DC *DGF*I2F*SB1*AW7*OB3
 CDF SEQ149 = IMSIV *IAF*HS1
 CDF SEQ150 = L1DC *DGF*AF1*I2F*CC5
 CDF SEQ151 = IMSIV *DG1*I2F*AW7
 CDF SEQ152 = FS9 *IAF*VI2
 CDF SEQ153 = SLBI *SA5*SBE*OSF*MS2
 CDF SEQ154 = SLBO *I31*MS2*OB1
 CDF SEQ155 = L1DC *DGF*DH2*I2F*I3F*I4F*CC4
 CDF SEQ156 = SLBO *I11*MS2*OB1
 CDF SEQ157 = LOOP *OGF*DH1*GF1*I3F*AW9





CDF SEQ158 = SLBO *IAF*MS2*AWB*LA1*LB2
 CDF SEQ159 = LOOP *OGF*GH1*TH2*SW1*CV6*AW4
 CDF SEQ160 = L1DC *DGF*AH4*I2F*I4F*CC4
 CDF SEQ161 = LOOP *OGF*GG1*TH2*FO4*CVF*ASF*AW4
 CDF SEQ162 = RT *DF1*I1F*AW8*OB1
 CDF SEQ163 = TLMFW *DG1*I2F*AW7
 CDF SEQ164 = LOOP *OGF*GF1*GG2*TH3*IAF*ASB
 CDF SEQ165 = TLMFW *IAF*HS1
 CDF SEQ166 = LOOP *OGF*DF1*GH1*I1F*AW9
 CDF SEQ167 = MLOCA *SA2*SB6*OSF
 CDF SEQ168 = LOOP *OGF*GH1*IAF*PRD*RF1
 CDF SEQ169 = LOOP *OGF*GG1*GH2*SW2*IAF*CCF
 CDF SEQ170 = SGTR *IAF*OP1*VI5
 CDF SEQ171 = SLBI *SBC*OSF*RP2*OB1
 CDF SEQ172 = SLBI *SA5*OSF*RP2*OB1
 CDF SEQ173 = L1DC *DGF*I2F*AW7*VB1
 CDF SEQ174 = LOOP *OGF*GG1*IAF*PRD*RF1
 CDF SEQ175 = PLMFW *DG1*I2F*CC3
 CDF SEQ176 = TT *DF1*I1F*AW8*OB1
 CDF SEQ177 = LOCV *DH1*I3F*CVF*AW8
 CDF SEQ178 = RT *I31*AW5*OB1
 CDF SEQ179 = LOCV *CVF*RT1*OSF
 CDF SEQ180 = RT *DH1*I3F*AW8*RF4
 CDF SEQ181 = RT *I11*AW5*OB1
 CDF SEQ182 = ISI *DH1*I3F*AW8
 CDF SEQ183 = L1DC *DGF*I2F*AW7*HRB
 CDF SEQ184 = PLMFW *DH1*I3F*CC2
 CDF SEQ185 = LOOP *OGF*BG1*GF1*GG2*IAF*ASF
 CDF SEQ186 = FS6 *AFF*AGF*IAF*CC5*RP2
 CDF SEQ187 = RT *SA1*SB2*RT7*OSF
 CDF SEQ188 = LCV *DG1*I2F*AW7
 CDF SEQ189 = LOSW *IAF*ASF*(RP2S)
 CDF SEQ190 = LCV *IAF*HS1
 CDF SEQ191 = LOOP *OGF*SW1*IAF*CC7*SE1
 CDF SEQ192 = TT *I31*AW5*OB1
 CDF SEQ193 = TT *I11*AW5*OB1
 CDF SEQ194 = TT *DH1*I3F*AW8*RF4





CDF SEQ195 = LOOP *OGF*DH1*I3F*AW8
 CDF SEQ196 = L1DC *DGF*I2F*AW7*OB3*CI2
 CDF SEQ197 = RT *SA1*SB2*OS1*MS2
 CDF SEQ198 = LOPF *IAF*AW1*OB1
 CDF SEQ199 = TT *SA1*SB2*RT7*OSF
 CDF SEQ200 = LOOP *OGF*GF1*GH2*CV2*AW4
 CDF SEQ201 = LOOP *OGF*GF1*GG2*CV3*CC5
 CDF SEQ202 = SLOC1*IAF*CC1
 CDF SEQ203 = LOOP *OGF*GG1*I32*PRD
 CDF SEQ204 = LOOP *OGF*GG1*GH2*IAF*CC5*PRD
 CDF SEQ205 = LOOP *OGF*TH1*SW3*IAF*AW3*OB1
 CDF SEQ206 = LOOP *OGF*TG1*SW3*IAF*AW3*OB1
 CDF SEQ207 = LOOP *OGF*GF1*GG2*TH3*FO4*CVF*ASF
 CDF SEQ208 = LOOP *OGF*GF1*GH2*IAF*SV5*AW9
 CDF SEQ209 = LOOP *OGF*GF1*IAF*AW3*OB1
 CDF SEQ210 = RT *IAF*HS1*RF4
 CDF SEQ211 = LOCV *DG1*I2F*CVF*AW7
 CDF SEQ212 = TT *SA1*SB2*OS1*MS2
 CDF SEQ213 = LOCV *CVF*HS1
 CDF SEQ214 = LOOP *OGF*GF1*GG2*IAF*CC5*PRD
 CDF SEQ215 = RT *DG1*I2F*AW7*RF4
 CDF SEQ216 = LOOP *OGF*GF1*GH2*IAF*AW4*CH2
 CDF SEQ217 = ISI *IAF*HS1
 CDF SEQ218 = ISI *DG1*I2F*AW7
 CDF SEQ219 = LOOP *OGF*GF1*GG2*CV3*ASB
 CDF SEQ220 = SGTR *IAF*OP1*MU1
 CDF SEQ221 = LOOP *OGF*GF1*GH2*IAF*CC5*PRD
 CDF SEQ222 = SLBI *DG1*I2F
 CDF SEQ223 = LOPF *IAF*SV1
 CDF SEQ224 = LOOP *OGF*GH1*TG2*SW1*IAF*CC5*AW4
 CDF SEQ225 = SLBI *DH1*I3F
 CDF SEQ226 = IMSIV *IAF*AW1*OB1
 CDF SEQ227 = SLBI *AH1*IAF*RP2
 CDF SEQ228 = RT *IAF*CC1*RP2*SE1
 CDF SEQ229 = TT *IAF*HS1*RF4
 CDF SEQ230 = LOOP *OGF*GF1*GG2*IAF*ASB*PRD
 CDF SEQ231 = LOOP *OGF*GH1*TH2*SW1*IAF*CC5*AW4



CDF SEQ232 =TT *DG1*I2F*AW7*RF4
 CDF SEQ233 =ELOCA *IAF
 CDF SEQ234 =LOOP *OGF*GH1*IAF*AW3*RF4
 CDF SEQ235 =TLMFW *IAF*AW1*OB1
 CDF SEQ236 =MLOCA *CV1*OSF
 CDF SEQ237 =PLMFW *DF1*I1F*AW8*OB1
 CDF SEQ238 =LOOP *OGF*DG1*I2F*AW7
 CDF SEQ239 =L1DC *DGF*I2F*AW7*OB3*V83
 CDF SEQ240 =TT *IAF*CC1*RP2*SE1
 CDF SEQ241 =LOOP *OGF*GG1*GH2*IAF*AW3
 CDF SEQ242 =SGTR *I31*SL2
 CDF SEQ243 =SGTR *I11*SL2
 CDF SEQ244 =IMSIV *IAF*SV1
 CDF SEQ245 =LOOP *OGF*BG1*GH1*SW1*IAF*AW4
 CDF SEQ246 =SLBO *DF1*I1F*MS2*OB1
 CDF SEQ247 =FS8 *AFF*AGF*AHF*IAF*CCF*PRD
 CDF SEQ248 =PLMFW *I31*AW5*OB1
 CDF SEQ249 =SLBO *AF1*IAF*MS2*OB1
 CDF SEQ250 =LOOP *OGF*GF1*GG2*IAF*AW3
 CDF SEQ251 =PLMFW *DH1*I3F*AW8*RF4
 CDF SEQ252 =LOS WV *IAF*SVF*CI1*(RF45)
 CDF SEQ253 =PLMFW *I11*AW5*OB1
 CDF SEQ254 =LOOP *OGF*BH1*GH1*SW1*IAF*AW4
 CDF SEQ255 =LOOP *OGF*AH1*GF1*IAF*AW4
 CDF SEQ256 =TLMFW *IAF*SV1
 CDF SEQ257 =LOOP *OGF*DG1*GF1*GH5*I2F*I4F*CVF*ASF*MS2
 CDF SEQ258 =LCV *IAF*AW1*OB1
 CDF SEQ259 =RT *OG1*GF1*GG2*GH3*CVF*ASF*RP2
 CDF SEQ260 =PLMFW *SA1*SB2*RT7*OSF
 CDF SEQ261 =L1DC *DF1*DGF*I1F*I2F*AS4*MS2
 CDF SEQ262 =SLBO *DG1*I2F*MS2*RF4
 CDF SEQ263 =SLBO *DH1*I3F*MS2*RF4
 CDF SEQ264 =LOOP *OGF*AF1*GH1*IAF*AW4
 CDF SEQ265 =SLOCI *DG1*I2F*LB3
 CDF SEQ266 =SLBO *AH1*IAF*MS2*RF4
 CDF SEQ267 =LOOP *OGF*GG1*TH2*IAF*PRD*LB3
 CDF SEQ268 =SLOCI *DH1*I3F*LA1






CDF SEQ269 = SLOCI *AG1*IAF*LB3
 CDF SEQ270 = L1DC *DGF*AF1*I2F*AS4
 CDF SEQ271 = SLOCI *AH1*IAF*LA1
 CDF SEQ272 = MLOCA *IAF*LV1
 CDF SEQ273 = EXFW *AH1*IAF*AW3
 CDF SEQ274 = PLMFW *SA1*SB2*OS1*MS2
 CDF SEQ275 = LOOP *OGF*GF1*GG2*IAF*PRD*LB3
 CDF SEQ276 = SLOCN *IAF*RW1
 CDF SEQ277 = EXFW *IAF*AW1*VI2
 CDF SEQ278 = TT *OG1*GF1*GG2*GH3*CVF*ASF*RP2
 CDF SEQ279 = LOOP *OGF*DH1*TG5*SW1*I3F*AW9
 CDF SEQ280 = SLBO *I21*MS2*OB1
 CDF SEQ281 = LCV *IAF*SV1
 CDF SEQ282 = LOOP *OGF*GH1*IAF*AW3*PRD
 CDF SEQ283 = RT *OG1*GF1*GH2*IAF*AW4*RP2
 CDF SEQ284 = LOOP *OGF*GG1*TH2*FO4*CVF*ASF*PRD
 CDF SEQ285 = LOOP *OGF*GF1*GH2*IAF*PRD*LA1
 CDF SEQ286 = SLBO *I41*MS2*OB1
 CDF SEQ287 = SGTR *IAF*OP1*LA1*LB2
 CDF SEQ288 = L1DC *DGF*I2F*AW7*S11*OB3
 CDF SEQ289 = LOSWV *IAF*SVF*S11*(RF45*CI15)
 CDF SEQ290 = LOOP *OGF*DG1*GH4*I2F*IAF*AWA
 CDF SEQ291 = RT *IAF*AW1*OB1*RF4
 CDF SEQ292 = LOOP *OGF*DH1*TH6*SW1*I3F*AW9
 CDF SEQ293 = LOCV *CVF*AW1*OB1
 CDF SEQ294 = RT *DF1*I1F*SV2
 CDF SEQ295 = PLMFW *IAF*HS1*RF4
 CDF SEQ296 = LOOP *OGF*AH1*GF1*GG2*CVF*ASF
 CDF SEQ297 = LOOP *OGF*AG1*GF1*GH5*CVF*ASF
 CDF SEQ298 = ISI *IAF*AW1*OB1
 CDF SEQ299 = L1DC *DGF*I2F*AW7*RF1
 CDF SEQ300 = LOOP *OGF*DH1*GF1*GG2*I3F*CVF*ASF
 CDF SEQ301 = PLMFW *DG1*I2F*AW7*RF4
 CDF SEQ302 = RT *AF1*IAF*SV2
 CDF SEQ303 = TT *OG1*GF1*GH2*IAF*AW4*RP2
 CDF SEQ304 = RT *IAF*AW1*LA1*LB2
 CDF SEQ305 = LOOP *OGF*GG1*CV3*PRD*LB3





CDF SEQ306 = RT *I21*AW5*OB1
 CDF SEQ307 = TT *IAF*AW1*OB1*RF4
 CDF SEQ308 = PLMFW*IAF*CC1*RP2*SE1
 CDF SEQ309 = TT *DF1*I1F*SV2
 CDF SEQ310 = RT *I41*AW5*OB1
 CDF SEQ311 = LOOP *OGF*DG1*GF1*I2F*AWA
 CDF SEQ312 = FS6 *AFF*AGF*IAF*AS4*RP2
 CDF SEQ313 = LOOP *OGF*AF1*GG1*GH2*CVF*ASF
 CDF SEQ314 = LOOP *OGF*GF1*GG2*GH3*SB1*CVF*ASF
 CDF SEQ315 = LOOP *OGF*GG1*GH2*IAF*PRD*SI2
 CDF SEQ316 = LOOP *OGF*GF1*GG2*IAF*PRD*SI2
 CDF SEQ317 = LOCV *CVF*SV1
 CDF SEQ318 = TT *AF1*IAF*SV2
 CDF SEQ319 = LOOP *OGF*SW1*IAF*AW3*OB1*RF4
 CDF SEQ320 = ISI *IAF*SV1
 CDF SEQ321 = TT *IAF*AW1*LA1*LB2
 CDF SEQ322 = LOOP *OGF*DF1*GG1*GH2*I1F*CVF*ASF
 CDF SEQ323 = LOOP *OGF*AG1*GF1*TG6*IAF*ASF
 CDF SEQ324 = RT *IAF*SV1*RF4
 CDF SEQ325 = TT *I21*AW5*OB1
 CDF SEQ326 = LOOP *OGF*DG1*GF1*TG6*I2F*ASF
 CDF SEQ327 = LLOCA *SA2*SB6*OSF
 CDF SEQ328 = LOOP *OGF*GG1*SW2*IAF*CC5
 CDF SEQ329 = TT *I41*AW5*OB1
 CDF SEQ330 = SLOCN *IAF*RF1*MU2
 CDF SEQ331 = LOOP *OGF*SW1*IAF*AW3*LA1*LB2
 CDF SEQ332 = FS1 *IAF*AW4*VI2*RF4
 CDF SEQ333 = LOOP *OGF*DF1*GG1*TG2*I1F*ASF
 CDF SEQ334 = FS5 *IAF*ASF*RP2*SE1
 CDF SEQ335 = RT *OG1*GF1*GG2*TG3*IAF*ASF*RP2
 CDF SEQ336 = L1DC *DGF*I2F*I32*AW7
 CDF SEQ337 = LOOP *OGF*AF1*GG1*TG2*IAF*ASF
 CDF SEQ338 = FS11 *DG1*I2F*ASF
 CDF SEQ339 = FS10 *IAF*AW4*OB1
 CDF SEQ340 = FS11 *DH1*I3F*ASF
 CDF SEQ341 = LOOP *OGF*GG1*GH2*IAF*PRD*CH2
 CDF SEQ342 = TT *IAF*SV1*RF4



CDF	SEQ343	= SLBI *IAF*AWB*RP2*VI2
CDF	SEQ344	= LOOP *OGF*GH1*TH2*FO2*CVF*ASF*AW4
CDF	SEQ345	= LOOP *OGF*GG1*TG2*FO2*CVF*ASF*AW4
CDF	SEQ346	= LOOP *OGF*GG1*TG2*SW1*IAF*CC5*PRD
CDF	SEQ347	= LOOP *OGF*GF1*GH2*SB1*AW4
CDF	SEQ348	= LOOP *OGF*GH1*TG2*SW1*IAF*SV5*AW9
CDF	SEQ349	= SGTR *DF1*I1F*SL2
CDF	SEQ350	= PLMFW *OG1*GF1*GG2*GH3*CVF*ASF*RP2
CDF	SEQ351	= LOOP *OGF*GH1*TG2*SW1*IAF*AW4*CH2
CDF	SEQ352	= TT *OG1*GF1*GG2*TG3*IAF*ASF*RP2
CDF	SEQ353	= L1DC *DGF*I2F*CC3*PRA
CDF	SEQ354	= SGTR *DH1*I3F*SL2
CDF	SEQ355	= RT *DH1*I3F*SV3
CDF	SEQ356	= SGTR *DG1*I2F*SL2
CDF	SEQ357	= LOOP *OGF*GH1*TH2*SW1*IAF*SV5*AW9
CDF	SEQ358	= LOOP *OGF*GH1*IAF*CC7*PRD
CDF	SEQ359	= FS1 *DH1*I3F*AW9
CDF	SEQ360	= LOOP *OGF*GH1*TG2*SW1*IAF*CC5*PRD
CDF	SEQ361	= RT *AH1*IAF*SV3
CDF	SEQ362	= LOOP *OGF*GH1*TH2*SW1*IAF*AW4*CH2
CDF	SEQ363	= LOOP *OGF*GG1*GH2*TG3*TH4*CVF*ASF*AW4
CDF	SEQ364	= LOOP *OGF*GG1*TG2*SW1*IAF*ASB*PRD
CDF	SEQ365	= LOOP *OGF*SW1*IAF*AS5*SE1
CDF	SEQ366	= LOOP *OGF*SW1*IAF*SV2*SI2
CDF	SEQ367	= LOOP *OGF*GG1*IAF*CC7*PRD
CDF	SEQ368	= LOOP *OGF*GH1*TH2*SW1*IAF*CC5*PRD
CDF	SEQ369	= EXFW *DG1*I2F*CC3
CDF	SEQ370	= FS1 *IAF*AW4*OB1*LA1
CDF	SEQ371	= FS1 *IAF*AW4*OB1*LB1
CDF	SEQ372	= TT *DH1*I3F*SV3
CDF	SEQ373	= PLMFW *OG1*GF1*GH2*IAF*AW4*RP2
CDF	SEQ374	= LPCC *DG1*I2F*ASF
CDF	SEQ375	= LOOP *OGF*IAF*HS1
CDF	SEQ376	= LPCC *DH1*I3F*ASF
CDF	SEQ377	= TT *AH1*IAF*SV3
CDF	SEQ378	= EXFW *DH1*I3F*CC2
CDF	SEQ379	= LOOP *OGF*SW1*IAF*HS1



CDF SEQ380 = L1DC *DGF*I2F*SA1*CC3
 CDF SEQ381 = L1DC *DGF*I2F*SB1*CC3
 CDF SEQ382 = LOOP *OGF*GH1*TG2*IAF*AW3
 CDF SEQ383 = PLMFW *IAF*AW1*OB1*RF4
 CDF SEQ384 = LOOP *OGF*GG1*IAF*SV4
 CDF SEQ385 = PLMFW *DF1*I1F*SV2
 CDF SEQ386 = LOOP *OGF*DH1*GG1*I3F*PRD
 CDF SEQ387 = LOOP *OGF*GG1*IAF*AW1
 CDF SEQ388 = LOOP *OGF*GF1*GH2*TG3*TH4*IAF*AW4
 CDF SEQ389 = LOOP *OGF*GH1*TH2*IAF*AW3
 CDF SEQ390 = SGTR *I21*SL2
 CDF SEQ391 = LOOP *OGF*AH1*GG1*IAF*PRD
 CDF SEQ392 = LOOP *OGF*GF1*GG2*TG3*SB1*ASF
 CDF SEQ393 = LOOP *OGF*AG1*GH4*IAF*PRD
 CDF SEQ394 = PLMFW *AF1*IAF*SV2
 CDF SEQ395 = LOOP *OGF*GG1*TG2*SW1*IAF*AW3
 CDF SEQ396 = SGTR *I41*SL2
 CDF SEQ397 = SLBO *IAF*MS2*AWB*VI2*RF4
 CDF SEQ398 = LOOP *OGF*GF1*GH2*TG3*IAF*SV5
 CDF SEQ399 = PLMFW *IAF*AW1*LA1*LB2
 CDF SEQ400 = L1DC *DGF*I2F*AW7*VI2*RF4
 CDF SEQ401 = PLMFW *I21*AW5*OB1
 CDF SEQ402 = LOOP *OGF*GF1*GH2*TH3*IAF*SV5
 CDF SEQ403 = LOOP *OGF*AH1*TG5*SW1*IAF*AW4
 CDF SEQ404 = LOOP *OGF*GH1*TG2*TH3*SW3*IAF*SV5
 CDF SEQ405 = PLMFW *I41*AW5*OB1
 CDF SEQ406 = RT *OG1*FO1*CVF*ASF*RP2
 CDF SEQ407 = LOOP *OGF*GF1*GH2*IAF*AW4*CI2
 CDF SEQ408 = LOOP *OGF*TH1*FO3*CVF*ASF*AW4
 CDF SEQ409 = LOOP *OGF*GG1*FO3*CVF*ASF*AW4
 CDF SEQ410 = SLOCN *I31*LA1
 CDF SEQ411 = SLBO *I31*MS2*VI2
 CDF SEQ412 = SLBO *I11*MS2*VI2
 CDF SEQ413 = LOOP *OGF*GH1*TG2*IAF*PRD*LA1
 CDF SEQ414 = LOOP *OGF*GG1*GH2*TG3*FO2*CVF*ASF
 CDF SEQ415 = LOOP *OGF*GF1*GH2*TH3*FO2*CVF*ASF
 CDF SEQ416 = LOOP *OGF*GH1*TG2*TH3*FO2*CVF*ASF



CDF	SEQ417	= LOOP *OGF*GF1*GG2*TG3*FO2*CVF*ASF
CDF	SEQ418	= LOOP *OGF*SW1*IAF*SV2*CH2
CDF	SEQ419	= LLOCA *IAF*LA3*L88
CDF	SEQ420	= LOOP *OGF*AH1*TH6*SW1*IAF*AW4
CDF	OTHER	= HAZCHM*ZHEHS5 *0.1 + CRFIRE
CDF	RP2S	= 1.-RP2
CDF	RF4S	= 1.-RF4
CDF	CI1S	= 1.-CI1
CDF	SI1S	= 1.-SI1
CDF	SW1S	= 1.-SW1
CDF	OG1S	= 1.-OG1
CDF	SA1S	= 1.-SA1
CDF	SB1S	= 1.-SB1
CDF	GF1S	= 1.-GF1
CDF	GG1S	= 1.-GG1
CDF	GH1S	= 1.-GH1
CDF	TG1S	= 1.-TG1
CDF	TH1S	= 1.-TH1
CDF	GG2S	= 1.-GG2
CDF	TG3S	= 1.-TG3
CDF	TH3S	= 1.-TH3
CDF	GH3S	= 1.-GH3
CDF	TH4S	= 1.-TH4
CDF	TH2S	= 1.-TH2
CDF	TG2S	= 1.-TG2
CDF	GH2S	= 1.-GH2
CDF	REOB1	= (OB1 + RF1 + LA1 + CH2)
CDF	RSEQ8	= ZHEFO6*RESLC3
CDF	RSEQ10	= (ZHEFW1 + AW4)*RESLC1
CDF	RSEQ24	= (OB1 + LA1 + RF1 + CH1 + VA1)
CDF	RSEQ25	= ZHEFO6*RESLC3
CDF	RSEQ34	= ZHERE2*RESLC3



Figure B-2: Sequences for Swing DG Maintenance Configuration
 Reference: PGE.1123.EVENT.TREES.INTERNALS.RMODEL.DGAOT.DG57AOT.CDFSCH.EQS

Calculation 1A:

C3A	1 TOTAL = CDF3 + NEWSEQ	TOTAL CORE MELT NO SCHEDULED MAINT ON SWING
C3A	5 NEWSEQ = SEIS1 + SEIS2 + GF1SEQ	CORE MELT CONTRIBUTION DUE TO DG F PREVENTIVE MAINTENANCE
C3A	6 SEIS1 = SEIS1C*0.0	CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C3A	7 SEIS2 = SEIS2C*0.0	CORE MELT - SEISMIC CCW FAILURES
C3A	8 GF1SEQ = GF1CND*0.0	CORE MELT - DG F FAILS - NONSEISMIC
C3A	9 SEIS1C = SEIS1T * (GF1*GG5*(GHB + TGI + GHA*AW4 + ASB) + GF1*GHA*AW4)	CONDITIONAL CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C3A	10 SEIS2C = SEIS2T * GF1 * GG5	CONDITIONAL CORE MELT - SEISMIC CCW FAILURES
C3A	11 GF1CND = SEQ003 + SEQ005 + SEQ007 + SEQ015 + SEQ017 + SEQ047 + SEQ054 + X1	CONDITIONAL CORE MELT - DG F FAILS - NONSEISMIC

Calculation 2:

C3D	1 TOTAL = CDF3 + NEWSEQ	TOTAL CORE MELT, 10 DAY SCHEDULED MAINT ON SWING
C3D	5 NEWSEQ = SEIS1 + SEIS2 + GF1SEQ	CORE MELT CONTRIBUTION DUE TO DG F PREVENTIVE MAINTENANCE
C3D	6 SEIS1 = SEIS1C * (10/(365*1.5))	CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C3D	7 SEIS2 = SEIS2C * (10/(365*1.5))	CORE MELT - SEISMIC CCW FAILURES
C3D	8 GF1SEQ = GF1CND * (10/(365*1.5))	CORE MELT - DG F FAILS - NONSEISMIC
C3D	9 SEIS1C = SEIS1T * (GF1*GG5*(GHB + TGI + GHA*AW4 + ASB) + GF1*GHA*AW4)	CONDITIONAL CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C3D	10 SEIS2C = SEIS2T * GF1 * GG5	CONDITIONAL CORE MELT - SEISMIC CCW FAILURES
C3D	11 GF1CND = SEQ003 + SEQ005 + SEQ007 + SEQ015 + SEQ017 + SEQ047 + SEQ054 + X1	CONDITIONAL CORE MELT - DG F FAILS - NONSEISMIC

Calculation 1B:

C7A	1 TOTAL = CDF7 + NEWSEQ	TOTAL CORE MELT NO SCHEDULED MAINT ON SWING
C7A	5 NEWSEQ = SEIS1 + SEIS2 + GF1SEQ	CORE MELT CONTRIBUTION DUE TO DG F PREVENTIVE MAINTENANCE
C7A	6 SEIS1 = SEIS1C*0.0	CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C7A	7 SEIS2 = SEIS2C*0.0	CORE MELT - SEISMIC CCW FAILURES
C7A	8 GF1SEQ = GF1CND*0.0	CORE MELT - DG F FAILS - NONSEISMIC
C7A	9 SEIS1C = SEIS1T * (GF1*GG5*(GHB + TGI + GHA*AW4 + ASB) + GF1*GHA*AW4)	CONDITIONAL CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C7A	10 SEIS2C = SEIS2T * GF1 * GG5	CONDITIONAL CORE MELT - SEISMIC CCW FAILURES
C7A	11 GF1CND = SEQ003 + SEQ005 + SEQ007 + SEQ015 + SEQ017 + SEQ047 + SEQ054 + X1	CONDITIONAL CORE MELT - DG F FAILS - NONSEISMIC



Calculation 3:

C7C	1 TOTAL = CDF7 + NEWSEQ	TOTAL CORE MELT, 7 DAY SCHEDULED MAINT ON SWING
C7C	5 NEWSEQ = SEIS1 + SEIS2 + GF1SEQ	CORE MELT CONTRIBUTION DUE TO DG F PREVENTIVE MAINTENANCE
C7C	6 SEIS1 = SEIS1C * (7/(365*1.5))	CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C7C	7 SEIS2 = SEIS2C * (7/(365*1.5))	CORE MELT - SEISMIC CCW FAILURES
C7C	8 GF1SEQ = GF1CND * (7/(365*1.5))	CORE MELT - DG F FAILS - NONSEISMIC
C7C	9 SEIS1C = SEIS1T * (GF1*GG5*(GHB + TGI + GHA*AW4 + ASB) + GF1*GHA*AW4)	CONDITIONAL CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C7C	10 SEIS2C = SEIS2T * GF1 * GG5	CONDITIONAL CORE MELT - SEISMIC CCW FAILURES
C7C	11 GF1CND = SEQ003 + SEQ005 + SEQ007 + SEQ015 + SEQ017 + SEQ047 + SEQ054 + X1	CONDITIONAL CORE MELT - DG F FAILS - NONSEISMIC

Calculation 6:

C7Y	1 TOTAL = CDF7 + SEIS1C + SEIS2C + GF1CND	
C7Y	2 SEIS1C = SEIS1T * (GF1*GG5*(GHB + TGI + GHA*AW4 + ASB) + GF1*GHA*AW4)	CONDITIONAL CORE MELT - SEISMIC - NONSEISMIC DG FAILURES
C7Y	3 SEIS2C = SEIS2T * GF1 * GG5	CONDITIONAL CORE MELT - SEISMIC CCW FAILURES
C7Y	4 GF1CND = SEQ003 + SEQ005 + SEQ007 + SEQ015 + SEQ017 + SEQ047 + SEQ054 + X1	CONDITIONAL CORE MELT - DG F FAILS - NONSEISMIC

Common Equations:

X1	= SEQ058 + SEQ059 + SEQ064 + SEQ067 + SEQ076 + SEQ081 + SEQ082 + X2
X2	= SEQ085 + SEQ108 + SEQ122 + SEQ146 + SEQ157 + SEQ164 + SEQ185 + X3
X3	= SEQ200 + SEQ201 + SEQ207 + SEQ208 + SEQ209 + SEQ214 + SEQ216 + X4
X4	= SEQ219 + SEQ221 + SEQ230 + SEQ250 + SEQ255 + SEQ257 + SEQ259 + X5
X5	= SEQ275 + SEQ278 + SEQ283 + SEQ285 + SEQ296 + SEQ297 + SEQ300 + X6
X6	= SEQ303 + SEQ311 + SEQ314 + SEQ316 + SEQ323 + SEQ326 + SEQ335 + X7
X7	= SEQ347 + SEQ350 + SEQ352 + SEQ373 + SEQ388 + SEQ392 + SEQ398 + X8
X8	= SEQ402 + SEQ407 + SEQ415 + SEQ417
SEQ003	= LOOP * OGF * GF1 * GG2 * GH3 * CVF * ASF * RESLC2
SEQ005	= LOOP * OGF * GF1 * GH2 * IAF * AW4 * (GG25 * TG35 * TH35) * RESLC1 * REOB1
SEQ007	= LOOP * OGF * GF1 * GG2 * TG3 * IAF * ASF * (GH35 * TH45) * RESLC2
SEQ015	= LOOP * OGF * GF1 * GG2 * IAF * CC5 * (GH35 * TG35 * TH35) * ZHERE2 * RESLC3
SEQ017	= LOOP * OGF * GF1 * GG2 * IAF * ASB * (GH35 * TG35 * TH35) * RESLC2
SEQ047	= LOOP * OGF * GF1 * GG2 * GH3 * CVF * ASF * AW4 * RESLC1
SEQ054	= LOOP * OGF * GF1 * GH2 * IAF * SV5 * ZHESV3
SEQ058	= LOOP * OGF * GF1 * GH2 * TG3 * IAF * AW4 * REOB1 * RESLC1
SEQ059	= LOOP * OGF * GF1 * GH2 * TH3 * IAF * AW4 * REOB1 * RESLC1





SEQ064 = LOOP *OGF*GF1*GG2*TG3*TH4*IAF*ASF*RESLC2
 SEQ067 = LOOP *OGF*GF1*GG2*GH3*CVF*ASF*PRD
 SEQ076 = LOOP *OGF*GF1*GH2*IAF*AW4*PRD
 SEQ081 = LOOP *OGF*GF1*IAF*SV2*ZHESV3*REAC12
 SEQ082 = LOOP *OGF*GF1*GG2*TG3*CV3*ASF*RESLC2
 SEQ085 = LOOP *OGF*GF1*GG2*TG3*IAF*ASF*PRD
 SEQ108 = LOOP *OGF*GF1*FO1*CVF*ASF
 SEQ122 = LOOP *OGF*GF1*GH2*IAF*CC5*AW4
 SEQ146 = LOOP *OGF*GF1*GG2*TH3*IAF*CC5
 SEQ157 = LOOP *OGF*DH1*GF1*I3F*AW9
 SEQ164 = LOOP *OGF*GF1*GG2*TH3*IAF*ASB
 SEQ185 = LOOP *OGF*BG1*GF1*GG2*IAF*ASF
 SEQ200 = LOOP *OGF*GF1*GH2*CV2*AW4
 SEQ201 = LOOP *OGF*GF1*GG2*CV3*CC5
 SEQ207 = LOOP *OGF*GF1*GG2*TH3*FO4*CVF*ASF
 SEQ208 = LOOP *OGF*GF1*GH2*IAF*SV5*AW9
 SEQ209 = LOOP *OGF*GF1*IAF*AW3*OB1
 SEQ214 = LOOP *OGF*GF1*GG2*IAF*CC5*PRD
 SEQ216 = LOOP *OGF*GF1*GH2*IAF*AW4*CH2
 SEQ219 = LOOP *OGF*GF1*GG2*CV3*ASB
 SEQ221 = LOOP *OGF*GF1*GH2*IAF*CC5*PRD
 SEQ230 = LOOP *OGF*GF1*GG2*IAF*ASB*PRD
 SEQ250 = LOOP *OGF*GF1*GG2*IAF*AW3
 SEQ255 = LOOP *OGF*AH1*GF1*IAF*AW4
 SEQ257 = LOOP *OGF*DG1*GF1*GH5*I2F*I4F*CVF*ASF*MS2
 SEQ259 = RT *OG1*GF1*GG2*GH3*CVF*ASF*RP2
 SEQ275 = LOOP *OGF*GF1*GG2*IAF*PRD*LB3
 SEQ278 = TT *OG1*GF1*GG2*GH3*CVF*ASF*RP2
 SEQ283 = RT *OG1*GF1*GH2*IAF*AW4*RP2
 SEQ285 = LOOP *OGF*GF1*GH2*IAF*PRD*LA1
 SEQ296 = LOOP *OGF*AH1*GF1*GG2*CVF*ASF
 SEQ297 = LOOP *OGF*AG1*GF1*GH5*CVF*ASF
 SEQ300 = LOOP *OGF*DH1*GF1*GG2*I3F*CVF*ASF
 SEQ303 = TT *OG1*GF1*GH2*IAF*AW4*RP2
 SEQ311 = LOOP *OGF*DG1*GF1*I2F*AWA
 SEQ314 = LOOP *OGF*GF1*GG2*GH3*SB1*CVF*ASF
 SEQ316 = LOOP *OGF*GF1*GG2*IAF*PRD*SI2





SEQ323 = LOOP *OGF*AG1*GF1*TG6*IAF*ASF
 SEQ326 = LOOP *OGF*DG1*GF1*TG6*I2F*ASF
 SEQ335 = RT *OG1*GF1*GG2*TG3*IAF*ASF*RP2
 SEQ347 = LOOP *OGF*GF1*GH2*SB1*AW4
 SEQ350 = PLMFW *OG1*GF1*GG2*GH3*CVF*ASF*RP2
 SEQ352 = TT *OG1*GF1*GG2*TG3*IAF*ASF*RP2
 SEQ373 = PLMFW *OG1*GF1*GH2*IAF*AW4*RP2
 SEQ388 = LOOP *OGF*GF1*GH2*TG3*TH4*IAF*AW4
 SEQ392 = LOOP *OGF*GF1*GG2*TG3*SB1*ASF
 SEQ398 = LOOP *OGF*GF1*GH2*TG3*IAF*SV5
 SEQ402 = LOOP *OGF*GF1*GH2*TH3*IAF*SV5
 SEQ407 = LOOP *OGF*GF1*GH2*IAF*AW4*CI2
 SEQ415 = LOOP *OGF*GF1*GH2*TH3*FO2*CVF*ASF
 SEQ417 = LOOP *OGF*GF1*GG2*TG3*FO2*CVF*ASF
 RP2S = 1.-RP2
 RF4S = 1.-RF4
 CI1S = 1.-CI1
 SI1S = 1.-SI1
 SW1S = 1.-SW1
 OG1S = 1.-OG1
 SA1S = 1.-SA1
 SB1S = 1.-SB1
 GF1S = 1.-GF1
 GG1S = 1.-GG1
 GH1S = 1.-GH1
 TG1S = 1.-TG1
 TH1S = 1.-TH1
 GG2S = 1.-GG2
 TG3S = 1.-TG3
 TH3S = 1.-TH3
 GH3S = 1.-GH3
 TH4S = 1.-TH4
 GH2S = 1.-GH2
 REOB1 = (OB1 + RF1 + LA1 + CH2)
 RSEQ8 = ZHEFO6*RESLC3
 RSEQ10 = (ZHESW1 + AW4)*RESLC1
 RSEQ24 = (OB1 + LA1 + RF1 + CH1 + VA1)



RSEQ25 = ZHEFO6*RESLC3
 RSEQ34 = ZHERE2*RESLC3
 GF1 = 1.0 SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 GG2 = GG4 SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 GH2 = GH7 SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 GH3 = GH8 SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 GH5 = GH9 SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 TG3 = TGC SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 TG6 = TGE SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 TH3 = THI SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 TH4 = THJ SPLIT FRACTION REPLACEMENT FOR TECH SPEC STUDY
 CDF3 = .0002078 \$ 1.728E-4 (non-seismic) + 3.497E-5 (seismic) 3 day aot
 CDF7 = .0002120 \$ 1.770E-4 (non-seismic) + 3.500E-5 (seismic) 7 day aot
 GG4 = .04339 \$ Revised split fractions with DG 13 in maintenance
 GH7 = .04319 \$
 GH8 = .04805 \$
 GH9 = .04339 \$
 TGC = .04643 \$
 TGE = .04319 \$
 THI = .04595 \$
 THJ = .05719 \$
 GG5 = .08114 \$
 GHA = .08064 \$
 GHB = .08685 \$
 TGI = .08531 \$





Figure B-3: DCPRA Base Split Fraction Values For Non-Seismic Initiating Events

<u>CSF</u>	<u>BOUNDARY CONDITION</u>	<u>MEAN</u>	<u>5TH %IL</u>	<u>MEDIAN</u>	<u>95TH %ILE</u>
SUPPORT SYSTEMS					
SPLIT FRACTIONS FOR TOP EVENT OG					
OG1	Given Offsite Grid success.	7.63E-04	4.20E-04	5.78E-04	1.35E-03
OGF	Given Offsite Grid fails (guaranteed failure OG).	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT NV					
NV1	Given all support available.	1.63E-04	2.60E-05	1.03E-04	3.76E-04
NV2	Given DC 13 or DC 12 failed and OG succeeded.	2.46E-03	8.29E-04	1.87E-03	4.60E-03
3NVF	Given DC 13 and DC 12 failed or, OG failed.	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT DF					
DF1	480 V vital bus 1F available.	7.05E-04	2.28E-04	5.56E-04	1.36E-03
SPLIT FRACTIONS FOR TOP EVENT DG					
DG1	480 V vital bus 1G available, DF succeeded.	7.05E-04	2.28E-04	5.56E-04	1.36E-03
DG2	480 V vital bus 1G available, DF failed.	7.02E-04	2.26E-04	5.53E-04	1.35E-03
DGF	Guaranteed failure.	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT DH					
DH1	480 V 1H available, DF-S, DG-S	7.00E-04	2.24E-04	5.51E-04	1.35E-03
DH2	480 V 1H available, DF-S, DG-F	6.98E-04	2.22E-04	5.49E-04	1.35E-03
DH3	480 V 1H available, DF-F, DG-S	6.98E-04	2.22E-04	5.49E-04	1.35E-03
DH4	480 V 1H available, DF-F, DG-F	6.96E-04	2.20E-04	5.47E-04	1.35E-03
SPLIT FRACTIONS FOR TOP EVENT AF					
AF1	All support available with recovery.	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AFA	All support available no recovery.	7.40E-04	1.63E-04	4.91E-04	1.45E-03
AFF	Guaranteed failure.	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT AG					
AG1	DF-S, AF-S with recovery	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AG2	DF-S, AF-F with recovery	8.37E-04	1.94E-04	5.63E-04	1.70E-03
AG3	DF-F with recovery	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AGA	DF-S, AF-S no recovery	7.13E-04	1.47E-04	4.66E-04	1.42E-03
AGB	DF-S, AF-F no recovery	5.18E-02	3.92E-03	2.57E-02	1.48E-01
AGC	DF-F no recovery	7.40E-04	1.63E-04	4.91E-04	1.45E-03
AGF	GUARANTEED FAILURE	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00





SPLIT FRACTIONS FOR TOP EVENT AH

AH1	DF-S, DG-S, AF-S, AG-S with recovery	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AH2	DF-S, DG-S, AF-S, AG-F, or DF-S, DG-S, AF-F, AG-S w.r.	8.01E-04	1.80E-04	5.32E-04	1.63E-03
AH3	DF-S, DG-S, AF-F, AG-F with recovery	4.72E-02	9.06E-04	7.96E-03	1.71E-01
AH4	DF-S, DG-F, AF-S or DF-F, DG-S, AG-S with recovery	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AH5	DF-S, DG-F, AF-F or DF-F, DG-S, AG-F with recovery	8.37E-04	1.94E-04	5.63E-04	1.70E-03
AH6	DF-F, DG-F with recovery	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AHA	DF-S, DG-S, AF-S, AG-S no recovery	6.92E-04	1.34E-04	4.43E-04	1.40E-03
AHB	DF-S, DG-S, AF-S, AG-F, or DF-S, DG-S, AF-F, AG-S n.r.	4.42E-02	1.16E-03	1.52E-02	1.37E-01
AHC	DF-S, DG-S, AF-F, AG-F no recovery	3.03E-01	6.28E-03	1.70E-01	8.17E-01
AHD	DF-S, DG-F, AF-S or DF-F, DG-S, AG-S no recovery	7.13E-04	1.47E-04	4.66E-04	1.42E-03
AHE	DF-S, DG-F, AF-F or DF-F, DG-S, AG-F no recovery	5.18E-02	3.92E-03	2.57E-02	1.48E-01
AHG	DF-F, DG-F no recovery	7.40E-04	1.63E-04	4.91E-04	1.45E-03
AHF	GUARANTEED FAILURE	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00

SPLIT FRACTIONS FOR TOP EVENT SF

SF1	All support available with recovery.	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SFA	All support available no recovery.	1.71E-03	4.34E-04	1.24E-03	3.22E-03

SPLIT FRACTIONS FOR TOP EVENT SG

SG1	SF-S with recovery	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SG2	SF-F with recovery	1.74E-03	4.70E-04	1.24E-03	3.30E-03
SG3	SF-B with recovery	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SGA	SF-S no recovery	1.65E-03	3.92E-04	1.19E-03	3.15E-03
SGB	SF-F no recovery	5.31E-02	6.81E-03	3.08E-02	1.36E-01
SGC	SF-B no recovery	1.71E-03	4.34E-04	1.24E-03	3.22E-03

SPLIT FRACTIONS FOR TOP EVENT SH

SH1	SF-S, SG-S with recovery	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SH2	SF-S, SG-F or SF-F, SG-S with recovery	1.70E-03	4.35E-04	1.21E-03	3.24E-03
SH3	SF-F, SG-F with recovery	3.03E-02	1.54E-03	6.44E-03	9.56E-02
SH4	SF-S, SG-B or SF-B, SG-S with recovery	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SH5	SF-F, SG-B or SF-B, SG-F with recovery	1.74E-03	4.70E-04	1.24E-03	3.30E-03
SH6	SF-B, SG-B with recovery	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SHA	SF-S, SG-S no recovery	1.60E-03	3.51E-04	1.15E-03	3.11E-03
SHB	SF-S, SG-F or SF-F, SG-S no recovery	4.42E-02	2.24E-03	2.07E-02	1.23E-01
SHC	SF-F, SG-F no recovery	2.90E-01	1.34E-02	1.83E-01	7.59E-01
SHD	SF-S, SG-B or SF-B, SG-S no recovery	1.65E-03	3.92E-04	1.19E-03	3.15E-03
SHE	SF-F, SG-B or SF-B, SG-F no recovery	5.31E-02	6.81E-03	3.08E-02	1.36E-01
SHG	SF-B, SG-B no recovery	1.71E-03	4.34E-04	1.24E-03	3.22E-03



SPLIT FRACTIONS FOR TOP EVENT BF

BF1	OG-F	1.44E-03	5.56E-04	1.14E-03	2.67E-03
SPLIT FRACTIONS FOR TOP EVENT BG					
BG1	OG-F, BF-S	1.44E-03	5.56E-04	1.14E-03	2.67E-03
BG2	OG-F, BF-F	1.49E-03	6.07E-04	1.18E-03	2.73E-03
SPLIT FRACTIONS FOR TOP EVENT BH					
BH1	OG-F, BF-S, BG-S	1.44E-03	5.56E-04	1.14E-03	2.67E-03
BH2	OG-F, BF-S, BG-F or OG-F, BF-F, BG-S	1.48E-03	5.96E-04	1.17E-03	2.71E-03
BH3	OG-F, BF-F, BG-F	1.19E-02	1.13E-03	3.14E-03	3.31E-02
SPLIT FRACTIONS FOR TOP EVENT GF					
GF1	All support available.	4.52E-02	2.90E-02	4.18E-02	6.28E-02
SPLIT FRACTIONS FOR TOP EVENT GG					
GG1	GF-S	4.48E-02	2.85E-02	4.13E-02	6.24E-02
GG2	GF-F	5.56E-02	3.91E-02	5.23E-02	7.33E-02
GG3	GF-B	4.52E-02	2.90E-02	4.18E-02	6.28E-02
SPLIT FRACTIONS FOR TOP EVENT GH					
GH1	GF-S, GG-S	4.44E-02	2.82E-02	4.09E-02	6.20E-02
GH2	GF-S/F, GG-F/S	5.41E-02	3.75E-02	5.08E-02	7.17E-02
GH3	GF-F, GG-F	8.27E-02	6.00E-02	7.72E-02	1.11E-01
GH4	GF-S/B, GG-B/S	4.48E-02	2.85E-02	4.13E-02	6.24E-02
GH5	GF-F/B, GG-B/F	5.56E-02	3.91E-02	5.23E-02	7.33E-02
GH6	GF-B, GG-B	4.52E-02	2.90E-02	4.18E-02	6.28E-02
SPLIT FRACTIONS FOR TOP EVENT 2G					
2G1	GF-S, GG-S, GH-S	4.40E-02	2.77E-02	4.05E-02	6.16E-02
2G2	GF-S/S/F, GG-S/F/S, GH-F/S/S	5.36E-02	3.70E-02	5.03E-02	7.14E-02
2G3	GF-S/F/F, GG-F/F/S, GH-F/S/F	6.25E-02	4.62E-02	5.95E-02	7.91E-02
2G4	GF-F, GG-F, GH-F	2.90E-01	1.28E-01	2.48E-01	5.02E-01
2G5	GF-S/S/B, GG-S/B/S, GH-B/S/S	4.44E-02	2.82E-02	4.09E-02	6.20E-02
2G6	GF-S/S/F/F/B/B, GG-F/B/B/S/S/F, GH-B/F/S/B/F/S	5.41E-02	3.75E-02	5.08E-02	7.17E-02
2G7	GF-F/F/B, GG-F/B/F, GH-B/F/F	8.27E-02	6.00E-02	7.72E-02	1.11E-01
2G8	GF-S/B/B, GG-B/S/B, GH-B/B/S	4.48E-02	2.85E-02	4.13E-02	6.24E-02
2G9	GF-F/B/B, GG-B/F/B, GH-B/B/F	5.56E-02	3.91E-02	5.23E-02	7.33E-02
2GA	GF-B, GG-B, GH-B	4.52E-02	2.90E-02	4.18E-02	6.28E-02
SPLIT FRACTIONS FOR TOP EVENT 2H					
2H1	GF-GG&GH-2G:SS&SS	4.36E-02	2.73E-02	4.01E-02	6.12E-02
2H2	GF-GG&GH-2G:SS&SF/FS, SF/FS&SS	5.32E-02	3.64E-02	4.99E-02	7.12E-02
2H3	GF-GG&GH-2G:FS/SF&SF/FS, SS&FF, FF&SS	6.21E-02	4.59E-02	5.90E-02	7.86E-02
2H4	GF-GG&GH-2G:SF/FS&FF, FF&SF/FS	6.92E-02	5.21E-02	6.62E-02	8.69E-02





2H5	GF-GG&GH-2G:FF&FF	7.73E-01	4.25E-01	7.95E-01	9.39E-01
2H6	GF-GG&GH-2G:SS&SB/BS, SB/BS&SS	4.40E-02	2.77E-02	4.05E-02	6.16E-02
2H7	GF-GG&GH-2G:SF/FS&SB/BS, SB/BS&FS/SF, FB/BF&SS, SS&FB/BF	5.36E-02	3.70E-02	5.03E-02	7.14E-02
2H8	GF-GG&GH-2G:SF/FS&FB/BF, FB/BF&SF/FS, BS/SB&FF, FF&SB/BS	6.25E-02	4.62E-02	5.95E-02	7.91E-02
2H9	GF-GG&GH-2G:FF&FB/BF, FB/BF&FF	2.90E-01	1.28E-01	2.48E-01	5.02E-01
2HA	GF-GG&GH-2G:SB/BS&BS/BS, SS&BB, BB&SS	4.44E-02	2.82E-02	4.09E-02	6.20E-02
2HB	GF-GG&GH-2G:BF/FB&SB/BS, BS/SB&FB/BF, FS/SF&BB, BB&FS/SF	5.41E-02	3.75E-02	5.08E-02	7.17E-02
2HC	GF-GG&GH-2G:FB/BF&BF/FB, FF&BB, BB&FF	8.27E-02	6.00E-02	7.72E-02	1.11E-01
2HD	GF-GG&GH-2G:SB/BS&BB, BB&SB/BS	4.48E-02	2.85E-02	4.13E-02	6.24E-02
2HE	GF-GG&GH-2G:FB/BF&BB, BB&FB/BF	5.56E-02	3.91E-02	5.23E-02	7.33E-02
2HG	GF-GG&GH-2H:BB&BB	4.52E-02	2.90E-02	4.18E-02	6.28E-02
SPLIT FRACTIONS FOR TOP EVENT SW					
SW0	All branch points for LOCA initiating event.	0.00E-01	0.00E-01	0.00E-01	0.00E-01
SW1	LOSP with equal number of DG operating on each unit.	5.00E-01	2.50E-02	2.50E-01	4.75E-01
SW2	LOSP with more DGs aligned to unit 2 than unit 1.	1.77E-03	9.55E-05	7.30E-04	6.82E-03
SW3	LOSP with more DGs aligned to unit 1 than unit 2.	9.98E-01	9.93E-01	9.98E-01	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT FO					
FO1	All support available.	2.16E-04	4.28E-05	1.40E-04	5.29E-04
FO2	Support available to one train only.	7.04E-03	3.49E-03	6.33E-03	1.11E-02
FO3	1/2 normal support unavailable, recover backup.	3.51E-04	1.02E-04	2.70E-04	7.18E-04
FO4	2/2 normal support unavailable, recover backups.	2.26E-02	5.70E-03	1.67E-02	4.90E-02
FO5	2/2 normal and 1/2 backup support unavail., rec. backup.	5.08E-02	1.73E-02	3.95E-02	1.01E-01
FOF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT I1					
I11	Given: DF-S,AF-S,AG-S or DF-S,AF-F,AG-S.	1.15E-03	4.16E-04	9.05E-04	2.11E-03
I12	Given: DF-S,AF-S,AG-F or DF-S,AF-F,AG-F.	1.74E-03	7.16E-04	1.49E-03	3.01E-03
I1F	Given: DF-F (guaranteed failure).	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT I2					
I21	Given: AG-S.	5.76E-04	2.08E-04	4.53E-04	1.05E-03
I22	Given: DG-S, AG-F	8.68E-04	3.58E-04	7.43E-04	1.51E-03
I23	Given: AG-S, I1-F	5.76E-04	2.08E-04	4.53E-04	1.05E-03
I24	Given: DG-S, AG-F, I1-F	8.68E-04	3.58E-04	7.43E-04	1.51E-03
I2F	Given: DG-F (guaranteed failure).	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT I3					
I31	Given: DH-S,AH-S,AG-S or DH-S,AH-F,AG-S.	1.15E-03	4.16E-04	9.05E-04	2.11E-03
I32	Given: DH-S,AH-S,AG-F or DH-S,AH-F,AG-F.	1.74E-03	7.16E-04	1.49E-03	3.01E-03
I3F	Given: DH-F (guaranteed failure).	1.00E+00	1.00E+00	1.00E+00	1.00E+00



SPLIT FRACTIONS FOR TOP EVENT I4

I41	Given: DG-S,AH-S,AG-S, or DG-S,AH-F,AG-S.	5.76E-04	2.08E-04	4.53E-04	1.05E-03
I42	Given: DG-F,AH-S or AG-F,DG-S,(AH-S or AH-F)	8.68E-04	3.58E-04	7.43E-04	1.51E-03
I4F	Given: DG-F, AH-F (guaranteed failure).	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00

SPLIT FRACTIONS FOR TOP EVENT SA

SA1	General Transient	7.58E-03	2.62E-03	5.43E-03	1.55E-02
SA2	Large Loss of Coolant Accident All 4 Channels Available	1.14E-02	3.82E-03	8.02E-03	2.40E-02
SA3	LLOCA with loss of power to two CP H-H channels (not I)	1.78E-02	6.71E-03	1.39E-02	3.49E-02
SA4	Steam Generator Tube Rupture	1.19E-02	3.61E-03	8.11E-03	2.56E-02
SA5	Steam Line Break Inside Containment All 4 Channels Avlb	1.40E-02	4.46E-03	9.72E-03	2.96E-02
SA6	SLBIC with loss of power to two CP H-H channels (not I)	2.04E-02	7.59E-03	1.58E-02	3.96E-02
SA7	Steam Line Break Outside Containment	1.19E-02	3.61E-03	8.11E-03	2.56E-02
SA8	Small Loss of Coolant Accident	1.19E-02	3.61E-03	8.11E-03	2.56E-02
SAF	Guaranteed Failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00

SPLIT FRACTIONS FOR TOP EVENT SB

SB1	GT given Train A success	7.48E-03	2.58E-03	5.32E-03	1.54E-02
SB2	GT given Train A failure	2.40E-02	5.32E-03	1.58E-02	5.63E-02
SB3	GT given AC I unavailable (same as SA1)	7.58E-03	2.62E-03	5.43E-03	1.55E-02
SB4	LLOCA given Train A success, all AC channels available	1.08E-02	3.33E-03	7.37E-03	2.32E-02
SB5	LLOCA given Train A success, AC II&III unavailable	1.09E-02	3.35E-03	7.42E-03	2.33E-02
SB6	LLOCA given Train A failure, all AC channels available	8.43E-02	2.11E-02	7.39E-02	1.53E-01
SB7	LLOCA given Train A failure, AC II&III unavailable	4.10E-01	1.22E-01	3.65E-01	7.19E-01
SB8	LLOCA given AC I and II(or III)unavailable (same as SA3)	1.78E-02	6.71E-03	1.39E-02	3.49E-02
SB9	SGTR given Train A success	1.17E-02	3.50E-03	7.86E-03	2.53E-02
SBA	SGTR given Train A failure	3.55E-02	6.54E-03	2.27E-02	8.65E-02
SBB	SGTR given AC I unavailable (same as SA4)	1.19E-02	3.61E-03	8.11E-03	2.56E-02
SBC	SLBIC given Train A success, all AC channels available	1.34E-02	3.95E-03	9.06E-03	2.89E-02
SBD	SLBIC given Train A success, AC II&III unavailable	1.35E-02	3.97E-03	9.12E-03	2.91E-02
SBE	SLBIC given Train A failure, all AC channels available	7.43E-02	1.88E-02	6.48E-02	1.36E-01
SBG	SLBIC given Train A failure, AC II&III unavailable	3.71E-01	1.03E-01	3.22E-01	6.79E-01
SBH	SLBIC given AC I and II(or III)unavailable (same as SA6)	2.04E-02	7.59E-03	1.58E-02	3.96E-02
SBI	SLBOC given Train A success	1.17E-02	3.50E-03	7.86E-03	2.53E-02
SBJ	SLBOC given Train A failure	3.49E-02	6.07E-03	2.20E-02	8.60E-02
SBK	SLBOC given AC I unavailable (same as SA7)	1.19E-02	3.61E-03	8.11E-03	2.56E-02
SBL	SLOCA given Train A success	1.17E-02	3.50E-03	7.86E-03	2.53E-02
SBM	SLOCA given Train A failure	3.49E-02	6.07E-03	2.20E-02	8.60E-02
SBN	SLOCA given AC I unavailable (same as SA8)	1.19E-02	3.61E-03	8.11E-03	2.56E-02
SBF	Guaranteed Failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00



SPLIT FRACTIONS FOR TOP EVENT RT

RT1	1/2 Trains (both SSPS signals generated)	6.58E-06	3.57E-08	5.17E-07	1.30E-05
RT2	1/2 Trains (DC power lost to one shunt trip)	6.59E-06	3.76E-08	5.28E-07	1.30E-05
RT3	1/2 Trains (DC power lost to both shunt trip coils)	7.24E-06	8.49E-08	8.59E-07	1.44E-05
RT4	1/1 Train (only one SSPS signal generated)	1.60E-05	6.13E-07	4.70E-06	4.49E-05
RT5	1/1 Train (one SSPS signal, LOP to shunt trip coil)	2.10E-05	8.62E-07	6.57E-06	6.37E-05
RT6	Gravity Insertion (insufficient power to prevent insert)	6.30E-06	5.60E-09	3.33E-07	1.25E-05
RT7	Operator initiated (DC power lost to both shunt coils)	1.93E-03	1.16E-04	7.74E-04	5.82E-03
RTF	Guaranteed failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00

SPLIT FRACTIONS FOR TOP EVENT CV

CV1	1/2 subtrains: All support available (OSP,2F,1G,1H,2H)	7.60E-04	2.15E-04	4.68E-04	1.36E-03
CV2	1/2 subtrains: Normal power for subtrain F unavail. (2F)	2.06E-02	6.81E-03	1.59E-02	4.24E-02
CV3	1/1 subtrain: No support for subtrain F (2F,1G)	5.68E-02	3.24E-02	5.11E-02	8.56E-02
CV4	1/1 subtrain: No support for subtrain H (1H,2H)	2.00E-02	8.56E-03	1.70E-02	3.34E-02
CV5	1/2 subtrains:LOSP, all vital buses avail. (2F,1G,1H,2H)	3.65E-03	1.63E-03	3.07E-03	5.99E-03
CV6	1/1 subtrains:LOSP, no support for subtrain H (1H,2H)	3.88E-02	2.21E-02	3.51E-02	5.60E-02
CVF	Guaranteed Failure: 480V 2F,1G,1H,2H unavailable	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
LOCV	Initiating Event frequency for 1 year	7.98E-02	3.56E-02	6.64E-02	1.35E-01


PLIT FRACTIONS FOR TOP EVENT SV

SV1	1/2 trains; OSP, 480V 1F,1H available	1.70E-06	4.70E-08	4.92E-07	5.47E-06
SV2	1/1 train start and run; 480V Bus 1F unavailable	1.80E-04	5.05E-06	4.99E-05	5.69E-04
SV3	1/1 train continue to run; 480 V Bus 1H unavail.	1.33E-04	3.02E-06	3.40E-05	4.17E-04
SV4	1/2 trains start and run; LOSP, 480V Bus 1F,1H availab.	2.57E-05	8.14E-07	7.84E-06	7.93E-05
SV5	Only recovery possible, Bus 1F,1H unavailable	5.62E-03	2.38E-04	1.78E-03	2.17E-02
SVF	Guaranteed failed, all inverters already failed	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SVI	Initiating Event frequency for 1 year	6.29E-05	4.56E-07	9.12E-06	2.02E-04
SV0	Station Blackout, guaranteed success.	0.00E-01	0.00E-01	0.00E-01	0.00E-01

SPLIT FRACTIONS FOR TOP EVENT AS

AS1	All Pump Trains Available: 2 Running, 2 Standby (OP1)	1.85E-06	3.74E-07	1.14E-06	4.17E-06
AS2	3 Pump Trains Available: Fail Train 11 (OP2)	3.55E-04	1.69E-04	3.10E-04	5.84E-04
AS3	3 Pump Trains Available: Fail Train 12 (OP1)	1.22E-04	4.38E-05	9.62E-05	2.34E-04
AS4	2 Pump Trains Available: Fail Trains 11 and 12 (OP2)	1.69E-02	6.58E-03	1.33E-02	3.16E-02
AS5	LOSP: 3 Pump Trains Available: Fail Train 11 (OP2)	3.58E-04	1.71E-04	3.13E-04	5.88E-04
AS6	LOSP: 3 Pump Trains Available: Fail Train 21 (OP1)	7.86E-06	3.04E-06	6.30E-06	1.47E-05
AS7	LOSP: 2 Pump Trains Available: Fail Trains 11 & 12 (OP2)	1.69E-02	6.66E-03	1.34E-02	3.17E-02
AS8	LOSP: 2 Pump Trains Available: Fail 11 & 21(or 22) (OP2)	4.71E-04	2.43E-04	4.12E-04	7.54E-04







AS9	LOSP: 2 Pump Trains Available: Fail Trains 12 & 21 (OP1)	2.74E-04	1.02E-04	2.13E-04	5.30E-04
ASA	LOSP: 2 Pump Trains Available: Fail Trains 21 & 22 (OPF)	1.83E-04	7.00E-05	1.52E-04	3.39E-04
ASB	LOSP: 1 Pump Train Available: Fail 11,12 & 21(or 22)(OP2)	2.70E-02	1.54E-02	2.37E-02	4.22E-02
ASC	LOSP: 1 Pump Train Available: Fail 11(or 12),21 & 22(OPF)	1.07E-02	6.68E-03	9.68E-03	1.57E-02
ASI	Loss of ASW Supply to Unit 1 Initiating Event Frequency	9.73E-05	2.47E-05	6.23E-05	1.97E-04
ASF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT CC					
CC1	All Support Available(N/3 pumps starts and/or runs)	1.88E-05	5.69E-06	1.31E-05	4.33E-05
CC2	Loss of 4KV Bus H (N/2 pumps runs)	5.69E-04	2.25E-04	4.79E-04	9.65E-04
CC3	Loss of 4KV Bus G (N/2 pumps starts and/or runs)	5.85E-04	2.32E-04	4.93E-04	9.99E-04
CC4	Loss of 4KV Buses G and H (1/1 pump runs)	2.67E-02	1.09E-02	2.07E-02	5.06E-02
CC5	Loss of 4KV Buses F and G (1/1 pump starts and runs)	2.87E-02	1.24E-02	2.27E-02	5.26E-02
CC6	LOSP - All Support Available(N/3 pumps starts and runs)	2.43E-05	8.65E-06	1.89E-05	4.89E-05
CC7	LOSP - Loss of one 4KV bus (N/2 pumps starts and runs)	6.63E-04	2.74E-04	5.55E-04	1.14E-03
CCI	Initiating Event Frequency (All pumps fail)	1.97E-04	3.05E-05	1.23E-04	4.84E-04
CCF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT IA					
IAF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
FRONTLINE SYSTEMS					
SPLIT FRACTIONS FOR TOP EVENT TT					
TT0	Turbine Trip - TT Initiator	0.00E-01	0.00E-01	0.00E-01	0.00E-01
TT1	Turbine Trip - All Support Available	1.55E-05	8.85E-07	5.20E-06	3.86E-05
TT2	Turbine Trip ATWT - All Support Available	3.27E-03	4.59E-04	1.84E-03	8.48E-03
TT3	Turbine Trip ATWT, Man. Rx trip - All Support	8.92E-03	6.22E-04	3.70E-03	2.58E-02
TT4	Turbine Trip - 1 Train of Support Avail.	2.98E-03	5.02E-04	1.67E-03	7.39E-03
TT5	Turbine Trip ATWT - 1 Train of Support Avail.	6.12E-03	1.44E-03	4.07E-03	1.38E-02
TT6	Turbine Trip ATWT, Man. Rx trip-1 Support Train	1.17E-02	1.79E-03	6.19E-03	3.16E-02
TTF	Turbine Trip - Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT MS					
MS0	Main Steam Isolation, TT failed, fire scenario 2	0.00E-01	0.00E-01	0.00E-01	0.00E-01
MS1	Main Steam Isolation, TT succeeds- All Support Avail.	7.51E-03	2.41E-03	6.13E-03	1.71E-02
MS2	MS Isolation - TT fails, All Support Avail.	1.00E+00	1.00E+00	1.00E+00	1.00E+00
MSF	MS Isolation - Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT AW					
AW1	All Support Sys Available, Lo Power	3.73E-05	8.78E-06	2.56E-05	8.10E-05
AW2	All Support Sys Available, Hi Power	1.17E-01	7.28E-02	1.07E-01	1.71E-01





AW3	Support for 1 MDP Unavail, Lo Power	1.24E-03	4.10E-04	9.65E-04	2.36E-03
AW4	Support for 2 MDP's Unavail, Lo Power	7.25E-02	3.73E-02	6.27E-02	1.18E-01
AW5	Support for All 10% Stm Dumps Unavail, Lo Power	3.30E-02	1.38E-05	2.10E-04	1.04E-01
AW6	Support for All 10% Stm Dumps Unavail, Hi Power	2.01E-01	7.86E-02	1.27E-01	5.31E-01
AW7	Support for All 10% SD's and TDP Unavail, Lo Power	3.50E-04	8.72E-05	2.23E-04	6.91E-04
AW8	Support for All 10% SD's and 1 MDP Unavail, Lo Power	8.00E-03	3.86E-04	9.39E-04	2.37E-03
AW9	Support for All 10% SD's and 2 MDP's Unavail, Lo Power	1.41E-01	4.34E-02	8.34E-02	3.70E-01
AWA	Support for All 10% SD's, 1 MDP & TDP Unavail, Lo Power	9.59E-02	1.66E-02	3.49E-02	3.28E-01
AWB	One SG depressurizes, All Support Sys Avail., Lo Power	2.41E-02	1.47E-02	2.21E-02	3.50E-02
AWC	ATWS; All Support Systems Available, TT Success	2.45E-03	7.98E-04	1.90E-03	4.69E-03
AWF	Guaranteed failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT TD					
TD1	Support for 2 MDP's Unavail., Seismic events	7.11E-02	3.68E-02	6.16E-02	1.16E-01
TD2	Support for all 10% SD's & 2 MDP's unavail., Seismic IE	1.41E-01	4.34E-02	8.34E-02	3.70E-01
TDF	Guaranteed failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT PR					
PR0	Guaranteed Success	0.00E-01	0.00E-01	0.00E-01	0.00E-01
PR1	1/2 PORV's or (1/3 SRV's), LOSP or SGTR	5.03E-04	5.26E-05	1.95E-04	9.51E-04
PR2	1/2 PORV's and 3/3 SRV's	1.00E-02	1.25E-03	4.86E-03	2.55E-02
PR3	2/2 PORV's and 3/3 SRV's	2.59E-02	6.45E-03	1.60E-02	5.75E-02
PR4	2/2 PORV's and 2/3 SRV's or (3/3 SRV'S)	8.86E-03	6.56E-04	3.76E-03	2.43E-02
PR5	1/2 PORV's or (1/3 SRV's), HPI or SLB	2.18E-05	1.24E-07	2.91E-06	4.51E-05
PR6	1/1 PORV or (1/3 SRV's), LOSP or SGTR	2.36E-04	3.49E-05	1.25E-04	5.33E-04
PR7	1/1 PORV and 3/3 SRV's	1.83E-02	3.95E-03	1.09E-02	4.15E-02
PR8	3/3 SRV's	9.45E-03	9.45E-04	4.42E-03	2.45E-02
PR9	1/1 PORV or (1/3 SRV's), HPI or SLB	2.92E-05	3.85E-07	6.19E-06	7.17E-05
PRA	1/3 SRV's	8.23E-03	3.44E-04	3.34E-03	2.32E-02
PRB	3/3 SRV's	9.31E-03	7.89E-04	4.28E-03	2.43E-02
PRC	1/3 SRV's	2.84E-03	3.18E-05	6.89E-04	8.47E-03
PRD	1/2 PORV's or (1/3 SRV's), LOSP/SGTR, no blk vlvs	4.88E-02	1.37E-02	3.81E-02	9.74E-02
PRE	1/2 PORV's and 3/3 SRV's blk vlvs not avail.	5.90E-02	1.91E-02	4.64E-02	1.15E-01
PRF	Guaranteed Failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
PRG	2/2 PORV's and 3/3 SRV's blk vlvs not avail.	7.47E-02	2.79E-02	5.98E-02	1.42E-01
PRH	2/2 PORV's and 2/3 SRV's or (3/3 SRV'S) no blk vlvs	5.74E-02	1.80E-02	4.49E-02	1.13E-01
PRI	1/2 PORV's or (1/3 SRV's), HPI or SLB no blk vlvs	2.13E-03	2.38E-05	5.03E-04	6.28E-03
PRJ	1/1 PORV or (1/3 SRV's), LOSP/SGTR, no blk vlvs	2.53E-02	5.90E-03	1.87E-02	5.41E-02
PRK	1/1 PORV and 3/3 SRV's no blk vlvs	4.33E-02	1.53E-02	3.35E-02	8.35E-02



PRL	3/3 SRV's no blk vlvs	3.41E-02	1.01E-02	2.58E-02	6.97E-02
PRM	1/1 PORV or (1/3 SRV's), HPI or SLB no blk vlvs	1.11E-03	1.04E-05	2.54E-04	3.19E-03
PRN	1/1 Block valve closes, All support available	7.66E-03	1.98E-03	4.96E-03	1.76E-02
PRP	1/2 PORV's or (1/3 SRV's), Manual reactor trip	6.11E-08	2.07E-09	1.60E-08	1.32E-07
PRQ	1/1 PORV or (1/3 SRV's), Manual reactor trip	2.73E-08	1.51E-09	9.91E-09	6.64E-08
PRR	1/3 SRV's, Manual reactor trip	9.57E-07	2.05E-08	2.48E-07	2.68E-06
PRS	1/2 PORV's or (1/3 SRV's), Manual reactor trip	5.69E-06	5.19E-07	2.97E-06	1.52E-05
PRT	1/1 PORV or (1/3 SRV's), Manual reactor trip	2.85E-06	2.50E-07	1.43E-06	7.67E-06
SPLIT FRACTIONS FOR TOP EVENT PO					
PO1	1/2 PORVs ATWT, boration, all support, AFW avail.	7.19E-04	1.44E-04	3.93E-04	1.24E-03
PO2	2/2 PORVs ATWT, boration, no block valves, no AFW	6.54E-02	2.30E-02	5.15E-02	1.25E-01
PO3	1/2 PORVs ATWT, boration, no block valves, AFW avail.	4.89E-02	1.39E-02	3.82E-02	9.72E-02
POF	Guaranteed Failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT OB					
OB1	Loss of Instrument air	2.89E-02	6.25E-03	1.71E-02	6.46E-02
OB2	Loss of Instrument air, charging failed	2.89E-02	6.25E-03	1.71E-02	6.46E-02
OB3	Loss of 1 DC bus Initiating event	3.75E-01	3.48E-01	3.65E-01	4.14E-01
OBF	Guaranteed Failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT CH					
CH1	All support available.	6.23E-04	3.01E-04	5.57E-04	9.65E-04
CH2	One standby pump train available only	1.41E-02	9.12E-03	1.32E-02	1.97E-02
CH3	Normally running pump train available only.	1.16E-02	7.46E-03	1.10E-02	1.61E-02
CH4	LOSP ; All support available	7.95E-04	4.17E-04	7.12E-04	1.22E-03
CHF	Guaranteed failure.	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT SI					
SI1	All support available (1/2)	3.25E-03	6.25E-04	1.62E-03	1.04E-02
SI2	One safety injection pump train available only(1/1)	1.60E-02	7.49E-03	1.31E-02	2.99E-02
SI3	Medium LOCA; All support available, CH failed. (2/2)	2.89E-02	1.40E-02	2.44E-02	5.16E-02
SIF	Guaranteed failure.	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT HR					
HR1	All support available	2.11E-04	1.11E-04	1.94E-04	3.22E-04
HR2	Top event CH or SI failed	1.91E-03	1.11E-03	1.59E-03	3.57E-03
HR3	Top event LA or LB failed	4.01E-03	2.55E-03	3.68E-03	5.86E-03
HR4	Top event CH or SI and top events LA or LB failed	4.33E-03	2.77E-03	3.99E-03	6.28E-03
HR5	4KV Bus F failed	2.29E-03	1.36E-03	2.11E-03	3.35E-03
HR6	4KV Bus F failed, top event CH or SI failed	3.99E-03	2.55E-03	3.65E-03	5.89E-03
HR7	4KV Bus F failed, top event LA or LB failed	6.08E-03	4.16E-03	5.74E-03	8.24E-03



HR8	4KV Bus F failed, top event CH or SI & LA or LB failed	6.40E-03	4.39E-03	6.04E-03	8.64E-03
HR9	4KV Bus F and 4KV Bus G failed	6.08E-03	4.16E-03	5.74E-03	8.24E-03
HRA	4KV Bus F and 4KV Bus H failed	2.36E-03	1.39E-03	2.19E-03	3.42E-03
HRB	4KV Bus G failed	4.01E-03	2.55E-03	3.68E-03	5.86E-03
HRC	4KV Bus G failed, top event CH or SI failed	6.43E-03	4.03E-03	6.01E-03	9.06E-03
HRD	4KV Bus H failed	4.56E-03	3.07E-03	4.36E-03	6.07E-03
HRE	4KV Bus H failed, top event CH or SI failed	8.66E-03	5.87E-03	8.24E-03	1.15E-02
HRF	Guaranteed failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT RC					
RC1	Both RHR pump trains operable	4.43E-05	5.88E-06	2.72E-05	1.10E-04
RC2	One RHR pump train operable	1.18E-03	6.84E-04	1.07E-03	1.83E-03
SPLIT FRACTIONS FOR TOP EVENT RF					
RF1	Switchover after SLOCA or B/F with CS failed	3.16E-03	4.78E-04	1.80E-03	8.26E-03
RF2	Switchover after SLOCA or B/F with CS success	3.37E-03	5.07E-04	1.92E-03	8.84E-03
RF3	Switchover after LLOCA or MLOCA initiating event	4.93E-03	9.22E-04	3.07E-03	1.21E-02
RF4	Switchover to recirculation after core melt	5.47E-02	9.54E-03	3.41E-02	1.34E-01
SPLIT FRACTIONS FOR TOP EVENT LA					
LA1	All support available. (SLOCA Case)	2.04E-02	1.13E-02	1.80E-02	3.22E-02
LA2	All support available. (Bleed & Feed case)	2.04E-02	1.12E-02	1.78E-02	3.23E-02
LA3	All support available. (LLOCA/MLOCA Case)	1.58E-02	9.03E-03	1.41E-02	2.42E-02
LAF	Guaranteed failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT LB					
LB1	All support available. Top event LA successful. (SLOCA)	1.56E-02	8.78E-03	1.38E-02	2.39E-02
LB2	All support available. Top event LA failed. (SLOCA)	2.32E-01	6.20E-02	1.79E-01	4.83E-01
LB3	Top Event LA Guaranteed Failure (SLOCA)	2.04E-02	1.13E-02	1.80E-02	3.22E-02
LB4	All support available. Top event LA successful. (B & F)	1.56E-02	8.78E-03	1.38E-02	2.39E-02
LB5	All support available. Top event LA failed. (B & F)	2.30E-01	6.04E-02	1.78E-01	4.73E-01
LB6	Top Event LA Guaranteed Failure (B & F)	2.04E-02	1.12E-02	1.78E-02	3.23E-02
LB7	All support available. Top event LA successful.(LLOCA)	1.55E-02	8.74E-03	1.37E-02	2.38E-02
LB8	All support available. Top event LA failed. (LLOCA)	3.75E-02	1.66E-02	2.81E-02	7.16E-02
LB9	Top Event LA Guaranteed Failure (LLOCA)	1.58E-02	9.03E-03	1.41E-02	2.42E-02
LBF	Guaranteed failure	1.00E + 00	1.00E + 00	1.00E + 00	1.00E + 00
SPLIT FRACTIONS FOR TOP EVENT LV					
LV1	All conditions(No support required)	4.59E-04	1.32E-04	3.00E-04	1.20E-03
SPLIT FRACTIONS FOR TOP EVENT RW					
RW1	All conditions(No support required)	3.94E-05	3.44E-06	1.78E-05	1.09E-04



SPLIT FRACTIONS FOR TOP EVENT VA

VA1	All support available.	4.38E-03	2.87E-03	4.17E-03	5.83E-03
VAF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT VB

VB1	All support available. Top event VA successful.	4.18E-03	2.69E-03	3.98E-03	5.64E-03
VB2	All support available. Top event VA failed.	5.00E-02	2.52E-02	4.51E-02	7.85E-02
VB3	Top Event VA Guaranteed Failure	4.38E-03	2.87E-03	4.17E-03	5.83E-03
VBF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT AC

AC1	All conditions(No support required)	6.27E-03	1.44E-03	3.30E-03	1.92E-02
-----	-------------------------------------	----------	----------	----------	----------

SPLIT FRACTIONS FOR TOP EVENT LI

LI1	All conditions except large LOCA;(No support required)	4.03E-06	7.90E-07	1.98E-06	1.25E-05
LI2	LLOCA initiating event: Given failure of top event AC	5.55E-04	1.99E-04	3.59E-04	9.43E-04

SPLIT FRACTIONS FOR TOP EVENT MU

MU1	Power available at AC buses G and H	7.98E-03	3.67E-03	6.51E-03	1.41E-02
MUF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
MU2	Power avail at AC buses G and H (Make-up Via RFW Pump)	1.54E-02	5.48E-03	1.09E-02	3.16E-02
MUV	Makeup to RWST	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT FC

FC1	2 OF 5 CFCUs start rate 24 hours	1.86E-06	1.72E-07	1.00E-06	4.88E-06
FC2	2 OF 4 CFCUs start and operate 24 hours	4.83E-06	9.90E-07	3.32E-06	1.09E-05
FC3	2 OF 3 CFCUs start and operate 24 hours	6.07E-05	1.84E-05	4.73E-05	1.19E-04
FC4	2 OF 2 CFCUs start and operate 24 hours	6.59E-03	2.88E-03	5.72E-03	1.11E-02
FCF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT CS

CS1	1/2 Trains Operates(All Support Available)	5.91E-04	2.24E-04	4.59E-04	1.12E-03
CS2	1/1 Train Operates(Loss of One Vital Bus or SSPS train)	1.43E-02	7.29E-03	1.24E-02	2.35E-02
CSF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT SR

SR1	1/2 Trains Operates(All Support Available)	3.80E-03	4.33E-04	1.76E-03	1.02E-02
SR2	1/1 Train Operates(Loss of 1 Bus or SSPS or RHR train)	9.47E-03	4.15E-03	7.18E-03	1.85E-02
SRF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT CI

CI1	Either inboard or outboard isol. valve(s) must close	4.06E-03	3.37E-04	1.93E-03	1.07E-02
CI2	Inboard vlves(pen 45) and 1/2 vlves(pen 50,51,52) close	5.77E-03	1.61E-03	3.69E-03	1.24E-02
CI3	Inboard isolation vlaves (pen 45,50,51,52) must close	7.31E-03	2.84E-03	5.29E-03	1.40E-02
CI4	Inbd. or Outbd. Isolation vlvs close - Excessive LOCA	4.06E-03	3.37E-04	1.93E-03	1.07E-02
CI5	Inbd.pen.45 & 1/2 vlvs pen.50,51,52 close - ELOCA	5.77E-03	1.61E-03	3.69E-03	1.24E-02



C16	Inbd.isol.vlvs.pen.45,50,51,52 close - ELOCA	7.31E-03	2.84E-03	5.29E-03	1.40E-02
CIF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT CP					
CP1	Either inboard or outboard isolation valve(s) must close	9.05E-07	1.51E-07	5.95E-07	2.06E-06
CP2	Outboard isolation valves must close	1.01E-05	3.66E-06	8.29E-06	1.95E-05
CP3	Fraction of time penetration 61, 62, or 63 is open	8.41E-03	8.41E-03	8.41E-03	8.41E-03
CP4	Same as CP1 with VI failed seismicly	9.05E-07	1.51E-07	5.95E-07	2.06E-06
CP5	Same as CP2 with VI failed seismicly	1.01E-05	3.66E-06	8.29E-06	1.95E-05
CP6	Same as CP3 with VI failed seismicly	8.41E-03	8.41E-03	8.41E-03	8.41E-03
SPLIT FRACTIONS FOR TOP EVENT WL					
WL1	Either FCV-500 (inboard) or FCV-501(outboard) must close	4.32E-05	5.17E-06	2.60E-05	1.11E-04
WL2	Inboard vlv FCV-500 (or outboard vlv FCV-501) must close	6.34E-04	2.19E-04	5.31E-04	1.23E-03
WL3	Fraction of time containment sump discharge line is open	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT SL					
SL1	All Support Available	6.06E-03	1.29E-03	3.67E-03	1.56E-02
SL2	Loss of support to 10% steam dump valves	6.52E-03	1.32E-03	3.88E-03	1.68E-02
SPLIT FRACTIONS FOR TOP EVENT VD					
VDI	Initiating event frequency (discharge side valves)	3.86E-06	1.33E-08	2.68E-07	7.97E-06
SPLIT FRACTIONS FOR TOP EVENT VS					
VSI	Initiating event frequency (suction side valves)	1.01E-06	5.03E-09	8.40E-08	2.14E-06
SPLIT FRACTIONS FOR TOP EVENT VO					
VO1	Pressure relief valves open 3/3 for VSI IE	6.99E-05	4.14E-06	2.90E-05	2.60E-04
VO2	Pressure relief valves open 2/2 for VDI IE	4.66E-05	2.76E-06	1.93E-05	1.73E-04
SPLIT FRACTIONS FOR TOP EVENT VC					
VC1	Leak rate of 1700 gpm for VSI IE	1.48E-01	5.98E-04	1.18E-02	2.96E-01
VC2	Leak rate of 800 gpm for VDI IE	6.93E-02	2.43E-04	4.83E-03	1.36E-01
SPLIT FRACTIONS FOR TOP EVENT VR					
VR1	Pressure relief valves reclose 3/3 for VSI IE	2.44E-01	1.17E-02	2.28E-01	6.39E-01
VR2	Pressure relief valves reclose 2/2 for VDI IE	1.80E-01	7.82E-03	1.58E-01	4.96E-01
SPLIT FRACTIONS FOR TOP EVENT IT					
IT1	RHR piping intact; VO successful	9.90E-01	4.95E-02	4.95E-01	9.40E-01
SPLIT FRACTIONS FOR TOP EVENT LW					
LW1	RCS flow to RWST for VSI IE	4.14E-04	1.15E-05	1.17E-04	1.32E-03
LW2	Guaranteed success	0.00E-01	0.00E-01	0.00E-01	0.00E-01
LW3	MOV support power not available	4.13E-04	1.44E-05	1.17E-04	1.81E-03
SPLIT FRACTIONS FOR TOP EVENT ME					
ME1	Medium LOCA; for VSI IE	5.00E-01	2.50E-02	2.50E-01	4.75E-01



ME2	Medium LOCA; for VDIIE	6.00E-03	3.00E-04	3.00E-03	5.70E-03
SPLIT FRACTIONS FOR TOP EVENT SM					
SM1	Small LOCA; for VSIIE	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SM2	Small LOCA; for VDIIE	5.00E-01	2.50E-02	2.50E-01	4.75E-01
SPLIT FRACTIONS FOR TOP EVENT OT					
OT1	Failure to isolate break, stops leakage; Initiates E-1	9.99E-02	5.00E-03	5.00E-02	9.50E-02
OTF	Operator fails to isolate break	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT OS					
OS1	Manual SI Actuation	1.89E-03	1.94E-04	1.04E-03	5.97E-03
OSF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT CD					
CD	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT FW					
FWF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT SE					
SE1	RCP Seal Cooling, CCW unavailable	9.91E-03	2.83E-03	7.42E-03	2.43E-02
SE2	RCP Seal Cooling, CCW available	0.00E-01	0.00E-01	0.00E-01	0.00E-01
SE0	Guaranteed Success	0.00E-01	0.00E-01	0.00E-01	0.00E-01
SEF	Guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT VI					
VI0	Vessel Integrity Guaranteed success	0.00E-01	0.00E-01	0.00E-01	0.00E-01
VI1	Vessel Integrity (TT & MS Failed)	1.10E-04	5.50E-06	5.50E-05	1.04E-04
VI2	Vessel Integrity Loss of Secondary Heat Sink	2.20E-02	1.10E-03	1.10E-02	2.09E-02
VI3	Vessel Integrity Medium LOCA Events	2.00E-03	1.00E-04	1.00E-03	1.90E-03
VI4	SGTR; With Successful ECCS Termination	1.80E-06	9.00E-08	9.00E-07	1.71E-06
VI5	SGTR; With Delayed ECCS Termination	8.99E-03	4.50E-04	4.50E-03	8.55E-03
SPLIT FRACTIONS FOR TOP EVENT RP					
RP0	Guaranteed Success	0.00E-01	0.00E-01	0.00E-01	0.00E-01
RP1	RCS pressure <1275#	1.00E+00	1.00E+00	1.00E+00	1.00E+00
RP2	CCW lost, operator must trip to prevent seal loca	9.96E-01	9.82E-01	9.98E-01	1.00E+00
RPF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
SPLIT FRACTIONS FOR TOP EVENT OI					
OIF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
OI1	when WL fails	1.00E+00	1.00E+00	1.00E+00	1.00E+00
OI2	when CP fails	1.00E+00	1.00E+00	1.00E+00	1.00E+00
OI3	when CI fails	1.00E+00	1.00E+00	1.00E+00	1.00E+00



SPLIT FRACTIONS FOR TOP EVENT OP

OP1	SGTR when SL S, terminate SI	4.16E-03	4.29E-04	2.28E-03	1.32E-02
OP2	SGTR when SL F,B; terminate SI	4.16E-03	4.29E-04	2.28E-03	1.32E-02

SPLIT FRACTIONS FOR TOP EVENT OE

OE1	initiate boration in 10 minutes given ATWT	2.32E-03	2.40E-04	1.28E-03	7.35E-03
OE2	initiate boration in 20 minutes given ATWT	2.32E-03	2.40E-04	1.28E-03	7.35E-03
OE3	initiate boration in 30 minutes given ATWT	2.32E-03	2.40E-04	1.28E-03	7.35E-03

SPLIT FRACTIONS FOR TOP EVENT HS

HS1	hot standby,all available	4.71E-06	2.37E-07	1.91E-06	1.73E-05
HS2	hot standby,with small LOCA	3.09E-06	3.18E-07	1.70E-06	9.77E-06
HS3	hot standby,instrumentation lost	5.06E-03	2.54E-04	2.05E-03	1.86E-02
HS4	hot standby,LOCA and instrumentation lost	1.00E+00	1.00E+00	1.00E+00	1.00E+00
HSF	guaranteed failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT RS

RS1	43 of 53 inserted within 10 minutes	1.00E+00	1.00E+00	1.00E+00	1.00E+00
RSF	reactor trip failed	1.00E+00	1.00E+00	1.00E+00	1.00E+00

SPLIT FRACTIONS FOR TOP EVENT PL

PL1	power level greater than 80%	0.00E-01	0.00E-01	0.00E-01	0.00E-01
-----	------------------------------	----------	----------	----------	----------

SPLIT FRACTIONS FOR TOP EVENT MC

MC1	moderator coefficient less negative than -7	1.00E-02	5.00E-04	5.00E-03	9.50E-03
-----	---	----------	----------	----------	----------

SPLIT FRACTIONS FOR TOP EVENT SS

SSF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
-----	--------------------	----------	----------	----------	----------

SPLIT FRACTIONS FOR TOP EVENT OD

ODF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
OV1	Failure to diagnoses a LOCA to RHR; Initiates ECA 1.2	1.00E+00	1.00E+00	1.00E+00	1.00E+00
OL1	Operator fails to depressurizes RCS	1.00E+00	1.00E+00	1.00E+00	1.00E+00
CT1	Seismic Failure of relays chattering givne /OP	0.00E-01	0.00E-01	0.00E-01	0.00E-01
CT2	Seismic Failure of relays chattering given OP	0.00E-01	0.00E-01	0.00E-01	0.00E-01
CTF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
EL1	Excessive LOCA	1.00E+00	1.00E+00	1.00E+00	1.00E+00
ELF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00
ID1	Identification of operator	0.00E-01	0.00E-01	0.00E-01	0.00E-01
IDF	Guaranteed Failure	1.00E+00	1.00E+00	1.00E+00	1.00E+00





APPENDIX C: SEISMIC SEQUENCE ANALYSIS

Figure C-1: First 200 Seismic Sequences


Reference: PGE.1123 EVENT.TREES SEISMIC SQLINKSO

SEQUENCE LIMIT OF, 2000 REACHED FOR TOTAL DAMAGE AT CUMULATIVE % OF 70.49 1

SUPPORT MODEL/MAINLINE MODEL MAXIMA8 SEQUENCE LINKING FOR D.C.P.R.A.(SEISMIC) 06/07/88
 DOMINANT SEQUENCE LIST FOR TOTAL DAMAGE
 FREQUENCY OF TOTAL DAMAGE 3.43E-05

NO.	INIT. EVENT SUP (FREQ) STATE		E.P. TREE END SEQ STATE NUM.		A.M. TREE RUN END SEQ STATE NUM.		F.L. TREE RUN END STATE NUM.		REC. TREE SEQ RUN END STATE NUM.		SEQUENCE SEQ RUN NUM.		PERCENT. FREQUENCY PER YEAR		CUMUL. OF TOTAL DAMAGE		% OF TOTAL
	1	SEIS4	SS27	EP48	1240	4	MS3	23	315	LT2A4	25	420	3H	13	455	2.196E-06	6.404
			FAILED SPLIT FRACTIONS														
	(1.17E-04)	STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
2	SEIS5	SS27	EP48	1240	5	MS3	23	417	LT2A5	25	520	3H	13	554	1.422E-06	4.147	10.551
			FAILED SPLIT FRACTIONS														
	(2.82E-05)	STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
3	SEIS4	SS27	EP48	437	4	MS3	23	315	LT2A4	25	420	3H	13	455	1.270E-06	3.703	14.254
			FAILED SPLIT FRACTIONS														
	(1.17E-04)	STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
4	SEIS5	SS27	EP48	437	5	MS3	23	417	LT2A5	25	520	3H	13	554	8.792E-07	2.564	16.818
			FAILED SPLIT FRACTIONS														
	(2.82E-05)	STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															





5	SEIS2	SS27	EP12	101	2	MS3	9	109	LT2A2	25	216	3H	13	252	8.583E-07	2.503	19.321
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
6	SEIS3	SS27	EP48	1240	3	MS3	23	218	LT2A3	25	319	3H	13	353	7.674E-07	2.238	21.559
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
7	SEIS5	SS89	EP153	2178	5	MS56	1302	461	LT2A5	26	539	3H	18	553	7.567E-07	2.207	23.766
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
8	SEIS4	SS27	EP12	101	4	MS3	9	307	LT2A4	25	420	3H	13	455	5.374E-07	1.567	25.333
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
9	SEIS6	SS27	EP48	1240	6	MS3	23	508	LT2A6	25	616	3H	13	654	5.209E-07	1.519	26.852
			FAILED SPLIT FRACTIONS														
			+ _____														
	(7.43E-06)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
10	SEIS5	SS27	EP48	1240	5	MS3	23	417	LT2A5	81	520	3H	13	554	4.741E-07	1.383	28.234
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														



11	SEIS3	SS27	EP12	101	3	MS3	9	210	LT2A3	25	319	3H	13	353	4.378E-07	1.277	29.511
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
12	SEIS4	SS89	EP153	2178	4	MS56	1302	357	LT2A4	26	443	3H	18	453	4.370E-07	1.274	30.785
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
13	SEIS4	SS88	EP153	2178	4	MS52	1290	357	LT2A4	26	443	3H	18	453	4.368E-07	1.274	32.059
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
14	SEIS3	SS27	EP48	437	3	MS3	23	218	LT2A3	25	319	3H	13	353	4.187E-07	1.221	33.280
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
15	SEIS2	SS27	EP48	1240	2	MS3	23	117	LT2A2	25	216	3H	13	252	4.123E-07	1.202	34.482
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
16	SEIS6	SS89	EP153	2178	6	MS56	1302	535	LT2A6	26	625	3H	18	653	4.065E-07	1.185	35.668
			FAILED SPLIT FRACTIONS														
			+ _____														
	(7.43E-06)		STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														



17	SEIS6	SS27	EP48	1240	6	MS3	23	508	LT2A6	81	616	3H	13	654	3.975E-07	1.159	36.827
			FAILED SPLIT FRACTIONS														
			+ _____														
	(7.43E-06)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
18	SEIS2	SS27	EP48	437	2	MS3	23	117	LT2A2	25	216	3H	13	252	3.352E-07	0.977	37.804
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
19	SEIS4	SS27	EP48	1240	4	MS3	23	315	LT2A4	81	420	3H	13	455	3.049E-07	0.889	38.693
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
20	SEIS5	SS27	EP48	437	5	MS3	23	417	LT2A5	81	520	3H	13	554	2.931E-07	0.855	39.548
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
21	SEIS6	SS27	EP48	437	6	MS3	23	508	LT2A6	25	616	3H	13	654	2.914E-07	0.850	40.398
			FAILED SPLIT FRACTIONS														
			+ _____														
	(7.43E-06)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
22	SEIS6	SS89	EP153	2178	6	MS56	1302	535	LT2A6	115	625	3H	18	653	2.641E-07	0.770	41.168
			FAILED SPLIT FRACTIONS														
			+ _____														
	(7.43E-06)		STAGES 1 AND 2, OG1 DF1 DG2 DH4/I1F I2F I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CT2 TDF CHF SIF AWF/FCF WL3 CIF O11														



23	SEIS2	SS88	EP46	366	2	MS52	1288	115	LT2A2	26	241	3H	18	253	2.603E-07	0.759	41,927	
			FAILED SPLIT FRACTIONS															
			+ (8.00E-04) STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F OSF CCF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1															
24	SEIS4	SS27	EP48	1240	4	MS3	23	315	LT2A4	26	420	3H	13	455	2.265E-07	0.661	42,588	
			FAILED SPLIT FRACTIONS															
			+ (1.17E-04) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF															
25	SEIS6	SS27	EP48	437	6	MS3	23	508	LT2A6	81	616	3H	13	654	2.224E-07	0.649	43,237	
			FAILED SPLIT FRACTIONS															
			+ (7.43E-06) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF															
26	SEIS5	SS89	EP153	2178	5	MS56	1302	461	LT2A5	115	539	3H	18	553	2.147E-07	0.626	43,863	
			FAILED SPLIT FRACTIONS															
			+ (2.82E-05) STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CT2 TDF CHF SIF AWF/FCF WL3 CIF OI1															
27	SEIS4	SS27	EP48	437	4	MS3	23	315	LT2A4	81	420	3H	13	455	1.763E-07	0.514	44,377	
			FAILED SPLIT FRACTIONS															
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF															
28	SEIS5	SS27	EP48	1240	5	MS3	23	417	LT2A5	26	520	3H	13	554	1.576E-07	0.460	44,836	
			FAILED SPLIT FRACTIONS															
			+ (2.82E-05) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF															





29	SEIS2	SS16	EP85	433	2	MS3	11	139	LT2A2	24	210	3D	11	251	1.468E-07	0.428	45.265
			FAILED SPLIT FRACTIONS														
			+ (8.00E-04) STAGES 1 AND 2, OG1 GF1 GG2 2G3/AF ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF														
30	SEIS1	SS27	EP12	101	1	MS3	9	12	LT2A1	25	113	3H	13	152	1.312E-07	0.383	45.647
			FAILED SPLIT FRACTIONS														
			+ (1.41E-02) STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
31	SEIS4	SS27	EP48	437	4	MS3	23	315	LT2A4	26	420	3H	13	455	1.310E-07	0.382	46.029
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
32	SEIS3	SS88	EP153	2178	3	MS52	1290	260	LT2A3	26	343	3H	18	354	1.300E-07	0.379	46.408
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
33	SEIS3	SS89	EP153	2178	3	MS56	1302	260	LT2A3	26	343	3H	18	354	1.296E-07	0.378	46.786
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
34	SEIS2	SS88	EP153	2178	2	MS52	1290	160	LT2A2	26	241	3H	18	253	1.250E-07	0.365	47.151
			FAILED SPLIT FRACTIONS														
			+ (8.00E-04) STAGES 1 AND 2, OG1 DF1 DG2 DH4/1F I2F I3F I4F OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														



35	SEIS4	SS11	EP10	368	4	MS1	7	306	LT3E4	49	408	2D	106	492	1.235E-07	0.360	47.511
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 SW1/IAF/ STAGES 3 AND 4, EL1/RF4														
36	SEIS4	SS1	EP47	367	4	MS1	7	314	LT3E4	49	400	2D	106	490	1.187E-07	0.346	47.857
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1/IAF/ STAGES 3 AND 4, EL1/RF4														
37	SEIS1	SS79	EP1	1	1	MS143	973	1	LT2A1	26	114	3H	18	153	1.170E-07	0.341	48.199
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.41E-02)		STAGES 1 AND 2, I11 SB3 OSF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
38	SEIS5	SS14	EP10	368	5	MS3	9	406	LT2A5	24	510	3D	11	552	1.149E-07	0.335	48.534
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 SW1/IAF CC7/ STAGES 3 AND 4, CHF SIF SE1/FCF														
39	SEIS2	SS25	EP79	421	2	MS1	7	135	LT2A2	14	214	3D	11	251	1.144E-07	0.334	48.867
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 GF1 GH2/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
40	SEIS2	SS1	EP1	1	2	MS1	7	101	LT3E2	49	200	2A	1	290	1.132E-07	0.330	49.197
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, IAF/ STAGES 3 AND 4, EL1/														



1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25
26
27
28
29
30
31
32
33
34
35
36
37
38
39
40
41
42
43
44
45
46
47
48
49
50
51
52
53
54
55
56
57
58
59
60
61
62
63
64
65
66
67
68
69
70
71
72
73
74
75
76
77
78
79
80
81
82
83
84
85
86
87
88
89
90
91
92
93
94
95
96
97
98
99
100



41	SEIS4	SS89	EP46	366	4	MS56	1300	313	LT2A4	26	443	3H	18	453	1.068E-07	0.312	49.509
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF CCF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
42	SEIS4	SS88	EP46	366	4	MS52	1288	313	LT2A4	26	443	3H	18	453	1.068E-07	0.311	49.820
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F OSF CCF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
43	SEIS1	SS27	EP48	437	1	MS3	23	32	LT2A1	25	113	3H	13	152	1.023E-07	0.298	50.118
			FAILED SPLIT FRACTIONS														
			+ (1.41E-02) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
44	SEIS5	SS27	EP48	437	5	MS3	23	417	LT2A5	26	520	3H	13	554	9.748E-08	0.284	50.403
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
45	SEIS2	SS27	EP12	101	2	MS3	9	109	LT2A2	26	216	3H	13	252	8.583E-08	0.250	50.653
			FAILED SPLIT FRACTIONS														
			+ (8.00E-04) STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
46	SEIS3	SS27	EP48	1240	3	MS3	23	218	LT2A3	26	319	3H	13	353	7.747E-08	0.226	50.879
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														



47	SEIS3	SS1	EP1	1	3	MS1	7	201	LT3E3	49	300	2D	106	390	7.720E-08	0.225	51.104
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, IAF/ STAGES 3 AND 4, EL1/RF4														
48	SEIS5	SS27	EP12	101	5	MS3	9	407	LT2A5	25	520	3H	13	554	7.692E-08	0.224	51.328
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
49	SEIS1	SS16	EP85	433	1	MS3	11	54	LT2A1	24	108	3D	11	151	7.578E-08	0.221	51.549
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.41E-02)		STAGES 1 AND 2, OG1 GF1 GG2 2G3/AF ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF														
50	SEIS4	SS27	EP12	101	4	MS3	9	307	LT2A4	81	420	3H	13	455	7.461E-08	0.218	51.767
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
51	SEIS5	SS28	EP48	1240	5	MS11	29	417	LT2A5	25	520	3H	18	553	7.401E-08	0.216	51.983
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF OS1 ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF WL3 CIF O11														
52	SEIS3	SS88	EP46	366	3	MS52	1288	216	LT2A3	26	343	3H	18	354	7.386E-08	0.215	52.198
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F OSF CCF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														



53	SEIS5	SS11	EP10	368	5	MS1	7	406	LT3E5	49	508	2D	106	592	7.373E-08	0.215	52.413
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 SW1/AF/ STAGES 3 AND 4, EL1/RF4														
54	SEIS3	SS89	EP46	366	3	MS56	1300	216	LT2A3	26	343	3H	18	354	7.361E-08	0.215	52.628
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF CCF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
55	SEIS5	SS27	EP48	1240	5	MS3	23	417	LT2A5	47	520	3H	13	554	7.263E-08	0.212	52.840
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														
56	SEIS6	SS27	EP48	1240	6	MS3	23	508	LT2A6	26	616	3H	13	654	6.943E-08	0.202	53.042
			FAILED SPLIT FRACTIONS														
			+ (7.43E-06) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
57	SEIS6	SS27	EP48	1240	6	MS3	23	508	LT2A6	47	616	3H	13	654	6.347E-08	0.185	53.227
			FAILED SPLIT FRACTIONS														
			+ (7.43E-06) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														
58	SEIS5	SS11	EP10	368	5	MS1	7	406	LT2E5	88	508	3H	13	571	6.340E-08	0.185	53.412
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 SW1/AF/ STAGES 3 AND 4, CT2 OC1 SEF/FCF CIF OIF														



59	SEIS2	SS21	EP69	403	2	MS1	7	129	LT1A2	32	213	5E	1239	215	6.202E-08	0.181	53.593
			FAILED SPLIT FRACTIONS														
	+																
		(8.00E-04)	STAGES 1 AND 2, OG1 GG1 GH2/IAF/ STAGES 3 AND 4, PRD/LAF LBF CSF CIF OIF														
60	SEIS5	SS5	EP47	367	5	MS3	9	416	LT2A5	24	504	3D	11	552	6.152E-08	0.179	53.772
			FAILED SPLIT FRACTIONS														
	+																
		(2.82E-05)	STAGES 1 AND 2, OG1/IAF CC6/ STAGES 3 AND 4, CHF SIF SE1/FCF														
61	SEIS1	SS25	EP79	421	1	MS1	7	50	LT2A1	14	111	3D	11	151	5.874E-08	0.171	53.944
			FAILED SPLIT FRACTIONS														
	+																
		(1.41E-02)	STAGES 1 AND 2, OG1 GF1 GH2/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
62	SEIS1	SS79	EP1	1	1	MS69	217	1	LT2A1	26	114	3H	18	153	5.849E-08	0.171	54.114
			FAILED SPLIT FRACTIONS														
	+																
		(1.41E-02)	STAGES 1 AND 2, I41 SA1 OSF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
63	SEIS2	SS25	EP59	386	2	MS1	7	124	LT2A2	14	214	3D	11	251	5.788E-08	0.169	54.283
			FAILED SPLIT FRACTIONS														
	+																
		(8.00E-04)	STAGES 1 AND 2, OG1 GH1 2G2 SW1/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
64	SEIS5	SS27	EP48	396	5	MS3	23	417	LT2A5	25	520	3H	13	554	5.694E-08	0.166	54.449
			FAILED SPLIT FRACTIONS														
	+																
		(2.82E-05)	STAGES 1 AND 2, OG1 GG1 2H2 FO4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														



65	SEIS4	SS27	EP12	101	4	MS3	9	307	LT2A4	26	420	3H	13	455	5.542E-08	0.162	54.611
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, AF1 AG2 AH3/IAF CCF/														
			STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
		(1.17E-04)															
66	SEIS2	SS25	EP57	383	2	MS1	7	122	LT2A2	14	214	3D	11	251	5.539E-08	0.162	54.772
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, OG1 GH1 2H2 SW1/IAF/														
			STAGES 3 AND 4, SIF AW4 OBF/FCF														
		(8.00E-04)															
67	SEIS5	SS11	EP10	368	5	MS1	7	406	LT1A5	32	508	5A	1237	513	5.527E-08	0.161	54.933
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, OG1 SW1/IAF/														
			STAGES 3 AND 4, PR1/LA1 LB2 CSF														
		(2.82E-05)															
68	SEIS3	SS1	EP1	1	3	MS1	7	201	LT1A3	32	300	5A	1237	310	5.263E-08	0.153	55.087
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, IAF/														
			STAGES 3 AND 4, PR1/LA1 LB2 CSF														
		(1.47E-04)															
69	SEIS3	SS16	EP85	433	3	MS3	11	240	LT2A3	24	311	3D	11	351	5.262E-08	0.153	55.240
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, OG1 GF1 GG2 2G3/IAF ASF/														
			STAGES 3 AND 4, CHF SIF SEF/FCF														
		(1.47E-04)															
70	SEIS4	SS27	EP48	1240	4	MS3	23	315	LT2A4	47	420	3H	13	455	5.032E-08	0.147	55.387
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/														
			STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														
		(1.17E-04)															
71	SEIS5	SS1	EP47	367	5	MS1	7	416	LT3E5	49	500	2D	106	590	4.686E-08	0.137	55.524
			FAILED SPLIT FRACTIONS														
			STAGES 1 AND 2, OG1/IAF/														
			STAGES 3 AND 4, EL1/RF4														
		(2.82E-05)															



72	SEIS3	SS27	EP48	1240	3	MS3	23	218	LT2A3	81	319	3H	13	353	4.603E-08	0.134	55.658
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
73	SEIS4	SS16	EP85	433	4	MS3	11	337	LT2A4	24	412	3D	11	451	4.578E-08	0.133	55.791
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1 GG2 2G3/AF ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF														
74	SEIS5	SS28	EP48	437	5	MS11	29	417	LT2A5	25	520	3H	18	553	4.576E-08	0.133	55.925
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF OS1 ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF WL3 CIF OI1														
75	SEIS5	SS27	EP48	437	5	MS3	23	417	LT2A5	47	520	3H	13	554	4.491E-08	0.131	56.056
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														
76	SEIS5	SS27	EP48	1240	5	MS3	23	417	LT2A5	115	520	3H	13	554	4.472E-08	0.130	56.186
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CT2 TD1 CHF SIF AWF/FCF CIF OIF														
77	SEIS3	SS27	EP12	101	3	MS3	9	210	LT2A3	26	319	3H	13	353	4.420E-08	0.129	56.315
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
78	SEIS3	SS27	EP48	437	3	MS3	23	218	LT2A3	26	319	3H	13	353	4.227E-08	0.123	56.438
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														



79	SEIS2	SS27	EP48	1240	2	MS3	23	117	LT2A2	26	216	3H	13	252	4.123E-08	0.120	56.559
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 AF1 AG2 AH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
80	SEIS3	SS27	EP48	396	3	MS3	23	218	LT2A3	25	319	3H	13	353	4.099E-08	0.120	56.678
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 GG1 2H2 FO4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
81	SEIS5	SS5	EP47	367	5	MS3	21	416	LT2A5	24	504	3D	11	552	4.077E-08	0.119	56.797
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1/CV2 CC6/ STAGES 3 AND 4, CHF SIF SE1/FCF														
82	SEIS5	SS89	EP46	366	5	MS56	1300	415	LT2A5	26	539	3H	18	553	3.957E-08	0.115	56.912
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, DF1 DG2 DH4/I1F I2F I3F I4F RT7 OSF CCF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
83	SEIS5	SS1	EP47	367	5	MS1	7	416	LT2E5	88	500	3H	13	570	3.919E-08	0.114	57.027
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1/IAF/ STAGES 3 AND 4, CT2 OC1 SEF/FCF CIF OIF														
84	SEIS6	SS27	EP48	437	6	MS3	23	508	LT2A6	26	616	3H	13	654	3.885E-08	0.113	57.140
			FAILED SPLIT FRACTIONS														
			+ _____														
	(7.43E-06)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														



85	SEIS3	SS1	EP47	367	3	MS1	7	217	LT3E3	49	300	2D	106	390	3.774E-08	0.110	57.250
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1/IAF/ STAGES 3 AND 4, EL1/RF4														
86	SEIS3	SS16	EP83	429	3	MS3	9	239	LT2A3	24	311	3D	11	351	3.693E-08	0.108	57.358
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 GF1 GG2/IAF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF														
87	SEIS4	SS16	EP83	429	4	MS3	9	336	LT2A4	24	412	3D	11	451	3.674E-08	0.107	57.465
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1 GG2/IAF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF														
88	SEIS3	SS27	EP48	393	3	MS3	23	218	LT2A3	25	319	3H	13	353	3.636E-08	0.106	57.571
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 GG1 FO3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
89	SEIS3	SS27	EP48	372	3	MS3	23	218	LT2A3	25	319	3H	13	353	3.636E-08	0.106	57.677
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 2H1 FO3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
90	SEIS4	SS27	EP48	396	4	MS3	23	315	LT2A4	25	420	3H	13	455	3.611E-08	0.105	57.782
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, OG1 GG1 2H2 FO4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
91	SEIS6	SS27	EP48	437	6	MS3	23	508	LT2A6	47	616	3H	13	654	3.551E-08	0.104	57.886
			FAILED SPLIT FRACTIONS														
			+ (7.43E-06) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														



92	SEIS2	SS16	EP83	429	2	MS3	9	138	LT2A2	24	210	3D	11	251	3.536E-08	0.103	57.989
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 GF1 GG2/AF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF														
93	SEIS4	SS27	EP48	372	4	MS3	23	315	LT2A4	25	420	3H	13	455	3.528E-08	0.103	58.092
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 2H1 FO3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
94	SEIS4	SS27	EP48	393	4	MS3	23	315	LT2A4	25	420	3H	13	455	3.527E-08	0.103	58.195
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 GG1 FO3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
95	SEIS3	SS25	EP79	421	3	MS1	7	236	LT2A3	14	317	3D	11	351	3.524E-08	0.103	58.297
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 GF1 GH2/AF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
96	SEIS5	SS27	EP12	101	5	MS3	11	407	LT2A5	25	520	3H	13	554	3.412E-08	0.099	58.397
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, AF1 AG2 AH3/AF AS4/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
97	SEIS2	SS27	EP48	437	2	MS3	23	117	LT2A2	26	216	3H	13	252	3.352E-08	0.098	58.495
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														



98	SEIS2	SS27	EP48	369	2	MS3	23	117	LT2A2	25	216	3H	13	252	3.304E-08	0.096	58.591
			FAILED SPLIT FRACTIONS														
			+ (8.00E-04) STAGES 1 AND 2, OG1 FO1/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
99	SEIS2	SS16	EP83	429	2	MS3	11	138	LT2A2	24	210	3D	11	251	3.119E-08	0.091	58.682
			FAILED SPLIT FRACTIONS														
			+ (8.00E-04) STAGES 1 AND 2, OG1 GF1 GG2/IAF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF														
100	SEIS4	SS27	EP12	101	4	MS3	11	307	LT2A4	25	420	3H	13	455	3.113E-08	0.091	58.773
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, AF1 AG2 AH3/IAF AS4/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
101	SEIS4	SS25	EP79	421	4	MS1	7	333	LT2A4	14	418	3D	11	451	3.097E-08	0.090	58.863
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1 GH2/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
102	SEIS1	SS25	EP59	386	1	MS1	7	39	LT2A1	14	111	3D	11	151	2.972E-08	0.087	58.950
			FAILED SPLIT FRACTIONS														
			+ (1.41E-02) STAGES 1 AND 2, OG1 GH1 2G2 SW1/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
103	SEIS4	SS27	EP48	437	4	MS3	23	315	LT2A4	47	420	3H	13	455	2.910E-08	0.085	59.034
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														
104	SEIS5	SS5	EP1	1	5	MS3	9	401	LT2A5	24	504	3D	11	552	2.896E-08	0.084	59.119
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, IAF CC1/ STAGES 3 AND 4, CHF SIF SE1/FCF														





105	SEIS1	SS25	EP57	383	1	MS1	7	37	LT2A1	14	111	3D	11	151	2.845E-08	0.083	59.202
			FAILED SPLIT FRACTIONS														
			+ (1.41E-02) STAGES 1 AND 2, OG1 GH1 2H2 SW1/AF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
106	SEIS3	SS16	EP83	429	3	MS3	11	239	LT2A3	24	311	3D	11	351	2.821E-08	0.082	59.284
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1 GF1 GG2/AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF														
107	SEIS5	SS27	EP48	437	5	MS3	23	417	LT2A5	115	520	3H	13	554	2.765E-08	0.081	59.365
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05) STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CT2 TD1 CHF SIF AWF/FCF CIF OIF														
108	SEIS6	SS89	EP48	1240	6	MS56	1302	508	LT2A6	26	625	3H	18	653	2.659E-08	0.078	59.442
			FAILED SPLIT FRACTIONS														
			+ (7.43E-06) STAGES 1 AND 2, OG1 AF1 AG2 AH3/112 I24 I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
109	SEIS3	SS27	EP12	101	3	MS3	9	210	LT2A3	81	319	3H	13	353	2.626E-08	0.077	59.519
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
110	SEIS3	SS1	EP47	367	3	MS1	7	217	LT1A3	32	300	5A	1237	310	2.573E-08	0.075	59.594
			FAILED SPLIT FRACTIONS														
			+ (1.47E-04) STAGES 1 AND 2, OG1/AF/ STAGES 3 AND 4, PR1/LA1 LB2 CSF														





111	SEIS5	SS27	EP12	101	5	MS3	9	407	LT2A5	81	520	3H	13	554	2.565E-08	0.075	59.669
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
112	SEIS3	SS27	EP48	437	3	MS3	23	218	LT2A3	81	319	3H	13	353	2.511E-08	0.073	59.742
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 GF1 GG2 GH3/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
113	SEIS3	SS27	EP12	101	3	MS3	11	210	LT2A3	25	319	3H	13	353	2.510E-08	0.073	59.815
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, AF1 AG2 AH3/AF AS4/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
114	SEIS5	SS14	EP52	374	5	MS3	9	419	LT2A5	24	510	3D	11	552	2.478E-08	0.072	59.887
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 2G1 SW3/AF CC7/ STAGES 3 AND 4, CHF SIF SE1/FCF														
115	SEIS4	SS16	EP83	429	4	MS3	11	336	LT2A4	24	412	3D	11	451	2.475E-08	0.072	59.959
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.17E-04)		STAGES 1 AND 2, OG1 GF1 GG2/AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF														
116	SEIS5	SS14	EP50	371	5	MS3	9	406	LT2A5	24	510	3D	11	552	2.451E-08	0.071	60.031
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 2H1 SW3/AF CC7/ STAGES 3 AND 4, CHF SIF SE1/FCF														



117	SEIS2	SS27	EP48	396	2	MS3	23	117	LT2A2	25	216	3H	13	252	2.337E-08	0.068	60.099	
			FAILED SPLIT FRACTIONS															
			+ (8.00E-04) STAGES 1 AND 2, OG1 GG1 2H2 FO4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
118	SEIS4	SS11	EP52	374	4	MS1	7	317	LT3E4	49	408	2D	106	492	2.265E-08	0.066	60.165	
			FAILED SPLIT FRACTIONS															
			+ (1.17E-04) STAGES 1 AND 2, OG1 2G1 SW3/IAF/ STAGES 3 AND 4, EL1/RF4															
119	SEIS4	SS11	EP50	371	4	MS1	7	306	LT3E4	49	408	2D	106	492	2.245E-08	0.065	60.231	
			FAILED SPLIT FRACTIONS															
			+ (1.17E-04) STAGES 1 AND 2, OG1 2H1 SW3/IAF/ STAGES 3 AND 4, EL1/RF4															
120	SEIS4	SS11	EP75	413	4	MS1	7	331	LT3E4	49	408	2D	106	492	2.131E-08	0.062	60.293	
			FAILED SPLIT FRACTIONS															
			+ (1.17E-04) STAGES 1 AND 2, OG1 GF1/IAF/ STAGES 3 AND 4, EL1/RF4															
121	SEIS3	SS16	EP66	398	3	MS3	9	229	LT2A3	24	311	3D	11	351	2.057E-08	0.060	60.353	
			FAILED SPLIT FRACTIONS															
			+ (1.47E-04) STAGES 1 AND 2, OG1 GG1 2G2 SW1/IAF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF															
122	SEIS4	SS16	EP66	398	4	MS3	9	326	LT2A4	24	412	3D	11	451	2.047E-08	0.060	60.412	
			FAILED SPLIT FRACTIONS															
			+ (1.17E-04) STAGES 1 AND 2, OG1 GG1 2G2 SW1/IAF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF															
123	SEIS5	SS89	EP48	1240	5	MS56	1302	417	LT2A5	26	539	3H	18	553	1.972E-08	0.057	60.470	
			FAILED SPLIT FRACTIONS															
			+ (2.82E-05) STAGES 1 AND 2, OG1 AF1 AG2 AH3/12 I24 I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11															



124	SEISS	SS27	EP48	396	5	MS3	23	417	LT2A5	81	520	3H	13	554	1.898E-08	0.055	60.525
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 GG1 2H2 FO4/CVF ASF/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF														
125	SEIS3	SS25	EP59	386	3	MS1	7	225	LT2A3	14	317	3D	11	351	1.891E-08	0.055	60.580
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 GH1 2G2 SW1/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
126	SEISS	SS16	EP83	429	5	MS3	11	440	LT2A5	24	512	3D	11	551	1.881E-08	0.055	60.635
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 GF1 GG2/IAF ASB/ STAGES 3 AND 4, CHF SIF SÈF/FCF														
127	SEISS	SS16	EP83	429	5	MS3	9	440	LT2A5	24	512	3D	11	551	1.863E-08	0.054	60.690
			FAILED SPLIT FRACTIONS														
			+ _____														
	(2.82E-05)		STAGES 1 AND 2, OG1 GF1 GG2/IAF CCS/ STAGES 3 AND 4, CHF SIF SEF/FCF														
128	SEIS2	SS16	EP66	398	2	MS3	9	128	LT2A2	24	210	3D	11	251	1.844E-08	0.054	60.743
			FAILED SPLIT FRACTIONS														
			+ _____														
	(8.00E-04)		STAGES 1 AND 2, OG1 GG1 2G2 SW1/IAF CCS/ STAGES 3 AND 4, CHF SIF SEF/FCF														
129	SEIS3	SS25	EP57	383	3	MS1	7	223	LT2A3	14	317	3D	11	351	1.811E-08	0.053	60.796
			FAILED SPLIT FRACTIONS														
			+ _____														
	(1.47E-04)		STAGES 1 AND 2, OG1 GH1 2H2 SW1/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														



130	SEIS2	SS27	EP48	412	2	MS3	23	117	LT2A2	25	216	3H	13	252	1.792E-08	0.052	60.848
			FAILED SPLIT FRACTIONS														
	+	(8.00E-04)	STAGES 1 AND 2, OG1 GG1 GH2 2G3 2H4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
131	SEIS2	SS16	EP86	435	2	MS3	11	139	LT2A2	24	210	3D	11	251	1.770E-08	0.052	60.900
			FAILED SPLIT FRACTIONS														
	+	(8.00E-04)	STAGES 1 AND 2, OG1 GF1 GG2 2G3 2H4/IAF ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF														
132	SEIS5	SS89	EP46	366	5	MS56	1302	415	LT2A5	26	539	3H	18	553	1.755E-08	0.051	60.951
			FAILED SPLIT FRACTIONS														
	+	(2.82E-05)	STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF AS4 SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														
133	SEIS1	SS16	EP83	429	1	MS3	9	53	LT2A1	24	108	3D	11	151	1.739E-08	0.051	61.002
			FAILED SPLIT FRACTIONS														
	+	(1.41E-02)	STAGES 1 AND 2, OG1 GF1 GG2/IAF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF														
134	SEIS6	SS89	EP48	1240	6	MS56	1302	508	LT2A6	115	625	3H	18	653	1.728E-08	0.050	61.052
			FAILED SPLIT FRACTIONS														
	+	(7.43E-06)	STAGES 1 AND 2, OG1 AF1 AG2 AH3/12 I24 I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CT2 TDF CHF SIF AWF/FCF WL3 CIF OI1														
135	SEIS2	SS1	EP47	367	2	MS1	7	116	LT3E2	49	200	2A	1	290	1.711E-08	0.050	61.102
			FAILED SPLIT FRACTIONS														
	+	(8.00E-04)	STAGES 1 AND 2, OG1/IAF/ STAGES 3 AND 4, EL1/														
136	SEIS1	SS27	EP48	369	1	MS3	23	32	LT2A1	25	113	3H	13	152	1.678E-08	0.049	61.151
			FAILED SPLIT FRACTIONS														
	+	(1.41E-02)	STAGES 1 AND 2, OG1 FO1/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														



137	SEIS4	SS25	EP59	386	4	MS1	7	322	LT2A4	14	418	3D	11	451	1.663E-08	0.048	61.200
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04)			STAGES 1 AND 2, OG1 GH1 2G2 SW1//AF/ STAGES 3 AND 4, SIF AW4 OBF/FCF											
138	SEIS4	SS27	EP48	1240	4	MS3	71	315	LT2A4	25	420	3H	13	455	1.629E-08	0.048	61.247
			FAILED SPLIT FRACTIONS														
			+ (1.17E-04)			STAGES 1 AND 2, OG1 AF1 AG2 AH3/SB1 CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF											
139	SEIS2	SS16	EP66	398	2	MS3	11	128	LT2A2	24	210	3D	11	251	1.625E-08	0.047	61.294
			FAILED SPLIT FRACTIONS														
			+ (8.00E-04)			STAGES 1 AND 2, OG1 GG1 2G2 SW1//AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF											
140	SEIS5	SS16	EP66	398	5	MS3	11	429	LT2A5	24	512	3D	11	551	1.613E-08	0.047	61.341
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05)			STAGES 1 AND 2, OG1 GG1 2G2 SW1//AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF											
141	SEIS1	SS16	EP83	429	1	MS3	11	53	LT2A1	24	108	3D	11	151	1.607E-08	0.047	61.388
			FAILED SPLIT FRACTIONS														
			+ (1.41E-02)			STAGES 1 AND 2, OG1 GF1 GG2//AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF											
142	SEIS5	SS16	EP66	398	5	MS3	9	429	LT2A5	24	512	3D	11	551	1.598E-08	0.047	61.435
			FAILED SPLIT FRACTIONS														
			+ (2.82E-05)			STAGES 1 AND 2, OG1 GG1 2G2 SW1//AF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF											



143	SEIS4	SS25	EP57	383	4	MS1	7	320	LT2A4	14	418	3D	11	451	1.591E-08	0.046	61.481	
			FAILED SPLIT FRACTIONS															
			+															
			(1.17E-04)	STAGES 1 AND 2, OG1 GH1 2H2 SW1/AF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
144	SEIS5	SS11	EP52	374	5	MS1	7	419	LT3E5	49	508	2D	106	592	1.589E-08	0.046	61.528	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 2G1 SW3/AF/ STAGES 3 AND 4, EL1/RF4														
145	SEIS5	SS14	EP75	413	5	MS3	9	435	LT2A5	24	510	3D	11	552	1.577E-08	0.046	61.574	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 GF1/AF CC7/ STAGES 3 AND 4, CHF SIF SE1/FCF														
146	SEIS5	SS11	EP50	371	5	MS1	7	406	LT3E5	49	508	2D	106	592	1.573E-08	0.046	61.620	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 2H1 SW3/AF/ STAGES 3 AND 4, EL1/RF4														
147	SEIS3	SS16	EP66	398	3	MS3	11	229	LT2A3	24	311	3D	11	351	1.571E-08	0.046	61.665	
			FAILED SPLIT FRACTIONS															
			+															
			(1.47E-04)	STAGES 1 AND 2, OG1 GG1 2G2 SW1/AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF														
148	SEIS6	SS89	EP48	437	6	MS56	1302	508	LT2A6	26	625	3H	18	653	1.488E-08	0.043	61.709	
			FAILED SPLIT FRACTIONS															
			+															
			(7.43E-06)	STAGES 1 AND 2, OG1 GF1 GG2 GH3/12 I24 I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
149	SEIS4	SS27	EP48	369	4	MS3	23	315	LT2A4	25	420	3H	13	455	1.450E-08	0.042	61.751	
			FAILED SPLIT FRACTIONS															
			+															
			(1.17E-04)	STAGES 1 AND 2, OG1 FO1/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														



150	SEIS4	SS16	EP66	398	4	MS3	11	326	LT2A4	24	412	3D	11	451	1.378E-08	0.040	61.791
			FAILED SPLIT FRACTIONS														
			+														
			(1.17E-04)	STAGES 1 AND 2, OG1 GG1 2G2 SW1/IAF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF													
151	SEIS5	SS11	EP52	374	5	MS1	7	419	LT2E5	88	508	3H	13	571	1.366E-08	0.040	61.831
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 2G1 SW3/IAF/ STAGES 3 AND 4, CT2 OC1 SEF/FCF CIF OIF													
152	SEIS5	SS16	EP83	429	5	MS3	23	440	LT2A5	24	512	3D	11	551	1.362E-08	0.040	61.871
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 GF1 GG2/CV3 ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF													
153	SEIS5	SS11	EP50	371	5	MS1	7	406	LT2E5	88	508	3H	13	571	1.352E-08	0.039	61.910
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 2H1 SW3/IAF/ STAGES 3 AND 4, CT2 OC1 SEF/FCF CIF OIF													
154	SEIS5	SS16	EP83	429	5	MS3	21	440	LT2A5	24	512	3D	11	551	1.349E-08	0.039	61.950
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 GF1 GG2/CV3 CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF													
155	EIS2	SS25	EP81	425	2	MS1	7	136	LT2A2	14	214	3D	11	251	1.265E-08	0.037	61.986
			FAILED SPLIT FRACTIONS														
			+														
			(8.00E-04)	STAGES 1 AND 2, OG1 GF1 GH2 2G3/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF													





156	SEISS	SS16	EP15	392	5	MS3	9	409	LT2A5	24	512	3D	11	551	1.254E-08	0.037	62.023	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 GG1 SW2/IAF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF														
157	SEISS	SS16	EP15	392	5	MS3	11	409	LT2A5	24	512	3D	11	551	1.240E-08	0.036	62.059	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 GG1 SW2/IAF AS7/ STAGES 3 AND 4, CHF SIF SEF/FCF														
158	SEIS2	SS25	EP80	423	2	MS1	7	125	LT2A2	14	214	3D	11	251	1.238E-08	0.036	62.095	
			FAILED SPLIT FRACTIONS															
			+															
			(8.00E-04)	STAGES 1 AND 2, OG1 GF1 GH2 2H3/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
159	SEIS2	SS25	EP61	389	2	MS1	7	125	LT2A2	14	214	3D	11	251	1.235E-08	0.036	62.131	
			FAILED SPLIT FRACTIONS															
			+															
			(8.00E-04)	STAGES 1 AND 2, OG1 GH1 2G2 2H3 SW3/IAF/ STAGES 3 AND 4, SIF AW4 OBF/FCF														
160	SEIS4	SS27	EP12	101	4	MS3	9	307	LT2A4	47	420	3H	13	455	1.231E-08	0.036	62.167	
			FAILED SPLIT FRACTIONS															
			+															
			(1.17E-04)	STAGES 1 AND 2, AF1 AG2 AH3/IAF CCF/ STAGES 3 AND 4, PRA CHF SIF/FCF CIF OIF														
161	SEISS	SS89	EP48	437	5	MS56	1302	417	LT2A5	26	539	3H	18	553	1.220E-08	0.036	62.203	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 GF1 GG2 GH3/12 I24 I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
162	SEIS1	SS27	EP48	396	1	MS3	23	32	LT2A1	25	113	3H	13	152	1.200E-08	0.035	62.238	
			FAILED SPLIT FRACTIONS															
			+															
			(1.41E-02)	STAGES 1 AND 2, OG1 GG1 2H2 FO4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														



163	SEISS	SS11	EP52	374	5	MS1	7	419	LT1A5	32	508	5A	1237	513	1.191E-08	0.035	62.272
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 2G1 SW3/IAF/ STAGES 3 AND 4, PR1/LA1 LB2 CSF													
164	SEISS	SS11	EP50	371	5	MS1	7	406	LT1A5	32	508	5A	1237	513	1.179E-08	0.034	62.307
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 2H1 SW3/IAF/ STAGES 3 AND 4, PR1/LA1 LB2 CSF													
165	SEIS3	SS27	EP48	369	3	MS3	23	218	LT2A3	25	319	3H	13	353	1.160E-08	0.034	62.341
			FAILED SPLIT FRACTIONS														
			+														
			(1.47E-04)	STAGES 1 AND 2, OG1 FO1/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
166	SEIS2	SS27	EP12	101	2	MS3	11	109	LT2A2	25	216	3H	13	252	1.154E-08	0.034	62.374
			FAILED SPLIT FRACTIONS														
			+														
			(8.00E-04)	STAGES 1 AND 2, AF1 AG2 AH3/IAF AS4/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
167	SEISS	SS27	EP48	408	5	MS3	23	417	LT2A5	25	520	3H	13	554	1.138E-08	0.033	62.408
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 GG1 GH2 2H3 FO5/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
168	SEISS	SS27	EP12	101	5	MS3	11	407	LT2A5	81	520	3H	13	554	1.138E-08	0.033	62.441
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, AF1 AG2 AH3/IAF AS4/ STAGES 3 AND 4, CT2 CHF SIF SEF HSF/FCF CIF OIF													



169	SEIS5	SS27	EP48	402	5	MS3	23	417	LT2A5	25	520	3H	13	554	1.137E-08	0.033	62.474	
			FAILED SPLIT FRACTIONS															
			+															
		(2.82E-05)	STAGES 1 AND 2, OG1 GG1 2G2 2H3 FO5/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
170	SEIS5	SS89	EP46	366	5	MS56	1300	415	LT2A5	115	539	3H	18	553	1.123E-08	0.033	62.507	
			FAILED SPLIT FRACTIONS															
			+															
		(2.82E-05)	STAGES 1 AND 2, DF1 DG2 DH4/1F I2F I3F I4F RT7 OSF CCF SVF/ STAGES 3 AND 4, CT2 TDF CHF SIF AWF/FCF WL3 CIF O11															
171	SEIS5	SS27	EP48	1240	5	MS3	71	417	LT2A5	25	520	3H	13	554	1.053E-08	0.031	62.537	
			FAILED SPLIT FRACTIONS															
			+															
		(2.82E-05)	STAGES 1 AND 2, OG1 AF1 AG2 AH3/SB1 CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
172	SEIS5	SS14	EP75	413	5	MS3	21	435	LT2A5	24	510	3D	11	552	1.046E-08	0.030	62.568	
			FAILED SPLIT FRACTIONS															
			+															
		(2.82E-05)	STAGES 1 AND 2, OG1 GF1/CV2 CC7/ STAGES 3 AND 4, CHF SIF SE1/FCF															
173	SEIS2	SS27	EP48	399	2	MS3	23	117	LT2A2	25	216	3H	13	252	1.036E-08	0.030	62.598	
			FAILED SPLIT FRACTIONS															
			+															
		(8.00E-04)	STAGES 1 AND 2, OG1 GG1 2G2 FO2/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
174	SEIS2	SS27	EP48	384	2	MS3	23	117	LT2A2	25	216	3H	13	252	1.036E-08	0.030	62.628	
			FAILED SPLIT FRACTIONS															
			+															
		(8.00E-04)	STAGES 1 AND 2, OG1 GH1 2H2 FO2/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF															
175	SEIS5	SS11	EP75	413	5	MS1	7	435	LT3E5	49	508	2D	106	592	1.012E-08	0.030	62.658	
			FAILED SPLIT FRACTIONS															
			+															
		(2.82E-05)	STAGES 1 AND 2, OG1 GF1/IAF/ STAGES 3 AND 4, EL1/RF4															





176	SEIS6	SS89	EP48	437	6	MS56	1302	508	LT2A6	115	625	3H	18	653	9.668E-09	0.028	62.686
			FAILED SPLIT FRACTIONS														
			+														
			(7.43E-06)	STAGES 1 AND 2, OG1 GF1 GG2 GH3/112 I24 I3F I4F RT7 OSF ASF SVF/ STAGES 3 AND 4, CT2 TDF CHF SIF AWF/FCF WL3 CIF O11													
177	SEIS3	SS27	EP48	408	3	MS3	23	218	LT2A3	25	319	3H	13	353	9.638E-09	0.028	62.714
			FAILED SPLIT FRACTIONS														
			+														
			(1.47E-04)	STAGES 1 AND 2, OG1 GG1 GH2 2H3 FO5/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
178	SEIS3	SS27	EP48	402	3	MS3	23	218	LT2A3	25	319	3H	13	353	9.638E-09	0.028	62.742
			FAILED SPLIT FRACTIONS														
			+														
			(1.47E-04)	STAGES 1 AND 2, OG1 GG1 2G2 2H3 FO5/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
179	SEIS5	SS14	EP10	368	5	MS3	11	406	LT2A5	24	510	3D	11	552	9.446E-09	0.028	62.770
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 SW1/AF AS5/ STAGES 3 AND 4, CHF SIF SE1/FCF													
180	SEIS4	SS27	EP48	437	4	MS3	71	315	LT2A4	25	420	3H	13	455	9.424E-09	0.027	62.797
			FAILED SPLIT FRACTIONS														
			+														
			(1.17E-04)	STAGES 1 AND 2, OG1 GF1 GG2 GH3/SB1 CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
181	SEIS1	SS27	EP48	412	1	MS3	23	32	LT2A1	25	113	3H	13	152	9.206E-09	0.027	62.824
			FAILED SPLIT FRACTIONS														
			+														
			(1.41E-02)	STAGES 1 AND 2, OG1 GG1 GH2 2G3 2H4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													



182	SEIS1	SS16	EP86	435	1	MS3	11	54	LT2A1	24	108	3D	11	151	9.142E-09	0.027	62.851	
			FAILED SPLIT FRACTIONS															
			+															
			(1.41E-02)	STAGES 1 AND 2, OG1 GF1 GG2 2G3 2H4/AF ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF														
183	SEIS1	SS16	EP66	398	1	MS3	9	43	LT2A1	24	108	3D	11	151	9.062E-09	0.026	62.877	
			FAILED SPLIT FRACTIONS															
			+															
			(1.41E-02)	STAGES 1 AND 2, OG1 GG1 2G2 SW1/AF CC5/ STAGES 3 AND 4, CHF SIF SEF/FCF														
184	SEIS1	SS79	EP1	1	1	MS69	997	1	LT2A1	26	114	3H	18	153	8.928E-09	0.026	62.903	
			FAILED SPLIT FRACTIONS															
			+															
			(1.41E-02)	STAGES 1 AND 2, I11 I41 OSF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
185	SEIS5	SS27	EP48	372	5	MS3	23	417	LT2A5	25	520	3H	13	554	8.900E-09	0.026	62.929	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 2H1 FO3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
186	SEIS5	SS27	EP48	393	5	MS3	23	417	LT2A5	25	520	3H	13	554	8.900E-09	0.026	62.955	
			FAILED SPLIT FRACTIONS															
			+															
			(2.82E-05)	STAGES 1 AND 2, OG1 GG1 FO3/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
187	SEIS1	SS90	EP1	1	1	MS103	397	1	LT2A1	26	138	3H	18	153	8.840E-09	0.026	62.981	
			FAILED SPLIT FRACTIONS															
			+															
			(1.41E-02)	STAGES 1 AND 2, I31 I41 OSF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														
188	SEIS1	SS90	EP1	1	1	MS127	691	1	LT2A1	26	138	3H	18	153	8.775E-09	0.026	63.006	
			FAILED SPLIT FRACTIONS															
			+															
			(1.41E-02)	STAGES 1 AND 2, I21 I31/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF O11														




189	SEISS	SS11	EP75	413	5	MS1	7	435	LT2E5	88	508	3H	13	571	8.701E-09	0.025	63.032
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)														
			STAGES 1 AND 2, OG1 GF1/AF/ STAGES 3 AND 4, CT2 OC1 SEF/FCF CIF OIF														
190	SEISS	SS16	EP85	433	5	MS3	11	441	LT2A5	24	512	3D	11	551	8.589E-09	0.025	63.057
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)														
			STAGES 1 AND 2, OG1 GF1 GG2 2G3/AF ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF														
191	SEISS	SS27	EP12	101	5	MS3	9	407	LT2A5	26	520	3H	13	554	8.529E-09	0.025	63.082
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)														
			STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF AW4/FCF CIF OIF														
192	SEIS4	SS27	EP48	402	4	MS3	23	315	LT2A4	25	420	3H	13	455	8.514E-09	0.025	63.106
			FAILED SPLIT FRACTIONS														
			+														
			(1.17E-04)														
			STAGES 1 AND 2, OG1 GG1 2G2 2H3 FO5/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
193	SEIS4	S27	EP48	408	4	MS3	23	315	LT2A4	25	420	3H	13	455	8.514E-09	0.025	63.131
			FAILED SPLIT FRACTIONS														
			+														
			(1.17E-04)														
			STAGES 1 AND 2, OG1 GG1 GH2 2H3 FO5/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF														
194	SEIS1	SS90	EP23	249	1	MS124	625	19	LT2A1	26	138	3H	18	153	8.408E-09	0.025	63.156
			FAILED SPLIT FRACTIONS														
			+														
			(1.41E-02)														
			STAGES 1 AND 2, DG1/2F I42 OSF/ STAGES 3 AND 4, CHF SIF AWF/FCF WL3 CIF OI1														



195	SEIS1	SS16	EP66	398	1	MS3	11	43	LT2A1	24	108	3D	11	151	8.376E-09	0.024	63.180
			FAILED SPLIT FRACTIONS														
			+														
			(1.41E-02)	STAGES 1 AND 2, OG1 GG1 2G2 SW1/AF ASB/ STAGES 3 AND 4, CHF SIF SEF/FCF													
196	SEIS5	SS27	EP48	432	5	MS3	23	417	LT2A5	25	520	3H	13	554	8.117E-09	0.024	63.204
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 GF1 GG2 2H3 FO4/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
197	SEIS2	SS16	EP85	433	2	MS3	23	139	LT2A2	24	210	3D	11	251	8.003E-09	0.023	63.227
			FAILED SPLIT FRACTIONS														
			+														
			(8.00E-04)	STAGES 1 AND 2, OG1 GF1 GG2 2G3/CV3 ASF/ STAGES 3 AND 4, CHF SIF SEF/FCF													
198	SEIS5	SS11	EP75	413	5	MS1	7	435	LT1A5	32	508	5A	1237	513	7.585E-09	0.022	63.249
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 GF1/AF/ STAGES 3 AND 4, PR1/LA1 LB2 CSF													
199	SEIS5	SS27	EP48	369	5	MS3	23	417	LT2A5	25	520	3H	13	554	7.304E-09	0.021	63.271
			FAILED SPLIT FRACTIONS														
			+														
			(2.82E-05)	STAGES 1 AND 2, OG1 FO1/CVF ASF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													
200	SEIS6	SS27	EP12	101	6	MS3	9	503	LT2A6	25	616	3H	13	654	7.292E-09	0.021	63.292
			FAILED SPLIT FRACTIONS														
			+														
			(7.43E-06)	STAGES 1 AND 2, AF1 AG2 AH3/AF CCF/ STAGES 3 AND 4, CHF SIF SEF HSF/FCF CIF OIF													






DIABLO CANYON
 POWER FROM SWING DIESEL UNAVAILABLE
 (DG13PDW2)

FIGURE D-3






DIABLO CANYON
 SWING DIESEL ALIGNED TO UNIT 2
 ONE DG IN UNIT 2 AVAILABLE
 (SWITCH1)

FIGURE D-4






DIABLO CANYON
 LOOP EVENT & ALL DG'S IN STANDBY
 (CASE1-LP)

FIGURE D-5






DIABLO CANYON
LOOP EVENT WITH LOCA IN UNIT 1
ALL DG'S IN STANDBY
(CASE1-1)

FIGURE D-6






DIABLO CANYON
LOOP EVENT & SWING DG OUT OF SERVICE
(CASE2)

FIGURE D-7






DIABLO CANYON
 LOOP EVENT WITH LOCA IN UNIT 1
 DG 1-2 OUT OF SERVICE
 (CASE3)

FIGURE D-8








DIABLO CANYON
LOOP EVENT, SIX DG'S IN STANDBY
(CASE4-LP)

FIGURE D-9






DIABLO CANYON
 LOOP EVENT WITH LOCA IN UNIT 1
 SIX DG'S IN STANDBY
 (CASE 4-1)

FIGURE D-10






DIABLO CANYON
 LOOP EVENT & ONE DG OUT OF SERVICE
 SIX DG CONFIGURATION
 (CASE5)
 FIGURE D-11







DIABLO CANYON
 LOOP EVENT WITH LOCA IN UNIT 1
 DG 1-2 OUT OF SERVICE
 SIX DG CONFIGURATION
 (CASE6)

FIGURE D-12

