



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D.C. 20555

August 21, 1991

Docket Nos. 50-275  
and 50-323

Mr. J. D. Shiffer  
Senior Vice President  
Nuclear Power Generation  
Pacific Gas and Electric Company  
77 Beale Street, Room 1451  
San Francisco, California 94106

Dear Mr. Shiffer:

SUBJECT: RELIEF FROM THE REQUIREMENTS OF THE DIABLO CANYON INSERVICE TESTING (IST) PROGRAM TO MEASURE PUMP BEARING TEMPERATURE

Background

By letter dated May 17, 1991, Pacific Gas and Electric Company (PG&E) requested relief from the requirement of ASME Section XI, Subsections IWP-3300 and IWP-3500(b) to annually measure the bearing temperature of all pumps in the IST program. The request was made pursuant to 10 CFR 50.55a(g) and NRC Generic Letter (GL) 89-04, "Guidance on Developing Acceptable Inservice Testing (IST) Programs."

PG&E's Basis for Requesting Relief

In lieu of measuring pump bearing temperatures annually, PG&E proposed to measure bearing vibration on a quarterly basis. The vibration testing would be conducted in accordance with the requirements and acceptance criteria specified in ASME Operation and Maintenance Pump Standard ASME OM-6. In support of the request for relief, PG&E stated that it has been demonstrated that pump bearing temperature rise occurs only a short time prior to bearing failure, making it improbable that annual bearing temperature measurements would effectively identify bearing degradation. Additionally, PG&E stated that many pumps in the Diablo Canyon IST Program are operated on recirculation flow for the purposes of the annual ASME Section XI test. Running the pumps until stable bearing temperatures are achieved requires excessive pump running time on recirculation flow (approximately 1 to 1.5 hours), which has been shown to contribute to pump degradation. In summary, PG&E stated that measuring pump bearing vibration in accordance with ASME OM-6 will provide a better indication of pump degradation than the presently used combination of ASME Section XI bearing vibration and temperature measurements, and will minimize the potential for pump degradation resulting from operation on recirculation flow.

9109050076 910821  
PDR ADOCK 05000275  
P PDR

NRG FILE CENTER COPY

*MR. J. D. SHIFFER*  
*DFOL*  
*11R*



11

11

11

Mr. J. D. Shiffer  
Pacific Gas and Electric Company

Diablo Canyon

Evaluation

The NRC staff has evaluated PG&E's request for relief and agrees that the temperature at the pump bearings will not increase significantly until immediately before a bearing failure. Therefore, the likelihood of detecting an impending bearing failure with a single annual bearing temperature measurement is very small. The staff finds that the quarterly pump vibration measurements provide more information about the degradation of the bearing than the annual bearing temperature measurement. On this basis the staff finds PG&E's relief request to be acceptable.

Conclusion

The NRC staff hereby grants the relief requested by PG&E from the requirement of ASME Section XI, Subsections IWP-3300 and IWP-3500(b) to annually measure the bearing temperature of all pumps in the IST program. The staff concludes that relief may be granted as requested pursuant to 10 CFR 50.55a(a)(3)(i) because the alternate testing proposed by PG&E provides an acceptable level of quality and safety.

Sincerely,



Harry Rood, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc:  
See next page



11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

Mr. J. D. Shiffer  
Pacific Gas and Electric Company

Diablo Canyon

cc:

Regional Administrator, Region V  
U.S. Nuclear Regulatory Commission  
1450 Maria Lane, Suite 210  
Walnut Creek, California 94596

NRC Resident Inspector  
Diablo Canyon Nuclear Power Plant  
c/o U.S. Nuclear Regulatory Commission  
P. O. Box 369  
Avila Beach, California 93424

Mr. Peter H. Kaufman  
Deputy Attorney General  
State of California  
110 West A Street, Suite 700  
San Diego, California 92101

Richard F. Locke, Esq.  
Pacific Gas & Electric Company  
Post Office Box 7442  
San Francisco, California 94120

Mr. John Hickman  
Senior Health Physicist  
Environmental Radioactive Mgmt. Unit  
Environmental Management Branch  
State Department of Health Services  
714 P Street, Room 616  
Sacramento, California 95814

Michael M. Strumwasser, Esq.  
Special Assistant Attorney General  
State of California  
Department of Justice  
3580 Wilshire Boulevard, Room 800  
Los Angeles, California 90010

Managing Editor  
The County Telegram Tribune  
1321 Johnson Avenue  
P. O. Box 112  
San Luis Obispo, California 93406

Chairman  
San Luis Obispo County Board of  
Supervisors  
Room 370  
County Government Center  
San Luis Obispo, California 93408

Ms. Sandra A. Silver  
Mothers for Peace  
660 Granite Creek Road  
Santa Cruz, California 95065

Dr. R. B. Ferguson, Energy Chair  
Sierra Club California  
6715 Rocky Canyon  
Creston, California 93432

Ms. Nancy Culver  
192 Luneta Street  
San Luis Obispo, California 93401

Ms. Jacquelyn C. Wheeler  
3303 Barranca Court  
San Luis Obispo, California 93401



11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27  
28  
29  
30  
31  
32  
33  
34  
35  
36  
37  
38  
39  
40  
41  
42  
43  
44  
45  
46  
47  
48  
49  
50  
51  
52  
53  
54  
55  
56  
57  
58  
59  
60  
61  
62  
63  
64  
65  
66  
67  
68  
69  
70  
71  
72  
73  
74  
75  
76  
77  
78  
79  
80  
81  
82  
83  
84  
85  
86  
87  
88  
89  
90  
91  
92  
93  
94  
95  
96  
97  
98  
99  
100

101  
102  
103  
104  
105  
106  
107  
108  
109  
110  
111  
112  
113  
114  
115  
116  
117  
118  
119  
120  
121  
122  
123  
124  
125  
126  
127  
128  
129  
130  
131  
132  
133  
134  
135  
136  
137  
138  
139  
140  
141  
142  
143  
144  
145  
146  
147  
148  
149  
150  
151  
152  
153  
154  
155  
156  
157  
158  
159  
160  
161  
162  
163  
164  
165  
166  
167  
168  
169  
170  
171  
172  
173  
174  
175  
176  
177  
178  
179  
180  
181  
182  
183  
184  
185  
186  
187  
188  
189  
190  
191  
192  
193  
194  
195  
196  
197  
198  
199  
200

August 21, 1991

Mr. J. D. Shiffer  
Pacific Gas and Electric Company

Diablo Canyon

Evaluation

The NRC staff has evaluated PG&E's request for relief and agrees that the temperature at the pump bearings will not increase significantly until immediately before a bearing failure. Therefore, the likelihood of detecting an impending bearing failure with a single annual bearing temperature measurement is very small. The staff finds that the quarterly pump vibration measurements provide more information about the degradation of the bearing than the annual bearing temperature measurement. On this basis the staff finds PG&E's relief request to be acceptable.

Conclusion

The NRC staff hereby grants the relief requested by PG&E from the requirement of ASME Section XI, Subsections IWP-3300 and IWP-3500(b) to annually measure the bearing temperature of all pumps in the IST program. The staff concludes that relief may be granted as requested pursuant to 10 CFR 50.55a(a)(3)(i) because the alternate testing proposed by PG&E provides an acceptable level of quality and safety.

Sincerely,

ORIGINAL SIGNED BY

Harry Rood, Senior Project Manager  
Project Directorate V  
Division of Reactor Projects III/IV/V  
Office of Nuclear Reactor Regulation

cc:  
See next page

DISTRIBUTION

Docket File	OGC	TMurley/FMiraglia
NRC & LPDRs	EJordan	JPartlow
PD5 Reading	ACRS (10)	Crossi
BBoger	RegionV (4)	GHill(4)
MVirgilio	JNorberg	GPA/PA
JDyer	ESullivan	OC/LFMB
HRood	KDempsey	JCaldwell (EDO)
RCesaro		RZimmerman
PDV Plant File		

DRPW/PD5/LA	DRPW/PD5/PM	DRPW/PD5/D
RCesaro	HRood	JDyer
08/21/91	08/20/91	08/21/91

OFFICIAL RECORD COPY

**NRC FILE CENTER COPY**



11-11-11

1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial statements and for providing a clear audit trail.

2. The second part of the document outlines the specific procedures that should be followed when recording transactions. It details the steps from identifying the transaction to posting it to the appropriate ledger account.

3. The third part of the document discusses the importance of reconciling the accounts regularly. It explains how this process helps to identify and correct any errors or discrepancies in the records.

4. The fourth part of the document provides a summary of the key points discussed and offers some final thoughts on the importance of maintaining accurate financial records.

5. The fifth part of the document contains some additional information and references for further reading.