

PACIFIC GAS AND ELECTRIC COMPANY

NUMBER STP M-81E

REVISION 1

DEPARTMENT OF NUCLEAR POWER GENERATION

PAGE 1 OF 15

DIABLO CANYON POWER PLANT

UNITS

1 AND 2

TITLE: SURVEILLANCE TEST PROCEDURE
DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

APPROVED: *B. W. H. P.*

10/24/91

10/24/91

DATE

EFFECTIVE DATE

** PROCEDURE CLASSIFICATION - QUALITY RELATED **

1.0 SCOPE

- 1.1 Performance of this procedure will provide guidance needed to perform maintenance inspections AND services on the Emergency Diesel Engine and Generator.
- 1.2 Performance of this procedure will also provide guidance for meeting requirements of Technical Specification 4.8.1.1.2.b.1.
- 1.3 This procedure covers items required to be serviced at specific time intervals. Because of the diesel engine infrequent operation, manufacturer's recommendations were modified and approved for Diablo Canyon Preventive Maintenance Program and Routine Surveillance Test Schedule. Operational Tests such as overspeed trip tests and Cooling Water Tests are not included.
- 1.4 References in procedure such as (MI-11025) refer to ALCO instruction Manual 663082-80. 81 ALCO Maintenance Instructions (MIs) have a number followed by a letter. MIs referenced herein will NOT have revision letter identified. Latest revision in controlled manual is to be used.
- 1.5 Sections of this procedure can be performed out of sequence as long as all items are completed for intervals scheduled.
- 1.6 STP M-81E was formerly Mechanical Section E of STP M-81.

2.0 RESPONSIBILITIES

- 2.1 Mechanical Maintenance Engineer, as Test Director, is to:
 - 2.1.1 Schedule test.
 - 2.1.2 Provide technical assistance.
 - 2.1.3 Review test results.

01035301.06z 1I

9204270118 920417
PDR ADDCK 05000275
P PDR

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

- 2.2 Mechanical Maintenance Foremen are to:
 - 2.2.1 Obtain equipment clearance.
 - 2.2.2 Perform inspections.
 - 2.2.3 Provide service to conduct tests.

3.0 FREQUENCY

- 3.1 This test shall be performed at the interval shown on STP M-81A Appendix 7.1.

4.0 TECHNICAL SPECIFICATIONS

- 4.1 Technical Specification 4.8.1.1.2.b.1.

5.0 ACCEPTANCE CRITERIA

- 5.1 All applicable mechanical data recorded is within acceptable limits.
- 5.2 All applicable electrical data recorded is within acceptable limits.

6.0 REFERENCES

- 6.1 PG&E Drawing No. 663082-80, Rev. 25, Unit 1, Instruction Manual, ALCO Diesel Engine 18-251-F.
- 6.2 PG&E Drawing No. 663082-81, Rev. 26, Unit 2, Instruction Manual, ALCO Diesel Engine 18-251-F.
- 6.3 Preventive Maintenance Letter from ALCO Division to PG&E, September 5, 1975, Maintenance File 425.8.
- 6.4 Preventive Maintenance Letter from ALCO Division to PG&E, December 3, 1982, File 425.8.
- 6.5 Technical Specification, 3/4.8, "Electrical Power Systems."
- 6.6 NPAP C-6, "Clearance Request/Job Assignment."
- 6.7 NPAP C-10, "Housekeeping - General."
- 6.8 NPAP C-12, "Identification and Resolution of Problems and Nonconformances."

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

-
- 6.9 AP C-4S3, "Control of Lifted Circuitry Jumpers During Maintenance."
 - 6.10 AP C-10S4, "Foreign Materials Exclusion Area Control."
 - 6.11 AP C-13, "Fire Loss Prevention."
 - 6.12 AP C-62, "Determination of Preventive Maintenance."
 - 6.13 AP D-753, "Control of Plant Lubricants."
 - 6.14 STP M-9A, "Diesel Engine Generator Routine Surveillance Test."
 - 6.15 MP M-21.4, "Diesel Lubricating Oil Filter Element Replacement."
 - 6.16 MP M-21.5, "Diesel Engine Water Pump Maintenance."
 - 6.17 MP M-21.6, "Diesel Engine Turbocharger Maintenance."
 - 6.18 MP M-21.8, "Diesel Engine Governor Drive."
 - 6.19 MP M-21.9, "Diesel Engine Lube Oil Pump."
 - 6.20 MP M-21.10, "Diesel Engine Pre-Lube Oil Pump."
 - 6.21 MP M-21.11, "Diesel Engine Fuel Injection Pump Maintenance."
 - 6.22 MP M-21.12, "Diesel Engine Cylinder Head."
 - 6.23 MP M-21.16, "Diesel Engine Camshaft."
 - 6.24 MP M-21.19, "Diesel Engine Governor Control Linkage."
 - 6.25 MP M-21.20, "Diesel Engine Radiator Fan and Drive."
 - 6.26 MP M-21.23, "Diesel Engine Fuel Pump Control Shaft and Crossover Linkage."
 - 6.27 MP M-21.24, "Diesel Engine Hose Fabrication, Inspection and Replacement."

DIABLO CANYON POWER PLANT

NUMBER
REVISION
PAGE

STP M-81E
1
4 OF 15

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

7.0 APPENDICES

None

8.0 ATTACHMENTS

None

9.0 RECORD OF REVIEWS

9.1 Prepared by: Rex Ozment

9.2 Sponsored by: Larry Price

9.3 Independent Technical Review by: Dave Stupf

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

START DATA SECTION

UNIT _____ DATE ____/____/____

DIESEL GENERATOR # _____ WORK ORDER # _____ ENGINE HR METER _____ Hrs.

10.0 PRECAUTIONS AND LIMITATIONS

INITIALS

10.1 IF cleaning solvents are used, fire precautions are required per AP C-13.

10.2 A pre-test briefing has been conducted by Test Director for involved personnel.

10.3 Drawings and procedures used in the performance of this test are of the current revision.

10.4 Precautions and Limitations have been read and understood.

11.0 PREREQUISITES

11.1 Diesel engine has been cleared AND tagged per NPAP C-6.

11.2 CO₂ system has been disabled for individual engine being inspected.

11.3 Generator 4kV circuit breaker has been racked out.

11.4 Starting Air, AND 480 volt switches for recirculation oil pump, oil and water heaters has been cleared.

11.5 Housekeeping Zone requirements have been established for disassembly work per NPAP C-10.

11.6 Foreign Materials Exclusion Area (FMEA) Controls have been established per AP C-10S4.

11.7 Diesel room floor drains have been taped off.

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

INITIALS

- 11.8 All M&TE used to perform this procedure is in current calibration, as evidenced by an affixed calibration sticker. _____
- 11.8.1 M&TE should be selected where values to be measured fall within middle range of instrument. _____
- 11.9 RECORD required M&TE information in Section 12.1.19, including:
 - 11.9.1 Step number where M&TE was used. _____
 - 11.9.2 M&TE Identification number(s). _____
 - 11.9.3 M&TE Calibration due date(s). _____
- 11.10 Steps in procedure, marked with "PM" entry, must have approval from Preventive Maintenance (PM) Evaluator before they can be deleted.
(See AP C-62 for additional information) _____
- 11.11 Quality Control (QC) Hold Points, identified in the Work Order, are annotated in the controlled copy of this procedure that is included in the Work Order package. _____
- NOTE: Assignment of QC Hold Points will be accomplished per QC procedures, and annotated in the controlled copy of this procedure during the Work Order approval process.
- 11.12 Any discrepancies identified in parts, materials, OR in workmanship which cannot be corrected during normal course of work, OR in procedures shall be reported AND documented per NPAP C-12. _____

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

12.0 INSTRUCTIONS

PERF
BY

12.1 Inspection and Maintenance

12.1.1 Visually inspect water pump as directed by Maintenance Engineer. (Reference M-21.5 and MI-11206)

a. Maintenance Engineer to evaluate water pump based upon inspection of tell-tale drain leakage and vibration analysis.

b. Maintenance Engineer to initiate an AR IF corrective action is required.

Pump condition acceptable [] YES

Pump maintenance required, initiated

AR # _____.

12.1.2 Maintenance Mechanic to inspect condition of Turbocharger. (Reference MP M-21.6, MI-11209)

NOTE: IF a problem with turbocharger is identified, THEN, change out with a complete unit is recommended. (Stock Code 42-3031)

a. Visually inspect air inlet side of turbocharger.

b. Visually inspect exhaust inlet side of turbocharger.

c. Measure axial thrust of turbocharger.

d. Visually inspect condition of air inlet boot.

e. Initiate an AR IF corrective action is required.

[] Turbocharger Acceptable.

[] Turbocharger maintenance required.

AR # _____ initiated.

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

PERF
BY

12.1.3 Evaluate condition of at least one cylinder and head from each bank (total of two required).

a. Maintenance Engineer to identify ^{cylinder/} head(s) for inspection and evaluation, based on Engine Performance Analyzer results from STP M-81A.

1. Inspect Right Bank cylinder/head(s)

No. _____

2. Inspect Left Bank cylinder/head(s)

No. _____

b. Maintenance Engineer, OR Alco representative, OR ISI representative to perform fiberscope inspection of cylinder head(s) identified above.

c. Maintenance Engineer to initiate an AR IF any corrective action is required.

[] Cylinder head(s) condition acceptable.

[] Cylinder head maintenance required.

AR # _____ initiated.

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

		PERF BY
PM	12.1.4 Perform maintenance on Radiator Fan Drive per following instructions:	
	a. Measure blade angles per Section 7.12 of MP M-21.20.	_____
	b. RECORD blade angles on MP M-21.20, Appendix 8.1.	_____
	c. Measure fan blade-to-shroud clearance per Section 7.15.8 of MP M-21.20.	_____
	d. RECORD clearance on MP M-21.20, Appendix 8.1.	_____
	e. Check fan blade track per MP M-21.20, Section 7.15.10.	_____
	f. RECORD tracking distance on MP M-21.20, Appendix 8.1.	_____
	12.1.5 Maintenance Engineer to identify any corrective maintenance required for the lube oil pump based on inspection results and evaluation of data from vibration analysis. (Reference STP M-81A)	_____
	<input type="checkbox"/> No Corrective Maintenance required.	_____
	<input type="checkbox"/> Corrective Maintenance required. See	
	AR # _____	

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

PERF
BY

12.1.6 Inspection and maintenance of Lube Oil
Regulating Valve.

a. Disassemble AND inspect valve(s) per
MI-12010:

DIESEL ENGINE
GENERATOR No.

VALVE No.

1-1

1-PCV-86

1-2

1-PCV-87

1-3

0-PCV-88

2-1

2-PCV-87

2-2

2-PCV-86

b. Initiate an AR IF any problems are
identified.

No problems were identified.

Problem(s) identified on:

AR # _____.

c. Reassemble valve(s) per MI-12010.

TITLE: DIESEL ENGINE GENERATOR INSPECTION
 (90 MONTH INTERVALS)

PERF
 BY _____

12.1.7 Inspection and maintenance of Lube Oil Relief Valve(s).

- a. Disassemble AND inspect valve(s), on following Diesel Engine Generators (DEG), per MI-12010:

<u>DIESEL ENGINE GENERATOR No.</u>	<u>VALVE No.</u>	_____
1-1	1-RV-68	_____
1-2	1-RV-69	_____
1-3	0-RV-70	_____
2-1	2-RV-69	_____
2-2	2-RV-68	_____

- b. Initiate an AR IF any problems were identified.

[] No problems were identified. _____

[] Problem(s) identified on: _____

AR # _____

- c. Reassemble valve(s) per MI-12010. _____

12.1.8 Replace Fuel Oil Regulating Valve(s) (Stock Code 94-6094) on following DEGs:

<u>DIESEL ENGINE GENERATOR No.</u>	<u>VALVE No.</u>	_____
1-1	1-PCV-83	_____
1-2	1-PCV-82	_____
1-3	0-PCV-80	_____
2-1	2-PCV-82	_____
2-2	2-PCV-83	_____

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

PERF BY
VERIF BY

12.1.9 Perform maintenance of Cooling Water Temperature Regulating Valve(s)

a. Replace valves (Stock Code 42-4208) on following DEGs:

DIESEL ENGINE GENERATOR No.

VALVE No.

1-1

1-TCV-3

1-2

1-TCV-4

1-3

1-TCV-5

2-1

2-TCV-3

2-2

2-TCV-4

b. Initiate requisition to return valves removed from service to supplier OR manufacturer for refurbishing.

1. Initiated requisition # _____.

12.1.10 Inspect Manual Fuel Priming Pump, AND recondition, IF necessary. (Reference MI-17021)

12.1.11 VERIFY camshaft gear train is acceptable.

a. Document condition. (Reference NI-11030)

Condition: _____

12.1.12 Measure camshaft gear backlash.

a. Adjust, IF necessary. (Ref. MI-11071)

12.1.13 RECORD "As Left" camshaft gear backlash.

Left side _____" (Max. allowable: 0.028")

Right side _____" (Max. allowable: 0.028")

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

PERF
BY
VERIF
BY

12.1.14 Replace camshaft gear cover gaskets with Stock Code 93-2988 (2 each, required).

12.1.15 VERIFY camshaft thrust and vibration dampers are in good condition AND all capscrews are properly lockwired.

a. Document condition: (Ref. MI-11071)

Condition: _____

12.1.16 Measure camshaft thrust per MP M-21.16.

12.1.17 RECORD "As Left" camshaft thrust.

Left side _____" (Max. allowable: 0.022")

Right side _____" (Max. allowable: 0.022")

12.1.18 Was any work performed in this section that would affect engine analyzer results?

[] YES [] NO

12.1.19 Test Equipment Used:

Step No.	Equipment	Manufacturer	Model No.	Company No.	Cal Due Date
_____	_____	_____	_____	_____	____/____/____
_____	_____	_____	_____	_____	____/____/____
_____	_____	_____	_____	_____	____/____/____
_____	_____	_____	_____	_____	____/____/____

Comments: _____

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

UNITS

1 AND 2

12.1.20 Test Performers and Verifiers:

(Signature/Print last name) Initials

(Signature/Print last name) Initials

(Signature/Print last name) Initials

(Signature/Print last name) Initials

(Signature/Print last name) Initials

(Signature/Print last name) Initials

REVIEWED BY FOREMAN: _____
(Signature/Print last name) Date

REVIEWED BY FOREMAN: _____
(Signature/Print last name) Date

APPROVED BY M.M. ENGINEER: _____
(Signature/Print last name) Date

APPROVED BY M.M. ENGINEER: _____
(Signature/Print last name) Date

****END DATA SECTION****

DIABLO CANYON POWER PLANT

NUMBER STP M-81E
REVISION 1
PAGE 15 OF 15
UNITS 1 AND 2

TITLE: DIESEL ENGINE GENERATOR INSPECTION
(90 MONTH INTERVALS)

13.0 DATA REDUCTION AND REPORTING OF RESULTS

13.1 Maintenance Foreman to review and sign data sheet and forward to Mechanical Maintenance Engineer.

13.2 Mechanical Maintenance Engineer to review and approve:

13.2.1 Data Sheets.

13.2.2 Update schedule (STP M-81A, Appendix 7.1).

