

# ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9307210162      DOC DATE: 93/07/06      NOTARIZED: YES      DOCKET #  
 FACIL: 50-275 Diablo Canyon Nuclear Power Plant, Unit 1, Pacific Ga      05000275  
       50-323 Diablo Canyon Nuclear Power Plant, Unit 2, Pacific Ga      05000323  
 AUTH. NAME      AUTHOR AFFILIATION  
 RUEGER, G.M.      Pacific Gas & Electric Co.  
 RECIP. NAME      RECIPIENT AFFILIATION  
                  Document Control Branch (Document Control Desk)

SUBJECT: Forwards License Amend Request 93-03 to Licenses DPR-80 & DPR-82, changing TS 3/4.3.2, "ESFAS Instrumentation" to relax slave relay test frequency for certain relays from quarterly to once per 18 months during refueling shutdown.

DISTRIBUTION CODE: A001D      COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 1+13  
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	PDV LA	1 1	PDV PD	1 1
	PETERSON, S	2 2		
INTERNAL:	ACRS	6 6	NRR/DE/EELB	1 1
	NRR/DRCH/HICB	1 1	NRR/DRPW/OTSB	1 1
	NRR/DSSA/SPLB	1 1	NRR/DSSA/SRXB	1 1
	NUDOCS-ABSTRACT	1 1	OC/EFDCB	1 0
	OGC/HDS1	1 0	REG FILE 01	1 1
EXTERNAL:	NRC PDR	1 1	NSIC	1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 21 ENCL 19



Pacific Gas and Electric Company

77 Beale Street, Room 1451  
P.O. Box 770000  
San Francisco, CA 94177  
415/973-4684  
Fax 415/973-2313

Gregory M. Rueger  
Senior Vice President and  
General Manager  
Nuclear Power Generation

July 6, 1993

PG&E Letter No. DCL-93-168



U.S. Nuclear Regulatory Commission  
ATTN: Document Control Desk  
Washington, D.C. 20555

Re: Docket No. 50-275, OL-DPR-80  
Docket No. 50-323, OL-DPR-82  
Diablo Canyon Units 1 and 2  
License Amendment Request 93-03  
Revision of Technical Specification 3/4.3.2 -  
Slave Relay Test Frequency Relaxation

Gentlemen:

Enclosed is an application for amendment to Facility Operating License Nos. DPR-80 and DPR-82. The enclosed license amendment request (LAR) proposes a change to Technical Specification (TS) 3/4.3.2, "Engineered Safety Features Actuation System Instrumentation," to relax the slave relay test frequency for certain slave relays from quarterly to once per 18 months during refueling or extended cold shutdowns. The affected slave relays cause isolation of the charging and letdown portions of the chemical and volume control system, and actuate charging pump suction valves associated with volume control tank and refueling water storage tank isolation.

While the changes proposed in this LAR are not required to address an immediate safety concern, PG&E desires to implement the requested changes as soon as possible for Diablo Canyon Units 1 and 2 to reduce the number of surveillance tests performed at power. PG&E therefore requests that review and approval of this LAR be given a medium priority. PG&E requests that the revised TS be made effective 30 days after issuance of a license amendment from the NRC.

Sincerely,

A handwritten signature in dark ink, appearing to read 'Greg Rueger'.

Gregory M. Rueger

cc: Edgar Bailey, DHS  
Bobby H. Faulkenberry  
Ann P. Hodgdon  
Mary H. Miller  
Sheri R. Peterson  
CPUC  
Diablo Distribution

190127

Enclosure

6169S/85K/PTN/1664

9307210162 930706  
PDR ADDCK 05000275  
P PDR

*File*

